

Many problems or potential problems can be identified with simple daily and monthly facility inspections. This list is just a guide; federal law may require more detailed inspections.



## Daily facility inspection

- Walk facility grounds, note general condition of property.
- Security: check lights, fencing, and locks.
- Clear any ice, snow and debris from tank vents.
- Check for leaks or drips from tanks and piping.
- Check for stains on ground beneath joints, valves or other connections.
- Verify valves are in the correct position (open/closed).
- Note any paint peeling, blistering or chipping on tanks.
- Make sure tanks/fuel lines are protected from vehicles/falling ice and snow.
- Drain standing water and clear snow from dyke/containment; check for sheen

NOTES: \_\_\_\_\_  
\_\_\_\_\_

More information available: <http://dec.alaska.gov/spar/ppr/prevention-preparedness/class-2-facilities/dec.spar.class2@alaska.gov> or 907-465-5237

Many problems or potential problems can be identified with simple daily and monthly facility inspections. This list is just a guide; federal law may require more detailed inspections.



## Monthly facility inspection

Today's date: \_\_\_\_\_ Staff initials: \_\_\_\_\_

- High level alarms functioning?  Yes  No
- Cracks/rips/vegetation in dyke/containment walls or liner?  Yes  No
- Tank foundations/pipe supports in good condition?  Yes  No
- Spill response equipment: onsite and adequate quantity?  Yes  No
- ADEC Spill reporting placards visibly posted?  Yes  No
- Condition of exterior of tank(s) (note pitting, rust, corrosion, damage):  
\_\_\_\_\_

- Signs of leaks from:
  - joints:  Yes  No
  - valves:  Yes  No
  - seams/welds:  Yes  No
  - tanks:  Yes  No
- Signs of damage to any pipe connections or valves?  Yes  No

Top 3 things to address this month: 1 \_\_\_\_\_ 2 \_\_\_\_\_ 3 \_\_\_\_\_

More information available: <http://dec.alaska.gov/spar/ppr/prevention-preparedness/class-2-facilities/dec.spar.class2@alaska.gov> or 907-465-5237