UNDERGROUND STORAGE TANKS ADEC CHECKLIST - INTERNAL INSPECTION

- An underground storage tank (UST) system that is upgraded, reconfigured, retrofit, or repaired, must be tightness tested or internally inspected by a licensed UST worker, in accordance with Title 18 Alaska Administrative Code (AAC) 78, *Underground Storage Tanks*, using industry standards adopted by reference, or an alternate approved procedure (18 AAC 78.055(c))
 - An internal inspection must be performed by a licensed UST worker, certified in inspection (18 AAC 78.017(g) and 78.455(a)(5)) and the Steel Tank Institute (STI) SP001, <u>or</u> the American Petroleum Institute (API) Standard 653 <u>with</u> the SP001 Adjunct; the non-destructive exam (NDE) technician must be certified on the equipment used; UST Inspector must be on site throughout inspection.
 - Definition of a UST system includes the tank, piping, and related equipment, the <u>failure of any component of which</u>, could cause a release, or permit a release to go unnoticed or uncontained (18 AAC 78.025(f)(1)(B))
 - Internal inspection definitions are in accordance with STI SP001 and 18 AAC 78; an internal inspection does not substitute for the required triennial third-party inspection (18 AAC 78.017) but may be required in conjunction with it
 - UST systems, shop-fabricated or field-erected, if larger than 20,000 gallons, may be difficult to inspect for <u>suitability to return-to-service</u> using tank-tightness testing (TTT) which must meet 18 AAC 78.065(d); a licensed UST worker certified in TTT, is required (18 AAC 78.455(a)(3)); TTT equipment and method must be third-party certified for the tank type and volume, as well as determination of depth-to-groundwater and presence of petroleum in the tank-nest bedding prior to performing tests (18 AAC 78.065(k))
 - Owner responsibilities must be in compliance with fire and safety ordinances, regulatory and industry standards.
- Criteria for internal inspection (18 AAC 78.055(c)(4)) are the procedures, codes or standards of:
 - National Leak Prevention Association (NLPA) Standard 631-Chapter C, Internal Inspection of Tanks for Retrofit of Cathodic Protection
 - Steel Tank Institute (STI) SP001-Standard for the Inspection of ASTs
 - American Petroleum Institute (API) Standard 653, Tank Inspection, Repair, Alteration, and Reconstruction.

I. UST OWNER				II. UST FACILITY			
NAME:				FACILITY NAME:			ADEC FAC #
ADDRESS:				PHYSICAL LOCATION:			
CITY: STATE, ZIP:				CITY:		FACILITY PHONE:	
UST CLASS A/B OPERATOR:				PHONE/EMAIL OF A/B OPERATOR:			
III. UST INSPECTOR				IV. NDE TECHNICIAN			
NAME:				NAME:			
EXPIRY DATE OF UST CERTIFICATION	LICENSE #:			COMPANY:			
DATE OF STI SPOO1 LI CERTIFICATION		LICENSE #:		CONTACT PHONE:		EMAIL:	
DATE OF API 653 CERTIFICATION				1. NDE METHOD USED, DATE OF CERTIFICATION:			
CONTACT PHONE:				2. NDE METHOD USED, DATE OF CERTIFICATION:			
EMAIL ADDRESS:				3. NDE METHOD USED, DATE OF CERTIFICATION:			
		V. T	ANK [DETAILS			
Use the ADEC Tank Number:	TANK	#	TAN	K #	TANK#		TANK #
PRODUCT:							
CAPACITY (GAL):							
TANK MATERIAL:	STEEL, F	STEEL, FIBERGLASS, ETC.		FIBERGLASS, ETC.	STEEL, FIBERGLASS, ETC.		STEEL, FIBERGLASS, ETC.
TANK CONFIGURATION:	DOUBLE-WALL MANIFOLD/SYPHON LEAK DETECTION SPILL BUCKET DROP TUBE OVERFILL, AS OR HLA		Double-Wall Manifold/Syphon Leak Detection Spill Bucket Drop Tube Overfill, AS or HLA		Double-Wall Manifold/Syphon Leak Detection Spill Bucket Drop Tube Overfill, AS or HLA		Double-Wall Manifold/Syphon Leak Detection Spill Bucket Drop Tube Overfill, AS or HLA
CORROSION PROTECTION:	GALVANIC □ IMPRESSED CURRENT □		GALVANIC ☐ IMPRESSED CURRENT ☐		GA IMPRESSED C		GALVANIC ☐ IMPRESSED CURRENT ☐
DATE OF LAST CP SURVEY:	Pass? □		Pass? □			Pass? □	Pass? □

VI. INTERNAL INSPECTION DETAILS							
DATE OF INTERNAL INSPECTION:							
DATE PRODUCT LAST STORED:							
Inspection Criteria:	SP001 □	SP001 □	SP001 □	SP001 □			
(18 ACC 78.055(c))	API 653 □	API 653 □	API 653 □	API 653 □			
STI <i>SP001</i> 5.4:	CATEGORY 2 ☐ CATEGORY 3 ☐	Category 2 ☐ Category 3 ☐	Category 2 ☐ Category 3 ☐	CATEGORY 2 ☐ CATEGORY 3 ☐			
1. NDE METHOD,							
FACTORS:							
2. NDE METHOD,							
FACTORS:							
3. NDE METHOD,							
FACTORS:							
WELD INSPECTION:	Visual □ NDE □	Visual. □ NDE □	Visual. □ NDE □	Visual. □ NDE □			
IF NDE WAS USED, LIST METHOD:							
IDENTIFY CONDITION AND RECORD MECHANICAL:	Damage □	Damage □	Damage □	Damage □			
ATTACH PHOTOGRAPHS	CRACKING ☐ CORROSION ☐	CRACKING ☐ CORROSION ☐	Cracking \square Corrosion \square	Cracking ☐ Corrosion ☐			
IDENTIFY CONDITION AND RECORD	Damage □	Damage □	Damage □	Damage □			
INTERNAL ATTACHMENTS:			Corrosion □	Corrosion □			
ATTACH PHOTOGRAPHS	DETERIORATION	DETERIORATION	DETERIORATION	DETERIORATION			
IDENTIFY CONDITION AND RECORD	MIC DAMAGE	MIC DAMAGE	MIC DAMAGE	MIC DAMAGE			
INTERNAL THICKNESS:	INTERNAL STRUCTURES INTERNAL WALL	INTERNAL STRUCTURES ☐ INTERNAL WALL ☐	INTERNAL STRUCTURES INTERNAL WALL	INTERNAL STRUCTURES ☐ INTERNAL WALL ☐			
ATTACH PHOTOGRAPHS AND A WALL MATRIX OR TEST-PLOT DIAGRAM	DIAGRAM ATTACHED	DIAGRAM ATTACHED	DIAGRAM ATTACHED	DIAGRAM ATTACHED			
PHOTOGRAPHIC RECORD	DIGITAL ATTACHED □	DIGITAL ATTACHED	DIGITAL ATTACHED □	DIGITAL ATTACHED			
VII. DE	TERMINATION OF SU	IITABILITY FOR CONT	INUED SERVICE				
MICROBIAL INDUCED CORROSION	Present □ Mitigated □	Present □ Mitigated □	Present □ Mitigated □	Present □ Mitigated □			
CORROSION UNDER INSULATION	Present □ Mitigated □	Present □ Mitigated □	Present □ Mitigated □	Present □ Mitigated □			
WALL THICKNESS: CATEGORY 3	D	B	D	B			
Express findings as a percentage of	PERCENT NEXT INTERNAL INSPECTION:	PERCENT NEXT INTERNAL INSPECTION:	PERCENT NEXT INTERNAL INSPECTION:	PERCENT NEXT INTERNAL INSPECTION:			
the original wall thickness.	Two Years	Two Years	Two Years	Two Years			
(SP001 \$10.2.2)	FIVE YEARS	FIVE YEARS	FIVE YEARS	Five Years			
WALL THICKNESS: <u>CATEGORY 2</u> 1. Any three square inches of any	1. THREE SQUARE INCHES IS	1. THREE SQUARE INCHES IS	1. THREE SQUARE INCHES IS	1. THREE SQUARE INCHES			
one square foot of the tank shell is	LESS THAN 75%, OR 2. LESS THAN 50% SHELL	LESS THAN 75%, OR 2. LESS THAN 50% SHELL	LESS THAN 75%, OR 2. LESS THAN 50% SHELL	IS LESS THAN 75%, OR ☐ 2. LESS THAN 50% SHELL			
less than 75 percent of the original wall thickness; <i>or</i>	REMAINS AT ANY POINT						
2. Remaining shell thickness is less than 50 percent of original wall	NEXT INTERNAL INSPECTION	NEXT INTERNAL INSPECTION IS IN FIVE YEARS	NEXT INTERNAL INSPECTION	NEXT INTERNAL INSPECTION			
thickness at any point. (SP001 §10.2.3)	IS IN FIVE YEARS						
DAMAGE TO BE REPAIRED	Wel.Ds □	WELDS □	Welds □	Welds 🗆			
DAIVIAGE TO BE REPAIRED							
	ATTACHMENTS ☐ OVERPRESSURE ☐	ATTACHMENTS ☐ OVERPRESSURE ☐	Attachments □ Overpressure □	ATTACHMENTS ☐ OVERPRESSURE ☐			
	Excessive Settling	Excessive Settling	Excessive Settling	Excessive Settling			
	Shifting □		SHIFTING □				

VIII. JIIE JACIU	
⇒ Provide a basic layout of the UST SYSTEM. Indicate North. Ref	erence streets or landmarks.
⇒ Provide a basic layout of the UST SYSTEM. Indicate North. Ref	LEGEND KEY (T) Tank, include ADEC Tank # (identify all compartments) (PS) Piping sumps (SP) Spill Buckets (OP) Overfill Alarm (IM) Tank Interstitial Monitoring Access (MG) Tank Manual-Gauging Access (RCT) Rectifier (AN) Location of Anodes (R₁, R₂, etc.) Reference-cell locations for CP (T₁, T₂, P₁, etc.) Structure CP Contact Points (V) Vents (D) Dispensers Indicate ↑ North Arrow Add GPS Coordinates OR Add Street(s) or Building landmarks
IX. UST WORKER CERTI	
UST Inspector License # Date:	PHONE:
PRINT NAME: SIGNATUR	E:
The UCT Inspector who experied the internal inspection of the H	ST existence) must complete and sign this document

UIII CITE CVETCL

The UST Inspector who supervised the internal inspection of the UST system(s) must complete and sign this document, and provide a copy to the owner and operator (18 AAC 78.455(a)(9)). Submit the <u>signed original</u> of this document, <u>within 30 days</u> of the internal inspection, to the ADEC SPAR CS UST Unit.