

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Adak	Water & Sewer Downsizing Feasibility Study	Sep-04	Approved.	
Adak	Water Treatment Plant PER	Jun-17	Approved. WTP siting, direct filtration, prefabricated building.	ADK062217
Adak	Wastewater System PER	Aug-19	Approved	ADK090619
Akiachak	Piped Water and Sewer System PEP	Sep-04	Approved.	
Akiak	Water and Sewer Service	Jun-18	Preferred alternative approved; second alternative is conditionally approved.	AKI061918
Akiak	Scattered Sites Streamlined PER	Mar-20	Conditionally approved upon resubmission of the updated PER	AKI041420
Alakanuk	Feasibility Study Water & Sewer for Service Area 7	Jan-02	Not approved.	
Alatna	Landfill Study	Dec-14	Approved but pop. doesn't meet VSW eligibility requirements - 25 minimum	AA-040615
Alatna	Sewage Lagoon PER	Feb-20	Approved	ALT061220
Aleknagik	Water and Sewer Feasibility Study	Jun-07	Approved.	
Allakaket	Wells & Septic PER	May-20	Approved	AET062520
Ambler	Water, Sewer & Solid Waste Facilities MP Update	May-03	Phases 1-4 approved. Phase 5 not approved.	
Ambler II	Sanitation Master Plan Update	Dec-11	Approved	
Ambler	Main Erosion PER	Nov-19	Approved	ABL020320
Anchor Point	Sewer Feasibility Study	Apr-07	Approved	
Anchor Point	WTP Deficiencies and Upgrade Evaluation	May-07	Approved	
Angoon	Sanitation Facilities Master Plan	Apr-06	Phase 3 approved. Ph 1&2 to be revisited. Ph 4 disapproved.	
Angoon	Aanya Street Sewer Main 65% PER	Aug-17	Critical Comments need to be addressed before review can be completed.	AGN090117
Angoon	Aanya Street Sewer Main Final PER	Jan-19	Approved	AGN032819
Angoon	Streets Repaving and Utility Rehabilitation PER	May-20	USDA Approved. Not Approved by VSW or HIS	
Anvik	Water and Sewer Feasibility Study	Jun-06	Approved	
Arctic Village	Sanitation Water & Sewer Haul Feasibility Study	Sep-06	Approved	
Atka	2008 Update to the 2001 Sanitation Feasibility Study	May-08	Items 4-6 approved. Items 7-12 not approved.	
Atka	Water Source Impoundment Facility PER	Dec-17	Approved	AKB012418
Atmautluak	Sanitation Facilities Master Plan	Jun-15	Not approved: piped water and pressure sewer system due to costs totaling ~\$33 million, a capital cost per home of approximately \$460,000.	

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Atmautluak	Washeteria Improvements PER	Jan-19	Approved	ATT022619
Beaver	Washeteria Replacement PER	Feb-19	Approved	WBQ041619
Bethel	Water & Sewer Facilities Master Plan Update	Apr-05	Approved	
Bethel	Water Distribution and Sewer Collection System PER	May-19	Phases 1 and 2 approved. Phase 3 not approved.	BET073119
Bethel II	Water Distribution and Sewer Collection System PER	Mar-20	Phase 3A approved, Phase 3B approval contingent on 3A results.	BET040620
Brevig Mission	Sanitation Facilities Master Plan	Oct-10	Approved, contingent upon proj submittal to SDS	
Buckland	Landfill Preliminary Engineering Report Revision 2	Sep-16	Approved, being a solid waste project, it may not score highly enough for federal funding	BKCo62217
Chalkyitsik	Water & Sewer Feasibility Study	Jun-01	Approved.	
Chalkyitsik II	Water & Sewer Feasibility Study Update	Mar-15	Approved: Existing Systems Deficiencies. Not approved: biomass boiler and water self-haul with separating toilets (Kivalina/ANTHC's PASS).	CIK092315
Chenega Bay	Water and Sewer Feasibility Study	May-13	Approved: Phase I (sludge disposal site) and Phase II (sewer system repairs). Disapproved: Phase III (water and sewer service to future subdivision).	NCN040116
Chevak	Sanitation Facilities Master Plan	Mar-14	Approved	VAK050614
Chignik Bay	Water and Sewer Master Plan Update	May-07	Phases 1-4 approved. Phase 5 not approved.	
Chignik Bay	Raw Water Source & Transmission Line PER	Mar-18	Approved up to \$2M upon securing funds for remainder of capital cost (hydro).	KBW040618
Chignik Lake	Water & Sewer System Feasibility Study	Sep-00	Approved	
Coffman Cove	Water & Sewer Feasibility Study	Sep-04	Phases 1-2 approved. Phases 3-8 not approved.	
Coffman Cove	Luck Point Sewer Study Draft PER	Mar-17	Approved. However, project may not score highly enough for funds.	KCC032417
Crooked Creek	Water & Sewer Conceptual Design Report	Feb-12	Not approved.	
Crooked Creek	Water Treatment Plant and Washeteria PER	Oct-19	Approved.	CDK121919
Diomedes	Water Source Development Study PER	Mar-18	Not approved. Need to address critical comments.	

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Diomed II	Water Source Development Study PER	Jun-18	Approved	DIO030619
Diomed	Water Storage Tank Technical Memorandum	Jul-19	Approved	DIO090619
Eagle Village	Sanitation Facilities Feasibility Study/Master Plan	May-01	Approved	
Eek	Water and Sewer Master Plan	Aug-04	Addendum/update approved	
Eek	Water and Sewer Master Plan Update	Jul-08	Approved	
Eek	Water and Sewer Project -- Master Plan Update	Nov-16	Approved. Originally sent June 2016 lacking info; attachment #6 added.	EEK112216
Ekwok	Wastewater System Preliminary Engineering Report	Jun-06	Approved	
Elfin Cove	Water and Sewer Feasibility Study	Jan-13	Not approved (population considerations, etc.)	
Elim	Sanitation Facilities Master Plan	Jan-11	Phases 2, 3, 4, and 5 approved.	
Elim	Water Storage Tank PER	Jul-17	Approved	ELL012418
Elim II	Shelby Subdivision Master Plan Update	Aug-15	Approved. But must submit separate funding requests for each phase.	ELL111315
Emmonak	Water Distrib & Vacuum Sewage Collection Upgrade	May-08	Phase 1 & 2 approved. Phase 3 not approved.	
Emmonak	Water and Wastewater Improvements PER	Mar-18	Approved: Water intake. Not approved: Storage tank, wastewater alternative.	EMK040618
Emmonak	Water and Sewer Main Extension and 5 Service Lines Streamlined PER	Sep-19	Approved	EMK093019
False Pass	On-site Wastewater Systems PER	Dec-17	Resubmitted adding 1 non-native house as requested by USDA. Approved.	KFP012418
False Pass	Water Treatment Improvements Final Design Analysis Report	May-20	Not Approved	
Gambell	Water, Sewer, & Solid Waste Eng Feasibility Study	Dec-03	R&R + upgrade components approved.	
Glennallen	Water Improvement Feasibil Study Addendum, Ph 1-	May-09	Approved	
Golovin	Sanitation Facilities Master Plan Update	Dec-12	Upon review of additional estimates sent March 2016, the following was approved: pipes for upper village, rehabilitation of raw water intake, and sewage lagoon rehabilitation.	GLV101916

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Grayling	Sanitation Facilities Project PER	May-18	Only component E was approved. Components A, B, C, D not approved.	KGX070618
Gulkana	Sanitation Master Plan/Feasibility Study	May-04	WTP only approved.	
Gulkana	Water Storage Tank PER	Mar-19	Approved.	GKN032919
Hoonah	Sanitation Facilities Master Plan Update – Final Repo	Mar-16	Approved: Phases 1, 2, and 3 after resubmitting with additional info requested. Originally submitted June 2016 but was not unclear what top priority project for	HNH013117
Hooper Bay	Water Treatment Study	Mar-01	Approved	
Hooper Bay	Wastewater Lagoon	May-18	Approved	HPB062018
Hooper Bay	Old Town Water & Sewer Improvements PER	Aug-19	Approved	HPB090619
Hughes	Eng Feasibility Study Update (as amended in 2006)	Jun-06	Approved	
Hughes	Feasibility Engineering Study and Addendum	Feb-07	Approved	
Hughes	Low Pressure System Replacement PER	Feb-19	Not approved. More information requested.	
Hughes II	Low Pressure System Replacement PER	Mar-19	Approved	HUS090619
Huslia	Sanitation Facilities Improvement Plan	Dec-01	Approved	
Huslia	W&S Connections for Homes Outside the Piped Area	Mar-17	Approved.	HSL090117
Hydaburg	Sewer Master Plan	Feb-18	Not approved	
Hydaburg	Source Storage Transmission PER	Mar-18	Approved	HYG022519
Iliamna	Sludge Disposal Preliminary Engineering Report	Feb-17	Not officially reviewed by SOA as EPA declined to fund project.	
Kachemak Selo	Water System Feasibility Study	Dec-11	1st 3 priorities approved ONLY.	
Kachemak Selo	Water Source Improvements PER	Sep-19	Conditional approval.	093019
Kaltag	Water System Upgrades PER	Mar-18	ANTHC to address EPA/Dennis Wagner's comments, resubmit to VSW	
Kaltag II	Water System Upgrades PER	Mar-18	All 6 phases approved	KAL041619
Karluk	Sanitation Facilities Master Plan	Sep-06	Approved	
Karluk II	Sanitation Facilities Master Plan	Aug-15	Not approved. Capital cost of upgrades is extremely high.	

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Karluk III	Water Master Plan Addendum	Apr-18	Not approved.	
Kasaan	Water & Sewer Master Plan + Update	Jan-07	Phase 1 only approved.	
Kasaan	Water Distribution System PER	Mar-17	Not approved. Scope associated with O&M, not capital cost project.	
Kiana	Sanitation Facilities Master Plan Update	Sep-11	Manhole repairs (\$50K), service line installations (\$80K), and Jackson service lines (\$50K) approved.	
Kiana II	Master Plan Update - Valley View Subdivision Ph 1	Dec-14	Approved: Revisions made to Phase 1 accomodating 5 new homes, specifically modifications to the gravity sewer collection main lines, lift station, water distribution main lines and number of homes served.	IAN111315
Kiana III	Manganese Removal PER	Jan-18	Approved but doesn't qualify as "Beneficial Need" thus may not be eligible	IAN070618
Kipnuk	Sanitation Facilities Master Plan	Apr-02	Not approved	
Kipnuk II	Sanitation Facilities Master Plan Update	Dec-15	Approved following upgrades to existing facilities: Raise Raw Water Reservoir Berms and Raise Community Sewage Lagoon Berm. Disapproved: Piped system and 4 recommended upgrades.	IJK101916
Kipnuk III	Water Source Improvements PER	Feb-18	Not approved. Waiting on feasibility study for piped distribution system.	
Kipnuk	Water Distribution and Sewage Collection PER	Mar-19	Not approved.	
Kivalina	Water and Sewer Feasibility Study	May-14		
Kivalina	Washeteria Replacement/Upgrades PER	Mar-18	Water Treatment Plant needs to be incorporated into PER scope for application to	KVL040618
Klukwan	Sewer Feasibility Study	Jun-06	Approved	
Kobuk	Sanitation Facilites Plan	Apr-12	Approved except for new WST.	
Kokhanok	Water and Wastewater Feasibility Study	Feb-11	Approved	
Koliganek	Sanitation Facilities Master Plan	Oct-06	Approved	
Koliganek II	New Koliganek Water Leak Study	Mar-13	Approved: replacement of pipes for supply and return. Not approved: replacement of entire main.	JZZ110915

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Koliganek	Water Treatment Plant PER	Mar-20	Conditional approval upon resubmission of updated PER	KGK042420
Kongiganak	Sanitation Facilities Master Plan Update	Aug-03	Approved	
Kongiganak II	Swg lagoon, HB dispose site, water point, laundry	Apr-18	Conditional approval.	KKH070618
Kotzebue	Sanitation Utilities Development Plan	Jul-05	Approved	
Kotzebue	Kotzebue Lift Stations #1, 7, 9, & 12 Final PER	Jun-17	Clarification from ANTHC received. Approved.	OTZ103117
Koyuk	Koyuk Sanitation Facilities Improvement Plan	Aug-10	Approved except for Ph I (H ₂ O study) + II (new H ₂ O source)	
Koyuk	Laundromat Replacement PER	Mar-19	Approved	AKKA040720
Koyuk	Water Storage Tank PER	May-19	Not reviewed	
Koyukuk	First Time Interior Plumbing for 22 Homes Tech Memo	May-20	Approved	KYU061220
Kwethluk	Water and Sewer Master Plan Update	Mar-11	Approved	
Kwigillingok	Water Storage Tank PER	Mar-19	Approved	KWK071919
Levelock	Wastewater Feasibil Study&Drainfield Failure Invest	Jan-13	Approved: replacement of 8 septic systems.	KLL101916
Lime Village	Sanitation Facilities for Individual Homes PER Supplemental Funding Request	Jul-17	Approved	LVD042420
Lowell Point	Water and Sewer Feasibility Study	Nov-08	Approved	
Lower Kalskag	Master Plan Capital Cost Update	May-08	Approved	
Marshall	Phase g Water Sewer Service	Nov-18	Approved	MLL122018
McGrath	Water & Sewer System Evaluation and Master Plan	Aug-03	Approved	
McGrath	Wastewater Collection & Treatment PER	Aug-17	Approved on 8/4/2017	MCG080417
McGrath	Piped Water Distribution PER	Sep-17	Approved 10/12/2017	MCG101317
Mekoryuk	Water Source Improvements Final PER	Oct-17	Approved 10/12/2017	MYU101217
Metlakatla	Disinfection Byproduct Reduction & Pipe Corrosion	May-17	Approved, but requires two separate funding applications	MTM062217

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Metlakatla	Chester Lake Dam PER	Apr-20	Approved but requires alternate funding source	MTM042420
Mountain Village	W&S Feasibility Study and Master Plan	Mar-11	Not approved. More information requested.	
Mountain Village	Community Water Supply Alternatives	Dec-17	Approved but requires utility to enact policies to deter water-wasting, ensure viability of supply.	MOU012418
Nanwalek	Water Source, Transmission and Distribution Report	Oct-06	Approved	
Nanwalek	Masterplan Update	Sep-16	Only approved: Replace water distribution system (Sub-phases 1, 2, 3) and Solid Waste Landfill (though federal funds may not be available)	KEB020317
Napakiak	Water Treatment System Upgrade PER	Dec-18	Temporary Alternative approved; Permanent Alternative not approved.	WNA032619
Nelson Lagoon	Water System Improvement Plan	Sep-02	Approved	
Nenana	Sanitation Facilities Master Plan	Jul-05	Tasks 1-9 approved. Tasks 10-14 not approved.	
New Stuyahok	Water Treatment Plant PER	Mar-18	Approved. Modular WTP.	KNW040618
Newhalen	Water and Wastewater Feasibility Study	Sep-06	Approved	
Nightmute	Water & Sewer Improvement Feasibility Study	Aug-04	Approved	
Nikolaevsk	Water Facilities Feasibility Study	Dec-06	Approved	
Nikolaevsk	Water System Improvements PER	Apr-17	WST Freeze Protection & Backup Water Source approved; Water Service to Unserved Residences not approved due to inadequate documentation.	NK-050817
Nikolai	Sanitation Facilities Master Plan	Jun-05	Approved	
Nikolski	Utility Master Plan Update	Apr-07	Approved	
Noatak	Water, Sewer & Solid Waste Facilities MP Update	May-03	Phases 1-4 & 8 approved. Ph 5, 6, 7, 9 & 10 disapproved.	
Nondalton	Water & Sewer Engineering Feasibility Study	Aug-03	Approved	
Nondalton	Water Distribution System PER	Apr-19	Approved	NNL041619
Noorvik	Sanitation Facilities Master Plan Update	Sep-04	Phases 1-3 approved. Phase 4 not approved.	

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Noorvik	Wastewater Lagoon Improvements PER	Sep-19	Approved.	ORV040620
Nulato	Water and Sewer Feasibility Study	May-07	Phases 1-3 approved	
Nunam Iqua	Combined Utility Building Settlement PER	Jun-18	Approved.	SXP080218
Nunapitchuk	Haul Lagoon Improvements Draft PER	Mar-17	Approved on 8/4/2017	NUP080417
Old Harbor	Water Distribution System PER	Feb-17	Not approved. Scope associated with O&M, not capital cost project.	
Oscarville	Utility System PER	Mar-20	Groundwater study approved. Construction funding conditional upon results of the groundwater study.	OSC040620
Ouzinkie	Utilities Master Plan	Dec-00	Approved	
Pelican	Water and Sewer Preliminary Engineering Report	Jun-05	Phases 1-2 approved. Phase 3 not approved	
Perryville	Sanitation Feasibility Study	May-14	Not approved. Need for additional information: key elements needed in WTP, discussion and evaluation of various alternatives for WTP, realistic estimate of construction costs for a modular WTP.	
Perryville	Water Treatment Plant	May-18	Approved	KPV061918
Perryville	Community Water Source PER	Mar-19	Approved	KPV090619
Pilot Station	Landfill Relocation Feasibility Study	Sep-04	Approved	
Pilot Station	Lagoon Relocation Feasibility Study	Jun-05	Approved	
Pilot Station II	Master Plan Update	Nov-14	Approved: Phase 1 and 2 with critical comments. Disapproved: 3 and 4.	PQS040615
Platinum	Public Water System PER	Mar-19	Approved	PTU032619
Port Alexander	Water Tank and Foundation Project Proposal	Jan-20	Approved.	PTD050720
Port Graham	Outfall Consolidation Report	Jun-06	Approved.	
Port Graham	Port Graham Sewage Sludge Lagoon PER	Oct-17	Approved. But may not score highly enough.	PGM120417

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Port Heiden	Sanitation Improvements Feasibility Study	May-04	Approved	
Port Protection	Wastewater Engineering Study	Aug-04	Approved	
Port Protection	Drinking Water Supply PER	Feb-20	Not approved	
Rampart	Sewage Lagoon PER Supplemental Funding Request	Apr-20	Approved	RMP050720
Rampart	Wells & Septic PER	May-20	Approved	RMP062520
Ruby	Wells & Septic PER	May-20	Approved	RB062520
Ruby	Sanitation Facilities Master Plan	Jun-01	Approved	
Saint George	Water and Sewer Utility Plan Update	Apr-07	Approved	
Saint George	Water Storage Preliminary Engineering Report	Jun-17	Approved. However, project may not score highly enough for funds.	STG062217
Saint Mary's	Water & Wastewater Feasibility Study	May-06	Approved	
Saint Mary's	Andreafski Water Distribution Loop PER	Feb-20	Approved	KSM042420
Saint Paul	Ellerman Heights Sewer System Improvements Feasibility Study	Jul-05	Approved	
Saint Paul	Wastewater Lift Station PER	Feb-20	Approved	SNP041420
Saxman	Water and Wastewater Facility Master Plan Update	May-07	Ph 1, 2 & 4 approved. Ph 3 approved for KGB connect. Ph 5 not approved.	
Scammon Bay	Water System Improvements PER	Apr-19	Approved	SCM041619
Selawik	Water & Sewer Expansion Feasibility Study	Mar-05	Phase 1 approved. Phases 2-3 not approved.	
Shageluk	Sanitation Facilities Master Plan Amendment	Aug-11	Approved for exploratory well drilling only at this time.	
Shageluk	Preliminary Eng Report Water & Sewer System	Dec-17	Approval with conditions.	SHX050918
Shaktoolik	Sanitation Master Plan	Jun-11	Approved	
Shaktoolik	Sanitation Facilities Plan	Apr-13	Ph 1,2,& 3 approved. Fututre applications must be made incrementally.	SKK050614

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Shishmaref	Sanitation Facilities Master Plan	Sep-10	Phases 1,2,4,5 & 6 approved. Phase 3 not approved.	
Shungnak	Sanitation Facilities Plan	Apr-12	Approved	
Slana	Water & Sewer Feasibility Study	Apr-99	Approved	
Sleetmute	Sanitation Facilities Improvement Plan 2002 Update	Sep-02	Approved	
South Naknek	Wastewater Upgrades PER	Jun-17	Not approved. ANTHC resubmitted on 11/3. VSW responded 12/4.	
Stebbins	Community Development Plan - Addendum	May-10	Not approved.	
Stebbins	Piped Water and Sewer PER	Apr-20	Approved.	WBB050520
Tanacross	Sanitation Master Plan Update	Jan-06	Components 1-2 approved. Other components not approved.	
Tanana	Water and Sewer Feasibility Study Update	Feb-06	Phases 1-3 approved. Phases 4-9 not approved	
Teller	Sanitation Master Plan	May-14	Approved	TLA050614
Tetlin	Sanitation Facilities Master Plan Update	Mar-15	Not approved. Need for additional info listed in review letter.	
Tetlin	Sewage Lagoon Upgrades PER	Feb-17	Approved. Repair wastewater lagoon for \$973,161.00	TEH030117
Tetlin II	Sewage Lagoon Upgrades PER Supplemental Funding Request	Apr-20	Approved	TEH050420
Thorne Bay	Water Treatment Plant Improvements PER	Jun-17	Approved. (Facility upgrades and Nanofiltration)	KTB062217
Togiak	(Heights) Wastewater System Replacement PER	May-18	Not approved. Funds available for current needs not preventative maintenance	
Trapper Creek	Well & Watering Point PER	Mar-18	Approved with request to model after Anchor Point Watering Point.	TC-040618
Tuluksak	Supplement to Preliminary Engineering Study	Mar-06	Approved	
Tuluksak II	Water Treatment Plant and Washeteria PER	Mar-18	Approved	TLT080218
Tuntutuliak	Water Treatment Plant/Washeteria PER	Mar-19	Approved	WTL041619
Tununak	Water Treatment Plant and Washeteria PER	Apr-17	Approved	TNK050817
Tununak	Water Treatment Plant and Washeteria PER	Apr-20	Approved	TNK050720
Twin Hills	Sanitation Facilities Master Plan	May-07	Ph 1 & 4 approved. Ph 2, 3 & 5 not approved	
Twin Hills II	Water Distribution PER	Mar-18	Not approved	

7/22/2020

VSW Project Planning Documents Review Status

e.g. Master Plans, Studies, Preliminary Engineering Reports, etc.

Cost estimates included in the plan must be updated after a 5 year span.

Community	Plan/Study Title	Plan Date	Review Status/Approval Date	Index #
Twin Hills III	Water Distribution PER	Mar-19	Approved	TWA041619
Tyonek	Surface Water Source, Treatmnt & Distribut Study	Dec-04	Not approved	
Unalakleet	Happy Valley Lift Station Project PER	Apr-17	Approved	UNK050817
Upper Kalskag	Water Quality and Lagoon Improvements PER	Dec-19	Approved	KLGo40620
Venetie	Sanitation Facilities Master Plan/Feasibility Study	Jan-05	Approved	
Venetie	Sanitation Facilities Master Plan Update	Jan-17	Phase 1 (New WTP) and Phase 3 (Landfill upgrades) approved.	VEE013117
Venetie	Water Treatment Plant and Washeteria Facility PER	Jun-17	Approved (Modular Water Treatment Plant with Mechanical Reuse)	VEE062217
Venetie	Wells & Septic PER	May-20	Approved	VEE062520
Voznesenka	Water Improvements PER	Apr-18	Approved with 2 clarifications: VSW eligible homes only, adequate wastewater.	VA-040618
Wales	Sanitation Facilities Master Plan	Sep-02	Approved for washeteria and WTP	
Wales	Honeybucket Disposal Improvements PER	Dec-18	Approved	WAA022519
White Mtn	Sanitation Facilities Improvement Plan	Sep-04	Phases 1 and 2 approved. Phase 3 not approved.	
Whittier	Water System Master Plan	Jun-05	Phase III approved	
Yakutat	City and Borough Water & Sanitation Systems PER	Jun-17	5 projects approved. Not approved: Airport Service Area Wastewater Improvements	YAK062217
Yakutat	Well and Pumphouse Upgrades PER	Apr-18	Not approved	

= Most recent reviews