Aurora Energy, LLC Chena Power Plant BACT Appendix

1990-08 NSPS ICI SO2 RE.pdf 2017-03 Aurora BACT Report.pdf 2017-11-16 ADEC BACT Comment Letter to Aurora.pdf 2017-11-16 ADEC Request for Additional Information for Chena Power Plant BACT Analysis.pdf 2017-11-16 EPA Comments on Aurora BACT 111517.pdf 2017-11-16 Voluntary BACT Analysis Letter Aurora 042415.pdf 2017-12-22 Aurora Response to ADEC BACT Information Request 1.pdf 2017-12-22 ERM Final BACT Addendum for Aurora.pdf 2018-09-10 ADEC Request for Additional Information for Chena Power Plant BACT Analysis.pdf 2018-09-13 ADEC BACT Comment Letter to Aurora.pdf 2018-09-13 EPA Comments on ADEC BACT Analysis for Aurora 052118.pdf 2018-11-01 Aurora BACT Proposal No. 1899-R1.pdf 2018-11-01 Aurora General Arrangement Photo.pdf 2018-11-01 Aurora Preliminary Opinion of Probable Cost with attachments.pdf 2018-11-01 Aurora Preliminary Opinion of Probable Cost.pdf 2018-11-01 Aurora Response to ADEC BACT Information Request 2 with enclosures.pdf 2018-11-01 Aurora Response to ADEC BACT Information Request 2.pdf 2018-11-01 Aurora_DSI_Opinion_of_Probable_Cost_rev0.pdf 2018-11-01 CDS v SDA Cost Comparison for Aurora.pdf 2018-11-01 ICI Boilers 20081118 final_revised-Jan2009.pdf 2018-11-01 NSPS ICI SO2 RE.pdf 2018-11-01 ufc_3_701_01_c1_2018.pdf 2018-11-19 Aurora Proposed BACT Alternative with Appendices.pdf 2018-11-19 Aurora Proposed BACT Alternative.pdf 2019-05-10 Appendix A.pdf 2019-05-10 Appendix B.pdf 2019-05-10 Appendix C.pdf 2019-05-10 Appendix D.pdf 2019-05-10 Aurora Attachments OCR.pdf 2019-05-10 Public Notice Chena BACT Determination.pdf 2019-07-26 AE Comments on Draft SIP.pdf 2019-07-26 BACT Analysis Addendum - Ind Eng Eval_Final_20.pdf 2019-07-26 David Fish e-mail Aurora Energy, LLC's Comments on Draft SIP.pdf 2019-07-26 David Fish e-mail Usibelli Coal Mine, Inc. Comments on Draft.pdf 2019-07-26 UCM Comments on Draft SIP.pdf 2019-11-13 Chena Power Plant Response to Comments.pdf 2019-11-13 Final Chena BACT Determination.pdf

The following documents are included in the BACT but not listed in this appendix due to their electronic nature:

2017-03 Aurora NOx cost calcs FINAL.XLSX

2017-03 SO2 cost calcs - LSFO - CUECOST3.xlsx

2017-12-22 FINAL-CUECost Calculator.xlsx

2017-12-22 FINAL-DSI Cost Calculator.xlsx

2019-11-13 Chena SCR Economic Analysis ADEC.xlsm

2019-11-13 Chena SNCR Economic Analysis ADEC.xlsm

2019-11-13 Chena SO2 Controls Economic Analyses.xlsx



EPA-450/3-90-016

Small Industrial-Commercial-Institutional Steam Generating Units --Background Information for Promulgated Standards

Emission Standards Division

U.S. ENVIRONMENTAL PROTECTION AGENCY Office of Air and Radiation Office of Air Quality Planning and Standards Research Triangle Park, North Carolina 27711

August 1990

Appendix III.D.7.7-3859

2.3.3 Percent Reduction Standard

1. <u>Comment</u>: Two commenters (IV-D-08, IV-D-28) requested that the 90 percent SO₂ reduction requirement be eliminated and replaced with an emission limit of 520 ng/J (1.2 lb/million Btu) heat input. One commenter (IV-D-08) objected to applying the 90 percent SO₂ reduction requirement to all coal regardless of sulfur content. This commenter stated that the EPA's conclusion that no units will be built in the size range between 22 and 29 MW (75 and 100 million Btu/hr) heat input capacity and operating at greater than 55 percent capacity factor is flawed. This commenter stated that the SO₂ standard of 520 ng/J (1.2 lb/million Btu) heat input for coal-fired plants should apply to all steam generating units in this source category, regardless of size. This commenter further recommended that the full 90 percent SO₂ removal be required only when the 520 ng/J (1.2 lb/million Btu) limit could not be met by using low sulfur coals or by pretreating the coals.

Another commenter (IV-D-28) stated that the 90 percent SO_2 reduction requirement should be removed and that coal-fired steam generating units in the 8.7 to 29 MW (30 to 100 million Btu/hr) range should be required only to meet the 520 ng/J (1.2 lb/million Btu) SO_2 limit. The commenter stated that the percent reduction requirement would place an unjustified cost and performance burden on units in this range that either already meet or are close to meeting the 520 ng/J (1.2 lb/million Btu) SO_2 limit.

<u>Response</u>: Section 111 of the CAA requires standards to reflect application of the best demonstrated technology considering costs, nonair quality health and environmental impacts, and energy requirements. Section 111 also requires that for fossil fuel-fired steam generating units a percent reduction standard be established. Read together, this means that the

2-22

Administrator is compelled to include a percent reduction standard unless the impacts associated with the requirements would be unreasonable. As discussed in the background document, "Model Boiler Cost Analysis for Controlling Sulfur Dioxide (SO₂) Emissions from Small Steam Generating Units" (EPA-450/3-89-14), a small coal-fired steam generating unit of 22 MW (75 million Btu/hr) size and operating at a 55 percent capacity factor has an incremental cost-effectiveness value of about \$3,600/Mg (\$3,300/ton) relative to an emission limit standard of 520 ng/J (1.2 lb/million Btu). Capital and annualized costs are projected to increase by approximately 20 percent over the regulatory baseline for the percent reductions standard. However, these values increase significantly for units less than 22 MW (75 million Btu/hr) heat input capacity and for any unit less than 29 MW (100 million Btu/hr) operating at an annual capacity factor for coal of less than 55 percent. Imposing these high costs for these units was considered to be unreasonable when compared to the increase in emission reductions achievable by the percent reduction requirement on these units. Therefore, in keeping with the requirements of the CAA, the final standards will not require percent reduction for any units operating at less than a 55 percent annual capacity factor for coal or any unit with a heat input capacity of 22 MW (75 million Btu/hr) or less.

Finally, no conclusion was made that coal-fired steam generating units greater than 22 MW (75 million Btu/hr) heat input and greater than 55 percent capacity factor would not be built. Rather, this was a projection of sales over the next five years based on sales trends over the past several years. The sales projections for coal-fired units had no influence on the conclusion of the reasonableness of the percent reduction requirement. (The assumption was used in generating national impacts of the standards.) The model steam generating unit analysis examined the potential impacts of the percent reduction requirement on a coal-fired unit greater than 22 MW (75 million Btu/hr) and greater than 55 percent capacity factor. Therefore, should a unit be built, requiring 90 percent reduction of emissions would be reasonable.

2-23



Best Available Control Technology Analysis

Chena Power Plant, Fairbanks, Alaska

March 2017, revised

www.erm.com

Best Available Control Technology Analysis

Chena Power Plant, Fairbanks, Alaska

Prepared for: Aurora Energy, LLC 100 Cushman St., Suite 210 Fairbanks, Alaska 99701-4674

March 2017, revised

Celler Kand

Kelley Hand Project Manager

Sture Hankini

Steve Hawkins Principal-in-Charge

Environmental Resources Management

9825 Kenwood Road, Suite 100 Cincinnati, Ohio 45242 Phone: (513) 830-9030

TABLE OF CONTENTS

1	INTI	INTRODUCTION AND BACKGROUND									
	1.1	PROCI	EDURAL MATTERS RELATED TO PM2.5 NONATTAINMENT	' 1							
	1.2	RECLASSIFICATION FROM MODERATE TO SERIOUS									
	1.3	REQUIREMENT TO INCORPORATE BACM/BACT									
	1.4	HISTORIC PERSPECTIVES IN BACT									
	1.5	APPLI	CATION OF BACT TO STATIONARY SOURCES	7							
	1.6	RA ENERGY AND THE CHENA POWER PLANT	10								
	1.7	ANT FEATURES OF THE ALASKA SIP	10								
		1.7.1	Identification of Relevant Control Technologies	10							
		1.7.2	Estimates of Secondary Particulate Loads on PM _{2.5} Filters	11							
		1.7.3	Basin-wide Emission Inventory	12							
2	DISC	DISCUSSION OF NOX CONTROL OPTIONS									
	2.1	REVIEW OF NOX BACT DATABASE									
	2.2	IDENTIFICATION OF NOX CONTROL OPTIONS									
	2.3	TECHNICALLY INFEASIBLE NO _X CONTROL OPTIONS									
		2.3.1	Alternate Fuel	17							
		2.3.2	Combustion Control	17							
		2.3.3	Steam and Water Injection	17							
		2.3.4	Reburn	18							
		2.3.5	Non-Selective Catalytic Reduction	18							
	2.4	TECHN	VICALLY FEASIBILE NOX CONTROL OPTIONS	18							
		2.4.1	Selective Catalytic Reduction	18							
		2.4.2	Selective Non-Catalytic Reduction	19							
		2.4.3	Effectiveness of Technically Feasible NOx Control Options	20							
		2.4.4	Economic Evaluation of NOx Control Options	21							

3 DISCUSSION OF SO₂ CONTROL OPTIONS

30

	3.1	REVIEW OF SO₂ BACT DATABASE					
	3.2	IDENTI	IFICATION OF SO ₂ CONTROL OPTIONS	30			
	3.3	TECHN	ICALLY INFEASIBILE SO ₂ CONTROL OPTIONS	32			
		3.3.1	Fuel Substitution	32			
		3.3.2	Dry Scrubber	32			
	3.4	TECHN	ICALLY FEASIBLE SO2 CONTROL OPTIONS	33			
		3.4.1	Wet Scrubber	33			
		3.4.2	Effectiveness of Technically Feasible SO_2 Control Options	34			
		3.4.3	Economic Evaluation of SO_2 Control Options	34			
	3.5	SUMM	ARY OF COST EFFECTIVENESS OF CONTROL OPTIONS	35			
4	DISC	CUSSION	OF SITE-SPECIFIC CONSIDERATIONS	39			
	4.1	LOCAT	TON LIMITATIONS	39			
	4.2	ENVIR	ONMENTAL AND ENERGY CONSIDERATIONS	40			
		4.2.1	Environmental Considerations	40			
		4.2.2	Energy Considerations	49			
	4.3	SUMM	ARY OF ENVIRONMENTAL AND ENERGY CONSIDERATION	ONS50			
5	DET	ERMINAT	TION OF BACT	51			
	5.1	DETER	MINATION OF BACT FOR NOX	51			
	5.2	DETER	MINATION OF BACT FOR SO2	52			

LIST OF TABLES

Table 1. Summary of Chena Power Plant Boilers and Emission Rates 11
Table 2. 2008 Baseline Episode Average Daily Emissions (ton/day) bySource Sector, Actual Point Source Emissions
Table 3. Summary of NOx BACT Permit Reviews 16
Table 4. Control Effectiveness of NOx Control Options 21
Table 5. Cost Effectiveness of NOx Control Options 21
Table 6. Capital Cost Summary: SCR for Combined Chena Exhaust
Table 7. Annualized Cost Summary: SCR for Combined Chena Exhaust 24
Table 8. Capital Cost Summary: SNCR for 76 MMBtu/hr Boiler
Table 9. Capital Cost Summary: SNCR for 269 MMBtu/hr Boiler
Table 10. Annualized Cost Summary: SNCR for 76 MMBtu/hr Boiler 27
Table 11. Annualized Cost Summary: SNCR for 269 MMBtu/hr Boiler 28
Table 12. Summary of Overall Annualized Costs for SNCR 29
Table 13. Summary of SO2 BACT Permit Reviews
Table 14. Control Effectiveness of SO2 Control Options 34
Table 15. Cost Effectiveness of SO2 Control Options
Table 16. CUECost Input and Calculation Summary: Wet Scrubber

LIST OF FIGURES

Figure 1. Chena Power Plant exhaust plume
Figure 2. Chena Power Plant daily coal combustion v ambient PM _{2.5} concentrations at the State Office Building monitor (2013)
Figure 3. Chena Power Plant daily coal combustion v ambient $PM_{2.5}$ concentrations at the Pioneer Road monitor (2013 to 2015)
Figure 4. Chena Power Plant daily coal combustion v ambient PM _{2.5} concentrations at downtown Fairbanks monitor 20904005-3 (2013 to 2014).

ACRONYMS AND ABBREVIATIONS

acfm	actual cubic feet per minute
ADEC	Alaska Department of Environmental Conservation
BACM	best available control measures
BACT	best available control technology
CAA	Clean Air Act
CMAQ	Community Multiscale Air Quality
CMB	chemical mass balance
dscf/min	dry standard cubic feet per minute
EPA	Environmental Protection Agency
FGD	flue gas desulfurization
FGR	flue gas recirculation
FNSB	Fairbanks North Star Borough
GVEA	Golden Valley Electric Association
HC	hydrocarbon
HNO ₃	nitric acid
LAER	Lowest Achievable Emission Rate
LAF	Location Adjustment Factor
lb/hr	pound per hour
LEA	lean excess air
LNB	low-NOx burners
LSFO	limestone forced oxidation
MW	megawatt
NAAQS	National Ambient Air Quality Standard
NGR	natural gas reburning
NH ₃	ammonia
NNSR	nonattainment new source
NOx	oxides of nitrogen
NSCR	non-selective catalytic reduction
NSPS	New Source Performance Standards
NSR	New Source Review

OFA	over-fire air
OH	hydroxyl
PM	particulate matter
ppm	parts per million
PSD	Prevention of Significant Deterioration
RACM	reasonably available control measures
RACT	reasonable available control technology
RFP	Reasonable Further Progress
SCR	selective catalytic reduction
SIP	State Implementation Plan
SNCR	selective non-catalytic reduction
SO ₂	sulfur dioxide
SSF	Site Sensitivity Factor
ton/yr	tons per year
U.S.	United States
V_2O_5	vanadium pentoxide
VOC	volatile organic compounds
µg/m³	micrograms per cubic

1 INTRODUCTION AND BACKGROUND

1.1 PROCEDURAL MATTERS RELATED TO PM_{2.5} NONATTAINMENT

The Clean Air Act (CAA) requires the U.S. Environmental Protection Agency (EPA) to set air quality standards (40 CFR Part 50) to protect the health and welfare of the public and the environment. In partial fulfillment of this charge, U.S. EPA has set National Ambient Air Quality Standards (NAAQS) for six principal criteria air pollutants, including particulate matter (PM), to ensure that health and environmental protection are adequate based on the scientific justifications. In 1997, U.S. EPA established annual and 24-hour NAAQS for PM_{2.5}. In 2006, U.S. EPA lowered the 24-hour ambient PM_{2.5} standard from 65 micrograms per cubic meter ($\mu g/m^3$) to 35 $\mu g/m^3$. States were required to examine monitoring data collected within their communities and make designation recommendations based on the new standard by December 2007. In 2009, U.S. EPA designated the Fairbanks North Star Borough (FNSB) as nonattainment for the 24-hour PM_{2.5} standard. As a result of this designation, and as described below, the Alaska Department of Environmental Conservation (ADEC) was required to prepare a State Implementation Plan (SIP) that defined those actions needed to bring the FNSB into attainment of the NAAQS.

In March 2012, the U.S. EPA issued a document specifically to guide states in preparing their SIP submissions and meeting plan requirements for the 2006 24-hour PM_{2.5} NAAQS. The guidance for the 2006 PM_{2.5} NAAQS was based, in large part, on the requirements finalized in the 2007 $PM_{2.5}$ Implementation Rule, which the U.S. EPA had based solely upon the statutory requirements of CAA Part D, Subpart 1. Under those provisions, states were required to submit a SIP within 3 years following a designation of nonattainment. Alaska's effective date of the FNSB designation as a nonattainment area was December 14, 2009. Alaska's original SIP submittal due date under CAA Part D, Subpart 1, therefore, was December 14, 2012. However, on January 4, 2013, the DC Circuit Court ruled that the CAA requires implementation of the PM_{2.5} NAAQS under CAA Part D, Subpart 4 (Sections 188-190) rather than implementation under Subpart 1. Subsequently, on June 2, 2014, U.S. EPA published a new rule that identified PM2.5 "Moderate" nonattainment areas and proposed December 31, 2014 as the new submittal due date of a Subpart 4 SIP to U.S. EPA. The SIP was required to demonstrate, using air quality modeling, that attainment was either possible or impracticable by December 31, 2015.

1.2 RECLASSIFICATION FROM MODERATE TO SERIOUS

On December 31, 2014, ADEC submitted the FNSB PM_{2.5} Moderate Nonattainment Area SIP that demonstrated through air quality modeling that it would be impracticable to attain the 24-hour PM_{2.5} NAAQS by December 31, 2015. U.S. EPA was to review ADEC's impracticable demonstration and conduct an independent analysis of the FNSB air quality. ADEC made additional submissions and provided clarifying information to supplement the SIP in January 2015, March 2015, July 2015, November 2015, March 2016, November 2016, and January 2017. The original SIP and all subsequent submissions are included in U.S. EPA Docket ID EPA-R10-OAR-2015-0131.1 On November 20, 2015, ADEC submitted a request to U.S. EPA to redesignate the boundary of the FNSB PM_{2.5} Nonattainment Area by dividing it into two separate areas. The request would divide the area along Badger Road, resulting in a western area containing Fairbanks and an eastern area containing North Pole. U.S. EPA has up to 18 months (May 2017) to evaluate and either approve or disapprove the request. Regardless, the U.S. EPA was still required to determine whether the FNSB was able to attain the 24-hour PM_{2.5} NAAQS by the December 31, 2015, deadline and to publish a notice of the determination in the Federal Register by June 30, 2016. If the area did not attain the 24-hour PM_{2.5} NAAQS, the area would be reclassified by operation of law as a Serious nonattainment area.

On October 11, 2016, two environmental groups filed a complaint for declaratory and injunctive relief against U.S. EPA arguing that it failed to fulfill its statutory duty under the CAA to declare whether or not the FNSB nonattainment area has attained the standard by the June 30, 2016 deadline. The complaint also requested that the court declare that the U.S. EPA is in violation of the CAA and issue an injunction requiring the agency to publish a notice regarding the FNSB attainment/nonattainment status and, if the area is found to still be nonattainment, to reclassify it as Serious nonattainment. On December 16, 2016, U.S. EPA published a proposed rule proposing to determine that the FNSB failed to attain the 2006 24-hour PM_{2.5} NAAQS by December 31, 2015 and proposing to reclassify the area from Moderate to Serious pursuant to CAA section

¹ Fairbanks PM_{2.5} Moderate Area Plan Regulatory Docket https://www.regulations.gov/docket?D=EPA-R10-OAR-2015-0131

188(b)(2).² As required by CAA Section 188(b)(2), upon finalization of the U.S. EPA's determination that the area failed to attain, the FNSB will be reclassified to Serious by operation of law and will be subject to all applicable Serious area attainment planning and nonattainment new source review (NNSR) requirements.

On February 2, 2017, the U.S. EPA published a proposed rule proposing to approve the Moderate SIP for the FNSB 24-hour PM_{2.5} (2006) NAAQS.³ Once the area is reclassified from Moderate to Serious, pursuant to Subpart 4, ADEC will have 18 months from the effective date of reclassification, or 2 years before the attainment date, whichever is earlier, to submit a Serious area attainment plan. This submittal date would be no later than December 31, 2017. However, CAA Section 188(d) provides a mechanism by which ADEC may request, and the U.S. EPA may grant, a 1-year extension of an area's attainment date if the State meets certain criteria.

The Serious area attainment plan must include the imposition of control measures consistent with best available control measures (BACM), which includes application of best available control technology (BACT) for major stationary sources, with the goal of bringing the area into attainment as expeditiously as practicable, but no later than the end of the 10th calendar year after designation.

1.3 REQUIREMENT TO INCORPORATE BACM/BACT

Implementation of PM_{2.5} NAAQS under CAA Part D, Subpart 4 includes the following state requirements related to the nonattainment area:

• Submit an attainment demonstration or demonstration that attainment by the applicable attainment date is impracticable [Section 189(a)(1)(B)];

² Federal Register, Volume 81, page 91089, December 16, 2016, 40 CFR Part 52 and 81,

Determinations of Attainment by the Attainment Date, Determinations of Failure To Attain by the Attainment Date and Reclassification for Certain Nonattainment Areas for the 2006 24-Hour Fine Particulate Matter National Ambient Air Quality Standards

³ Federal Register, Volume 82, February 2, 2017, 40 CFR Part 52, Air Plan Approval; AK, Fairbanks North Star Borough; 2006 PM_{2.5} Moderate Area Plan, Proposed Rule.

• Assure implementation of reasonably available control measures (RACM) and reasonable available control technology (RACT) for Moderate nonattainment areas [Section 189(a)(1)(C)];

• Assure implementation of BACM and BACT no later than 4 years after the date the area is classified (or reclassified) as a Serious nonattainment area [Section 189(b)(1)(B)];

• Redefine the terms "major source" and "major stationary source" to include any stationary source or group of stationary sources located within a contiguous area and under common control that emits, or has the potential to emit, at least 70 tons of $PM_{2.5}$ (or $PM_{2.5}$ precursors) per year; and

• Apply PM_{2.5} precursor control requirements for major stationary sources [Section 189(e)].

On March 23, 2015, U.S. EPA published a proposed rule entitled, "Fine Particulate Matter National Ambient Air Quality Standards: State Implementation Plan Requirements" that provides additional guidance to affected states related to the requirements listed above. The final rule was promulgated on August 24, 2016.⁴ In this rule, U.S. EPA also defined requirements that agencies would have to meet as they implement the NAAQS for PM_{2.5}. Various aspects of this rule are relevant to the process for evaluating what constitutes BACT at a major stationary source. Because implementation of BACT in a Serious nonattainment area is not a traditional process, incorporation of some of the nuances associated with the final rule and its potential interpretation are considered justified herein.

An important aspect of the final rule relates to whether a particular $PM_{2.5}$ precursor is determined to be a significant contributor to ambient $PM_{2.5}$ levels. Scientific research has shown that various pollutants can contribute to ambient $PM_{2.5}$ concentrations. In addition to direct $PM_{2.5}$ emissions, these include the following precursors:

- sulfur dioxide (SO₂);
- oxides of nitrogen (NOx);

⁴ Federal Register, Volume 81, pages 58010 through 58162, August 24, 2016, 40 CFR Parts 50, 51, and 93, Fine Particulate Matter National Ambient Air Quality Standards: State Implementation Plan Requirements; Final Rule.

- volatile organic compounds (VOC); and
- ammonia (NH₃).

These gas-phase precursors undergo chemical reactions in the atmosphere to form secondary $\mathrm{PM}_{2.5}$.

The final rule describes how in some cases a state may demonstrate that the adoption of additional emission reduction measures for a particular precursor is not needed for purposes of achieving expeditious attainment nor for advancing the attainment date by at least a year in a nonattainment area. The rule also describes three optional approaches for demonstrating that a particular precursor is not a significant contributor to ambient PM_{2.5} levels that exceed the standard in a particular nonattainment area. These three precursor demonstrations are: (1) comprehensive precursor demonstration; (2) major stationary source precursor demonstration; and (3) NNSR precursor demonstration.

These three precursor demonstrations are described below:

- 1. A comprehensive precursor demonstration would show that emissions of a particular precursor from all existing stationary, area, and mobile sources located in the nonattainment area do not contribute significantly to PM_{2.5} levels that exceed the standard in the area.
- 2. A major stationary source precursor demonstration differs from the comprehensive demonstration in that it only evaluates existing major sources, and therefore may only be used to justify the exclusion of existing major sources from the control requirements for the applicable precursor.
- 3. A NNSR precursor demonstration is part of any Moderate or Serious area plan. This specific type of precursor demonstration is the only one of the three demonstrations described in this section that if approved would exempt new and modified major stationary sources of a precursor from regulation under the NNSR permitting program.

If the U.S. EPA approves a comprehensive precursor demonstration for a Moderate or Serious plan, then the state would not be obligated to evaluate RACM/RACT or BACM/BACT measures, as appropriate, for reducing that precursor in the nonattainment area, nor would it need to account for that precursor in the Reasonable Further Progress (RFP) plan, quantitative milestones, and contingency measures. If a major stationary source precursor demonstration is approved, then the state would not be obligated to evaluate RACM/RACT or BACM/BACT measures for reducing that precursor from major sources in the nonattainment area, nor would it need to account for emissions of that precursor from major sources in the RFP plan, quantitative milestones, and contingency measures.

The first two of these demonstrations relate to existing sources in a nonattainment area. Even if a state fails to make demonstration, however, or if the U.S. EPA fails to approve a state demonstration, lack of a significant contribution to PM_{2.5} nonattainment by a stationary source should be considered an important feasibility factor in the environmental evaluation included in a RACT or BACT analysis (see section 1.5 for a discussion of the BACT evaluation process). Although a Serious plan is not yet required for the FNSB, U.S. EPA has proposed to approve the ADEC Moderate SIP precursor demonstration for major stationary sources of NOx and for all sources of VOCs within the FNSB nonattainment area. In making this proposal, U.S EPA concluded that it is not necessary to evaluate and impose controls on major stationary sources of NOx in the Moderate plan.⁵ By extension, this same conclusion would be expected for any precursor demonstration fa future FNSB Serious SIP.

1.4 HISTORIC PERSPECTIVES IN BACT

The control concept that represents use of BACT on air pollutant sources has been in existence since the mid-1970s. BACT is part of a hierarchical approach to air pollution control based in part on the air quality in the area in which a stationary source was, or would be, located. The hierarchy specified three differing degrees of air pollution control depending on whether an area was in attainment of the prescribed NAAQS and whether the source requiring control was existing or new. BACT was specified to be applicable only to new sources in areas that were in attainment of the NAAQS. In comparison, new sources in nonattainment areas were required to apply technology producing the Lowest Achievable Emission Rate (LAER), whereas existing sources in nonattainment areas were required to apply RACT. No parallel concept exists for existing sources in attainment areas.

In general, the distinction between the three levels of control introduced above is a cost consideration. Economics play the greatest role when

⁵ Federal Register, Volume 82, page 9042, February 2, 2017, 40 CFR Part 52, Air Plan Approval; AK, Fairbanks North Star Borough; 2006 PM_{2.5} Moderate Area Plan, Proposed Rule.

identifying RACT for a source. Although no hard-fast cost line exists, a source is required to apply RACT only if the cost is "reasonable." An economic test also is required when defining BACT, but an underlying acceptance is that the economic threshold for BACT is higher than for RACT. One rationale for this acceptance is that, because BACT is (until the concept of nonattainment BACT was conceived) only applied to new sources, one can include pollution control technology considerations during the design stage. Contrary to RACT and BACT, no cost consideration is given to specification of LAER technology, this due to the fact that already "dirty" areas must be protected at all costs from further degradation. The hierarchy generally described herein leads to the conclusions that RACT requirements are typically less stringent than BACT, and BACT requirements are less stringent than LAER. All three levels of control rely on application of demonstrated control techniques, as opposed to innovative technologies or techniques that have not been fully developed or demonstrated in practice.

1.5 APPLICATION OF BACT TO STATIONARY SOURCES

Since originally defined in the mid-1970s, the process of making a BACT determination has undergone numerous refinements. Specification of "nonattainment BACT" in the CAA is the most recent, and perhaps the most complex, refinement. Until that time, BACT requirements were limited to new major source review activities in attainment areas (i.e., the regulations for Prevention of Significant Deterioration [PSD]). Since the promulgation of the PSD regulations, preconstruction review for new or modified major air pollutant sources located in clean air areas (i.e., attainment areas) has always required an evaluation of the use of BACT. Although the specific procedures have varied over the decades, the PSD BACT evaluation entails a pre-construction review that demonstrates that BACT will be applied on a pollutant-by-pollutant basis for each air pollutant emitted at a rate that exceeds its pollutant-specific PSD significant emission rate. Selection of a BACT emission limit is a case-bycase process that must consider site-specific aspects of the project, including the economics of the selection as well as the environmental and energy impacts that could result from the use of the technique or technology.

Aside from the CAA specification of nonattainment BACT, two other historic "refinements" define the character of a BACT determination or demonstration, and both are related to the manner in which technologies are ranked for consideration. The more significant refinement of the two is adoption of the BACT analysis "top-down" procedure published in U.S. EPA's draft 1990 New Source Review (NSR) Workshop Manual. This topdown procedure identifies the following steps as part of a BACT review:

- 1. Identify all control technologies
- 2. Eliminate technically infeasible options
- 3. Rank remaining control technologies by control effectiveness (highest to lowest)
- 4. Evaluate the most effective controls (using economic, environmental, and energy criteria) and document results
- 5. Select BACT.

The third step in this process, rank remaining control technologies by control effectiveness, is the heart of the top-down approach. This step requires that, after technically infeasible control options have been eliminated, the remaining technology with the greatest degree of control should be considered BACT unless one of the other evaluation criteria indicates an adverse impact will result. While this review process appears to be very well defined, the level at which a specific evaluation criterion would be considered "adverse" is not clearly defined; this uncertainty often provides the basis for extensive debate between the source operator and the permitting authority.

A second historic refinement relates to another new source regulatory program, the New Source Performance Standards (NSPS). The NSPS are applicable nationwide to industrial sources that meet the "new source" applicability date established by U.S. EPA for many categories of industrial emitters, including coal-fired (and other fossil fuel-fired) steam generators and utility boilers. The NSPS are designed to implement the best technology currently available, taking into account cost and energy impacts. Unlike the case-by-case aspect of BACT, these standards are the same for every new emitter. When one exists, an NSPS represents the minimum requirement that will be imposed on a new air pollutant source. New sources undergoing PSD review could possibly be required to meet more stringent emission limits than imposed by NSPS. Thus, no BACT determination can conclude that a BACT emission limit is less stringent than an applicable NSPS. As explained by U.S. EPA in response to numerous requests for interpretations:

"Since an applicable NSPS must always be met, it provides a legal 'floor' for the BACT, which cannot be less stringent."

Presently, as the U.S. EPA and states are developing plans to bring areas into attainment of the NAAQS for PM_{10} and $PM_{2.5}$, U.S. EPA has determined that further refinement of the BACT process may be in order.

U.S. EPA has, therefore, included a multi-faceted discussion of evaluating BACT in Serious nonattainment areas in the March 23, 2015, proposed rule and August 24, 2016, final rule. Part of the discussion relates nonattainment BACT to other BACT evaluations and concludes similarity to existing BACT evaluation procedures. Another part of the discussion is less related to the manner in which a BACT evaluation is performed and more related to the proposed manner in which BACT might actually be implemented in a Serious PM_{2.5} nonattainment area.

Two aspects of the newly-conceived nonattainment BACT requirement make this regulatory concept very difficult to implement. The first aspect is related to retrofitting an existing source with new (BACT) equipment. This potential requirement eliminates the economic efficiency of installing add-on control equipment to a new source as is typically done as an outcome of a BACT determination. Another aspect of a nonattainment BACT evaluation that leads to implementation difficulty, as mentioned earlier in Section 1.3 of this BACT report, is the use of optional precursor demonstrations. In some PM_{2.5} nonattainment areas, a particular precursor or precursors may not contribute significantly to PM_{2.5} levels that exceed the relevant NAAQS.6 Thus, adoption of additional emission reduction measures for a particular precursor may not be needed for purposes of achieving expeditious attainment. In evaluating the various precursor demonstration options, U.S. EPA generally agreed that a significance level could be established for the contribution of a particular precursor source group to the total ambient PM_{2.5} concentration. In its 2016 Draft PM_{2.5} Precursor Demonstration Guidance, U.S. EPA recommended an insignificant threshold value of $1.3 \,\mu\text{g}/\text{m}^3$ for the 24hour PM_{2.5} NAAQS as the level of insignificance that would eliminate the need to establish a control measure for the source or source category.⁷ This concept is important when considering the environmental benefits of any mandated control measure as it relates to defining BACT for existing sources in a nonattainment area. However, lack of final guidance on the manner in which a BACT analysis should incorporate a finding of insignificant improvement in air quality concentrations for the nonattainment area pollutant (other than by a state demonstration described above) leaves implementation of nonattainment BACT openended.

⁶ Federal Register, Volume 81, page 58017, August 24, 2016, 40 CFR Parts 50, 51, and 93, Fine Particulate Matter National Ambient Air Quality Standards: State Implementation Plan Requirements; Final Rule.

⁷ Page, Stephen D., Director Office of Air Quality Planning and Standards, Draft PM_{2.5} Precursor Demonstration Guidance, November 17, 2016.

1.6 AURORA ENERGY AND THE CHENA POWER PLANT

Aurora Energy LLC (Aurora) owns the Chena Power Plant in downtown Fairbanks, Alaska, within the FNSB. The Chena Power Plant consists of four, sub-bituminous coal-fired boilers, which produce electricity and locally-distributed steam. The PM produced during coal combustion in the Chena Power Plant boilers is currently controlled by a single baghouse and is emitted through a combined stack (capacity of 250,000 actual cubic feet per minute [acfm]). Table 1 summarizes the Chena Power Plant boilers and emissions measured during the most recent emission testing, performed in November 2011. As shown in Table 1, the Chena Power Plant has the potential to emit, primarily from their four coal-fired boilers, at least 70 tons of PM_{2.5} precursors per year (SO₂ and NO_x). Therefore, Aurora Energy is subject to the nonattainment BACT analysis requirements for SO₂ and NO_x. PM_{2.5} is already adequately controlled through the use of a baghouse, and no further control technique review is required for PM.

1.7 RELEVANT FEATURES OF THE ALASKA SIP

1.7.1 Identification of Relevant Control Technologies

The ADEC prepared a full control technology evaluation as part of the SIP and concluded that stationary source control should concentrate on primary $PM_{2.5}$ emissions and that control of secondary $PM_{2.5}$ emissions would be ineffective in bringing about attainment. The ADEC performed a traditional RACT evaluation for SO₂ and NOx produced during coal combustion for each specific coal combustion source in the FNSB. The ADEC concluded that the continued use of low sulfur coal at industrial and utility boilers represents RACT for SO₂. This conclusion is consistent with historic SO₂ control concepts employed by the U.S. EPA. The ADEC also concluded that use of add-on control equipment to reduce NOx emissions during coal combustion was too expensive and much less technically effective than control programs designed to reduce the direct $PM_{2.5}$ emissions from area-wide sources, such as motor vehicles and wood-burning stoves. Both of these conclusions are supported by the

			(Average Measured Emissions ^(a)							
			low in ^{(a,b}		SO_2		NOx				
Boiler	Boiler Size (10 ⁶ Btu/hr)	Installation Date	Average Air/ Rate (dscf/m	lb/hr ^(c)	ppm ^(d, e)	ton/yr ^(f)	lb/hr	undd	ton/yr		
Boiler No. 1 (travelling grate stoker equipped with over-fire air and air preheaters)	76	1954									
Boiler No. 2 (travelling grate stoker equipped with over-fire air and air preheaters)	76	1952									
Boiler No. 3 (travelling grate stoker equipped with over-fire air and air preheaters)	76	1952	141,610	189.4	134.3	829.6	177.0	174.0	775.3		
Boiler No. 5 (spreader stoker equipped with over-fire air, low excess air, and air preheaters)	269	1970									

 Table 1. Summary of Chena Power Plant Boilers and Emission Rates

a. Average measured airflow and emissions during November 2011 source test

- b. dscf/min = dry standard cubic feet per minute
- c. lb/hr = pound per hour
- d. ppm = parts per million
- e. SO_2 ppm limit is 500 ppm
- f. ton/yr = tons per year

analyses presented later in this BACT evaluation. The ADEC supported their conclusion that NOx control would be ineffective by including a stationary source precursor demonstration in the control evaluation. The ADEC conclusion was sound, but the U.S. EPA had not provided a recommended procedure or insignificant impact level prior to SIP development. As stated earlier, the U.S. EPA has now proposed to approve the precursor demonstration for NOx. ADEC did not prepare a precursor demonstration for SO₂.

1.7.2 Estimates of Secondary Particulate Loads on PM_{2.5} Filters

The ADEC included background reports in the SIP that provided estimates of the various source contributions to ambient $PM_{2.5}$ concentrations. A chemical mass balance (CMB) technique was used by the University of Montana to estimate source contributions for each day that a filter was collected at several monitoring stations in the FNSB between 2005 and 2013.⁸ Using two different source profiles, the report authors estimated the contributions due to secondary sulfates and nitrates, wood smoke, and various other sources in the FNSB. Looking at the CMB estimates for days that exceeded the standard at downtown Fairbanks monitors, one sees very high contributions from wood smoke (50 to 76 percent of the PM_{2.5} mass using the EPA profile and 8 to 59 percent of the PM_{2.5} mass using the OMNI profile), and in many cases at the State Building and Peger Road stations, the EPA profile yields estimates that PM_{2.5} contributions from wood smoke alone exceeds the NAAQS. The contribution from ammonium nitrate was estimated to be small, ranging from 1.0 to 8.0 μ g/m³ and 0 to 5.8 μ g/m³ on days when the standard was exceeded in Fairbanks using the EPA and OMNI profiles, respectively. Similar patterns were observed at the North Pole monitoring stations.

The SIP also included a modeling evaluation of base year (2008) emissions and future year (2015 and 2019) emissions. The modeling evaluations for future years were run with and without the stationary source NOx emissions. This modeling evaluation became the basis for a stationary source precursor demonstration in the Moderate attainment plan and could become the basis for a State-developed comprehensive precursor or major stationary source demonstration in a Serious attainment plan. As stated earlier, this precursor demonstration indicates that stationary source NOx control is ineffective in the FNSB and has been proposed to be approved by the U.S. EPA.

1.7.3 Basin-wide Emission Inventory

As part of the SIP development process, the ADEC also prepared a basinwide emission inventory of all point and area sources. Table 2 presents a reproduction of the 2008 Actual Emission Inventory for the FNSB $PM_{2.5}$ nonattainment area and the Grid 3 modeling domain during 35 episode days. (For the Fairbanks SIP, modeling inventories were developed over a gridded modeling domain called "Grid 3," which encompasses an area of 201 × 201 grid cells, each 1.33 km square. The domain encompasses portions of four counties/boroughs: Fairbanks North Star, Denali, Southeast Fairbanks, and Yukon-Koyukuk.) The emissions are presented in units of (average) tons per day (ton/day) because the $PM_{2.5}$ NAAQS is a 24-hour standard. This is consistent with the U.S. EPA's final $PM_{2.5}$ rule that allows use of "episodic" averaging periods when evaluating

⁸ The Fairbanks, Alaska PM_{2.5} Source Apportionment Research Study Winters 2005/2006-2012/2013, and Summer 2012; Final Report, Amendments 6 and 7, December 23, 2013, Tony J. Ward, Ph.D., University of Montana – Missoula , Center for Environmental Health Sciences.

contributors to ambient PM_{2.5} concentrations. This approach could help to ensure the nonattainment area inventory reflects the emissions conditions that led to an initial nonattainment area designation.⁹

For comparison to the SIP inventory presented in Table 2, the Chena Power Plant has "typical" emissions of 1.9 and 1.8 ton/day of SO₂ and NOx, respectively, which represent about 14.8% and 7.6% of the area daily SO₂ and NOx emissions, respectively. These typical Chena emission rates were based on the average coal consumed in 2015 on days when the PM_{2.5} standard was exceeded. Use of 2015 Chena data to compare to the 2008 baseline is warranted as ADEC assumed 2008 emissions would hold constant through 2015 due to uncertainty of activity growth and fuel switching for specific facilities.¹⁰

Table 2. 2008 Baseline Episode Average Daily Emissions (ton/day) bySource Sector, Actual Point Source Emissions¹¹

Course Contain	Grid 3 Domain Emissions (ton/day)					NA Area Emissions (ton/day)				
Source Sector	PM _{2.5}	SO ₂	NOx	VOC	NH ₃	PM _{2.5}	SO ₂	NOx	VOC	NH ₃
Point (Actual)	1.526 ¹²	8.380	13.395	0.096	n/a	1.412	8.167	13.285	0.096	n/a
Area, Space Heating	3.098	4.286	2.391	12.369	0.149	2.756	3.865	2.182	11.058	0.136
Area, Space Heat, Wood	2.986	0.095	0.421	12.207	0.110	2.656	0.084	0.373	10.914	0.098
Area, Space Heat, Oil	0.062	4.121	1.774	0.098	0.003	0.056	3.719	1.617	0.088	0.003
Area, Space Heat, Other	0.050	0.070	0.196	0.065	0.037	0.043	0.062	0.192	0.056	0.035
Area, Other	0.064	0.000	0.003	0.692	0.000	0.061	0.000	0.002	0.569	0.000
On-Road	0.811	0.057	5.743	7.439	0.088	0.676	0.046	4.625	5.725	0.071
On-Road, Running Exh	0.503	0.050	4.322	0.941	0.088	0.435	0.040	3.561	0.765	0.071
On-Road, Start & Idle Exh	0.308	0.008	1.421	6.410	0.000	0.242	0.006	1.064	4.894	0.000
On-Road, Evap	0.000	0.000	0.000	0.088	0.000	0.000	0.000	0.000	0.066	0.000
Non-Road	0.238	0.151	2.135	12.262	0.005	0.027	0.077	1.088	0.451	0.003
TOTALS	5.736	12.875	23.667	32.859	0.242	4.932	12.155	21.182	17.898	0.210

n/a = not available.

⁹ Federal Register, Volume 81, pages 58031, August 24, 2016, 40 CFR Parts 50, 51, and 93, Fine Particulate Matter National Ambient Air Quality Standards: State Implementation Plan Requirements; Final Rule.

¹⁰ ADEC, Amendments to: State Air Quality Control Plan, Volume II: Analysis of Problems, Control Actions; Section III: Area-wide Pollutant Control Program; D: Particulate Matter; 5: Fairbanks North Star Borough PM_{2.5} Control Plan, Section 5.06, page III.D.5.6-43

¹¹ ADEC, Amendments to: State Air Quality Control Plan Volume II: Analysis of Problems, Control Actions; Section III: Area-wide Pollutant Control Program; D: Particulate Matter; 5: Fairbanks North Star Borough PM_{2.5} Control Plan, Section 5.06, page III.D.5.6-27.

¹² Docket Document 105_Clarification 11.3.16, https://www.regulations.gov/document?D=EPA-R10-OAR-2015-0131-0016

2 DISCUSSION OF NOx CONTROL OPTIONS

NOx emissions from combustion sources consist primarily of two types: thermal NOx and fuel-related NOx. Thermal NOx is formed by the high temperature reaction of nitrogen and oxygen during combustion. The amount of NOx formed is a function of the combustion chamber design and the combustion source operating parameters, including flame temperature, residence time at flame temperature, combustion pressure, and fuel/air ratios in the primary combustion zone. Fuel NOx is formed by the gas phase oxidation of fuel-bound nitrogen. Fuel NOx formation is largely independent of combustion temperature and the nature of the organic nitrogen compound present in the fossil fuel. Its formation is dependent on fuel nitrogen content and combustion oxygen levels.

The coal burned in the Chena boilers is Usibelli, sub-bituminous coal with 0.39 to 0.59 weight percent fuel-bound nitrogen. Therefore, NOx emissions likely consist of both thermal and fuel-NOx. The combined NOx emission rate from the four Chena boilers is 0.36 lb/MMBtu, which is achieved through the use of the existing combustion controls. According to U.S. EPA, the baseline NOx emission rate for sub-bituminous coal-fired boilers is 0.50 lb/MMBtu.¹³

Control options for NOx fall into two categories: add-on controls and combustion controls. Add-on controls involve chemical reactions with NOx in the combustion gas to convert the NOx to nitrogen. The common technologies include selective catalytic reduction (SCR) and selective non-catalytic reduction (SNCR). Both of these technologies require introduction of ammonia or urea into the gas stream. The primary difference between the two technologies is that SCR has a much higher capital cost and can be performed at a lower temperature than SNCR. Combustion controls consist of techniques to reduce the peak combustion temperature, and therefore the thermal NOx formation. These techniques include use of low-NOx burners (LNB), flue gas recirculation (FGR), natural gas reburning (NGR), over-fire air (OFA), lean excess air (LEA), water or steam injection, staged combustion, and combustion optimization.

¹³ New Source Performance Standards, Subpart Da – Technical Support for Proposed Revisions to NOx Standard, U.S. EPA, Office of Air Quality Planning and Standards, EPA-453/R-94-012, June 1997.

Adopted

2.1 REVIEW OF NOx BACT DATABASE

Typically, databases maintained by U.S. EPA and the ADEC are reviewed to obtain a summary of previous BACT analyses. These reviews allow an applicant to identify control technologies in use at other similar facilities. The database review is then followed by a site-specific review of the emission reduction technique(s) to be incorporated into the proposed project. The requirements identified in 18 AAC 50, Article 3 must be considered when performing a BACT analysis.

Databases are maintained by U.S. EPA and the ADEC that provide summaries of previous control technology determinations related to RACT, BACT, and LAER. The U.S. EPA database is referred to as the RACT/BACT/LAER Clearinghouse ('the Clearinghouse"). The Clearinghouse was reviewed for data pertaining to NOx emission control methods for coal-fired boilers with heat input capacity greater than 250 MMBtu/hr and less than 100 MMBtu/hr.

The Clearinghouse lists four facilities (seven sources) with coal-fired boilers greater than 250 MMBtu/hr and BACT NOx emission limits imposed within the last 5 years. Table 3 summarizes the projects in the database search that are pertinent to the BACT evaluation for the Aurora project. BACT for two of the sources was determined to be SNCR in combination with combustion modifications (e.g., staged combustion). BACT for the other five sources identified in the database query was determined to be combustion modifications (e.g., LNB, OFA], staged combustion, and/or good combustion practices). It should be noted that all the sources identified in the search are much larger than the largest Chena Power Plant boiler. Also, the units identified in the BACT database are new and did not require retrofitting considerations. No BACT records were identified in the search for small boilers less than 100 MMBtu/hr capacity.

A review of the ADEC permit database identified eight Title I construction permits issued within the last 5 years. However, none of these permits were issued to facilities with coal-burning emission units. The University of Alaska Fairbanks Campus obtained a minor permit in October 2016 for a coal-fired boiler replacement project; however, the University obtained Owner Requested Limits to avoid PSD and the requirement to perform a BACT evaluation.

Search Criteria	Facility ID	Facility Name	Emission Unit	Permit Date	NOx Limit	Control Required	Comment
	OK-0152	O G and E – Muskogee Generating Station	Coal-fired Boiler (550 MW = 1,880 MMBtu/hr)	01/30/2013	0.15 lb/MMBtu (BART)	Low-NOx burners (LNB) and overfire air (OFA) (30% reduction)	
Permit Date =	OK-0151	O G and E - Sooner Generating Station	Coal-fired Boiler (550 MW = 1,880 MMBtu/hr)	01/17/2013	0.15 lb/MMBtu (BART)	LNB and OFA	
1/1/2011 to 1/1/2016	ND-	Minnkota Power Cooperative - M.R. Young Station	Cyclone Boilers, Unit 1 (3,200 MMBtu/hr)	03/08/2012	0.36 lb/MMBtu (BACT-PSD)	Low bed temperature staged combustion; SNCR (58% reduction)	Lignite coal. The BACT determination was required as part
Process = coal-fired, >250 MMBtu/hr	0026		Cyclone Boilers, Unit 2 (6,300 MMBtu/hr)		0.35 lb/MMBtu (BACT-PSD)		of a Consent Decree for alleged PSD violations.
Pollutant Name = NOx	Sal Ag AZ-0055 Pov Na Ger	Salt River Project Agricultural and Power District – Navajo Generating Station	Three pulverized coal boilers, each 7,725 MMBtu/hr	02/06/2012	0.24 lb/MMBtu (BACT-PSD)	LNB and OFA	Permit issued on 11/20/2008 and administratively amended on 2/6/2012. Affected Class I areas can be found in BART regulatory docket.
Permit Date = 1/1/2011 to 1/1/2016	No search	results.					
Process = coal-fired, <100 MMBtu/hr							
Pollutant Name = NOx							

Table 3.	Summary	of NOx	BACT	Permit	Reviews
----------	---------	--------	------	--------	---------

2.2 IDENTIFICATION OF NOx CONTROL OPTIONS

NOx control options generally consist of the following types:

- Combustion Controls
 - o fuel switching
 - LNB and other combustion controls
 - o steam/water injection
 - o natural gas reburn
- Post-Combustion Controls
 - o SNCR
 - o SCR
 - Non-Selective Catalytic Reduction (NSCR)

2.3 TECHNICALLY INFEASIBLE NOx CONTROL OPTIONS

2.3.1 Alternate Fuel

This evaluation considers retrofit of existing coal-fired equipment. It is assumed that use of another type of coal would not reduce NOx emissions, and use of an alternate fuel is considered technically infeasible.

2.3.2 *Combustion Control*

All four of the boilers are stokers, which means the coal combusts on a grate and the boilers do not have burners. Therefore, LNB is not an option. However, Chena Power Plant Unit 5 is equipped with OFA, LEA (i.e., oxygen trim system), and air preheaters. Units 1, 2, and 3 have OFA and air preheaters. An oxygen trim system is not available for these traveling grate boilers. These combustion controls are conservatively expected to achieve a 30 to 50 percent reduction in NOx emissions.

2.3.3 Steam and Water Injection

Steam/water injection into the combustion zone to reduce the firing temperature has been traditionally associated with minimizing NOx emissions from gas combustion turbines but not coal-fired boilers. In addition, steam/water has several disadvantages, including increases in carbon monoxide and un-burned hydrocarbon emissions and increased fuel consumption. Therefore, steam/water injection is considered technically infeasible.

2.3.4 Reburn

Reburn was developed as a NOx combustion control technique primarily for use on coal-fired furnaces, which involves splitting the combustion zone by installing a second level of burners above the primary combustion zone. Most installations employing reburn for NOx control have used natural gas as the reburn fuel; however, reburn combustion control requires significant changes to the design of the furnace and the additional operating expense of the reburn fuel. In essence, reburn is not a retrofit technology. Therefore, reburn is considered technically infeasible.

2.3.5 Non-Selective Catalytic Reduction

NSCR is an add-on NOx control technology that uses a catalyst reaction to simultaneously reduce NOx, CO, and hydrocarbon (HC) to water, carbon dioxide, and nitrogen. NSCR is generally used for internal combustion engines rather than industrial boilers. Therefore, NSCR is considered technically infeasible.

2.4 TECHNICALLY FEASIBLE NOx CONTROL OPTIONS

Because all technically feasible combustion control methods have already been employed to reduce emissions, the only remaining potential NOx control for the Chena Power Plant units would entail use of SCR or SNCR.

2.4.1 Selective Catalytic Reduction

SCR is a post-combustion control technology in which ammonia is introduced into the exhaust gas from a boiler to react with NOx in the presence of a catalyst to form water and nitrogen. The active surface of the catalyst is usually a noble metal, base metal (titanium or vanadium) oxide, or a zeolite-based material. Most SCR systems operate in the 500 to 800 degrees Fahrenheit temperature range. An ammonia injection grid is located upstream of the catalyst body and designed to disperse ammonia throughout the exhaust flow before entering the catalyst unit. Exhaust gas temperature dramatically affects NOx reduction, because the catalyst exhibits optimum performance within a narrow temperature range. Below this optimum temperature range, the catalyst activity is greatly reduced, allowing unreacted ammonia to "slip" through the catalyst bed and out of the exhaust stack. This slip results in increased ammonia concentration in the exhaust gas that is discharged into the atmosphere. Above the optimal temperature range, ammonia begins to be oxidized to form additional NOx. In addition, operation of the equipment above the

optimal temperature range for an extended period of time accelerates the catalyst-poisoning rate, which requires early replacement of the catalyst. Thus, the use of the SCR process requires tight operating temperature controls plus continual adjustment of the ammonia injection rate to match the rate of NOx formation.

Use of SCR in a high-sulfur environment presents some technical complications. Exposing a catalyst to sulfur-bearing fuels and ammonia forms ammonium sulfate (an ammonium salt that is a source of $PM_{2.5}$). These salts foul the surface of the catalyst, rendering the catalyst useless and necessitating premature replacement. Sulfur-tolerant SCR catalysts are available, but are composed of vanadium pentoxide (V_2O_5), a hazardous substance. These catalysts (V_2O_5) are still susceptible to some ammonium sulfate fouling. The spent V_2O_5 catalyst would have to be shipped off-site for disposal. To address this concern, many catalyst vendors operate exchange programs where spent catalysts are exchanged for new catalysts at a reduced price. Exchange programs alleviate customer waste disposal concerns and allow the vendor to recycle the precious metals that compose many of the catalysts.

Carefully designed SCR systems can achieve NOx emission rates of 0.1 lb NOx/MMBtu (i.e., 80 percent reduction from the baseline of 0.5 lb/MMBtu or 72 percent reduction from the current Chena NOx emission rate of 0.36 lb/MMBtu), with vendor guarantees of no greater than 10 ppm ammonia slip available.¹⁴

2.4.2 Selective Non-Catalytic Reduction

SNCR is a post-combustion control technology in which either ammonia or urea is injected into the firebox of a boiler at a location where the flue gas is between 1,600 and 2,100 degrees Fahrenheit to react with the NOx formed in the combustion process. NOx reduction levels range from 30 to 50 percent. The resulting product of the chemical reaction is molecular nitrogen, carbon dioxide, and water. Units with furnace exit temperatures of 1,550 to 1,950 degrees Fahrenheit, residence times greater than one second, and high levels of uncontrolled NOx (e.g., 200 to 400 ppm) are good candidates for SNCR. NOx concentrations in the Chena combined exhaust are barely at a level that would make use of SNCR technically feasible, in that the average NOx concentration is less than 200 ppm.

¹⁴ Achieving NOx Compliance at Least Cost: A Guideline for Selecting the Optimum Combination of NOx Controls for Coal-Fired Boilers, TR-111262, December 1998, EPRI

SNCR systems can achieve NOx emission rates of 0.25 lb NOx/MMBtu (i.e., 50 percent reduction from the baseline of 0.5 lb NOx/MMBtu or 30 percent reduction from the current Chena Power Plant NOx emission rate of 0.36 lb NOx/MMBtu), but a lesser efficiency would be expected at Chena Power Plant due to the low NOx concentration. Thus, use of this technology is only marginally technically feasible.

Urea-based systems have advantages over ammonia-based systems. Ammonia slip may cause formation of ammonium sulfates, which can plug or corrode downstream equipment (i.e., the baghouse), cause ammonia absorption into fly ash, affecting disposal or reuse, and increase PM_{2.5} emissions. Conversely, urea is a non-toxic, less volatile liquid that can be stored and handled more safely than ammonia. Urea solution droplets can penetrate farther into the flue gas when injected into the boiler, enhancing the mixing. However, urea is more expensive than ammonia. In addition, a urea solution stored in the cold Fairbanks climate would need to be heated to prevent crystallization.

Additional costs for SNCR retrofit can be 10 to 30 percent of the SNCR system cost. In general, SNCR retrofit of large and medium size boilers is relatively simple; however, the difficulty significantly increases for smaller boilers, such as those at Chena Power Plant where there is limited wall space for installation of the injectors. Movement and/or removal of existing equipment and asbestos also may be required. In addition, adequate space adjacent to the boiler must be available for distribution system equipment and for maintenance.

2.4.3 Effectiveness of Technically Feasible NOx Control Options

Table 4 presents the technically feasible NOx control options and ranks them by control effectiveness. Table 5 presents the technically feasible NOx control options and ranks them by cost effectiveness. Based on the systems identified in the RBLC search, emission rates varied from 0.15 to 0.24 lb NOx/MMBtu with LNB and OFA to 0.36 lb/MMBtu with low bed temperature staged combustion and SNCR. The Chena Power Plant already achieves 0.36 lb NOx/MMBtu with the existing combustion controls.

Rank	Control Option	Emission Unit	Control Efficiency and Emission Rate Achieved
1	SCR	Chena Power Plant (combined exhaust)	80 percent control from baseline; 0.10 lb/MMBtu (i.e., 72 percent control of Chena's current NOx emission rate)
2	SNCR	Chena Power Plant, Units 1, 2, and 3 Chena Power Plant, Unit 5	50 percent control from baseline; 0.25 lb/MMBtu (i.e., 30 percent control of Chena's current NOx emission rate)
3	Combustion controls	Chena Power Plant, Units 1, 2, 3, and 5	0.36 lb/MMBtu

Table 5.	Cost Effectiveness	of NOx Control	Options
		01 1 1 0 0 0 0.	

Rank	Control Option	Emission Unit	Cost Effectiveness, \$/ton
1	SCR	Chena Power Plant (combined exhaust)	28,347
2	SNCR	Chena Power Plant, Units 1, 2, and 3	7,649 (each boiler)
		Chena Power Plant, Unit 5	12,059
3	Combustion controls	Chena Power Plant, Units 1, 2, 3, and 5	 (already installed)

2.4.4 Economic Evaluation of NOx Control Options

Capital costs associated with the installation of a SCR system or SNCR systems are based on cost estimating procedures developed by U.S. EPA. Total capital investment costs were estimated as if the project would be constructed in the lower 48 U.S. states and then corrected using two correction factors taken from the Department of Defense Unit Cost/Area Cost Factors and Facilities Pricing Guide UFC 3-730-01. The first correction factor is a site-specific Location Adjustment Factor (LAF) of 2.2 for Fairbanks, Alaska. The second factor, the Site Sensitivity Factor (SSF) of 1.101, was calculated using an equation that accounts for labor availability (slightly below normal, +0.041), housing availability (slightly below normal, +0.022), material availability (slightly below normal, +0.01), and a +0.028 factor for a congested work area. The LAF and SSF were also applied to material costs in the calculation of annualized costs to reflect the added expense of transporting materials to the Chena Power Plant. Additionally, a retrofit factor of 30 percent has been added to the cost estimate, but this factor is likely low. The cost summaries indicate the extent to which these factors have been applied.

Cost-effectiveness of each NOx control system was calculated in a conventional BACT manner by dividing the total annual cost by the annual tons of pollutant removed. Annual costs also were divided by daily tons of pollutant removed. Costs were converted to 2015 dollars using the Chemical Engineering Composite Price Index. All indices used are noted. The following tables present summaries of capital and annualized costs:

- Table 6 Capital Cost Summary: SCR for Combined Chena Exhaust
- Table 7 Annualized Cost Summary: SCR for Combined Chena Exhaust
- Table 8 Capital Cost Summary: SNCR for 76 MMBtu/hr Boiler
- Table 9 Capital Cost Summary: SNCR for 269 MMBtu/hr Boiler
- Table 10 Annualized Cost Summary: SNCR for 76 MMBtu/hr Boiler
- Table 11 Annualized Cost Summary: SNCR for 269 MMBtu/hr Boiler
- Table 12 Summary of Overall Annualized Costs for SNCR
Table 6. Capital Cost Summary: SCR for Combined Chena Exhaust

Capital costs were estimated using equations from the EPA document "Cost of Selectin Reduction (SCR) Application for NOx Control on Coal-fired Boilers" (EPA/600/R-01/08	ve Catalytic 7. October 2001)	
These equations estimate retrofit costs in CY2000 dollars. Therefore, all costs were c	corrected to	
2015 dollars using the Composite CE Price Index.		
A = plant capacity (kW) = (H x 10^6 x G x 0.00029 kW/Btu/hr / conv. eff.) =	192,173	
$B = NOx (lb/10^6 Btu)$ at the inlet of SCR reactor =	0.36	
C = NOx removal efficiency (percent) =	72	
G = annual capacity factor (expressed as a fraction) =	0.8	
H = heat input (10 ⁶ Btu/hr) =	497	
assumed boiler conversion efficiency	0.6	
Composite CE Index for 2000 (cost year of equation)	394.1	
Composite CE index for 2015 (cost year of review)	578.4	
Consisted const (D) ZE (200,000 [(D/4,E) ^{0.05} (C/4,00) ^{0.4}](A) ^{0.35} [CEI(204,E)/CEI(2000)]		
D = capital cost (D) = 75 (300,000 [(D/1.3) (C/100)]/A) [CEI(2015)/CEI(2000)]	120	
$D = capital cost (\phi/KW) =$	120	
Item	Cost (\$)	
DIRECT COSTS		
DIRECT CAPITAL COSTS (includes equipment, installation, engineering,	23,028,006	
contingency, spare parts, and commissioning) ^a (A x D)		
Taxes (0.05 x Direct Capital Cost)	1,151,400	
Freight (0.05 x Direct Capital Cost)	1,151,400	
TOTAL DIRECT COSTS	25,330,806	
Construction management (10% of total purchased equipment costs)	2.302.801	
Construction fee (10% of total purchased equipment costs)	2.302.801	
Performance test (1% of total purchased equipment costs)	230,280	
TOTAL INDIRECT COSTS	4,835,881	
TOTAL CAPITAL COST	30,166,687	
CORRECTED TOTAL CAPITAL COST (notes c and d)	73,069,750	
a. Capital costs were estimated using equations from the EPA document "Cost of Sele	ctive Catalytic	
Reduction (SCR) Application for NOx Control on Coal-fired Boilers" (EPA/600/R-01/08	7, October 2001).	
b. Cost methodology based on "Guidance for Estimating Capital and Annual Costs of Systems", by PEDCo Environmental, Inc., March 1983 (Ohio EPA Engineering Guide # otherwise specified.	Air Pollution Control #46) unless	
c. LAF = 2.2 Location Adjustment Factor for Fairbanks, AK from DoD Facilities Pricing 701-01, Change 8, July 2015.	Guide\2\/2/, UFC 3-	
d. SSF = 1.101 Site Sensitivity Factor (related to limited labor and housing, limited material availability,		
June 2011.	0103-370-01, 0	

Table 7. Annualized Cost Summary: SCR for Combined Chena Exhaust

A = plant capacity (kW) = (H x 10 ⁶ x G x 0.00029kW/Btu/hr / conv. eff.) =	192,173
$B = NOx (lb/10^6 Btu)$ at the inlet of SCR reactor =	0.36
C = NOx removal efficiency (percent) =	72
D = capital cost (\$/kW) =	120
G = annual capacity factor (expressed as a fraction) =	0.8
H = heat input (10 ⁶ Btu/hr) =	497
assumed boiler conversion efficiency	0.6
Anhydrous NH ₃ cost (\$/ton [year 2000 \$]) =	225
Composite CE Index for 2000 (cost year of equation)	394.1
Composite CE Index for 2015 (cost year of review)	578.4
1.005 = design margin that accounts for NH3 slip (see the appendix)	
1.05 = design margin that accounts for small amount of NO2 in flue gas (SCR chemistry	
requires 2 moles of NH3 per mole of NO2 instead of 1 mole of NH3 per 1 mole of NO)	
0.025 = catalyst deactivation factor for coal-fired units (yr-1)	
2.12 = a constant (\$/kW-yr) = 0.03 (cost of energy in Yr 2000 \$/kWh) * CEI(2015)/CEI(2000)	
* 8760 (h/yr) * 0.0055 (fraction cost of auxiliary power/unit of generation)	
ltom	Cost (\$)
	COSI (\$)
DIRECT ANNUAL COSTS	
FIXED OPERATION AND MAINTENANCE (E) (includes annual maintenance material and labor	
cost) ^a	
$E = [D \times LAF \times SSF] \times A \times 0.0066/yr$	368,138
	50.400
Ammoniaª	58,199
NH ₃ use cost (\$/yr) = G x (Anh. NH ₃ Cost, [Yr 2000 \$/ton]) x CEI(2015)/CEI(2000) x (0.37B x H	
x C/100 x 8760/2000) x 1.005 x 1.05	
Annual Catalyst Replacement ^a	91,084
Annual catalyst replacement cost (\$/yr) = G x 0.025 x [D x LAF x SSF] x A x [(B/1.5) ^{0.05}	
(C/100) ^{0.4}]	
Electricity ^a	326,132
Energy requirement cost (\$/yr) = G * 2.12 * A	
Ammonia Risk Management Professional (1040 hr/yr @ \$40/hr)	41,600
TOTAL DIRECT ANNUAL OPERATING COSTS	885,152
INDIRECT ANNUAL COSTS	
Overhead (80% of total operation and maintenance labor)	294.510
Administrative charges (2% of total capital investment)	1.461.395
Insurance (1% of total capital investment)	730,698
Property tax (1% of total capital investment)	730,698
Capital recovery (16.275% of total capital investment: 10 yr at 10% interest)	11,892,102
	1
TOTAL INDIRECT ANNUAL OPERATING COSTS	15,109,402
TOTAL ANNUALIZED OPERATING COSTS	15,994,554
TOTAL UNCONTROLLED NO _x EMISSIONS, tons	/84
NO _x REMOVAL EFFICIENCY, %	72%
TOTAL NO _x REMOVED, tons	564
NO _x COST-EFFECTIVENESS, \$/ton removed	28,347

Capital costs were estimated using equations from the EPA document "EPA AIR POLITIE	
COST MANUAL. Sixth Edition" (EPA/452/B-02-001, January 2002).	
These equations estimate costs in CY1998 dollars. Therefore, all costs were corrected to	2015 dollars
using the Composite CE Price Index.	
L. 10.577	
$(MMBtu)$ 2375 $\frac{MMBtu}{hr}$	(CE_{201})
$\frac{Direct \ Capital \ Cost \ (D)(\$) = \frac{1}{MMBtu} \ Q_B\left(\frac{1}{hr}\right) \left \frac{n}{Q_B\left(\frac{MMBtu}{hr}\right)} \right \qquad (0.66 + 0.85\eta)$	$(\frac{CE_{equation}}{CE_{equation}})$
Q _B = Boiler size (MMBtu/hr)	76
n _{NOx} = NOx removal efficiency	0.30
Composite CE Index for 1998 (cost year of equation)	389.5
Composite CE Index for 2015 (cost year of review)	578.4
Retrofit Factor	30%
ltem	Cost (\$)
DIRECT COSTS	
Direct Capital Cost (includes urea-based SNCR equipment instrumentation sales tax	714 838
freight, field measurements, numerical modeling, system design; installation of auxiliary	,
equipment (e.g., ductwork, compressor), foundations and supports, handling and	
erection electrical nining insulation and nainting; and ashestos removal) ^a	
erection, electrical, piping, insulation, and painting, and assestos removaly	
Additional Retrofit Cost (10 to 30% of SNCR system cost) ^b	214,451
TOTAL DIRECT COSTS (A)	929,289
INDIRECT COSTS	
General Facilities (0.05 A) (Startup, Performance Test, and Model Study)	46.464
Construction/field expenses (0.20 A)	185.858
Construction Fee (0.10 A)	92,929
Engineering (0.10 A)	92,929
Process Contingency (0.05 A)	46,464
TOTAL INDIRECT COSTS (B)	464,645
Project Contingency (C = $0.15 \times (A + B)$)	209.090
Total Plant Cost ($D = A + B + C$)	1,603,024
Allowance for Funds During Construction ($E = 0$, assumed for SNCR)	0
Royalty Allowance (F = 0, assumed for SNCR)	0
Preproduction Cost (G = 0.02 x (D + E))	32,060
Inventory Capital (H = Volreggent(gal) x Costreagent(\$0.85/gal), assume 2-week supply of	509
50% urea)	
Initial Catalyst and Chemicals (I = 0, assumed for SNCR)	0
TOTAL CAPITAL COST (D + E + F + G + H + I)	1,635,594
 a. EPA AIR POLLUTION CONTROL COST MANUAL, Sixth Edition (EPA/452/B-02-001, J b. Section 4.2, Chapter 1, Section 1.2.5 of the Cost Control Manual states that "Retrofit in system generally calls for additional expenditures in the range of 10% to 30% of the SNCR 	anuary 2002) stallation of the SNCR system cost."

Table 9. Capital Cost Summary: SNCR for 269 MMBtu/hr Boiler

Consists exerts were estimated using equations from the EDA desument "EDA AID DOL LUT	
Capital Costs Were estimated using equations from the EPA document EPA AIR POLLUTI	UN CUNTRUL
COST MANOAL, SIXIT EURION (EFA452/B-02-001, Sanuary 2002).	
These equations estimate costs in CY1998 dollars. Therefore, all costs were corrected to	2015 dollars
using the Composite CE Price Index.	
$(MMBt_{i})$ $\left[2375\frac{MMBt_{i}}{3}\right]^{0.577}$	
$Direct Capital Cost (D)($) = \frac{$950}{MMB_{12}} Q_{B} \left(\frac{MMBtu}{l}\right) \left \frac{2575}{MMB_{12}}\right (0.66 + 0.85\eta)$	$\left(\frac{CE_{2016}}{2E}\right)$
$MMBtu \sim (hr) \left[Q_B \left(\frac{MMBtu}{hr} \right) \right]$	(CE _{equation})
Q _B = Boiler size (MMBtu/hr)	269
$n_{NCY} = NOx removal efficiency$	0.30
Composite CE Index for 1998 (cost year of equation)	389.5
Composite CE Index for 2015 (cost year of review)	578.4
Retrofit Factor	30%
Item	Cost (\$)
DIRECT COSTS	
Direct Capital Cost (includes urea-based SNCR equipment, instrumentation, sales tax,	1,220,137
freight, field measurements, numerical modeling, system design; installation of auxiliary	
equipment (e.g., ductwork, compressor), foundations and supports, handling and	
erection, electrical, piping, insulation, and painting; and asbestos removal) ^a	
Additional Detrofit Cost (40 to 200), of SNCD system cost) ^b	366.041
Additional Retrofit Cost (10 to 30% of SNCR system cost)	500,041
	1 596 179
TOTAL DIRECT COSTS (A)	1,500,170
INDIRECT COSTS	
General Facilities (0.05 A) (Startup Performance Test, and Model Study)	79,309
Construction/field expenses (0.20 A)	317,236
Construction Fee (0.10 A)	158.618
Engineering (0.10 A)	158,618
Process Contingency (0.05 A)	79,309
TOTAL INDIRECT COSTS (B)	793,089
Project Contingency (C = 0.15 x (A + B))	356,890
Total Plant Cost ($D = A + B + C$)	2,736,158
Allowance for Funds During Construction (E = 0, assumed for SNCR)	0
Royalty Allowance (F = 0, assumed for SNCR)	0
Preproduction Cost (G = 0.02 x (D + E))	54,723
Inventory Capital (H = $Vol_{reagent}(gal) \times Cost_{reagent}(\$0.85/gal)$, assume 2-week supply of	1,803
50% urea)	
Initial Catalyst and Chemicals (I = 0, assumed for SNCR)	0
	0 700 004
TOTAL CAPITAL COST (D + E + F + G + H + I)	2,792,684
EDA AIR ROLLUTION CONTROL COST MANULAL Sixth Edition (ERA/452/R 02.001	lonuon (2002)
a. EFA AIR FOLLUTION CONTROL COST MANUAL, Sixili Edition (EFA/452/B-02-001, J	anuary 2002)
b. Section 4.2, Chapter 1, Section 1.2.5 of the Cost Control Manual states that Refform in the range of 10% to 20% of the SNCE	Stallation of the SNCK
system generally calls for additional experiditures in the range of 10% to 30% of the SNCP	c system cost.

Table 10. Annualized Cost Summary: SNCR for 76 MMBtu/hr Boiler

Q _B = Boiler size (MMBtu/hr)	76
n _{NOx} =NOx removal efficiency	0.30
NOx: $(lb/10^6 Btu)$	0.44
NSR = Normalized Stoichiometric Ratio = $[(2 \times NOx)] + 0.71 \times n_{10}$ /NOx	1.08
$ \text{Itilization} = n_{\text{MSR}} / \text{NSR}$	28%
m (assume urea) (lb/br)	2070
$- NOx \times O \times n \times NSP \times 60.06 a/mole/2 \times 46.01 a/mole)$	7.1
$= 100 \lambda_{in} \times Q_B \times 1_{ NOx} \times 1051 \times 00.00 \text{ g/mole/2 } \times 40.01 \text{ g/mole})$ $m = (50\% \text{ colution}) (h/hr) = m = (0.5)$	1.1.1
$\Pi_{sol}(50\% \text{ solution})(10/11) = \Pi_{reagent}(0.5)$	14.1
$q_{sol} (gal/nr) = m_{sol} \times 7.481 gal/nr^{-} / 1.0 lb/nr^{-}$	1.49
$Cost_{reag}$ (50% urea solution) (\$/gai)	0.85
t_{op} (SNCR operating time) (hr/yr) (80% capacity factor)	7,008
Power Consumption (P) (kW) = $0.47 \times NOX_{in} \times NSR \times Q_B / 9.5$	1.78
Cost _{elec} (\$/kW)	0.21
Concentration of urea solution stored (C _{urea sol stored})	50%
Concentration of urea solution injected (C _{urea sol inj})	10%
Water to dilute urea (q _{water}) (gal/hr)	6.76
= m _{sol} / p _{water} x (C _{urea sol stored} /C _{urea sol inj} - 1)	
Cost _{water} (\$/1,000 gal)	0.28
Heat of Vaporization (H _v) of water at 310 F (Btu/lb)	900
ΔCoal (MMBtu/hr) = H _{water} x m _{reagent} x (1/C _{urea sol inj} -1) / 10 ⁶ Btu/MMBtu	0.06
Cost _{coal} (\$/MMBtu)	2.00
High Heating Value (HHV) of coal (Btu/lb)	7,500
wt% ash	10%
Δ Ash (ton/hr) = Δ Coal x 10 ⁶ Btu/MMBtu x wt% ash / HHV / 2,000 lb/ton	0.0004
Cost _{ash} (\$/ton)	25
ltem	Cost (\$)
	(1)
DIRECT ANNUAL COSTS	
DIRECT ANNUAL COSTS	
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46)	92,170
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost)	92,170 13,825
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the	92,170 13,825 24 534
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST)	92,170 13,825 24,534
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST)	92,170 13,825 24,534
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op})	92,170 13,825 24,534 8,854
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (BucQust, and b)	92,170 13,825 24,534 8,854
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op})	92,170 13,825 24,534 8,854 2,623
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op})	92,170 13,825 24,534 8,854 2,623
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op})	92,170 13,825 24,534 8,854 2,623 13
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op})	92,170 13,825 24,534 8,854 2,623 13
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op})	92,170 13,825 24,534 8,854 2,623 13 801
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op})	92,170 13,825 24,534 8,854 2,623 13 801
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op})	92,170 13,825 24,534 8,854 2,623 13 801 67
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op})	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor)	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887 104,423
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment)	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887 104,423 16,356
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest)	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887 104,423 16,356 266,193
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS NDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest) TOTAL INDIRECT ANNUAL OPERATING COSTS	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887 104,423 16,356 266,193
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS NDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest) TOTAL INDIRECT ANNUAL OPERATING COSTS	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887 104,423 16,356 266,193 386,972
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site data; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS NDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest) TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL INDIRECT ANNUAL OPERATING COSTS	92,170 13,825 24,534 8,854 2,623 13 801 67 142,887 104,423 16,356 266,193 386,972 529,859

Table 11. Annualized Cost Summary: SNCR for 269 MMBtu/hr Boiler

Q _B = Boiler size (MMBtu/hr)	269
n _{NOx} =NOx removal efficiency	0.30
NOx_{in} (lb/10 ⁶ Btu)	0.29
NSR = Normalized Stoichiometric Ratio = $[(2 \times NOx_{in})+0.7] \times n_{NO}/NOx_{in}$	1.32
	23%
m (assume urea) (lb/br)	2070
- NOx, x O ₂ x n _v , x NSR x 60.06 g/mole/2 x 46.01 g/mole)	20.2
$m_{\rm e} (50\% \text{ solution}) (lb/br) = m_{\rm e} /0.5$	40.5
$r_{sol}(50\% 300000)(15/11) = r_{reagent}(5.5)$	4.26
$q_{sol} (gal/III) = II_{sol} \times 7.461 gal/II / 71.0 ID/II$	4.20
t (SNCP exercise time) (br/w) (200/ expensity factor)	7.009
l_{op} (SNCR operating time) (III/yr) (80% capacity factor)	7,000
Power Consumption (P) (kvv) = 0.47 x NOx _{in} x NSR x Q _B / 9.5)	5.11
Cost _{elec} (\$/KW)	0.21
Concentration of urea solution stored (C _{urea sol stored})	50%
Concentration of urea solution injected (C _{urea sol inj})	10%
Water to dilute urea (q _{water}) (gal/hr)	19.39
= m _{sol} / p _{water} x (C _{urea sol stored} /C _{urea sol inj} - 1)	
Cost _{water} (\$/1,000 gal)	0.28
Heat of Vaporization (H_v) of water at 310 F (Btu/lb)	900
ΔCoal (MMBtu/hr) = H _{water} x m _{reagent} x (1/C _{urea sol ini} -1) / 10 ⁶ Btu/MMBtu	0.16
Cost _{coal} (\$/MMBtu)	2.00
High Heating Value (HHV) of coal (Btu/lb)	7,500
wt% ash	10%
Δ Ash (ton/hr) = Δ Coal x 10 ⁶ Btu/MMBtu x wt% ash / HHV / 2,000 lb/ton	0.0011
Cost _{ash} (\$/ton)	25
ltem	Cost (\$)
DIRECT ANNUAL COSTS	
DIRECT ANNUAL COSTS	
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46)	92,170
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost)	92,170 13,825
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the	92,170 13,825 41 890
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST)	92,170 13,825 41,890
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST)	92,170 13,825 41,890
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op})	92,170 13,825 41,890 25,389
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op})	92,170 13,825 41,890 25,389
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op})	92,170 13,825 41,890 25,389 7,521
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op})	92,170 13,825 41,890 25,389 7,521
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op})	92,170 13,825 41,890 25,389 7,521 38
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op})	92,170 13,825 41,890 25,389 7,521 38
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op})	92,170 13,825 41,890 25,389 7,521 38 2,296
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op})	92,170 13,825 41,890 25,389 7,521 38 2,296
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op})	92,170 13,825 41,890 25,389 7,521 38 2,296 191
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op})	92,170 13,825 41,890 25,389 7,521 38 2,296 191
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor)	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321 118,308
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment)	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321 118,308 27,927
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest)	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321 118,308 27,927 454,509
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest)	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321 118,308 27,927 454,509
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS NDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest) TOTAL INDIRECT ANNUAL OPERATING COSTS	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321 118,308 27,927 454,509 600,745
DIRECT ANNUAL COSTS Operating labor Operator labor (\$63.13/hr x 4 man-hours/day, on-site wages; EG46) Supervision (15% of operator labor cost) Maintenance (labor and material cost, including nozzle tip replacement for the injectors) (0.015 x TOTAL CAPITAL COST) Reagent (q _{sol} x Cost _{reag} x t _{op}) Electricity (P x Cost _{elec} x t _{op}) Water (q _{water} /1,000 x Cost _{water} x t _{op}) Coal (ΔCoal x Cost _{coal} x t _{op}) Ash (ΔAsh x Cost _{ash} x t _{op}) TOTAL DIRECT ANNUAL OPERATING COSTS INDIRECT ANNUAL COSTS Overhead (80% of total operation and maintenance labor) Insurance (1% of total capital investment) Capital recovery (16.275% of total capital investment: 10 yr at 10% interest) TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL INDIRECT ANNUAL OPERATING COSTS	92,170 13,825 41,890 25,389 7,521 38 2,296 191 183,321 118,308 27,927 454,509 600,745 784 066

	1 Boiler @ 269 MMBtu/hr	3 Boilers @ 76 MMBtu/hr	Combined
Chena Power Plant Total Capacity, MMBtu/hr	269	228	497
Total Annualized Operating Costs, \$	\$784,066	\$1,589,578	\$2,373,645
Total Uncontrolled NOx Emissions, tons per year	342	439	781
NOx Removal Efficiency, %	30%	30%	30%
Total NOx Removed, tons per year	103	132	235
Average NOx removed, tons per day	0.28	0.36	0.64
Overall NOx			
Cost-Effectiveness,	7,649	12,059	10,130
total \$ per year/ton per year removed			
Overall NOx			
Cost-Effectiveness,	2,800,000	4,400,000	3,700,000
total \$ per year/ton per day removed			

Table 12. Summary of Overall Annualized Costs for SNCR

3 DISCUSSION OF SO₂ CONTROL OPTIONS

SO₂ emissions are formed from the combustion of sulfur-containing fuels, such as coal, where the sulfur in the fuel is oxidized during the combustion process. The Usibelli, sub-bituminous coal burned in the Chena Power Plant boilers has a sulfur content ranging from 0.1 to 0.3 percent (ultimate analysis). The 500 ppm SO₂ allowable emission limit for the boilers is based on 0.4 percent sulfur content of the coal.

3.1 REVIEW OF SO₂ BACT DATABASE

The Clearinghouse lists two facilities (four sources) with coal-fired boilers and BACT SO₂ emission limits imposed within the last 5 years. Table 13 summarizes the projects in the database search that are pertinent to the BACT evaluation for the Chena Power Plant BACT evaluation.

It should be noted that all the sources identified in the search are much larger than the largest Chena Power Plant boiler. No BACT records were identified in the search for small boilers less than 100 MMBtu/hr capacity. Both sources identified in the database query specified wet flue gas desulfurization. One did not specify an emission limit; the second record specified a controlled emission rate of 1.2 lb SO₂/MMBtu.

The Chena Power Plant boilers burn low-sulfur Usibelli coal, and emissions from the combined stack have been measured to be $0.39 \text{ lb } SO_2/MMBtu$, one-third of the most recent BACT determination.

3.2 IDENTIFICATION OF SO₂ CONTROL OPTIONS

SO₂ control options generally consist of the following types:

- Pre-Combustion Controls
 - fuel substitution
- Post-Combustion Controls
 - wet scrubbers
 - dry scrubbers

Tuble 10: Summary of 502 brief remain Reviews							
Search Criteria	Facility ID	Facility Name	Emission Unit	Permit Date	SO ₂ Limit	Control Required	Comment
Permit Date = 1/1/2011 to 1/1/2016 Process = coal-fired,	AZ- 0055	Salt River Project Agricultural and Power District - Navajo Generating Station	Three pulverized coal boilers, each 7,725 MMBtu/hr	02/06/2012	not specified	Flue Gas Desulfurization (FGD), Scrubber	Permit issued on 11/20/2008 and administratively amended on 2/6/2012. Affected Class I areas can be found in BART regulatory docket.
Pollutant Name =	TX-0601	Texas Municipal Power Agency Gibbons Creek Steam Electric Station	Boiler (5,060 MMBtu/hr)	10/28/2011	1.2 MMBtu/hr (BACT-PSD)	Wet FGD	
Permit Date = 1/1/2011 to 1/1/2016	No search	n results.					
Process = coal-fired, <100 MMBtu/hr							
Pollutant Name = SO2							

Table 13. Summary of SO₂ BACT Permit Reviews

Post combustion controls for flue gas desulfurization (FGD) are basically selected along the lines of coal sulfur levels; that is, dry systems are being selected for boilers that burn a low sulfur coal, and wet limestone forced oxidation (LSFO) systems are being selected for boilers that burn coals with 2 percent or greater sulfur levels.

3.3 TECHNICALLY INFEASIBLE SO₂ CONTROL OPTIONS

3.3.1 Fuel Substitution

This evaluation considers retrofit of existing coal-fired equipment. The Chena Power Plant boilers already use low-sulfur Usibelli coal with an average of 0.2 percent sulfur content, and switching to another coal source would not result in an appreciable reduction in SO₂ emissions. In addition, switching to fuel oil would not result in a reduction of SO₂ emissions, and adequate sources of natural gas are not readily available in Fairbanks to supply the Chena Power Plant with a reliable gas supply. Therefore, fuel substitution is considered technically infeasible.

3.3.2 Dry Scrubber

SO₂ control for the Chena Power Plant units could entail use of a FGD system. Most FGD systems employ two stages: one for fly ash removal and the other for SO₂ removal. In wet scrubbing systems, the flue gas first passes through a fly ash removal device, either an electrostatic precipitator or a baghouse, and then into the SO₂ absorber. However, in dry injection or spray drying operations, the SO₂ is first reacted with the sorbent, and then the flue gas passes through a PM control device. The combined exhaust from the Chena Power Plant is currently controlled by a common baghouse. Therefore, installation of a dry injection or spray drying operation would require the existing baghouse be retrofit with a new PM control system to accommodate the much greater PM loading produced by a dry injection or spray dry system. This would be cost-prohibitive; therefore, dry injection or spray drying operations are considered technically infeasible and only a wet FGD system is considered technically feasible for SO₂ control at the Chena Power Plant.

3.4 TECHNICALLY FEASIBLE SO₂ CONTROL OPTIONS

3.4.1 Wet Scrubber

In a wet scrubber system, flue gas is ducted to spray tower where an aqueous slurry of sorbent is injected into the gas. SO₂ dissolves into the slurry droplets where it reacts with the alkaline sorbent. The slurry is collected at the bottom of the spray tower, and treated flue gas is directed to a mist eliminator to remove any remaining slurry droplets. The spent slurry can either be recycled back to the absorber or dewatered and disposed. Typical sorbent materials are limestone (least expensive, least efficient), lime (more expensive, more efficient), or proprietary sorbents (most expensive, most efficient).

Some disadvantages of wet scrubbing techniques are (1) the cost of neutralizing chemicals, (2) disposal of the liquid stream containing soluble sulfur-containing salts, (3) scale build-up in the absorber, and (4) energy costs.

Limestone forced oxidation (LSFO) is a wet limestone scrubbing process that reduces the formation of gypsum scale in the absorber by oxidizing the spent slurry and removing the gypsum before it is recycled to the tower. The gypsum product can then be sold, thereby eliminating the disposal costs. However, limited markets exist for this gypsum product, and no viable outlets may actually be available for the gypsum.

Wet limestone scrubbing generally has high capital and operating costs due to the need to handle both liquid reagent and waste. As reported in a 2007 journal article, virtually no wet lime systems are currently being requested by the utility industry. As a result, FGD vendors are generally not offering wet lime systems.¹⁵ In addition, moisture in the scrubber exhaust can result in a visible plume, which can become ice fog in the winter months in Fairbanks.

The SO₂ control efficiency currently achieved in practice by large coal utility units with wet FGD units ranges from 0.15 to 0.25 lb SO₂/MMBtu. This is in line with New Source Performance Standards, which require a SO₂ emission rate of 0.20 lb MMBtu or less. The Chena Power Plant currently emits 0.39 lb SO₂/MMBtu, which would require a 50 percent

¹⁵ "Is It Time to Rethink SO₂ Control Technology Selection?" *Power Engineering*, November 1, 2007.

reduction in emissions to achieve an emission rate similar to other large coal-fired boilers.

3.4.2 Effectiveness of Technically Feasible SO₂ Control Options

Table 14 presents the technically feasible SO_2 control options and ranks them by control effectiveness. Table 15 presents the technically feasible SO_2 control options and ranks them by cost effectiveness.

Rank	Control Option	Emission Unit	Control Efficiency and Emission Rate Achieved
1	Wet Scrubber	Chena Power Plant (combined exhaust)	0.20 lb/MMBtu (i.e., 50 percent control of Chena's current SO ₂ emission rate)
2	Low sulfur coal	Chena Power Plant (combined exhaust)	0.39 lb/MMBtu (already used)

Table 14. Control Effectiveness of SO₂ Control Options

Table 15. Cost Effectiveness of SO2 Control Options

Rank	Control Option	Emission Unit	Cost Effectiveness
			\$74,146 per year/
1	Wat Scrubbar	Chena Power Plant	ton per year removed
1	Wet Scrubber	(combined exhaust)	\$27,100,000 per year/
			ton per day removed
n	Low cultur cool	Chena Power Plant	
2	Low sumur coal	(combined exhaust)	(already used)

3.4.3 Economic Evaluation of SO₂ Control Options

Capital costs associated with the installation of a Wet Scrubber system are based on cost estimating procedures developed by U.S. EPA in the Coal Utility Environmental Cost (CUECost) tool. The CUECost tool is an Excel workbook (an interrelated set of spreadsheets) that produces rough-orderof-magnitude (ROM) cost estimates (+/-30% accuracy) of the installed capital and annualized operating costs for air pollution control systems installed on coal-fired power plants, including those to control emissions of SO₂. The SO₂ emission control technologies currently in the workbook include: limestone FGD system with forced oxidation (i.e., wet scrubber) and lime spray drying FGD system (i.e., dry scrubber).

The wet scrubber portion of the CUECost tool was used and included the following site-specific information:

- Location
- Net Plant Heat Rate (Btu/kWhr) = 497 MMBtu/hr total heat input divided by 42 MW net output
- Retrofit Factor = 1.6 (1.0 = new, 1.3 = medium, 1.6 = difficult)
- Coal ultimate and proximate analysis data and ash analysis data obtained from http://www.usibelli.com/Coal-data.php
- Site specific SO₂ emission rate = 0.39 lb SO₂/MMBtu
- Cost Basis = 2015
- SO₂ Removal Required = 50 percent

All other values used were default values.

The cost-effectiveness of the SO₂ control system is calculated in the CUECost tool by dividing the total annual cost by the annual tons of pollutant removed. Cost-effectiveness also was calculated by dividing the total annual cost by the daily tons of pollutant removed. Costs were corrected to 2015 dollars using the Chemical Engineering Composite Price Index. Table 16 presents a summary of the CUECost inputs and calculation summary for the wet scrubber, including the cost effectiveness of the technology. The ADEC performed a similar cost evaluation for coal boilers in Fairbanks. ADEC reported in the SIP that available cost information for wet scrubbers and spray dry systems indicate that these systems are not cost effective for units smaller than 500 MWe (Chena Power Plant combined heat input capacity is 150 MWe).

Appendix A presents the detailed CUECost output tables.

3.5 SUMMARY OF COST EFFECTIVENESS OF CONTROL OPTIONS

Cost effectiveness estimates are presented in Table 12 (for NOx control) and Table 15 (for SO₂ control). Although some question exists as to whether the control options are actually technically feasible, the cost effectiveness values exceed the amounts that could be considered cost effective. When looking at the costs on a ton per day removed basis (which is appropriate for control options designed to improve air quality compared to a 24-hr NAAQS), the cost effectiveness of NOx or SO₂ control options is seen to be tremendously high. Thus, implementation of any of these controls should be considered a huge economic burden and not cost effective means for bringing about PM_{2.5} NAAQS attainment in the FNSB.

Coal Utility Environmental Cost Version 1, November 25, 1998 (revised 2-9-00 as CUECost3.xls) INPUTS Description Units Control System MW Discription Control System MW NW NW </th <th colspan="4">CUECost</th>	CUECost			
Version 1, November 25, 1998 (revised 2-9-00 as CUECost3.xls) INPUITS Description Units Input 1 General Plant Technical Inputs Location - State Abrev. AK Description Units Input 1 General Plant Technical Inputs Location - State Abbrev. AK MW Equivalent of Flue Gas to Control System MW 150 Net Plant Heat Rate Btu/kWhr 11333 Plant Capacity Factor % 0.65 Total Air Downstream of Economizer % 0.12 Air Heater Outlet Gas Temperature °F 300 Indet Air Temperature °F 80 Anbient Absolute Pressure in. of H2O -12 Moisture in Air Bk/lb dry air 0.013 Ash Split 0.8 80 Fly Ash % 0.2 Seismic Zone Integer 1.6 (L0 = new, 1.3 = medium, 1.6 = difficult)	Coal Utility Environmental Cost			
Version 1, November 25, 1998 (revised 2-9-00 as CUECost3.xls) INPUITS Input 1 Description Units Input 1 General Plant Technical Inputs Number 20 AK Location - State Abbrev. AK MW Equivalent of Flue Gas to Control System MW 150 Net Plant Heat Rate Btu/kWhr 11833 Plant Capacity Factor % 0.65 Total Air Downstream of Economizer % 0.12 Air Heater Cutlet Gas Temperature °F 80 Otal Air Downstream of Economizer % 0.12 Air Heater Outlet Gas Temperature °F 80 Outsure in Air Ib/Ib dry air 0.013 Absisture in Air Ib/Ib dry air 0.013 Ash Split: ~ ~ 0.2 Seismic Zone Integer 1 R Retrofit Factor Integer 1 R Ided Air Temperature % 0.2 Seismic Cole Economic Inputs 0.2 0.2 Seismic Cole				
INPUTS Input 1 General Plant Technical Inputs Input 1 General Plant Technical Inputs Input 3 Location - State Abbrev. MW Equivalent of Flue Gas to Control System MW MW Equivalent of Flue Gas to Control System MW Plant Capacity Factor % 0.65 Total Air Downstream % 0.12 Air Heate Leage % 0.12 Air Heate Leage % 0.12 Air Heate Leage % 0.12 Air Heate Cast Emperature °F 300 Inlet Air Temperature °F 80 Ambient Absolute Pressure in. of H2O -12 Moisture in Air lb/lb dry air 0.013 Ash Split: 0.12 Fly Ash % 0.8 Bottom Ash % 0.2 Seismic Zone Integer 1.6 (1.0 = new, 1.3 = medium, 1.6 = difficult) 1.6 (1.0 = new, 1.3 = medium, 1.6 = difficult) 1.6 1.6 Selected Coal a Powder River Basin Coal? Year 2015 Service Life (levelization period) Years 30 Inflation Rate % 0.03 After Tax Discount Rate (current \$'s) %	Varcian 1 Norramber 25 1998 (regised 2	-9-00 as CHECost3 x ls)		
INPUITS Units Input 1 General Plant Technical Inputs General Plant Technical Inputs General Plant Technical Inputs General Plant Heat Rate Abbrev. AK MW MW Equivalent of Flue Gas to Control System MW 150 Net Plant Heat Rate Btu/kWhr 11833 Plant Capacity Factor % 0.65 Total Air Downstream of Economizer % 0.65 Total Air Downstream of Economizer % 0.12 Air Heater Outlet Gas Temperature °F 80 Ambient Absolute Pressure Aire Air Heater in. of Hg 29.4 Pressure Aire Air Heater in. of Hg 29.4 Pressure Aire Air Heater in. of Hg 29.4 Pressure Aire Air Heater in. of Hg 0.013 Ash 5plit: 0.12 Sisture in Air 1b/lb dry air 0.013 Ash 5plit: 0.2 Seismic Zone Integer 1 Retroit Factor Integer 1 Retroit Factor Integer 1 Seiset Cal a la Ireger Air Basit So and	version 1, November 25, 1996 (revised 2	-9-00 us Calcost3.215)		
Intervents Units Input 1 General Plant Technical Inputs	INDUTC			
Description Units Input 1 General Plant Technical Inputs	INPUI5			
General Plant Technical Inputs Abbrev. AK Location - State MW 150 MW Equivalent of Flue Gas to Control System MW 150 Net Plant Heat Rate Btu/kWhr 11833 Plant Capacity Factor % 0.65 Total Air Downstream of Economizer % 0.12 Air Heater Cutlet Gas Temperature °F 80 Inlet Air Emperature °F 80 Ambient Absolute Pressure in. of Hg 29.4 Pressure After Air Heater in. of Hg 29.4 Moisture in Air Ib/lb dry air 0.013 Ash Split:	Description	Units	Input 1	
General Plant Lechnical Inputs				
Location - StateAbbrev.AKMW Equivalent of Flue Gas to Control SystemMW150Net Plant Tleat RateBtt/KWhr11833Plant Capacity Factor%0.65Total Air Downstream of Economizer%0.12Air Heater Outlet Gas Temperature%0.12Air Heater Outlet Gas Temperature%0.12Air Heater Outlet Gas Temperature%0.12Inlet Air Temperature%0.12Pressure After Air Heaterin. of H2O-12Moisture in AirIb/Ib dry air0.013Ash Split:%0.2Fly Ash%0.2Seismic ZoneInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)Select CoalPress/ NoNoEconomic InputsCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30After Tax Discount Rate (current \$'s)%0.03After Tax Discount Rate (current \$'s)%0.017Sales Tax%0.06Economic Larying Charge (current \$'s)%0.017Sales Tax%0.03After Tax Discount Rate (current \$'s)%0.017Sales Tax%0.03After Tax Discount Rate (current \$'s)%0.017Sales Tax%0.06Economic LinguitsConst Basis CE Plant Index.%0.03After Tax Discount Rate<	<u>General Plant Technical Inputs</u>			
Location - state Akbrev. Ak MW Equivalent of Flue Gas to Control System MW 150 Net Plant Heat Rate Btu/kWhr 11833 Plant Capacity Factor % 0.65 Total Air Downstream of Economizer % 0.12 Air Heater Outlet Gas Temperature °F 80 Ambient Absolute Pressure in. of Hg 29.4 Pressure After Air Heater in. of H2O -12 Moisture in Air Ib/lb dry air 0.013 Ash Split:			1.76	
MW Equivalent of Flue Gas to Control SystemMW150Net Plant Heat RateBtu/kWhr11833Plant Capacity Factor%0.65Total Air Downstream of Economizer%0.12Air Heater Leakage%0.12Air Heater Outlet Gas Temperature°F300Inlet Air Temperature°F80Ambient Absolute Pressurein. of Hg294Pressure After Air Heaterin. of H2O-12Moisture in AirIb/lb dry air0.013Ash Split:%0.2Fly Ash%0.2Seismic ZoneInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)1Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoVest / No%0.03After Tax Discount Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.03Constumables (O&M)%0.03Capital Costs:	Location - State	Abbrev.	AK	
Net Plant Capacity Factor Bitu/kWhr 11833 Plant Capacity Factor % 0.65 Total Air Downstream of Economizer % 0.12 Air Heater Leakage % 0.12 Air Heater Outlet Gas Temperature °F 300 Inlet Air Temperature °F 80 Ambient Absolute Pressure in. of Hg 29.4 Pressure After Air Heater in. of H2O -12 Moisture in Air Ib/Ib dry air 0.013 Ash Split:	MW Equivalent of Flue Gas to Control System	MW	150	
Plant Capacity Factor % 0.65 Total Air Downstream of Economizer % 0.12 Air Heater Cutlet Gas Temperature °F 300 Inlet Air Temperature °F 80 Ambient Absolute Pressure in. of Hg 29.4 Pressure After Air Heater in. of H2O -12 Moisture in Air lb/lb dry air 0.013 Ash Split:	Net Plant Heat Kate	Btu/kWhr	11833	
Iotal Air Downstream of Economizer%1.2Air Heater Leakage%0.12Air Heater Cutlet Gas Temperature°F300Inlet Air Temperature°F80Ambient Absolute Pressurein. of Hg29.4Pressure After Air Heaterin. of HZO-12Moisture in Airlb/lb dry air0.013Ash Split:''0.13Fly Ash%0.8Bottom Ash%0.2Seismic ZoneInteger1Retrofit FactorInteger1(1.0 = new, 1.3 = medium, 1.6 = difficult)''Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Year2015Sevice Life (levelization period)Years30Inflation Rate%0.03116After Tax Discount Rate (current \$'s)%0.169First-year Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.017Levelized Carrying Charge (constant \$'s)%0.03Capital Costs:''0.03Capital Costs:''0.03Capital Costs:''0.03Capital Costs''0.03Capital Costs:''0.03Construction Labor Rate%0.03Construction Labor Rate%0.03Cost Basis CP Plant Index.Integer578.4If "No' input escalation rate.%0.03Construction Labor Rate%/Nr60<	Plant Capacity Factor	%	0.65	
Arr Heater Leakage % 0.12 Air Heater Outlet Gas Temperature °F 300 Inlet Air Temperature °F 80 Ambient Absolute Pressure in. of Hg 29.4 Pressure After Air Heater in. of H2O -12 Moisture in Air Ib/Ib/dry air 0.013 Ash Split: 0.12 Fly Ash % 0.8 Bottom Ash % 0.2 Seismic Zone Integer 1 Retrofit Factor Integer 1.6 (1.0 = new, 1.3 = medium, 1.6 = difficult) Select Coal Integer 8 Is Selected Coal a Powder River Basin Coal? Yes / No No Economic Inputs Cost Basis - Year Dollars Year 2015 Sevice Life (levelization period) Years 30 Inflation Rate % 0.03 After Tax Discount Rate (current \$'s) % 0.168 First-year Carrying Charge (current \$'s) % 0.046	Total Air Downstream of Economizer	%	1.2	
Air Heater Outlet Gas Temperature %F 300 Inlet Air Temperature %F 80 Ambient Absolute Pressure in. of Hg 29.4 Pressure After Air Heater in. of H2O -12 Moisture in Air Ib/Ib dry air 0.013 Ash Split: " 0.12 Fly Ash % 0.8 Bottom Ash % 0.2 Seismic Zone Integer 1 Retrofit Factor Integer 1.6 (1.0 = new, 1.3 = medium, 1.6 = difficult) Integer 8 Select Coal Integer 8 Is Selected Coal a Powder River Basin Coal? Yes / No No Economic Iuputs " " " Cost Basis -Year Dollars Year 2015 Sevice Life (levelization period) Years 30 1 Inflation Rate % 0.03 After Tax Discount Rate (current \$'s) % 0.022 Levelized Carrying Charge (current \$'s) % 0.108 5 First-year Carrying Cha	Air Heater Leakage	%	0.12	
Inlet Air Temperature°F80Ambient Absolute Pressurein. of Hg29.4Pressure After Air Heaterin. of Hg29.4Moisture in Airlb/lb dry air0.013Ash Split:0.013Fly Ash%0.8Bottom Ash%0.2Seismic ZoneInteger1Retrofit FactorInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNoEconomic InputsCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.137Levelized Carrying Charge (constant \$'s)%0.03Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes' If "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr60Prime Contractor's Markup<	Air Heater Outlet Gas Temperature	°F	300	
Ambient Absolute Pressure in. of Hg 29.4 Pressure After Air Heater in. of H2O -12 Moisture in Air Ib/Ib dry air 0.013 Ash Split: % 0.2 Fly Ash % 0.2 Setom Ash % 0.2 Setimic Zone Integer 1 Retrofit Factor Integer 1.6 (1.0 = new, 1.3 = medium, 1.6 = difficult) Select Coal Integer 8 Is Selected Coal a Powder River Basin Coal? Yes / No No Economic Inputs Cost Basis -Year Dollars Year 2015 Sevice Life (levelization period) Years 30 Inflation Rate % 0.03 AFDC Rate (current \$'s) % 0.108 First-year Carrying Charge (current \$'s) % 0.117 Sales Tax % 0.016 Evelized Carrying Charge (constant \$'s) % 0.017	Inlet Air Temperature	°F	80	
Pressure After Air Heater in, of H2O -12 Moisture in Air Ib/Ib dry air 0.013 Ash Split: 1 0.013 Fly Ash % 0.2 Seismic Zone Integer 1 Retrofit Factor Integer 1.6 (1.0 = new, 1.3 = medium, 1.6 = difficult)	Ambient Absolute Pressure	in. of Hg	29.4	
Moisture in AirIb/Ib dry air0.013Ash Split:Fly Ash%0.8Bottom Ash%0.2Seismic ZoneInteger1Retrofit FactorInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNoCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.03Cost Jacta Costs:Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes" Input cost basis CE Plant Index.IntegerIf "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25	Pressure After Air Heater	in. of H2O	-12	
Ash Split: $\%$ 0.8Fly Ash%0.2Bottom Ash%0.2Seismic ZoneInteger1Retrofit FactorInteger1.6 $(1.0 = new, 1.3 = medium, 1.6 = difficult)$ \cdots Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNo \cdots \cdots Economic Inputs \cdots Cost Basis -Year DollarsYearSevice Life (levelization period)YearsSovice Life (levelization period)YearsInflation Rate%AFD Cate (current \$'s)%First-year Carrying Charge (current \$'s)%First-year Carrying Charge (constant \$'s)%Levelized Carrying Charge (constant \$'s)%Levelized Carrying Charge (constant \$'s)%Sales Tax%Consumables (O&M)%Is Chem. Eng. Cost Index available?Yes / NoYes ' If "No" input eost basis CE Plant Index.IntegerIf "No" input cost basis CE Plant Index.IntegerIf "No" input cost basis CE Plant Index.IntegerIf "No" input cost basis CE Plant Index.%If "No" input cost basis CE Plant Index.%If "No" input cost basis CE Plant Index.NoYes / If "No" input cost basis CE Plant Index.IntegerIf "No" input cost basis CE Plant Index.MIf "No" input cost basis CE Plant Index.IntegerIf "No" input cost basis CE Plant Index.IntegerIf "No" input cost basis CE Plant In	Moisture in Air	lb/lb dry air	0.013	
Fly Ash%0.8Bottom Ash%0.2Seismic ZoneInteger1Retrofit FactorInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)Integer8Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNoEconomic InputsCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.117Sales Tax%0.03Consumables (O&M)%0.03Consumables (O&M)%0.03Capital Costs:If "Yes" input cost basis CE Plant Index.IntegerIf "Yes" input cost basis CE Plant Index.IntegerIf "Yes" input cost basis CE Plant Index.%0.03Construction Labor Rate%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25	Ash Split:			
Bottom Ash%0.2Seismic ZoneInteger1Retroit FactorInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)Integer8Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNoEconomic InputsCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.1257Levelized Carrying Charge (current \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.06Escalation Rate:Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoIf "Yes" input cost basis CE Plant Index.IntegerIf "Yes" input cost basis CE Plant Index.IntegerIf "Yes" input cost basis CE Plant Index.Miles/WhIf "Yes" input cost basis CE Plant Index.%If "Yes" input cost basis CE Plant Index.Miles/WhOrstruction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power Cost\$/1000 lbs3.5	Fly Ash	%	0.8	
Seismic ZoneInteger1Retrofit FactorInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)	Bottom Ash	%	0.2	
Retrofit FactorInteger1.6(1.0 = new, 1.3 = medium, 1.6 = difficult)Integer8Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNoEconomic InputsCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.03Consumables (O&M)%0.03Capital Costs:%0.03If "No" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost%/1000 lbs3.5	Seismic Zone	Integer	1	
(1.0 = new, 1.3 = medium, 1.6 = difficult)Integer8Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNoEconomic InputsCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Econsumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes / If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25	Retrofit Factor	Integer	1.6	
Select CoalInteger8Is Selected Coal a Powder River Basin Coal?Yes / NoNoEconomic InputsYes / NoNoEconomic InputsYear2015Cost Basis -Year DollarsYears30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.03Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes ' Input cost basis CE Plant Index.IntegerIf "No" input escalation rate.%0.03Construction Labor Rate%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	(1.0 = new, 1.3 = medium, 1.6 = difficult)			
Is Selected Coal a Powder River Basin Coal? Feonomic Inputs Cost Basis -Year Dollars Sevice Life (levelization period) Inflation Rate After Tax Discount Rate (current \$'s) AFDC Rate (current \$'s) First-year Carrying Charge (current \$'s) First-year Carrying Charge (current \$'s) Keelized Carrying Charge (constant \$'s) Seles Tax Consumables (O&M) Capital Costs: Is Chem. Eng. Cost Index available? Is Chem. Eng. Cost Index available? Mills/kWh 25 Steam Cost Steam Cost Steam Cost Steam Cost Staam C	Select Coal	Integer	8	
Economic InputsImage: Construction periodYear2015Cost Basis -Year DollarsYears30Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.123Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.06Escalation Rates:Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes' input cost basis CE Plant Index.IntegerIf "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power Cost\$/1000 lbs3.5	Is Selected Coal a Powder River Basin Coal?	Yes / No	No	
Economic InputsCost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoIf "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5				
Cost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.223Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:	Economic Inputs			
Cost Basis -Year DollarsYear2015Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.223Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.03Consumables (O&M)%0.03Capital Costs:**If "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate%0.03Operating Labor Rate%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5				
Sevice Life (levelization period)Years30Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.223Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.03Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes' input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Cost Basis -Year Dollars	Year	2015	
Inflation Rate%0.03After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.223Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.03Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Sevice Life (levelization period)	Years	30	
After Tax Discount Rate (current \$'s)%0.092AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.223Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.06Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Inflation Rate	%	0.03	
AFDC Rate (current \$'s)%0.108First-year Carrying Charge (current \$'s)%0.223Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.03Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYesIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	After Tax Discount Rate (current \$'s)	%	0.092	
First-year Carrying Charge (current \$'s)%0.223Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.06Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYesIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	AFDC Rate (current \$'s)	%	0.108	
Levelized Carrying Charge (current \$'s)%0.169First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:%0.03Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYesIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate%/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	First-year Carrying Charge (current \$'s)	%	0.223	
First-year Carrying Charge (constant \$'s)%0.157Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYesIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate%/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Levelized Carrying Charge (current \$'s)	%	0.169	
Levelized Carrying Charge (constant \$'s)%0.117Sales Tax%0.06Escalation Rates:Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes' input cost basis CE Plant Index.IntegerIf "Yes" input cost basis CE Plant Index.1ntegerIf "No" input escalation rate.%Onstruction Labor Rate\$/hrPrime Contractor's Markup%Operating Labor Rate\$/hrPower CostMills/kWh25\$team Cost	First-year Carrying Charge (constant \$'s)	%	0.157	
Sales Tax%0.06Escalation Rates:Consumables (O&M)%Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes' input cost basis CE Plant Index.IntegerIf "Yes" input cost basis CE Plant Index.IntegerIf "No" input escalation rate.%Construction Labor Rate\$/hrPrime Contractor's Markup%Operating Labor Rate\$/hrPower CostMills/kWh25\$team Cost	Levelized Carrying Charge (constant \$'s)	%	0.117	
Escalation Rates:Consumables (O&M)%Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYes' input cost basis CE Plant Index.IntegerIf "No" input escalation rate.%Construction Labor Rate%/hrPrime Contractor's Markup%Operating Labor Rate\$/hrPower CostMills/kWhSteam Cost\$/1000 lbsSteam Cost\$/1000 lbs	Sales Tax	%	0.06	
Consumables (O&M)%0.03Capital Costs:Is Chem. Eng. Cost Index available?Yes / NoYesIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate%/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Escalation Rates:			
Capital Costs:YesIs Chem. Eng. Cost Index available?Yes / NoIf "Yes" input cost basis CE Plant Index.IntegerIf "No" input escalation rate.%Construction Labor Rate%/hrPrime Contractor's Markup%Operating Labor Rate\$/hrPower CostMills/kWhSteam Cost\$/1000 lbs3.5	Consumables (O&M)	%	0.03	
Is Chem. Eng. Cost Index available?Yes / NoYesIf "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Capital Costs:			
If "Yes" input cost basis CE Plant Index.Integer578.4If "No" input escalation rate.%0.03Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Is Chem. Eng. Cost Index available?	Yes / No	Yes	
If "No" input escalation rate.%0.03Construction Labor Rate%/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	If "Yes" input cost basis CE Plant Index.	Integer	578.4	
Construction Labor Rate\$/hr60Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	If "No" input escalation rate.	%	0.03	
Prime Contractor's Markup%0.03Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Construction Labor Rate	\$/hr	60	
Operating Labor Rate\$/hr63Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Prime Contractor's Markup	%	0.03	
Power CostMills/kWh25Steam Cost\$/1000 lbs3.5	Operating Labor Rate	\$/hr	63	
Steam Cost \$/1000 lbs 3.5	Power Cost	Mills/kWh	25	
	Steam Cost	\$/1000 lbs	3.5	

Table 16. CUECost Input and Calculation Summary: Wet Scrubber

Limestone Forced Oxidation (LSFO) Inputs		
SO2 Removal Required	%	0.5
L/G Ratio	gal / 1000 acf	125
Design Scrubber with Dibasic Acid Addition?	Integer	2
(1 = ves, 2 = no)		
Adiabatic Saturation Temperature	٥F	127
Reagent Feed Ratio	Factor	1.05
(Mole CaCO3 / Mole SO2 removed)		100
Scrubber Slurry Solids Concentration	Wt %	0.15
Stacking, Landfill, Wallboard	Integer	1
(1 = stacking, 2 = lanfill, 3 = wallboard)	8	
Number of Absorbers	Integer	1
(Max Capacity = 700 MW per absorber)	integer	-
Absorber Material	Integer	1
$(1 = \text{alloy} \ 2 = \text{RL}(S)$	integer	-
Absorber Pressure Drop	in H2O	6
Reheat Required ?	Integer	1
$(1 = \text{ves} \ 2 = \text{no})$	integer	1
Amount of Reheat	٥È	25
Reagent Bulk Storage	Davs	60
Reagent Cost (delivered)	\$/ton	15
Landfill Dienosal Cost	\$/ton	30
Stacking Disposal Cost	\$/ton	6
Credit for Cynsum Bynroduct	\$/ton	2
Maintonanco Factors by Aroa (% of Installed Cost)	φ/ ιοπ	2
Reagont Food	0/_	0.05
SO2 Romoval	0/_	0.05
Elue Cos Handling	0/	0.05
Waste / Burreduct	0/	0.05
Support Equipment	/0	0.05
Contingency by Area (% of Installed Cost)	/0	0.05
Reagent Feed	0/	0.2
CO2 Removal	/0	0.2
SO2 Kellioval	/0	0.2
Masta / Providuat	/0	0.2
Support Equipment	/0	0.2
Constal Equipment	/0	0.2
Beagent Facilities by Area (% or Installed Cost)	0/	0.1
CO2 Barrage 1	70	0.1
SO2 Removal	% 0/	0.1
Flue Gas Handling	%	0.1
Waste / Byproduct	% 0/	0.1
Support Equipment	70	0.1
Engineering Fees by Area (% of Installed Cost)	0/	0.1
Keagent Feed	% 	0.1
SU2 Kemoval	%	0.1
Flue Gas Handling	%	0.1
Waste / Byproduct	%	0.1
Support Equipment	%	0.1

Table 16. CUECost Input and Calculation Summary: Wet Scrubber(continued)

SUMMARY OF COSTS		
cription Units		Input 1
SO2 Control Costs		LSFO
Total Capital Requirement (TCR)	\$	\$88,476,054
	\$/kW	\$589.84
First Year Costs		
Fixed O&M	\$	\$5,133,156
	\$/kW-Yr	\$34.22
	Mills/kWH	6.01
	\$/ton SO2 removed	\$18,604.0
Variable O&M	\$	\$621,703
	\$/kW-Yr	\$4.14
	Mills/kWH	0.73
	\$/ton SO2 removed	\$2,253.2
Fixed Charges	\$	\$19,730,160
	\$/kW-Yr	\$131.53
	Mills/kWH	23.10
	\$/ton SO2 removed	\$71,507.6
TOTAL	\$	\$25,485,020
	\$/kW-Yr	\$169.90
	Mills/kWH	29.84
	\$/ton SO2 removed	\$92,364.8
Levelized Current Dollars		
Fixed O&M	\$/kW-Yr	\$46.57
	Mills/kWH	8.18
	\$/ton SO2 removed	\$25,316.6
Variable O&M	\$/kW-Yr	\$5.64
	Mills/kWH	0.99
	\$/ton SO2 removed	\$3,066.2
Fixed Charges	\$/kW-Yr	\$99.68
	Mills/kWH	17.51
	\$/ton SO2 removed	\$54,191.9
TOTAL	\$/kW-Yr	\$151.89
	Mills/kWH	26.68
	\$/ton SO2 removed	\$82,574.7
Levelized Constant Dollars		
Fixed O&M	\$/kW-Yr	\$34.22
	Mills/kWH	6.01
	\$/ton SO2 removed	\$18,604.0
Variable O&M	\$/kW-Yr	\$4.14
	Mills/kWH	0.73
	\$/ton SO2 removed	\$2,253.2
Fixed Charges	\$/kW-Yr	\$69.01
	Mills/kWH	17.22
	\$/ton SO2 removed	\$53,289.1
TOTAL	\$/kW-Yr	\$107.38
	Mills/kWH	23.95
	\$/ton SO2 removed	\$74,146.3

Table 16. CUECost Input and Calculation Summary: Wet Scrubber
(continued)

4 DISCUSSION OF SITE-SPECIFIC CONSIDERATIONS

4.1 LOCATION LIMITATIONS

Several location limitations exist that could cause seemingly technically feasible emission reduction options to be only marginally feasible. Some of these location factors include:

- Plant congestion
- Transportation and ease of obtaining raw materials
- Climate

The BACT evaluation has included some consideration of the economic impact of congestion at the Chena Power Plant. An important aspect of operating on an older, small industrial site is the ability to actually place additional equipment needed to operate add-on control equipment. All of the identified feasible technologies require installation of tanks for reagent storage, and in some of the cases the technology itself must be erected in available space. The congested nature of the existing Chena Power Plant site is such that the retrofit installation costs are likely to be higher than those estimated and presented in the cost tables provided earlier. Additionally, lack of available space on site could make installation of additional equipment completely infeasible. The impact of site congestion is even more aggravated if multiple pollutant control technologies are selected. This limitation would not be completely understood prior to preliminary design of any identified system.

Each of the identified SO₂ and NOx technologies also requires routine delivery of reagents to operate the system, and the SO₂ technologies will require removal of residues produced by the process. Fairbanks is approximately 400 miles from Anchorage, which is a logical location for origination of raw materials. Delivery of hazardous liquids over potentially icy roadways may interrupt raw material deliveries to the point where interruptions in plant operations could occur. The hazardous driving conditions also may cause the transportation costs for raw materials or process equipment to be greater than presented in the cost sheets, thereby causing the cost effectiveness of control to be a larger value than calculated.

Climate considerations factor into the BACT evaluation in two ways: 1) climate causes the costs to become inflated due to the need for additional insulation, heated vessels, and heat tracing, and 2) climate affects the ability of the precursor emissions from the Chena Power Plant to react in the atmosphere and form $PM_{2.5}$. The first factor is partially considered in the NOx control cost calculation in that a SSF and LAF are included in the cost estimate. However, no site factors are included in the SO₂ control cost calculations. Thus, the SO₂ control costs, while already extremely high, are underestimated. The atmospheric factor, which may limit atmospheric reaction rates, is briefly discussed in the next section on environmental considerations.

4.2 ENVIRONMENTAL AND ENERGY CONSIDERATIONS

Environmental and energy considerations must be considered in a BACT evaluation. With respect to nonattainment BACT, precursor control options that are determined to be economically feasible may not yield the desired objective of improving PM_{2.5} air quality. (This statement is true even though none of the control options evaluated in this BACT evaluation were found to be economically feasible.) A rash conclusion to implement a (economically feasible) precursor control as BACT may in fact produce insignificant environmental benefits and at the same time produce adverse energy or environmental impacts. These topics are discussed below.

4.2.1 Environmental Considerations

The rationale for ensuring that benefits of a precursor control option are indeed real and significant is founded in the CAA. CAA section 189(e) explicitly requires that the control requirements applicable for major stationary sources of direct $PM_{2.5}$ emissions must also apply to major stationary sources of $PM_{2.5}$ precursors, unless the state provides a demonstration that emissions of a particular precursor from major stationary sources do not contribute significantly to levels that exceed the standard in the nonattainment area of concern. Thus, the statute generally requires control of all $PM_{2.5}$ precursors in a nonattainment area, but it provides an express exception applicable to major stationary sources in such areas if an appropriate demonstration is made.¹⁶

A key conclusion derived by looking at the CMB evaluations for PM filters collected in the FNSB is that control of Chena Power Plant PM_{2.5} precursors will not provide significant reduction of ambient PM_{2.5}. This

¹⁶ Federal Register, Volume 81, page 58091, August 24, 2016, 40 CFR Parts 50, 51, and 93, Fine Particulate Matter National Ambient Air Quality Standards: State Implementation Plan Requirements; Final Rule.

conclusion can easily be validated by looking solely at the wood smoke contribution and comparing it to the $PM_{2.5}$ standard. As is seen on many episode days, the standard is exceeded solely due to contribution from wood smoke, while the impact of nitrates on episode days is minor. The contribution of sulfates also is minor. A demonstration of this occurrence, was included in the Moderate SIP submittal as part of a precursor demonstration. U.S. EPA subsequently proposed to approve the Moderate plan precursor demonstration.¹⁷

Various procedures can be used to determine a specific source contribution to ambient PM_{2.5} concentrations and, by extension, the air quality improvements in PM_{2.5} air quality should one or more control measures be implemented at the Chena Power Plant. Because no one procedure answers every question one may have, a variety of procedures are often employed. This is a key issue that relates the magnitude of reductions in daily precursor emissions to commensurate reductions in PM_{2.5} concentrations. In many cases, indirect procedures must be employed to estimate air quality benefits resulting from installation of precursor emission controls. For example, SNCR (the NOx control option identified herein that has the best cost-effectiveness) was estimated to be able to achieve a 30 percent reduction in NOx emissions from the Chena Power Plant boilers, and the most cost-effective SO₂ control option identified herein can achieve a 50 percent reduction in SO_2 emissions from the boilers. As introduced earlier in Section 1.7.3, on average, Chena Power Plant boilers emitted 1.8 and 1.9 ton/day of NOx and SO_{2} , respectively, in 2015 on days when the PM_{2.5} standard was exceeded. Thus, application of NOx and/or SO₂ controls at Chena Power Plant would result in an average NOx reduction of 0.54 ton/day and an average SO_2 reduction of 0.95 ton/day. These reductions represent only 2.6 percent and 7.8 percent of the estimated NOx and SO₂ nonattainment area-wide emissions, respectively, estimated to occur on PM2.5 episode days in 2008 (see Table 2, presented previously).

ADEC included CMB results in the SIP to provide some insight into establishing source contributions in the FNSB. As discussed in Section 1.7.2, the CMB analysis employed during SIP development estimates that ammonium nitrate contributed a maximum of 8 μ g/m³ (at most) to the PM_{2.5} mass on filters collected in downtown Fairbanks on high PM_{2.5} concentration days between 2005 and 2013. (Appendix III.D.5.7 of the SIP

¹⁷ Federal Register, Volume 82, February 2, 2017, 40 CFR Part 52, Air Plan Approval; AK, Fairbanks North Star Borough; 2006 PM_{2.5} Moderate Area Plan, Proposed Rule.

reports that "nitrates comprise about 4% of the measured $PM_{2.5}$ concentrations in Fairbanks. This corresponds to a hydrated ammonium nitrate concentration of $3.4 \ \mu g/m^3$.")¹⁸ The CMB analysis also estimates a maximum sulfate contribution of 28.8 $\mu g/m^3$ (at most) over the same time period. Assuming that all of the precursor emission reductions noted above for Chena Power Plant culminate in the same level of ambient PM_{2.5} reductions, the identified NOx and SO₂ control technologies would benefit ambient air quality in downtown Fairbanks by only 0.2 $\mu g/m^3$ for nitrates (i.e., 8.0 μg nitrate/m³ times 2.6 percent reduction in daily NOx emissions) and only 2.2 $\mu g/m^3$ for sulfates (i.e., 28.8 μg sulfate/m³ times 7.8 percent reduction in daily SO₂ emissions). The improvements on an average basis would be about half these amounts. (The ambient nitrate improvement due to Chena Power Plant NOx reductions using the SIP-reported contribution would be less than 0.1 $\mu g/m^3$ for nitrates [i.e., 3.4 μg nitrate/m³ times 2.6 percent reduction in daily NOx emissions]).

As discussed in the 2017 proposed approval, the U.S. EPA noted that ADEC also ran the Community Multiscale Air Quality (CMAQ) model to estimate stationary source nitrate contributions to ambient $PM_{2.5}$ concentrations. U.S. EPA noted that, for the 2015 model simulation, the impact from major stationary source NOx to $PM_{2.5}$ at the State Office Building monitor location was $0.5 \ \mu g/m^3$ averaged across all modeled episode days (all days within the episode produce $PM_{2.5}$ less than $0.6 \ \mu g/m^3$). These observations agree well with the expected improvements discussed in the prior paragraphs.

The estimated nitrate improvements in $PM_{2.5}$ air quality presented above are below the U.S. EPA-recommended 24-hour significant level of 1.3 µg/m³ as presented in the recent Draft Precursor Guidance, and only slightly above the significant level when considering sulfate concentrations. This comparison indicates that the environmental benefit of installing NOx controls at Chena Power Plant will produce no noticeable improvement in ambient $PM_{2.5}$ air quality.

Another environmental factor impacting the true effectiveness of a control option is the atmospheric reaction process that leads to conversion of precursor emissions to PM_{2.5}. Two major issues must be considered when evaluating the Chena Power Plant's contribution to nitrate and sulfate

¹⁸ ADEC, Amendments to: State Air Quality Control Plan SIP, Vol. III: Appendix III.D.5.7, Appendix to Volume II. Analysis of Problems, Control Actions; Section III. Area-wide Pollutant Control Program; D. Particulate Matter; 5. Fairbanks North Star Borough PM_{2.5} Control Plan, December 24, 2014, page III.D.5.7-66.

levels within the FNSB air basin: 1) precursor reaction chemistry in arctic wintertime conditions when exceedances of the PM_{2.5} NAAQS occur, and 2) transport and dispersion of the Chena Power Plant boiler stack plume above and beyond the capped inversion layer that encapsulates the FNSB air basin causing accumulation of ground-level PM_{2.5} within the air basin.

Formation of secondary PM_{2.5} depends on numerous factors including the concentrations of precursors; the concentrations of other gaseous reactive species; atmospheric conditions including solar radiation, temperature, and relative humidity; and the interactions of precursors with preexisting particles and with cloud or fog droplets. The relative contribution to ambient PM_{2.5} concentrations from each of these precursor pollutants varies by climatological area. The relative effect of reducing emissions of these pollutants is also highly variable.¹⁹

Nitrates are formed from the oxidation of NOx into nitric acid (HNO₃) either during the daytime (reaction with OH) or during the night (reactions with ozone and water). Nitric acid continuously transfers between the gas and the condensed phases through condensation and evaporation processes in the atmosphere. The formation of aerosol ammonium nitrate is favored by the availability of ammonia, temperatures near freezing, and high relative humidity²⁰. A 2009 wintertime study²¹ in eastern Wisconsin evaluated high PM_{2.5} episodes, which were characterized by low pressure systems, shallow/stable boundary layer, light winds, and increased temperature and relative humidity relative to climatological mean conditions. They often occurred in the presence of regional snow cover at temperatures near freezing, when snow melt and sublimation could generate fog and strengthen the boundary layer inversion. These climatological conditions are not consistent with those that typically generate high PM_{2.5} concentrations in the FNSB, which include low-light conditions with very cold surface temperatures (less than -20 °F) where little to no moisture is available for enhancing particle growth. U.S. EPA acknowledges the identified

¹⁹ Federal Register, Volume 73, page 28325, May 16, 2008, 40 CFR Parts 51 and 52, Implementation of the New Source Review (NSR) Program for Particulate Matter Less Than 2.5 Micrometers (PM_{2.5}).

²⁰ NARSTO (2004) Particulate Matter Science for Policy Makers: A NARSTO Assessment. P. McMurry, M. Shepherd, and J. Vickery, eds. Cambridge University Press, Cambridge, England. ISBN 0 52 184287 5.

²¹ Overview of the LADCO winter nitrate study: hourly ammonia nitric acid and PM2.5 composition at an urban and rural site pair during PM2.5 episodes in the US Great Lakes region. Atmos. Chem. Phys., 12, 11037–11056, 2012.

limitation of secondary particulate formation from NOx in its proposed approval of the Fairbanks Moderate plan.

Sulfates are typically formed in the atmosphere by formation of sulfuric acid from SO_2 that subsequently reacts with ammonia to form ammonium sulfate. There are three different pathways for the transformation of SO_2 to sulfuric acid²²:

- 1. Gaseous SO_2 can be oxidized by the hydroxyl radical (OH) to create sulfuric acid. This gaseous SO_2 oxidation reaction occurs slowly and only in the daytime.
- 2. SO₂ can dissolve in cloud water (or fog or rainwater), and there it can be oxidized to sulfuric acid by a variety of oxidants, or through catalysis by transition metals such as manganese or iron. If ammonia is present and taken up by the water droplet, then ammonium sulfate will form as a precipitate in the water droplet.
- 3. SO₂ can be oxidized in reactions in the particle-bound water in the aerosol particles themselves. This process takes place continuously, but only produces appreciable sulfate in alkaline (dust, sea salt) coarse particles.

Again, these climatological conditions that are conducive to sulfate formation from transformation of SO₂ are not consistent with the conditions that typically generate high PM_{2.5} concentrations in the FNSB.

Finally, an issue arises in FNSB related to the dispersion of precursor emissions from the Chena Power Plant boiler stack and the ability of the dispersed emissions to actually impact the ambient air quality monitors. It has been observed, and it is reasonable to expect, that the boiler stack plume is carried above the winter inversion layer. As such, transport of the precursor pollutants occurs above the inversion layer, where the concentrations of the pollutants can be transported and dispersed by the stronger aloft winds. In addition, the Fairbanks PM_{2.5} Source Apportionment Research Study²³ concluded that dominant aloft wind direction during PM_{2.5} episodes is from the northeast, which would transport the Chena Power Plant emissions away from the ambient air

²² NARSTO (2004) Particulate Matter Science for Policy Makers: A NARSTO Assessment. P. McMurry, M. Shepherd, and J. Vickery, eds. Cambridge University Press, Cambridge, England. ISBN 0 52 184287 5.

²³ The Fairbanks, Alaska PM_{2.5} Source Apportionment Research Study Winters 2005/2006-2012/2013, and Summer 2012; Final Report, Amendments 6 and 7, December 23, 2013, Tony J. Ward, Ph.D., University of Montana – Missoula , Center for Environmental Health Sciences.

quality monitors located in downtown Fairbanks and North Pole. Figure 1 presents a photograph showing the Chena Power Plant boiler stack exhaust plume height well above the inversion layer.



Figure 1. Chena Power Plant exhaust plume.²⁴

²⁴ The exhaust from the Aurora Energy power plant breaks through an inversion layer as seen from the Hagelbarger Road pullout off the Steese Highway. Photo credits: Frank DeGenova, January 30, 2008, <u>http://marcvaldez.blogspot.com/2008/05/wintertime-smokestack-plumes-in.html#links</u>, accessed December 12, 2016.

Data collected at several of the existing FNSB ambient $PM_{2.5}$ monitors corroborate these observations. Figure 2, Figure 3, and Figure 4 present plots of daily Chena Power Plant coal combustion and (wintertime) ambient $PM_{2.5}$ concentrations on days between 2013 and 2015 when the $PM_{2.5}$ standard was exceeded. (ADEC does not use episodes with violations during the summer months because those have historically been associated with exceptional events, such as wildfires.)²⁵ Each of these monitors collect $PM_{2.5}$ data on a daily schedule. As this series of plots reveal, a very poor correlation exists between Chena Power Plant coal consumption and the ambient $PM_{2.5}$ levels observed at these FNSB monitors. The State Office Building monitor actually shows an inverse relationship (negative slope) between Chena Power Plant coal consumption and ambient $PM_{2.5}$ concentrations.





²⁵ Federal Register, Volume 82, page 9036, February 2, 2017, 40 CFR Part 52, Air Plan Approval; AK, Fairbanks North Star Borough; 2006 PM_{2.5} Moderate Area Plan, Proposed Rule.







Figure 4. Chena Power Plant daily coal combustion v ambient $PM_{2.5}$ concentrations at downtown Fairbanks monitor 20904005-3 (2013 to 2014).

These poor correlations indicate that changes in Chena Power Plant emissions do not explain the majority of the changes in ambient PM_{2.5} levels. Because the Chena Power Plant emissions are not seemingly influencing the ambient PM_{2.5} concentrations to any significant extent, the ambient levels must be the result of other emission sources in the FNSB.

This observation can be further illustrated using the following example for the highest $PM_{2.5}$ day (early January) in 2015 at downtown Fairbanks monitors when Chena Power Plant coal consumption was at its greatest rate (2.2 million pounds/day). If this was during one of the coldest days, then the Chena Power Plant impact at ground level would have been less than on other days because: 1) the buoyancy term for the Chena Power Plant boiler plume would be at its greatest because the temperature differential between stack and ambient air temperatures would have been greatest, and 2) the momentum term for the boiler plume would also have been at its greatest because the exhaust gas flow rate would be greater than at lesser coal combustion rates. Because the impact of Chena Power Plant emissions would likely have been less on this episode day than other days, the $PM_{2.5}$ mass on the filters in question would had to have been contributed by other sources in the FNSB.

To summarize these environmental considerations related to photochemistry and precursor transport within the FNSB, the U.S. EPA makes the following corroborating points:

"The low amount of $PM_{2.5}$ from major stationary source NOx precursor emissions is consistent with other aspects of the FNSB Moderate Plan...the photochemistry to produce large amounts of particle bound nitrate is limited during wintertime pollution events in the FNSB nonattainment area. Furthermore, major stationary sources with elevated stacks emit most of their precursors into the extremely stable atmosphere present during wintertime pollution events. Only a fraction of the elevated plumes returns to ground level in the FNSB where air quality monitors are located and much less than might be expected in most parts of the lower 48 states. Therefore, the analysis indicates that NOx emissions from these sources will have very little impact on ground level chemistry and thus on secondary $PM_{2.5}$ formation in the FNSB nonattainment area."²⁶

²⁶ Federal Register, Volume 82, page 9043, February 2, 2017, Air Plan Approval; AK, Fairbanks North Star Borough; 2006 PM₂₅ Moderate Area Plan, Proposed Rule.

4.2.2 Energy Considerations

Retrofit BACT as a means to reduce the pollutant load in an air basin must necessarily look at the effect that employing BACT on a specific source would have on other sources in the air basin and whether this effect would negatively impact the air quality improvement that is presumed to occur when BACT is employed. As discussed below, in the case of the Chena Power Plant, installing add-on control devices for NOx and/or SO_2 control would increase the parasitic load at the Plant. As stated previously, the Chena Power Plant boilers are operated to generate steam that supplies local steam customers as well as steam turbines for electric generation. The four boilers already operate at near full load year round. The only variation in seasonal operating characteristics is the percent of the steam distributed to steam customers. Steam distribution to customers is highest in the heating season, whereas electric generation is highest in the non-heating season. In all seasons, Aurora must meet its contractual steam demand by distributing a constant steam load to its customers. Any surplus steam produced is used to generate electricity that is used on site and/or exported to the grid.

When the parasitic load at the Plant increases, electricity and/or steam exported to the grid is reduced. Regional electricity demands are satisfied by various electricity-generating plants that are members of the regional co-op, i.e., the Golden Valley Electric Association (GVEA). Per its contract, GVEA purchases up to 25 megawatts (MW) of electricity from Aurora. When Aurora, or one of the other co-op facilities, reduces its net electricity generation/export to the grid, GVEA must make up for this reduction by arranging for increased electricity production from one of the other local co-op facilities or import from the Anchorage grid.

Current overall steam production efficiency at Chena Power Plant is approximately 60 percent, i.e., 60 percent of the heat content of the combusted coal is converted to steam. The mechanical loss during electricity generation contributes to an additional 14 percent loss in energy conversion efficiency. In the heating season, when almost all of the PM_{2.5} exceedances are observed within the FNSB, Aurora provides most of its output as steam, and generates (on average) 525 MWh/day that are exported to the grid. Should Aurora install and operate add-on control devices to reduce NOx and/or SO₂ stack emissions, operation of the new equipment will add to the current parasitic load at the plant and lower its overall energy conversion efficiency. The parasitic load of add-control equipment is estimated to be 4 MWh/day for SCR and 6 MWh/day for a wet scrubber, and this loss of electricity for export would have to be supplemented by increased generation at Aurora, other GVEA co-op facilities, or the State-wide grid. When this increased generation is produced by local fuel-consuming facilities, the net change in regional emissions will be close to zero or actually an increase if the supplemented electricity is produced in less-efficient power-generating units.

Overall, when considering add-on control equipment for the existing Chena Power Plant boilers, the situation could occur wherein an emission reduction at Chena would not yield an emission reduction in the FNSB because the parasitic load from the add-on equipment would need to be supplemented by additional fuel consumption (and emissions) from other co-op (i.e., local) facilities. If this situation does indeed occur, a potential reduction in ambient PM_{2.5} concentrations due to emission reductions at Chena Power Plant would be negligible, or completely non-existent, because other emission units in the FNSB would have to increase emissions to compensate for the loss in electricity exported by Aurora. Additionally, the potential regional benefit of emission reductions at the Chena Power Plant is negated by the fact that PM_{2.5} is a secondary air pollutant, and impacts from a specific emission unit are not necessarily observed in close proximity to the emission point.

4.3 SUMMARY OF ENVIRONMENTAL AND ENERGY CONSIDERATIONS

As discussed above, the environmental considerations associated with installation of NOx and/or SO₂ controls on the Chena Power Plant produce uncertain assurances that any improvement in FNSB air quality will result. In fact, the data suggest that insignificant environmental improvements at best could occur.

The energy considerations point to a likely lack of an air quality benefit in FNSB in the event that NOx and/or SO_2 controls are implemented at Chena Power Plant. In fact, such implementation could actually increase the air pollutant load in FNSB from sources more likely to produce a $PM_{2.5}$ ambient impact than Chena Power Plant.

5 DETERMINATION OF BACT

The previous sections evaluated the three aspects that must be considered in a BACT determination, those being economics, environment, and energy. The results of the economic analysis show that none of the NOx or SO₂ control options are economically feasible as retrofit options for the Chena Power Plant. From an environmental standpoint, ADEC recognizes that controlling direct PM_{2.5} emissions is 13 times more effective at reducing ambient PM_{2.5} concentrations than controlling precursor air pollutants that produce secondary $PM_{2.5}$. This, coupled with the fact that the ambient $PM_{2.5}$ benefit that can be achieved by reducing NOx and/or SO_2 emissions is extremely uncertain and difficult to calculate, suggests that no significant environmental benefit would be obtained by requiring controls on Chena Power Plant. A further environmental consideration is that retrofit BACT as a means to reduce the pollutant load in an air basin must necessarily look at the effect that employing BACT on a specific source would have on other sources in the air basin and whether this effect would negatively impact the air quality improvement that is presumed to occur when BACT is employed. Specifically, from an energy standpoint, installing add-on control devices for NOx and/or SO₂ control would increase the parasitic load at the Chena Power Plant. Loss of this energy output would require supplemental energy consumption at other sources within the FNSB to compensate for this parasitic load. This supplemental energy consumption at other sources may actually produce an increase in direct PM_{2.5} emissions if the lost capacity were to be offset by fuel consumption for sources such as wood-burning stoves or oil-fired boilers, which tend to emit more direct PM_{2.5} than Chena Power Plant (see Table 2), and at lower elevations. Furthermore, based on CMB evaluations of PM filters in the FNSB, these lower level sources are already identified as the more significant contributors to ambient PM_{2.5} concentrations. Thus, the energy impacts of requiring NOx and/or SO₂ controls on Chena Power Plant could potentially have the exact opposite effect as desired and produce increases in ambient PM_{2.5} concentrations in the FNSB.

5.1 DETERMINATION OF BACT FOR NOx

Nitrates comprise about 4 percent of the measured $PM_{2.5}$ concentrations in Fairbanks, which equates to a maximum contribution of $8.0 \ \mu g/m^3$ to the total $PM_{2.5}$ mass on filters. This is because atmospheric conditions do not lead to a high rate of conversion from NOx emissions to ambient $PM_{2.5}$. Controlling NOx emissions is not expected to achieve a meaningful

reduction in PM_{2.5}. This, in concert with the high cost to install NOx control technology and potential detrimental effects on emissions from other energy consuming sources in the FNSB, leads to the determination that BACT for NOx emissions from Chena Power Plant is the continued use of existing combustion controls.

5.2 DETERMINATION OF BACT FOR SO₂

Alaska coal has very low sulfur content, and uncontrolled sulfur emissions are four times lower than at a plant burning "low sulfur coal" in the lower 48 states.²⁷ The result is that the cost effectiveness of SO₂ control technologies is poorer in Alaska than the lower 48 states. In addition, EPA guidance states use of scrubbers on units smaller than 100 MW is unrealistic.

Current SO_2 emission rates from the Chena Power Plant are one-third of those identified as BACT in the most recent BACT determinations included in the RBLC database. Therefore, BACT for SO_2 emissions from Chena Power Plant is determined to be the continued use of low-sulfur coal.

²⁷ ADEC, Amendments to: State Air Quality Control Plan SIP, Vol. III: Appendix III.D.5.7, Appendix to Volume II. Analysis of Problems, Control Actions; Section III. Area-wide Pollutant Control Program; D. Particulate Matter; 5. Fairbanks North Star Borough PM_{2.5} Control Plan, December 24, 2014, page III.D.5.7-78.

APPENDIX A

CUECost Output for Wet Scrubber for SO₂ Control

INPUTS					
			Default		
Description	Units	Range	Values	Input 1	
				-	
General Plant Technical Inputs					
Location - State	Abbrev.	All States	PA	AK	
MW Equivalent of Flue Gas to Control System	MW	100-2000	500	150	
Net Plant Heat Rate (w/o APC)	Btu/kWhr		10,500	11,833	
Plant Capacity Factor	%	40-90%	65%	65%	
Percent Excess Air in Boiler	%		120%	120%	
Air Heater Inleakage	%		12%	12%	
Air Heater Outlet Gas Temperature	°F		300	300	
Inlet Air Temperature	°F		80	80	
Ambient Absolute Pressure	In. of Hg		29.4	29.4	
Moisture in Air	lh/lh dru oir		-12	-12	
Ash Split:	10/10 ury an		0.015	0.015	
Fly Ash	%		80%	80%	
Bottom Ash	%		20%	20%	
Seismic Zone	Integer	1-5	1	1	
Retrofit Factor	Integer	1.0-3.0	1.3	1.6	
(1.0 = new, 1.3 = medium, 1.6 = difficult)					
Select Coal	Integer	1-8	1	8	
Is Selected Coal a Powder River Basin Coal?	Yes / No	See Column K	Yes	No	
		Coals Available i	<u>n Library</u>		
		Coal 1, Wyoming PR	B: 8,227 Bt	u, 0.37% S, 3	5.32% ash
		Coal 2, Armstrong, F	PA: 13,100 B	tu, 2.6% S, 9	9.1% ash
<u>></u>		Coal 3, Jefferson, OF	I: 11,922 Bt	u, 3.43% S,	13% ash
		Coal 4, Logan, WV:	12,058 Btu,	0.89% S, 16	.6% ash
		Coal 5, No. 6 Illinois: 10,100 Btu, 4% S, 16% ash			ash
		Coal 6, Rosebud, M	F: 8,789 Btu,	0.56% S, 8.	15% ash
		Coal 7, Lignite, ND:	7,500 Btu, 0	0.94% S, 5.99	% ash
		Coal 8, "User Specif:	ied": 7,560 E	$\frac{3 \text{tu}, 0.3\% \text{ S}}{1}$	/% ash
Economic Inputs					
Cast Davis Varu Dallan	V		1009	2015	
Cost Basis - Fear Dollars	I ear		1998	2015	[
Inflation Pate	1 ears		3.00%	3.00%	
After Tax Discount Rate (current \$'s)	%		9.20%	9.20%	
AFDC Rate (current \$'s)	%		10.80%	10.80%	
First-vear Carrying Charge (current \$'s)	%		22.30%	22.30%	
Levelized Carrying Charge (current \$'s)	%		16.90%	16.90%	
First-year Carrying Charge (constant \$'s)	%		15.70%	15.70%	
Levelized Carrying Charge (constant \$'s)	%		11.70%	11.70%	
Sales Tax	%		6%	6%	
Escalation Rates:					
Consumables (O&M)	%		3%	3%	
Capital Costs:					
Is Chem. Eng. Cost Index available?	Yes / No		Yes	Yes	
	T /		200	570.4	
If "Yes" input cost basis CE Plant Index.	Integer		388	578.4 20/	
If No input escalation rate.	% \$/ha		5% \$25	3% \$60	
	¢/nr		\$33	<u> 200</u>	
Prime Contractor's Markup	0%		3%	3%	
Operating Labor Rate	5/hr		\$30	\$63	
Power Cost	Mills/kWh		25	25	
Steam Cost	\$/1000 lbs		3.5	3.5	

Limestone Forced Oxidation (LSFO) Inputs					
SO2 Removal Required	%	90-98%	95%	50%	
L/G Ratio	gal / 1000 acf	95-160	125	125	
Design Scrubber with Dibasic Acid Addition?	Integer	1 or 2	2	2	
(1 = yes, 2 = no)					
Adiabatic Saturation Temperature	°F	100-170	127	127	
Reagent Feed Ratio	Factor	1.0-2.0	1.05	1.05	
(Mole CaCO3 / Mole SO2 removed)					
Scrubber Slurry Solids Concentration	Wt. %		15%	15%	
Stacking, Landfill, Wallboard	Integer	1,2,3	1	1	
(1 = stacking, 2 = landfill, 3 = wallboard)					
Number of Absorbers	Integer	1-6	1	1	
(Max. Capacity = 700 MW per absorber)					
Absorber Material	Integer	1 or 2	1	1	
(1 = alloy, 2 = RLCS)					
Absorber Pressure Drop	in. H2O		6	6	
Reheat Required ?	Integer	1 or 2	1	1	
(1 = yes, 2 = no)					
Amount of Reheat	°F	0-50	25	25	
Reagent Bulk Storage	Days		60	60	
Reagent Cost (delivered)	\$/ton		\$15	\$15	
Landfill Disposal Cost	\$/ton		\$30	\$30	
Stacking Disposal Cost	\$/ton		\$6	\$6	
Credit for Gypsum Byproduct	\$/ton		\$2	\$2	
Maintenance Factors by Area (% of Installed Cost)					
Reagent Feed	%		5%	5%	
SO2 Removal	%		5%	5%	
Flue Gas Handling	%		5%	5%	
Waste / Byproduct	%		5%	5%	
Support Equipment	%		5%	5%	
Contingency by Area (% of Installed Cost)					
Reagent Feed	%		20%	20%	
SO2 Removal	%		20%	20%	
Flue Gas Handling	%		20%	20%	
Waste / Byproduct	%		20%	20%	
Support Equipment	%		20%	20%	
General Facilities by Area (% of Installed Cost)					
Reagent Feed	%		10%	10%	
SO2 Removal	%		10%	10%	
Flue Gas Handling	%		10%	10%	
Waste / Byproduct	%		10%	10%	
Support Equipment	%		10%	10%	
Engineering Fees by Area (% of Installed Cost)					
Reagent Feed	%		10%	10%	
SO2 Removal	%		10%	10%	
Flue Gas Handling	%		10%	10%	
Waste / Byproduct	%		10%	10%	
Support Equipment	%		10%	10%	
Indicates user inputs specific to Aurora.					

CUECost				
Coal Utility Env	vironmental Cost			
Version 1, November 25, 1998 (revised 2-9-00 as CUECost3.xls)				
INPUTS				
Description	Units	Input 1		
General Plant Technical Innuts				
<u></u>				
Location - State	Abbrev.	AK		
MW Equivalent of Flue Gas to Control System	MW	150		
Net Plant Heat Rate	Btu/kWhr	11,833		
Plant Capacity Factor	%	65%		
Total Air Downstream of Economizer	%	120%		
Air Heater Leakage	%	12%		
Air Heater Outlet Gas Temperature	°F	300		
Inlet Air Temperature	°F	80		
Ambient Absolute Pressure	In. of Hg	29.4		
Pressure After Air Heater	In. of H2O	-12		
Moisture in Air	lb/lb dry air	0.013		
Ash Split:				
Fly Ash	%	80%		
Bottom Ash	%	20%		
Seismic Zone	Integer	1		
Retrofit Factor	Integer	16		
(1.0 = new, 1.3 = medium, 1.6 = difficult)	lineger			
Select Coal	Integer	8		
Is Selected Coal a Powder River Basin Coal?	Yes / No	No		
	1057110			
Economic Innuts				
<u></u>				
Cost Basis -Year Dollars	Year	2015		
Sevice Life (levelization period)	Years	30		
Inflation Rate	%	3%		
After Tax Discount Rate (current \$'s)	%	9%		
AFDC Rate (current \$'s)	%	11%		
First-year Carrying Charge (current \$'s)	%	22%		
Levelized Carrying Charge (current \$'s)	%	17%		
First-vear Carrying Charge (constant \$'s)	%	16%		
Levelized Carrying Charge (constant \$'s)	%	12%		
Sales Tax	%	6%		
Escalation Rates:	/0	570		
Consumables (O&M)	%	3%		
Capital Costs:	/0	570		
Is Chem Eng Cost Index available?	Yes / No	Yes		
If "Yes" input cost basis CF Plant Index	Integer	578.4		
If "No" input escalation rate	%	3%		
Construction Labor Rate	\$/hr	\$60		
Prime Contractor's Markup	ψ/ III 0/2	3%		
Operating Labor Rate	\$/br	\$63		
Power Cost	Wille /kWh	25		
Steam Cost	\$/1000 lbs	3.5		
	+/ -000 100	2.0		

Limestone Forced Oxidation (LSFO) Inputs		
	<i><i><i>n</i></i></i>	- 000
SO2 Removal Required	%	50%
L/G Ratio	gal / 1000 act	125
Design Scrubber with Dibasic Acid Addition?	Integer	2
(1 = yes, 2 = no)		
Adiabatic Saturation Temperature	°F	127
Reagent Feed Ratio	Factor	1.05
(Mole CaCO3 / Mole SO2 removed)		
Scrubber Slurry Solids Concentration	Wt. %	15%
Stacking, Landfill, Wallboard	Integer	1
(1 = stacking, 2 = lanfill, 3 = wallboard)		
Number of Absorbers	Integer	1
(Max. Capacity = 700 MW per absorber)		
Absorber Material	Integer	1
(1 = alloy, 2 = RLCS)		
Absorber Pressure Drop	in. H2O	6
Reheat Required ?	Integer	1
(1 = yes, 2 = no)		
Amount of Reheat	°F	25
Reagent Bulk Storage	Days	60
Reagent Cost (delivered)	\$/ton	\$15
Landfill Disposal Cost	\$/ton	\$30
Stacking Disposal Cost	\$/ton	\$6
Credit for Gypsum Byproduct	\$/ton	\$2
Maintenance Factors by Area (% of Installed Cost)		
Reagent Feed	%	5%
SO2 Removal	%	5%
Flue Gas Handling	%	5%
Waste / Byproduct	%	5%
Support Equipment	%	5%
Contingency by Area (% of Installed Cost)		
Reagent Feed	%	20%
SO2 Removal	%	20%
Flue Gas Handling	%	20%
Waste / Byproduct	%	20%
Support Equipment	%	20%
General Facilities by Area (% of Installed Cost)		
Reagent Feed	%	10%
SO2 Removal	%	10%
Flue Gas Handling	%	10%
Waste / Byproduct	%	10%
Support Equipment	%	10%
Engineering Fees by Area (% of Installed Cost)		
Reagent Feed	%	10%
SO2 Removal	%	10%
Flue Gas Handling	%	10%
Waste / Byproduct	%	10%
Support Equipment	%	10%
	1	1

SUMMARY OF COSTS		
Description	Units	Input 1
Description	Cints	input i
SO2 Control Costs		LSEO
Total Capital Requirement (TCR)	¢	\$88.476.054
Total Capital Requirement (TCR)	\$/1/10/	\$590
First Year Costs	φ/κν	4050
Fixed O&M	s	\$5 133 156
	\$/kW_Vr	34.22
	Mills/kWH	6.01
	\$/ton SO2 removed	\$18,604,0
Variable O&M	\$	\$621 703
	\$/kW-Yr	4 14
	Mills/kWH	0.73
	\$/ton SO2 removed	\$2 253 2
Fixed Charges	\$	\$19,730,160
	\$/kW-Yr	131 53
	Mills/kWH	23.10
	\$/ton SO2 removed	\$71,507.6
TOTAL	\$	\$25,485,020
	\$/kW-Yr	169.90
	Mills/kWH	29.84
	\$/ton SO2 removed	\$92,365
Levelized Current Dollars	\$7 ton 002 Tento (cd	¢7 _ 7000
Fixed O&M	\$/kW-Yr	46.57
	Mills/kWH	8.18
	\$/ton SO2 removed	\$25,316.6
Variable O&M	\$/kW-Yr	5.64
	Mills/kWH	0.99
	\$/ton SO2 removed	\$3,066.2
Fixed Charges	\$/kW-Yr	99.68
	Mills/kWH	17.51
	\$/ton SO2 removed	\$54,191.9
TOTAL	\$/kW-Yr	151.89
	Mills/kWH	26.68
	\$/ton SO2 removed	\$82,574.7
Levelized Constant Dollars		
Fixed O&M	\$/kW-Yr	34.22
	Mills/kWH	6.01
	\$/ton SO2 removed	\$18,604.0
Variable O&M	\$/kW-Yr	4.14
	Mills/kWH	0.73
	\$/ton SO2 removed	\$2,253.2
Fixed Charges	\$/kW-Yr	69.01
	Mills/kWH	17.22
	\$/ton SO2 removed	\$53,289.1
TOTAL	\$/kW-Yr	107.38
	Mills/kWH	23.95
	\$/ton SO2 removed	\$74,146.3
LSFO Material Balance - Preliminary		Case1
-------------------------------------	-------------	-----------
Flue Gas Downstream of ID Fans		
Temperature	°E	295
Pressure	in. H2O	10
Flow Rate	SCFM	205.106
Flow Rate	ACFM	295,678
CO2	lb/hr	167,773
N2	lb/hr	662,514
SO2	lb/hr	194
02	lb/hr	52,552
HCl	lb/hr	0
Other Gases	lb/hr	150
H2O	lb/hr	59,659
Fly Ash	lb/hr	15
Total (gas only)	lb/hr	942,842
Flue Gas, to Absorber		
Temperature	°F	295
Pressure	in. H2O	10
Flow Rate	SUFM	205,106
Flow Rate	ACFM	295,678
N2	lb/hr	167,773
	lb/hr	104
02	lb/hr	52 552
HCI	lb/hr	0
Other Gases	lb/hr	150
H2O	lb/hr	59.659
Fly Ash	lb/hr	15
Total (gas only)	lb/hr	942,842
Flue Gas, from Absorbers (total)		
Temperature	°F	127
Pressure	in. H2O	4
Flow Rate	SCFM	213,946
Flow Rate	ACFM	243,352
CO2	lb/hr	167,840
N2	lb/hr	662,836
SO2	lb/hr	97
02	lb/hr	52,625
HCl	lb/hr	0
Other Gases	lb/hr	150
H2O	lb/hr	84,552
Fly Asn	ID/IIF	15
Heat Canacities	10/11	908,099
	Btu/lbmolºF	7 213
CO2	Btu/Ibmol°E	9 354
N2	Btu/lbmol°F	6 999
H2O	Btu/lbmol°F	8.069
NO	Btu/lbmol°F	7.164
SO2	Btu/lbmol°F	9.830
HCl	Btu/lbmol°F	6.951
02	Btu/lb°F	0.225
CO2	Btu/lb°F	0.213
N2	Btu/lb°F	0.250
Н2О	Btu/lb°F	0.448
NO	Btu/lb°F	0.239
SO2	Btu/lb°F	0.153
HCl	Btu/lb°F	0.191
Reheated Gas Temperature:	°C	66.7
	K	339.7
FGD Outlet Temperature:	°C v	52.8
Total Ptu/hr	K Dty/ha	525.8
10tal DUU/Nr	Btu/nr	6,275,628

Hot Reheat Air		
Temperature	°F	440
Pressure	in. H2O	1
Flow Rate	SCFM	19,267
Flow Rate	ACFM	33,852
N2	lb/hr	66,106
02	lb/hr	19,936
H2O	lb/hr	1,133
Total	lb/hr	87,175
Heat Capacities of Hot Reheat Air		
02	Btu/lbmol°F	7.332
N2	Btu/Ibmol°F	7.113
H20	Btu/Ibmol°F	8.338
02 N2	Btu/ID ⁻ F	0.229
N2 H2O	Dtu/ID F	0.234
Haatad Tamparatura:		0.403
Treated Temperature.	ĸ	/00 7
EGD Outlet Temperature	°C	667
	К	339.7
Heat Canacities of Inlet Reheat Air	IX	557.1
$\frac{1}{0}$	Btu/lbmol°F	7 304
N2	Btu/lbmol°F	7.087
H2O	Btu/lbmol°F	8.276
02	Btu/lb°F	0.228
N2	Btu/lb°F	0.253
H2O	Btu/lb°F	0.459
Heated Temperature:	°C	226.7
	K	499.7
Inlet Air Temperature:	°C	26.7
•	K	299.7
Required Heat	Btu/hr	7,844,535
Oxidation Air (total)		
Temperature	°F	60
Pressure	in. H2O	0
Flow Rate	SCFM	94
Flow Rate	ACFM	95
N2	lb/hr	321
02	lb/hr	97
H2O	lb/hr	 5
Total (gas only)	lb/hr	423
Limestone to Ball Mill		
Temperature	°F	 80
Wt.% Solids	wt. %	100%
Inerts	lb/hr	8
CaCO3	lb/hr	159
Total	lb/hr	167
Limestone Sturry to Limestone Sturry Tank		
Temperature	°F	90
Flow Rate	GPM	0.6
wt.% Solids	Wt. %	40%
	Ib/hr	8
	ID/nr lb/hr	250
Total	ID/III lb/br	417
Total	10/111	41/
Limestone Slurry to Reaction Mix Tank (total)		
	017	(9
I emperature		08
FIOW KALE	GPM	1.4
WL.70 DUIUS	WL. %	20%
	10/11F 1b/br	0
H20	lb/hr	667
Total	lb/hr	834
- Out	10/111	0.07

Slurry to Absorber			
Temperature	°F		126
Flow Rate	GPM		30,047
Wt.% Solids	wt. %		15%
CaSO3*1/2H2O	lb/hr		0
CaSO4*2H2O	lb/hr		2,448,768
	lb/hr		/3,/1/
	lb/hr		71 177
H20	lb/hr		14 697 418
Total	lb/hr		17,291,080
Slurry from Rxn Tank to Thickener			
Temperature	°F		126
Flow Rate	GPM		3.2
Wt.% Solids	wt. %		15%
CaSO3*1/2H2O	lb/hr		0
CaSO4*2H2O	lb/hr		260
Inerts CoCl2	lb/hr		8
	lb/nr		0
H20	lb/hr		0
Total	lb/hr		1,839
	10/11		1,007
LSFO Equipment Capital Costs			Case1
Cost Basis (Year)			2015
		Sizing Criteria	2010
Reagent Feed System	\$	kpph Reag.	\$10.628,589
Ball Mill & Hydroclone System	\$	TPH Reag.	\$2,767,930
DBA Acid Tank (pump, heater, agitator)	\$	gpm DBA	\$0
SO2 Removal System	\$	kpph SO2	\$2,850,322
Absorber Tower	\$	kACFM	\$8,477,991
Spray Pumps	\$	slurry gpm	\$629,404
Flue Gas Handling System	\$	*	\$4,823,011
ID Fans	\$	ACFM	\$973,101
Waste / Byproduct Handling System	\$	kpph SO2	\$120,818
Thickener System	\$	TPH solids	\$172,635
Support Equipment	\$	MW	\$2,167,145
Chimney	\$	ACFM	<u>\$3,768,539</u>
TOTAL	\$		\$37,379,484
* Based on flue gas flow and reheat temperature.			
Capital Costs with Retrofit Factors			
Reagent Feed System	\$		\$17,005,742
Ball Mill & Hydroclone System	\$		\$4,428,688
DBA Acid Tank (pump, heater, agitator)	\$		\$0
SO2 Removal System	\$		\$4,560,516
Absorber Tower	\$		\$13,564,785
Spray Pumps	\$		\$1,007,047
Flue Gas Handling System	\$		\$7,710,817
Waste / Ryproduct Handling System	¢		\$103 200
Thickener System	3 S		\$195,508
Support Equipment	\$		\$3,467,432
Chimney	\$		\$6.029.662
TOTAL	\$		\$59,807.174
	Ψ		<i>407,007,171</i>
General Facilities			
Reagent Feed System	.s		\$1,700,574
Ball Mill & Hydroclone System	\$		\$442.869
DBA Acid Tank (pump, heater, agitator)	÷	+	+=,000
· · · · · · · · · · · · · · · · · · ·	\$		\$0
SO2 Removal System	\$		\$0 \$456,052

Spray Pumps	\$	\$100,705
Flue Gas Handling System	\$	\$771,682
ID Fans	\$	\$155,696
Waste / Byproduct Handling System	\$	\$19,331
Thickener System	\$	\$27,622
Support Equipment	\$	\$346,743
Chimney	\$	<u>\$602,966</u>
TOTAL	\$	\$5,980,717
Engineering Fees		
Reagent Feed System	\$	\$1,700,574
Ball Mill & Hydroclone System	\$	\$442,869
DBA Acid Tank (pump, heater, agitator)	\$	\$0
SO2 Removal System	\$	\$456,052
Absorber Tower	\$	\$1,356,479
Spray Pumps	\$	\$100,705
Flue Gas Handling System	\$	\$771,682
ID Fans	\$	\$155,696
Waste / Byproduct Handling System	\$	\$19,331
Thickener System	\$	\$27,622
Support Equipment	\$	\$346,743
Chimney	\$	<u>\$602,966</u>
TOTAL	\$	\$5,980,717
Contingency		
Reagent Feed System	\$	\$3,401,148
Ball Mill & Hydroclone System	\$	\$885,738
DBA Acid Tank (pump, heater, agitator)	\$	\$0
SO2 Removal System	\$	\$912,103
Absorber Tower	\$	\$2,712,957
Spray Pumps	\$	\$201,409
Flue Gas Handling System	\$	\$1,543,363
ID Fans	\$	\$311,392
Waste / Byproduct Handling System	\$	\$38,662
Thickener System	\$	\$55,243
Support Equipment	\$	\$693,486
Chimney	\$	<u>\$1,205,932</u>
TOTAL	\$	\$11,961,435
Total Plant Cost (TPC)	\$	\$83,730,044
Total Plant Cost (TPC) w/ Prime Contractor's Markup	\$	\$86,241,945
Total Cash Expended (TCE)	\$	\$86,241,945
Allow. for Funds During Constr. (AFDC)	\$	\$0
Total Plant Investment (TPI)	\$	\$86,241,945
Preproduction Costs	\$	\$2,232,307
Inventory Capital	\$	\$1,802
Total Capital Requirement (TCR)	\$	\$88,476,054
	\$/kW	\$590
Maintenance Cost by Area		Case1
		Cuser
TPC w/o Retrofit Factor		
Reagent Feed System	2	\$15 305 168
Ball Mill & Hydroclone System	ψ ¢	\$2 085 810
DBA Acid Tank (numn heater agitator)	ψ \$	ψ <i>3,703,017</i> \$0
SO2 Removal System	\$ 	\$4 104 464
Absorber Tower	\$	\$12,208,307
Spray Pumps	\$	\$906.342
Flue Gas Handling System	\$	\$6.945.135
ID Fans	\$	\$1.401.265

Waste / Byproduct Handling System	\$	\$173,977
Thickener System	\$	\$248,594
Support Equipment	\$	\$3,120,689
Chimney	\$	\$5,120,009
ТОТАІ	ф \$	\$53, <u>420,070</u> \$53,826,457
IOIAL	φ	\$55,820,457
First Voar Maintonance Costs		
Passent Food System	¢	¢7/5 059
Reagent Feed System	\$	\$765,258
Ball Mill & Hydrocione System	\$	\$199,291
DBA Acid Tank (pump, heater, agitator)	\$	\$0
SO2 Removal System	\$	\$205,223
Absorber Tower	\$	\$610,415
Spray Pumps	\$	\$45,317
Flue Gas Handling System	\$	\$347,257
ID Fans	\$	\$70,063
Waste / Byproduct Handling System	\$	\$8,699
Thickener System	\$	\$12,430
Support Equipment	\$	\$156,034
Chimney	\$	\$271.335
TOTAL	\$	\$2.691.323
		1 1
ISEO O&M Data and Costs		Casal
		 Casel
Cost Basis (Year)		<u>2015</u>
<u>Parameters</u>		
Reagent Required	lbs/hr	167
	lbs/MMBtu	0.336
DBA Required	lbs/hr	0.0
Percent SO2 Removal	%	50%
FGD Sludge to Disposal	lbs/hr, dry	276
Steam to FGD System	lbs/hr	9.173
Total FGD Power Consumption	kW	3,000
FGD Byproduct	lbs/hr	0
	105/11	
Fixed O&M Costs		
Number of Operators		12
(40 hrs/woolc)		12
(40 ms/week)	<u>م</u> (¢1 (20 002
Operating Labor Cost **	\$/yr	\$1,629,903
Maint. Labor & Matis. Cost	\$/yr	\$2,691,323
Admin. & Support Labor	\$/yr	<u>\$811,930</u>
TOTAL	\$/yr	\$5,133,156
Variable Operating Costs **		
Reagent Costs	\$/yr	\$7,124
DBA Costs	\$/yr	\$0
Disposal Costs	\$/yr	\$4,713
Credit for Byproduct	\$/yr	\$0
Steam Costs	\$/yr	\$182,817
Power Costs	\$/yr	\$427,050
TOTAL	\$/yr	\$621,703
** These costs assume inputs are in current dollars (no escalation included).		
Intermediate Material Palance Cales		0 1
Intermediate Material Balance Calcs.		Casel
Sulfite Reaction		
SO2	lbmole/hr	1.51
CaCO3	llama a la /lam	1.51
H2O	Iomole/m	
C_2O2*1/2020	lbmole/hr	0.76
CasO3*1/2H2O	lbmole/hr lbmole/hr	0.76
C02	lbmole/hr lbmole/hr lbmole/hr	0.76 1.51 1.51
CO2 SO2	lbmole/hr lbmole/hr lbmole/hr lbmole/hr	0.76 1.51 1.51 97
C02 S02 CaCO3	lbmole/hr lbmole/hr lbmole/hr lb/hr lb/hr	0.76 1.51 1.51 97 151

CaSO3*1/2H2O	lb/hr	195
CO2	lb/hr	67
Sulfate Reaction		
CaSO3*1/2H2O	lbmole/hr	1.51
02	lbmole/hr	0.76
H2O	lbmole/hr	2.27
CaSO4*2H2O	lbmole/hr	1.51
CaSO3*1/2H2O	lb/hr	195
O2	lb/hr	24
H2O	lb/hr	41
CaSO4*2H2O	lb/hr	260
Water in Absorber		
Mole Fraction H2O in Absorber	%	0.1389
Moles H2O in Absorber	lbmole	4,693.33
DBA Feed Calculations		
SO2 Removed	lbs/hr	97
DBA Added	lbs/hr	0.00
DBA Added	GPM	0.00

November 19, 2019

Adopted ERM has over 140 offices across the following countries and territories worldwide

Argentina Australia Belgium Brazil Canada China Colombia France Germany Hong Kong Hungary India Indonesia Ireland Italy Japan Kazakhstan Malaysia Mexico The Netherlands New Zealand Panama Peru Poland Portugal Puerto Rico Romania Russia Singapore South Africa South Korea Spain Sweden Taiwan Thailand United Arab Emirates UK US Vietnam

ERM's Cincinnati Office

9825 Kenwood Road Suite 100 Cincinnati, Ohio 45242 T: 513-830-9030 F: 513-830-9031

www.erm.com



November 19, 2019 Department of Environmental Conservation

DIVISION OF AIR QUALITY Director's Office

410 Willoughby Avenue, Suite 303 PO Box 111800 Juneau, Alaska 99811-1800 Main: 907-465-5105 Toll Free: 866-241-2805 Fax: 907-465-5129 www.dec.alaska.gov

CERTIFIED MAIL: 7017 1450 0002 0295 9745 Return Receipt Requested

GOVERNOR BILL WALKER

November 16, 2017

dopted

David Fish, Environmental Manager Aurora Energy, LLC 100 Cushman St., Ste. 210 Fairbanks, AK 99701

THE STATE

of

Subject: Request for additional information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant by December 22, 2017

Dear Mr. Fish:

A portion of the Fairbanks North Star Borough (FNSB) has been in nonattainment with the 24hour National Ambient Air Quality Standard for fine particulate matter ($PM_{2.5}$) since 2009. In a letter dated April 24, 2015, I requested that the Aurora Chena Power Plant and other affected stationary sources voluntarily provide the Alaska Department of Environmental Conservation (ADEC) with a Best Available Control Technology (BACT) analysis in advance of the nonattainment area being reclassified to a Serious Area. On May 10, 2017, the US Environmental Protection Agency (EPA) published their determination that the FNSB $PM_{2.5}$ nonattainment area would be reclassified from a Moderate Area to a Serious Area effective June 9, 2017.¹

Once the nonattainment area was reclassified to Serious, it triggered the need for Best Available Control Measure (BACM)/BACT analyses. A BACM analysis requires that ADEC review potential control measure options for the various sectors that contribute to the PM_{2.5} air pollution in the nonattainment area. A BACT analysis must be conducted for applicable stationary sources such as the Aurora Chena Power Plant. BACM and BACT are required to be evaluated regardless of the level of contribution by the source to the problem or its impact on the areas ability to attain.² The BACT analysis is a required component of a Serious State Implementation Plan (SIP).³ ADEC sent an email to Mr. Fish at Aurora on May 11, 2017 notifying him of the reclassification to Serious and

Clean Air

¹ Federal Register, Vol. 82, No. 89, Wednesday May 10, 2017 (<u>https://dec.alaska.gov/air/anpms/comm/docs/2017-09391-CFR.pdf</u>)

² https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf, Clean Air Act 189 (b)(1)(B) and 189 (e) and CFR 51.1010(4)(i) require the implementation of BACT for point sources and precursors emissions and BACM for area sources.

³ <u>https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf</u>, Clean Air Act 189 (b)(1)(B) and 189 (e) require the implementation of BACT for point sources and precursors emissions and BACM for area sources

Adopted Aurora Energy, LLC

included a request for the BACT analysis to be completed by August 8, 2017. The BACT analysis from Aurora, which included emission units found in Operating Permits AQ0315TVP03 Revision 1, was submitted by email to the Department on March 20, 2017.

ADEC and EPA reviewed the BACT analysis provided for the Aurora Chena Power Plant and ADEC is requesting additional information to assist it in making a legally and practicably enforceable BACT determination for the source. Both the ADEC and EPA comments are enclosed in this letter. ADEC requests a response by December 22, 2017. If ADEC does not receive a response to this information request by this date, ADEC will make a preliminary BACT determination based upon the information originally provided. However, ADEC does not have the in depth knowledge of your facility's infrastructure and without additional information, may select a more stringent BACT for your facility in order to be approvable by EPA. It is ADEC's intent to release the preliminary BACT determinations for public review along with any precursor demonstrations and BACM analysis before the required public comment process for the Serious SIP. In order to provide this additional comment opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated.

After ADEC makes a final BACT determination for Aurora, it must include the determination in Alaska's Serious SIP that then ultimately requires approval by EPA.⁴ In addition, the BACT implementation 'clock' was also triggered by the EPA reclassification of the area to Serious on June 9, 2017. Therefore, the control measures that are included in the final BACT determination will be required to be fully implemented prior to June 9, 2021 - 4 years after reclassification.⁵

As indicated in a meeting on September 21, 2017 between ADEC Air Quality staff and the stationary sources affected by the BACT requirements, ADEC will also be using the information submitted or developed to support the BACT determinations for Most Stringent Measure (MSM) consideration. MSMs will be a required element of the state implementation plan if the State applies for an extension of the attainment date from EPA. Therefore, the information you submit will be used for both analyses.

ADEC appreciates the cooperation that we've received from Aurora. ADEC staff would like to continue periodic meetings to keep track of timelines and progress. If you have any questions related to this request, please feel free to contact us. Deanna Huff (email: <u>Deanna.huff@alaska.gov</u>) and Cindy Heil (email: <u>Cindy.heil@alaska.gov</u>) are the primary contacts for this effort within the Division of Air Quality.

Sincerely,

min Pal

Denise Koch, Director Division of Air Quality

⁴ <u>https://www.gpo.gov/fdsys/pkg/USCODE-2013-title42/html/USCODE-2013-title42-chap85-subchapI-partD-subpart4-sec7513a</u>
 ⁵ 40. CFR 51.1010(4)

Page 2 of 3

Adopted Aurora Energy, LLC

Enclosures:

November 16, 2017	ADEC Request for Additional Information for Aurora Energy LLC, BACT Analysis
November 15, 2017	EPA Aurora Energy - Chena Power Plant BACT Analysis Review Comments
May 11, 2017	Serious SIP BACT due date email
April 24, 2015	Voluntary BACT Analysis for Aurora Energy, LLC

cc: Larry Hartig, ADEC/ Commissioner's Office Alice Edwards, ADEC/ Commissioner's Office Cindy Heil, ADEC/Air Quality Deanna Huff, ADEC/ Air Quality Jim Plosay, ADEC/ Air Quality Aaron Simpson, ADEC/Air Quality David Fish/Aurora Energy, LLC Tim Hamlin, EPA Region 10 Dan Brown, EPA Region 10 Zach Hedgpeth, EPA Region 10

Page 3 of 3

ADEC Request for Additional Information Aurora Energy LLC. – Chena Power Plant BACT Analysis Review Environmental Resources Management Report, March 2017

November 16, 2017

Please address the following comments by providing the additional information identified by December 22, 2017. Following the receipt of the information the Alaska Department of Environmental Conservation (ADEC) intends to make its preliminary Best Available Control Technology (BACT) determination and release that determination for public review. In order to provide this additional review opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated. Additional requests for information may result from comments received during the public review period or based upon the new information provided in response to this information request.

This document does not represent a final BACT determination by ADEC. Please contact Aaron Simpson at <u>aaron.simpson@alaska.gov</u> with any questions regarding ADEC's comments.

- 1. <u>Alternative Fuel Source</u> Page 17 of the analysis indicates that it is assumed that use of another type of coal would not reduce NOx emissions, and use of an alternate fuel is considered technically infeasible, but did not include a substantive analysis. As indicated in the Approval and Promulgation the State of Washington's Regional Haze State Implementation Plan¹, the use of SNCR and Flex Fuel² was selected as BART for the TransAlta coal-fired power plant. Evaluate alternative coal sources as a potential control option for the coal-fired boilers and identify energy, environmental, and economic impacts and other costs that would affect the selection of an alternative source of coal as a technically feasible control option. Evaluate the control efficiency of alternative coal sources based on a comparison of the coal's heat content as well as nitrogen and sulfur content.
- 2. Low Excess Air (LEA) and Overfire Air (OFA) Operating at LEA involves reducing the amount of combustion air to the lowest possible level while maintaining efficient and environmentally compliant boiler operation. NOx formation is inhibited because less oxygen is available in the combustion zone. Overfire air is the injection of air above the main combustion zone. Implementation of these techniques may also reduce operational flexibility; however, they may reduce NOx by 10 to 20 percent from uncontrolled levels.³ Evaluate these technically feasible control technologies using EPA's top down approach.
- 3. <u>Additional SO₂ Control Technologies</u> The BACT analysis does not include a substantive analysis of spray-dry scrubbing, dry flue gas desulfurization, dry scrubbing, or dry sorbent injection (DSI). All of these technologies have the potential to offer SO₂ removal, and therefore must be included in the analysis. Page 32 of the analysis indicates that the combined exhaust from the Chena Power Plant is currently controlled by a common baghouse and that installation of a dry injection or spray drying operation would require the existing baghouse be retrofit with a new PM control system to accommodate the much greater PM loading produced by a dry

¹ EPA-R10-OAR-2012-0078, FRL-9675-5

² Flex Fuel is the "switch from Centralia, Washington coal to coal from the Power River Basin in Wyoming. Powder River Basin coal has a higher heat content requiring less fuel for the same heat extraction, as well as a lower nitrogen and sulfur content than coal from Centralia. Flex Fuel also required changes to boiler design to accommodate Powder River Basin coal."

³ https://www3.epa.gov/ttn/chief/ap42/ch01/final/c01s01.pdf

injection or spray dry system. It further states that the installation of such technologies would be cost-prohibitive and therefore technically infeasible. However, the BACT analysis must include rigorous site-specific evaluation of the technical feasibility and cost effectiveness of these technologies.

The EPA cost manual does not currently include a chapter covering dry sorbent injection (DSI). However, as part of their Regional Haze FIP for Texas, EPA Region 6 developed cost estimates for DSI as applied to a large number of coal fired utility boilers. See the Technical Support Documents for the Cost of Controls Calculations for the Texas Regional Haze Federal Implementation Plan (Cost TSD) for additional information. The Cost TSD and associated spreadsheets are located at: <u>https://www.regulations.gov/document?D=EPA-R06-OAR-2014-0754-0008</u>. Please update the cost analysis for these technologies and provide technical justifications for all assumptions used in the analysis submitted as part of the BACT analysis (i.e., direct and indirect contingency costs, startup costs, initial performance test costs, electricity rate, and reagent costs). Provide in the analysis: the control efficiency associated with the technologies, Captured Emissions (tons per year), Emissions Reduction (tons per year), Capital Costs (2017 dollars), Operating Costs (dollars per year), Annualized Costs (dollars per year), and Cost Effectiveness (dollars per ton) using EPA's cost manual. Please see Comments 5, 6, and 7 for additional information related to retrofit costs, baseline emissions, and factor of safety.

- 4. <u>BACT limits</u> BACT limits by definition, are numerical emission limits. However regulation allows a design, equipment, or work/operational practices if technological or economic limitations make a measurement methodology infeasible. Provide numerical emission limits (and averaging periods) for each proposed BACT selection, or justify why a measurement methodology is technically infeasible and provide the proposed design equipment, or work/operational practices for pollutant for each emission unit included in the analysis. Startup, Shutdown, and Malfunction (SSM) must be addressed in the BACT analysis. Measures to minimize the occurrence of these periods, or to minimize emissions during these periods are control options. Combinations of steady-state control options and SSM control options can be combined to create distinct control strategies. In no event shall application of BACT result in emissions of any pollutant which would exceed the emissions allowed by an applicable standard under 40 C.F.R. parts 60 (NSPS) and 61 (NESHAP).
- 5. <u>Retrofit Costs</u> EPA's Control Cost Manual indicates that study-level cost estimates (± 30 percent) should not include a retrofit factor greater than 30 percent, so detailed cost estimates (± 5 percent) is required for higher factors. High retrofit cost factors (50 percent or more) may be justified in unusual circumstances (e.g., long and unique ductwork and piping, site preparation, tight fits, helicopter or crane installation, additional engineering, and asbestos abatement). Provide detailed cost analyses and justification for difficult retrofit (1.6 1.9 times the capital costs) considerations used in the BACT analysis.
- 6. <u>Baseline Emissions</u> Include the baseline emissions for all emission units included in the analysis. Typically, the baseline emission rate represents a realistic scenario of upper bound uncontrolled emissions for the emissions unit (unrestricted potential to emit not actual emissions). NSPS and NESHAP requirements are not considered in calculating the baseline emissions. The baseline is usually the legal limit that would exist, but for the BACT determination. Baseline takes into account the effect of equipment that is part of the design of the unit (e.g., water injection and LNBs) because they are considered integral components to the unit's design. If the uncontrolled emission rate is 'soft,' run the cost effectiveness calculations using two or three different baselines.

- 7. <u>Factor of Safety</u> If warranted, include a factor of safety when setting BACT emission limitations. The safety factor is a legitimate method of deriving a specific emission limitation that may not be exceeded. These limits do not have to reflect the highest possible control efficiencies, but rather, should allow the Permittee to achieve compliance with the numerical emission limit on a consistent basis.
- 8. <u>Good Combustion Practices</u> –For each emission unit type (coal boilers, distillate boilers, engines, and material handling) for which good combustion practices was proposed as BACT, describe what constitutes good combustion practices. Include any work or operational practices that will be implemented and describe how continuous compliance with good combustion practices will be achieved.

Aurora Energy - Chena Power Plant

BACT Analysis Review Comments Report dated March 2017 – Environmental Resources Management

Zach Hedgpeth, PE EPA Region 10 – Seattle November 15, 2017

- 1. <u>Equipment Life</u> Some of the calculations¹ submitted with the analysis use a 10 year equipment life at ten percent interest rate. The analysis must use a reasonable estimate of the actual life of the control equipment for each control technology, based on the best evidence available. The analysis must also provide written basis for the interest rate assumed if it differs from the standard seven percent rate used in the EPA Air Pollution Control Cost Manual.
- 2. <u>SO₂ Control Technologies</u> The BACT analyses must include substantive analysis of the following four SO₂ control technologies, at a minimum: wet scrubbing (such as limestone slurry forced oxidation), spray-dry scrubbing, dry flue gas desulfurization (dry scrubbing), and dry sorbent injection. The BACT analysis must include rigorous site-specific evaluation of the technical feasibility and cost effectiveness of these technologies.
- 3. <u>Control Technology Availability</u> Technically feasible control technologies may only be eliminated based on lack of availability if the analysis includes documented information from multiple control equipment vendors (who provide the technology in question) which confirms the technology is not available for the emission unit in question.
- 4. <u>Basis for Costs and Assumptions</u> Documents cited in the analyses which form the basis for costs used in the analyses and assumptions made in the analyses must be provided.
- 5. <u>EPA Cost Spreadsheets</u> The EPA has recently updated the cost manual chapters pertaining to SCR and SNCR, and developed cost spreadsheets to be used for evaluation of this technology for cost effectiveness². The cost analyses for these technologies must be consistent with the updated cost manual chapter and cost spreadsheet.
- 6. <u>Space Constraints</u> In order to establish a control technology as not technically feasible due to space constraints or other retrofit considerations, detailed site specific information must be submitted in order to establish the basis for such a determination, including detailed drawings, site plans and other information to substantiate the claim.
- 7. <u>Retrofit Costs</u> EPA Region 10 believes that installation factors which would complicate the retrofit installation of the control technology should be evaluated by a qualified control equipment vendor and be reflected in a site-specific capital equipment purchase and installation cost estimate or quote. Lacking site-specific cost information, all factors that the facility believes complicate the retrofit installation of each technology should be described in detail, and detailed substantiating information must be submitted to allow reasonable determination of an appropriate retrofit factor.
- 8. <u>Potential vs. Actual Emissions</u> All BACT cost effectiveness calculations must use potential-toemit (PTE), regardless of the emission unit usage history or actual historical emission rates. The

¹ See for example, NOx cost calcs-MARCH 2017 FINAL.xlsx

² <u>https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution</u>

facility should consider operating limits in cases where certain emission units do not need to retain relatively high PTE for facility operational purposes.

9. <u>Control Efficiency</u> – Cost effectiveness calculations for each control technology must be based on a reasonable and demonstrated high end control efficiency achievable by the technology in question at other emission units, or as stated in writing by a control equipment vendor. If a lower pollutant removal efficiency is used as the basis for the analysis, detailed technical justification must be provided.

November 19, 2019 Department of Environmental Conservation

DIVISION OF AIR QUALITY Director's Office

410 Willoughby Avenue, Suite 303 PO Box 111800 Juneau, Alaska 99811-1800 Main: 907-465-5105 Toll Free: 866-241-2805 Fax: 907-465-5129 www.dec.alaska.gov

CERTIFIED MAIL: 7014 0510 0001 9932 8880 Return Receipt Requested

GOVERNOR BILL WALKER

April 24, 2015

Adopted

David Fish, Environmental Manager Aurora Energy, LLC 100 Cushman St., Ste. 210 Fairbanks, AK 99701

THE STATE

oţ

Subject: Voluntary BACT Analysis for Chena Power Plant

Dear Mr. Fish:

Portions of the Fairbanks North Star Borough are in nonattainment with the 24-hour National Ambient Air Quality Standard for Fine Particulate Matter (PM 2.5). The Alaska Department of Environmental Conservation (ADEC) expects that the Environmental Protection Agency (EPA) will change the nonattainment designation from a Moderate Area to a Serious Area in June 2016. Once EPA designates the area as Serious, an 18-month clock begins for submittal of an implementation plan that includes best available control technologies (BACT) analysis and determination for stationary sources with over 70 tons per year (TPY) potential to emit (PTE) for PM2.5 or its precursors.

ADEC has neither the funding nor the in depth knowledge of your facility's infrastructure to determine the most appropriate BACT for your facility. Without the information or resources necessary to conduct detailed cost analysis and produce supporting documentation, ADEC may select a more stringent BACT for your facility in order to be approvable by EPA. In addition, 18 months is likely not adequate to complete a thorough BACT analysis.

Therefore, ADEC requests that your facility voluntarily begin the BACT analysis. We request that you submit an initial BACT analysis to ADEC by December 2015 and the final BACT analysis by March 2016 to ADEC. ADEC is required to make a BACT determination for every eligible facility within the designated PM2.5 nonattainment area and final BACT determinations are ultimately reviewed by EPA and subject to federal approval as part of the federally required PM2.5 implementation plan.

Background

EPA required that ADEC submit a State Implementation Plan (SIP) because portions of the Fairbanks North Star Borough (FSNB) are in nonattainment with the health based 24-hour National

Clean Air

Ambient Air Quality Standard for PM2.5. ADEC submitted an initial, Moderate Area PM2.5 SIP for FNSB to EPA on December 31, 2014.

Unfortunately, this Moderate Area SIP was developed as an impracticable SIP because modeling was unable to demonstrate that attainment with the health standard was possible by December 30, 2015. Preliminary air monitoring results also indicate that FNSB will not demonstrate attainment in 2015. Attainment is calculated on a rolling three year average of the highest 98th percentile concentration at each monitor. When those monitoring results become final in May 2016 and an official three year design value is calculated, the FNSB non-attainment area will remain over the 24-hr PM 2.5 standard of 35 μ g/m³. The final determination of this design value will result in the FNSB non-attainment area being reclassified from a Moderate Area to a Serious Area¹ (40 CRF Parts 50, 51 and 93). This reclassification will happen by operation of law as outlined in Clean Air Act Sections 188 and 189. It is anticipated that the formal designation to Serious Area will occur in June 2016.

A Serious Area designation will result in several new, more stringent requirements, one of which is that all source categories in the nonattainment area that meet the BACT threshold of 70 TPY PTE for PM_{2.5} and its precursor pollutants (NOx, SO2, VOC, NH3) must be analyzed for Best Available Control Measures (BACM). As part of BACM, a Best Available Control Technologies (BACT) analysis will be required. The Serious Area BACT trigger requires the same approach as a PSD/NSR BACT project. A Serious non-attainment area BACT limit is set using a top-down analysis on a case-by-case basis taking into account energy, environmental and economic impacts, and costs. The analysis must include all emission units at the source.

The timelines for completion of the BACT analysis, subsequent BACT determination, and the submittal of the Serious Area SIP are outlined in the preamble of the Particulate Matter 10 (PM10) rule and reconfirmed in the newly proposed $PM_{2.5}$ Implementation Rule². Both rules require a completed SIP 18 months after designation to Serious. This 18 month time period does not allow enough time to thoroughly evaluate BACT, update the emission inventory, complete the modeling and allow for development and processing for a Serious Area SIP.

ADEC believes that it is best for facilities to complete the BACT analysis for their own facilities. ADEC does not have the funding to develop the analysis nor the in depth knowledge of each sources' infrastructure. ADEC would therefore base the cost analysis on the installation of control equipment without being able to factor in all the costs associated with retrofitting existing equipment. Without the detailed cost analysis and supporting documentation to support less stringent BACT options, it is doubtful that the BACT portions of the Serious SIP will be approvable without using the most stringent measures.

By requesting an early BACT analysis for facilities before the official Serious Area designation, it will help ADEC meet the following timelines and ultimately submit a Serious Area SIP to EPA by the required due date. Early analysis also has the potential to increase flexibility for each Stationary Source under the rules.

Page 2 of 3

¹ 40 CFR Parts 50,51 and 93 <u>http://www.epa.gov/airquality/particlepollution/actions.html</u>

² <u>http://www.epa.gov/airquality/particlepollution/actions.html</u>

- Serious Area SIP inventory development starts:
- BACT kick off meeting:
- Submit initial BACT results to ADEC:
- Submit complete/final BACT analysis to ADEC:
- Serious Area SIP modeling by ADEC starts:
- Serious Area designation by EPA (Expected):
- Serious Area SIP draft:
- Serious Area SIP public notice period:
- Serious Area SIP submitted by ADEC to EPA:

January, 2015 March 5, 2015 December, 2015 March, 2016 March, 2016 June, 2016 December, 2016 February, 2017 December, 2017

Meeting the BACT analysis requirements is a major component of a Serious SIP. This is a challenging issue. It is important that ADEC accurately reflect the contributions of industrial sources to the air pollution problem and the potential improvements available within this emission sector along with the other emission sources in the community.

ADEC staff would like to continue periodic meetings to keep track of timelines and progress. If you have any questions related to this request, please feel free to contact us. Deanna Huff (email: <u>Deanna.huff@alaska.gov</u>) and Cindy Heil (email: <u>Cindy.heil@alaska.gov</u>) are the primary contacts for this effort within the Division of Air Quality.

Sincerely,

and lin

Denise Koch, Director Division of Air Quality

cc: Larry Hartig, ADEC/ Commissioner's Office Alice Edwards, ADEC/ Commissioner's Office John Kuterbach, ADEC/ Air Quality Cindy Heil, ADEC/Air Quality Deanna Huff, ADEC/ Air Quality

Page 3 of 3

November 19, 2019

Adopted



December 22, 2017

Denise Koch Director, Division of Air Quality Alaska Department of Environmental Conservation PO Box 111800 Juneau, AK 99811-1800

Subject: Response to November 16, 2017 request for additional information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant by December 22, 2017

Dear Ms. Koch:

Aurora is responding to the request for additional information to supplement the Best Available Control Technology (BACT) Technical Memorandum provided to the Alaska Department of Environmental Conservation (ADEC) on March 20, 2017. In response, a detailed BACT analysis for sulfur controls is included as an addendum to the original BACT analysis. We are confident that our initial submittal and enclosed response are sufficient to make a preliminary BACT determination consistent with our selected BACT. Aurora is convinced expending additional and substantial resources to provide further analysis is not warranted considering that ADEC has established, through moderate area planning efforts, that our facility's contribution to ground level particulate matter during air quality events is minimal.

Aurora realizes that a BACT analysis must be conducted for applicable stationary sources regardless of the level of contribution to the problem or impact on the area's ability to achieve attainment. However, the request for additional information hints at the Departments next steps of requiring heat and power producers, such as Aurora, to install technology which will have minimal impact on bringing the area into attainment.

Collectively, the large stationary sources contribute less than 10% of the total PM_{2.5} concentration as illustrated by ADEC.¹ According to the moderate area planning efforts, Aurora makes up less than 1% of the contribution from large stationary sources.² The cost to mitigate Aurora's less than one percent contribution to ground-level particulate matter would require tens of millions of dollars in capital investments and annualized operating costs which would be passed on to the consumer in increased power and district heat rates. Current electric rates in the Interior are already some of the highest in the country. Market competition dictates that district heating costs are priced to be competitive with oil and natural gas. An increase in district heat

¹ Clear the Air Conference. 2017. <u>http://co.fairbanks.ak.us/transportation/Pages/AQConference2017.aspx</u>, Source Apportionment Presentation, Slide 21, accessed 11/29/2017.

² State Implementation Plan, ADEC. 2014. <u>http://dec.alaska.gov/air/anpms/comm/docs/fbxSIPpm2-5/III.D.5-PM2.5_SIP_Sections-Adopted_09.07.16.pdf</u>, pg 167 of 233. Accessed 11/29/2017.

Adopted ADEC D. Koch Page 2

rates could encourage consumers to switch to ground-level heating sources, such as oil and wood, which would exacerbate the area's air quality problems and impede local progress toward attainment.

In short, BACT is prohibitively costly, impractical, and ineffective in this situation. The implementation of additional control technology on Aurora would, at best, provide minimal benefit to air quality and would likely result in unintended consequences. Aurora believes that ADEC, EPA and Aurora could work together to identify a mechanism in the planning process that recognizes the air quality benefit of Aurora's district heating system which displaces the equivalent of over two million gallons of wintertime ground-level heating oil emissions. As such, district heating is a proven solution to Fairbanks' air quality issues. Aurora hopes that ADEC will take these points into consideration in anticipation of the Department's preliminary BACT determination for public review.

16 Wrste Sincerely, Buki Wright

President



Prepared for: Aurora Energy, LLC

Addendum to Best Available Control Technology Analysis

Chena Power Plant Fairbanks, Alaska

December 2017

www.erm.com



Addendum to Best Available Control Technology Analysis

Chena Power Plant Fairbanks, Alaska

Prepared for: Aurora Energy, LLC 100 Cushman St., Suite 210 Fairbanks, Alaska 99701-4674

December 2017

Kelley Kand

Kelley Hand Project Manager

J.D. Gibbs Partner-in-Charge

Environmental Resources Management

200 East Campus View Boulevard, Suite 200 Columbus, Ohio 43235 Phone: (513) 830-9030

TABLE OF CONTENTS

1	INT	RODUCT	ION	1
	1.1	ADDIT	TONAL SO ₂ CONTROLS SELECTED FOR EVALUATION	3
	1.2	SPRAY	´DRYER/ABSORBER	4
		1.2.1	Site-specific Considerations for Using SDA at Chena	5
	1.3	DRY S	ORBENT INJECTION	10
		1.3.1	Sorbent Type	11
		1.3.2	Flue Gas Temperature at the Injection Location	12
		1.3.3	Sorbent Particle Size	12
		1.3.4	Sorbent Injection Rate (or NSR)	12
		1.3.5	PM Control Device Type	13
		1.3.6	Flue Gas Properties	14
		1.3.7	Site-specific Considerations for Using DSI at Chena	14
	1.4	REVIE	W OF SO ₂ BACT DATABASE	17
	1.5	SUMM	ARY OF TECHNICAL FEASIBILITY	21
2	ECO	NOMIC	EVALUATION OF SO ₂ CONTROL OPTIONS	23
	2.1	SDA E	CONOMIC EVALUATION	23
	2.2	DSI EC	CONOMIC EVALUATION	24
3	DIS ENE	CUSSION RGY ASP	I OF SITE-SPECIFIC TECHNICAL, ENVIRONMENTAL, AND PECTS OF DRY SCRUBBING TECHNOLOGY USE AT CHENA	1
	POV	VER PLA	NT	35
	3.1	SUMM	ARY OF TECHNICAL FEATURES AND CHALLENGES	35
	3.2	LOCAT	TION CONSIDERATIONS	38
	3.3	ENVIR	ONMENTAL CONSIDERATIONS	39
	3.4	ENERC	<i>GY CONSIDERATIONS</i>	46

	3.5	SUMMARY OF ENVIRONMENTAL AND ENERGY CONSIDERATION	NS46
4	ANA	LYSIS OF ASPECTS RELATED TO BACT	47
	4.1	DETERMINATION OF BACT FOR SO ₂	4 8

LIST OF TABLES

Table 1. Summary of SO2 BACT Permit Reviews
Table 2. CUECost Input and Calculation Summary for SDA 25
Table 3. Annualized Cost Summary for DSI for the Combined Boiler Exhaust 30
Table 4. Annualized Cost Summary for DSI for the Large Boiler Exhaust
Table 5. Summary of Cost Effectiveness of SO ₂ Control Options
Table 6. Summary of Technical Challenges Associated with Dry SO2Scrubbing at Chena Power Plant36

LIST OF FIGURES

Figure 1.	Aerial View of Chena Power Plant.	. 2
Figure 2.	Chena Power Plant exhaust plume	44

ACRONYMS AND ABBREVIATIONS

ADEC	Alaska Department of Environmental Conservation
BACT	best available control technology
CAA	Clean Air Act
CMB	chemical mass balance
EPA	Environmental Protection Agency
FGD	flue gas desulfurization
FNSB	Fairbanks North Star Borough
ft	foot or feet
GVEA	Golden Valley Electric Association
LAER	Lowest Achievable Emission Rate
lb/hr	pound per hour
MW	megawatt
NAAQS	National Ambient Air Quality Standard
NOx	oxides of nitrogen
NSPS	New Source Performance Standards
NSR	Normalized stoichiometric ratio
OH	hydroxyl
PM	particulate matter
ppm	parts per million
PSD	Prevention of Significant Deterioration
RACT	reasonable available control technology
SIP	State Implementation Plan
SO ₂	sulfur dioxide
ton/yr	tons per year
U.S.	UnitedStates
VOC	volatile organic compounds
µg/m³	micrograms per cubic

Adopted

1 INTRODUCTION

As described in the original Best Available Control Technology (BACT) Analysis report, Aurora Energy, LLC (Aurora) operates four coal-fired boilers, three similarly-sized smaller units and one larger unit, at the facility known as the Chena Power Plant (Chena).¹ The combined exhaust from the four boilers at Chena is currently directed to a single fabric filter for control of particulate matter (PM). Figure 1 presents an aerial view of the Chena facility where the four coal-fired boilers are located. The duct work from the three smaller boilers can be seen coming out of two different buildings along 1st Avenue. The duct work from the larger boiler is not clearly visible, but comes out of a third building and connects to the other combined ducts just prior to entering the south side of the fabric filter housing. The fabric filter housing, visible as a blue structure in the figure, is one of the larger individual structures that occupies the site. The PM collected in the fabric filter is conveyed to the adjacent ash silo for storage until trucked off site.

The four Chena boilers combust low sulfur coal to achieve a sulfur dioxide (SO_2) emission rate equivalent to 0.39 pounds of SO_2 per million Btu of heat input (lb $SO_2/MMBtu$). The coal is "local" coal mined at the Usibelli Coal Mine in Healy, Alaska.

The techniques available for controlling SO_2 emissions from a coal-fired boiler include the following:

- Use of flue gas desulfurization (FGD) technology
 - Wet scrubber
 - Dry scrubber (lime injection and spray dryer/absorber)
 - Limestone or other dry sorbent injection

Most wet FGD systems employ two stages: one for fly ash removal and the other for SO₂ removal. In wet scrubbing systems, the flue gas first passes through a fly ash removal device, either an electrostatic

¹ Environmental Resources Management, Inc., Best Available Control Technology Analysis, Chena Power Plant, Fairbanks, AK, revised March 2017.







Figure 1. Aerial View of Chena Power Plant.

precipitator (ESP) or a fabric filter, and then into the SO₂ absorber. Due to cost constraints, wet FGD systems are not commonly used to reduce SO₂ emissions from boilers combusting low-sulfur coal. The original Chena Power Plant BACT Analysis presented a detailed discussion of the technical feasibility and cost of using a wet scrubber at Chena. Wet scrubbing technology was discounted as BACT in the original analysis due to the high cost-effectiveness (although many other technical challenges, such as space constraints, exist when considering wet scrubber technology at Chena). Additional discussion of FGD using a wet scrubber is therefore not needed at this time.

1.1 ADDITIONAL SO₂ CONTROLS SELECTED FOR EVALUATION

This BACT Addendum concentrates on evaluation of dry FGD technology, which consists of the spray dryer/absorber (SDA) option and the dry sorbent injection (DSI) option. In SDA or DSI operations, the SO_2 is first reacted with the sorbent, and then the flue gas passes through a PM control device.

The ability of a SDA or DSI system to achieve any reasonable degree of SO₂ control is highly influenced by the presence of other constituents in the gas stream that will compete with the calcium or sodium injected into the gas. In the case of coal-fired boiler flue gases, the primary competing constituent is chlorine. Chlorine present in the coal will form hydrochloric acid (HCl) in the flue gas and consume a portion of the injected lime. In an SDA system, actual sorbent consumption is influenced by the discharge temperature selected for the system, as this controls the amount of water sprayed into the flue gas.

The ability to employ an add-on SO₂ control system also is influenced by site-specific factors, including space limitations. Use of a SDA or DSI system in concert with the somewhat peculiar equipment orientation at Chena, i.e., four boilers controlled by a single fabric filter, would require major alterations of the existing ductwork and possibly the fabric filter. The boiler houses and ducts would need to be retrofit with various equipment items to accommodate the sorbent delivery systems and PM handling systems required by a SDA or DSI system.

The following paragraphs present an overview of these two selected dry FGD technologies in general and a description of some of the site-specific issues associated with their use at Chena.

1.2 SPRAY DRYER/ABSORBER

A U.S. EPA Air Pollution Control Technology Fact Sheet for FGD technologies states that scrubbers are capable of reduction efficiencies in the range of 50 to 98%.² The highest removal efficiencies are achieved by wet scrubbers, and the lowest by dry scrubbers (typically less than 80%). Low SO₂ loadings to a dry absorber, as are obtained when using low sulfur coal, tend to produce lower removal efficiencies, between 40% and 70%. For comparison, the Consent Decree between the Golden Valley Electric Association, Inc. (GVEA) and the US EPA (dated November 19, 2012) and the subsequent Minor Permit issued by the Alaska Department of Environmental Conservation (ADEC) specified a 30-day SO₂ emission rate of no greater than 0.10 lb/MMBtu for Healy Power Plant (Healy) Unit 2 in Healy, AK while using SDA.³ The Healy facility combusts similar coal as the Chena Power Plant, which produces an average uncontrolled emission rate of 0.39 lb SO₂/MMBtu. Achieving an emission rate of 0.10 lb SO₂/MMBtu thus represents a 74% reduction of average uncontrolled SO₂ emissions, which generally falls within the published range of performance for a SDA system.

In SDA systems, a slurry of sorbent material and water is fed to a spray dryer tower. In the tower, the slurry is atomized and injected into the gas, where droplets react with SO_2 as the liquid evaporates. This action produces a dry product that is collected in the bottom of the spray dryer and in the downstream PM removal equipment (i.e., fabric filter or electrostatic precipitator, ESP). The majority of the reaction takes place in the spray dryer. When a fabric filter is used, as the PM collects on the filter cloth, a filter cake would develop and allow the gas a second chance to react with the reagent, thus increasing utilization of the reagent and control efficiency. The fabric filter or ESP, downstream of the spray dryer, removes the PM, ash, reaction products (e.g., CaSO₃, CaSO₄, Na₂SO₄), and unreacted sorbent. The waste product can be disposed, sold as a byproduct (depending on its quality), or recycled to the slurry. Various calcium and sodium-based reagents can be utilized as sorbent. SDA systems typically inject lime because it is more reactive than limestone and less expensive than sodium-based reagents. SO2 control efficiencies

² US EPA, Air Pollution Control Technology Fact Sheet, Flue Gas Desulfurization,

EPA-452/F-03-034, <u>https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf</u>, accessed December 18, 2017. ³ Technical Analysis Report – Permit AQ0173MSS01, April 14, 2014, Golden Valley Electric Association-Healy Power Plant.

are somewhat comparable for wet limestone scrubbers and spray dry systems, however, the capital and operating cost for spray dryer systems are lower than for wet systems, because equipment for handling liquid reagent and wet waste products is not required. In addition, carbon steel can be used to manufacture the absorber because the flue gas is less humid.

It is reasonable to expect that SDA technology performance depends on the facility-specific process characteristics. The properties most important for a SDA application are an inlet gas temperature that allows the slurry to be evaporated in the flue gas (a necessity for a spray dry scrubber), adequate mixing and residence time that allow the sorbent to react with the SO_2 in the gas, and the use of a PM control device to separate the reaction products from the gas stream.

1.2.1 Site-specific Considerations for Using SDA at Chena

*Flue Gas Take-off Point--*The Chena plant employs a fabric filter to remove the PM from the combined flue gases of the four boilers operating at the site. A very short duct run, only about 10 feet, exists between the location where the flue gases are combined and the combined gas enters the fabric filter housing. At this point, the flue gas from Boiler 5 combines with the previously-combined flue gas from Boilers 1, 2, and 3. Three general SDA equipment orientations are possible for taking off flue gas for treatment in a spray dryer tower at Chena. The first orientation would take the flue gas from the point where all boiler flue gases have been combined prior to entering the fabric filter, i.e., in the 10-foot (ft) duct run. A second orientation would take the flue gas from Boiler 5 only (at some point prior to the 10-ft duct run) and provide control only of the SO₂ emitted by the larger boiler. A third orientation would take the combined flue gas as it exits the fabric filter. In any of these orientations, construction of duct work needed to deliver flue gas to the spray dryer tower would be complicated. Major changes to the gas flue flow regime would occur for any take-off point prior to the fabric filter. Major structural modifications of the fabric filter housing would be needed to accommodate a take-off point downstream of the fabric filter.

Spray Dryer Tower Location-- The Chena site is extremely congested, and very little vacant space is available for new construction. Therefore, spatial considerations are necessary when locating a spray dryer tower. A similarly sized boiler facility exists at the Golden Valley Electric Association (GVEA) plant in Healy, Alaska. The Healy Unit #2 boiler (683 MMBtu/hr) employs a SDA system, which is a similarly sized boiler

burning run-of-mine coal from Usibelli. The spray dryer tower at the GVEA plant is 34 ft 9 in in diameter and stands 36 ft 9 in from the ground with a 29 ft 4 in, 60° Cone Hopper. Because of the congested area at Chena, a spray dryer tower would have to be located on the northern boundary of the property south of the river on the east or west of the outfall house. That location would situate the tower approximately 150 to 250 ft away from the combined flue gas junction just prior to the fabric filter inlet. After exiting the spray dryer tower, the treated gas would be redirected back to the 10-ft duct run at the fabric filter inlet for removal of PM. The baghouse design for the flue gas temperature at the inlet is 350 °F. Typically, the combined flue gases are between 300 and 315 °F at the inlet of the baghouse. The outlet temperature varies between 285 and 300 °F. The optimal temperature for SO₂ removal in a SDA is 10 to 15 °C below the saturation temperature to maximize the removal of SO₂. At approximately 15% moisture of Chena's flue gas, the saturation temperature would be around 88 °C (190 °F). This would cause wet solids to deposit on the absorber and downstream equipment. For spray dry systems, the temperature of the flue gas exiting the absorber must be 10 to 15 °C (20 to 50 °F) above the adiabatic saturation temperature.⁴ The Healy plant inlet temperature is 300 °F and exists at 175 °F; however the O&M manual for the SDA references 185 °F as the outlet set point. Regardless, the long return duct run from the tower to the fabric filter would require reheating to prevent moisture from condensing out of the gas. The reheating requirements will add to the increase in energy consumption from the control technology.

In a second option, Boiler 5 flue gas would be treated independently with a SDA system. For this option, the flue gas take-off point could be closer to the boiler, but the tower itself will still need to be located at a spot with available space approximately 100 to 200 ft away, and gas reheat would still be required as described for option 1. A separate spray tower for the combined flue gases from Boilers 1, 2, and 3 would have to be situated in the same area on the north side of the property as described above with ducting between 150 and 250 ft. This configuration is essentially the same as described in option 1 and therefore is not considered independently as an option.

⁴ Ibid (Air Pollution Control Technology Fact Sheet).

A third option would place the spray dryer tower after the fabric filter. This orientation would require a second fabric filter housing to be constructed at the facility. Based on an air-to-cloth ratio of 10 ft/min for lime⁵, 0.39 lb/MMBtu SO₂ in the flue gas, a stoichiometric conversion from SO₂ to CaSO₃ (1.875), and a 75% removal efficiency, the filter area required of the secondary baghouse would be 25,000 ft². The current baghouse has a filter area of 61,000 ft² and a footprint of 35,035 ft² (not including the ducting and ID fans). Assuming the profile would be similar for the secondary baghouse, a footprint of 14,360 ft² would be required. Space is not available on Aurora's property for the installation of a second baghouse which would be about 40% the size of the current baghouse.

*Existing PM Collection and Storage Equipment--*A SDA placed upstream of the existing Chena fabric filter would have several negative operational impacts. First, the amount of additional PM generated and sent to the existing fabric filter could cause the existing filter system to clean more continuously. The baghouse cleans when the differential pressure drop between inlet and outlet reaches 6 inches water column. The baghouse currently cycles through cleaning about 24 times a day. Assuming 4% fly ash is generated at an average operating load of 220,000 ton/yr of coal (2,000 lb/hour fly ash), the increase in fly ash at the projected maximum coal input rate of 283,824 ton/yr (2,592 lb/hour fly ash) would cause the baghouse to cycle 31 times a day (24 cycles/day x 2,592 lb/hr ÷ 2000 lb/hr). The additional particulate generation could increase the ash load to the baghouse by 267 lb/hr (0.39 lb SO_2 /MMBtu at 75% removal efficiency). The additional load would increase the baghouse daily cleaning cycle to 34. The additional cycling of the system would require an increase in electrical consumption and operational maintenance.

While the particle loading could be accommodated by the existing baghouse, it is unlikely that additional airflow from added control technologies could be accommodated through the baghouse at maximum load. A stoichiometric analysis of the combustion flue gas, with 7% oxygen yields 11.1 lb of exhaust/lb of coal. The density of the exhaust air

⁵ EPA. 2002. Air Pollution Cost Control Manual: Section 6, Particulate Matter Controls. <u>https://www3.epa.gov/ttncatc1/dir1/c_allchs.pdf</u>. Research Triangle Park, North Carolina.

from the plant, based on average test data, is 0.048 lb/ft^{3.6} If a maximum projected heat input rate of 486 MMBtu/hr (283,824 ton/yr coal) were realized, the air flow through the baghouse would be 250,000 ft³/min, which is the rated capacity of the baghouse. The stoichiometric analysis does not consider air infiltration which would increase the air flow to the baghouse beyond its capacity. Additional airflow needed for add-on control technologies would exceed the design air flow of the existing baghouse.

The duct reconstruction at the flue gas take-off point as well as the point where the treated flue gas is re-introduced to the fabric filter inlet also will require additional gas-handling equipment. Therefore, the additional PM load to the fabric filter and silo would necessitate an increase in electricity consumption and operational maintenance necessary to address potential plugging and filter replacement.

A take-off point after the existing fabric filter would alleviate the excessive PM loading issue. This orientation would require that a new outlet gas duct be retrofit onto the existing fabric filter housing to deliver the outlet gas to a second fabric filter. The existing filter vents through a roof monitor (also referred to as a monovent). In order to direct the fabric filter outlet gas to a downstream SDA system, one would need to open the top of the existing filter housing, weld new gas distribution plates to the outlet plenum, and construct a single gas outlet duct. This outlet duct would then be directed to the downstream SDA system, new fabric filter, and PM silo. The structural stability of the existing filter housing may be inadequate for handling the additional stress of the gas distribution components, in which case, extensive structural reinforcement would be needed. Construction of these items would demand more space than is available. As is clearly apparent by looking at Figure 1, the site has no extra space in which to build any such equipment for PM collection and storage. Additionally, operation of such a system orientation would increase the electric consumption at the facility. The average total electrical power consumption for the SDA system at the Healy Clean Coal

⁶ Airflow Sciences Corporation. Chena PJFF Inlet Ductwork Flow Modeling. Fairbanks, Alaska. October 2015.

Project for their Healy Unit #2 during a performance test was 550.5 kW.⁷ The Chena Power Plant baghouse power consumption is 460 kW. An SDA would potentially double the pollution control load of the plant and decrease the net sales of power approximately 2.4%.

*Contamination of Collected Particulate--*The ash constituent loading would change as a result of adding sorbents used in the process. This change could render the ash unsuitable for beneficial use as a fill material. Fly ash collected at Chena is beneficially used as a construction fill material. The addition of sorbents could compromise the leaching characteristics of the ash which is a metric to determine its suitability for beneficial structural fill. Without adequate testing, there is uncertainty as to the impact of the sorbents on the leaching characteristics of the ash. Use of an SDA system downstream of the exiting fabric filter could alleviate this issue if the sorbent byproducts were addressed separately from combustion ash.

Facility Space Limitations for Ancillary Equipment-- Regardless of whether a SDA is placed upstream or downstream of the existing fabric filter, the spatial requirement of the system and auxiliary equipment will be difficult to accommodate. A SDA system would employ lime, Trona, or sodium bicarbonate as the scrubbing reagent. Extensive preliminary engineering would need to be performed to define space requirements for the scrubber tower(s); raw reagent receiving areas, piping, conveyors, and storage tanks and silos, and reagent mills; as well as similar equipment for handling the solid waste material generated in the system. The GVEA Healy plant, in addition to the SDA vessel, houses conveyors, recycle surge bin (12-ft diameter), slurry feed tank (7.5-ft diameter), slurry mixing tank (10.5-ft diameter), mill classifier, and a storage silo for the sorbent.

Much of the equipment needed for an SDA system would be large items that occupy a substantial footprint. As can be seen in Figure 1, very little unused space exists at the facility. No space exists for an enclosed spray tower, and therefore a tower would need to be sited outdoors. No space exists between the combined boiler ducts and the fabric filter (as seen in Figure 1) to insert a spray tower. Because all of these duct runs are located

⁷ Alaska Industrial Development and Export Authority. 1999. Spray Dryer Absorber System Performance Test Report, Healy Clean Coal Project. Healy, AK.
outdoors, maintaining the flue gas temperatures needed for the reaction and preventing moisture in the fabric filter will be expensive and difficult. Finally, as can be visualized by looking at Figure 1, the site does not have enough unused area to accommodate a dry material receiving operation and slurry preparation area. There is a likelihood that material receiving would have to occur on the north side of the Chena River. This would necessitate another river crossing which adds another layer of complexity to the process. Ultimately, the spatial considerations for the equipment would require a building to house the technology and heat to maintain the temperatures needed for the application. The parasitic load from electrical consumption and heating for the application would be substantial; at the least greater than 2.5% of current net generation.

1.3 DRY SORBENT INJECTION

In the utility industry, SO₂ may be removed by injecting a dry sorbent (limestone, Trona, or sodium bicarbonate are the common sorbents) into the combustion gases, typically above the burners or in the backpass before or after the air heater. Furnace DSI involves injection of the sorbent into the boiler system at a location downstream of the combustion zone through special injection ports. In DSI, the sorbent contacts the hot gas, decomposes, and reacts in suspension with SO₂ to form reaction products, such as calcium sulfate (CaSO₄), when using lime or limestone, or sodium sulfate (Na₂SO₄) when using Trona (sodium sesquicarbonate) or sodium bicarbonate. The reaction products, unreacted sorbent, and fly ash are removed at the PM control device (either an ESP or fabric filter) downstream from the boiler.

DSI has historically been used for reducing concentrations of hydrochloric acid (HCl), mercury, and sulfates (SO₃) from coal-fired boiler flue gas. Recently, DSI has seen greater use primarily as a system to comply with the Maximum Achievable Control Technology (MACT) requirements for boilers, aka, Boiler MACT. As operators began using DSI for HCl control in response to Boiler MACT, incidental removal of SO₂ was also being observed. SO₂ removal efficiencies of 30% to 70% have been reported for DSI in the utility industry when sorbent is injected and mixed at optimum conditions, and higher removals have been demonstrated in test/pilot operations. However these performance levels have yet to be widely demonstrated on a long-term continuous basis at permanent installations. For comparison, the Consent Decree between GVEA and the US EPA and the subsequent Minor Permit issued by the ADEC specified a 30-day SO₂ emission rate of no greater than 0.30 lb/MMBtu commencing

September 30, 2015 or 18 months after Healy Unit 2 first fired coal.⁸ This emission rate represents a 23% reduction of average uncontrolled SO₂ emissions through the use of a DSI system.

In practice, the reaction chemistry of a DSI system is very straight forward. As a result, some level of SO_2 removal should be obtained when conditions exist that allow the reaction to take place. The performance of a DSI system for SO_2 removal is a function of several factors:

- Sorbent type
- Flue gas temperature at the injection location
- Sorbent particle size
- Sorbent injection rate, or Normalized Stoichiometric Ratio (NSR)
 - Extent of sorbent-to-gas mixing
 - Reaction residence time prior to the PM collection device
- PM control device type
- Flue gas properties
 - \circ Concentrations of other acid gases competing with SO₂ reaction chemistry
 - Flow distribution and moisture content

Discussion of some of the more important aspects of DSI system performance is provided in the following paragraphs.

1.3.1 Sorbent Type

It is generally accepted that sodium-based sorbents (Trona and sodium bicarbonate) produce higher SO₂ removal rates than calcium-based sorbents (lime or limestone). This observation has been borne out by the operations at the Healy, AK coal-fired boiler facility. When first implemented, the DSI system at the Healy facility was based on limestone injection. After a period of operation, the limestone-based DSI system was replaced with a Trona-based system to improve performance. The Trona-based system was subsequently replaced with a sodium bicarbonate DSI system to further improve performance. As was the case at Healy, coal-fired boiler installations seem to be moving to use of the sodium sorbents to achieve SO₂ removal efficiencies of at least 40%. Therefore, no additional discussion of calcium sorbents is provided herein.

⁸ Ibid (Technical Analysis Report).

1.3.2 Flue Gas Temperature at the Injection Location

Flue gas temperature will have a direct effect on reaction kinetics. A higher efficiency can be achieved when DSI is injected at a location where the flue gas temperature is approximately 500° F, and removal becomes less as the injection location is cooler or hotter. When a sorbent particle is introduced into a hot flue gas, it decomposes to sodium carbonate and the surface area of the particle increases. As reported in a recent Technical Report, the particle surface area begins to increase at 300° F (the minimum recommended sorbent injection temperature) and peaks at 500° F (the "optimum" temperature).⁹ Above 500° F the particle structure begins to change and particle sintering may begin, effectively decreasing the activity of the particle. As the particle surface areas increases, a greater portion of the sorbent material is available to participate in the reaction with SO₂, thus producing an increased removal rate.

1.3.3 Sorbent Particle Size

Sorbent consumption and acid gas removal rates have been improved over the past several years with the understanding of the importance of uniform sorbent particle size and high sorbent surface areas. To effect these improvements, most DSI systems now employ in-line milling equipment for all sodium sorbents.

1.3.4 Sorbent Injection Rate (or NSR)

The NSR reflects the sorbent utilization rate, or the efficiency by which the injected sorbent is utilized in the SO₂ removal reaction. All else being equal, the SO₂ removal rate increases (up to an upper limit) as the NSR is increased. In addition to the particle size factor discussed above, sorbent-to-gas mixing and residence time prior to entering the PM control device will influence the NSR needed to achieve a desired removal rate. Poor mixing conditions and low residence (i.e., reaction) times will produce the situation where a greater NSR is needed to achieve the same level of performance as observed in a well-mixed, adequately timed duct system. A DSI cost model defines its typical NSR for milled Trona with an ESP as

⁹ Dr. Sahu, Ranajit, Technical Report on Dry Sorbent Injection (DSI) and Its Applicability to TVA's Shawnee Fossil Plant, Commissioned by the Southern Alliance for Clean Energy, Knoxville, TN, April 2013.

1.40 (target removal is 50%), and its typical NSR for milled Trona with a fabric filter as 1.55 (target removal is 70%).¹⁰ These NSR represent sorbent injection rates of 40% and 55% above the stoichiometric amount of Trona needed for the SO₂ reaction. When other than optimum conditions exist for DSI use (such as poor mixing or inadequate residence time), the NSR must be increased to account for less than optimum sorbent utilization. The actual performance of a DSI system can vary from 0% to 90% depending on the NSR and other operating characteristics.¹¹

A separate operating issue has been observed when DSI systems operate with a high NSR. As the NSR increases, a brown nitrogen oxide (NOx) plume begins to be generated and emitted from the stack. This situation produces an undesirable environmental impact of using a DSI system.

1.3.5 PM Control Device Type

One of the more influential DSI system parameters is the PM collection system. This influence is important because the sorbent remains available to participate in the SO₂ reaction while in the ESP or fabric filter used to collect the PM in the flue gas. A system that employs a fabric filter will inherently achieve a greater SO₂ removal rate than one that employs an ESP because a dust cake that builds on the surface of the filter bags provides additional surface area upon which the SO₂ can react. Although studies on the effect of bag cleaning mechanisms could not be found, a pulse air jet bag cleaning system would appear to produce a lesser (secondary) SO₂ removal rate than a shaker system due to the fact that the pulse air system is designed to periodically completely break the dust cake from the cloth, as opposed a shaker cleaning system in which some remnant dust particles would remain on the surface and in the weave of the cloth after cleaning.

 ¹⁰ Sargent & Lundy, IPM Model – Updates to Cost and Performance for APC Technologies, Dry Sorbent Injection for SO₂ Control Cost Development Methodology (Final report), prepared for Systems Research and Applications Corporation, March 2013.
 ¹¹ Ibid (Sargent & Lundy).

1.3.6 Flue Gas Properties

The ability of DSI system to achieve any reasonable degree of SO_2 control is highly influenced by the presence of other constituents in the gas stream that will compete with the sodium injected into the gas. In the case of coal-fired boiler flue gases, the primary competing constituent is chlorine. Chlorine present in the coal will form HCl in the flue gas and consume a portion of the injected sorbent. Careful consideration of the chlorine content of the coal, therefore, is needed when sizing the system and defining the NSR.

Distribution of flow with the flue gas duct work is important for at least two reasons: 1) the distribution influences in-duct mixing, and 2) flow distribution may contribute to sorbent deposition within the duct or impaction and plating upon the walls. Many DSI equipment vendors offer Computational Fluid Dynamic (CFD) modeling of plant duct flows to predict and enhance sorbent distribution in flue gas, thereby maximizing performance and minimizing sorbent usage.

1.3.7 Site-specific Considerations for Using DSI at Chena

Two aspects of boiler operation at Chena are good for considering a DSI system: 1) the facility uses a fabric filter for PM control, which improves DSI performance by allowing for continued contact between SO₂ and sorbent, and 2) the flue gas temperature entering the fabric filter is approximately 300° F, which is near the minimum recommended temperature at the sorbent inject location. Some aspects of the Chena operation and site, however, are less than optimum for retrofitting a DSI system, and some of these aspects (i.e., constraints) are discussed below.

Stoker Design – Many of the initial DSI systems were demonstrated on fluidized bed combustion units and employed sorbent injection into the boiler combustion zone. Unlike a fluidized bed combustor, the old traveling grate stokers used at Chena are not designed for suspension burning. Sorbent injected into the combustion zone in a stoker unit would settle onto the stoker coal bed and become unavailable for reaction. This would result in dead burning of the sorbent. For this reason, sorbent injection would need to occur outside of the combustion zone in downstream duct locations that are cooler than in the combustion zone. As noted above, however, adequate temperature exists in other duct locations to allow DSI use at Chena. Alternative DSI System Orientations – Three basic DSI system orientations exist at Chena. Sorbent could either be injected into duct work for each individual boiler (four injection locations), a single injection location where all four duct systems converge just prior to entering the fabric filter, or at two locations – one for the large boiler and one for the three combined small boilers. The simplest of these options would be a single injection point. This option could, however, impact sorbent utilization (see NSR discussion below). Regardless of the selected orientation, a DSI system could be provided that employs a single sorbent receiving and storage area and associated conveying system with or without splitters to convey sorbent to more than one injection location. Assuming that the sorbent is milled in-line, immediately prior to injection, at least two sorbent mills would be needed for each injection location (one mill for use and one redundant mill). Therefore, between two and eight sorbent mills (depending on the number of injection points and ease of moving redundant equipment between injection points when needed) would be required depending on the DSI system orientation.

Factors Influencing NSR – The congested site layout will potentially adversely impact the amount of sorbent needed (i.e., NSR) to achieve reasonable reductions using DSI. Figure 1 previously showed the arrangement of flue gas duct work for Boiler 1, 2, and 3. Although not visible in Figure 1, these three duct systems combine with the flue gas duct work for Boiler 5 just prior to entering the fabric filter. If a single sorbent injection location is specified, this location would provide a short mixing zone with a low residence time prior to the fabric filter. Approximately 10 ft of duct is available between the location where the flue gas ducts converge and the combined gas enters the fabric filter. Gas velocities between 55 ft per second (ft/s) and 75 ft/s exist at this location, indicating that the sorbent and flue gas would be afforded only between 0.1 and 0.2 seconds of mixing/residence time prior to entering the fabric filter housing. The GVEA Healy plant's Unit #1 (305 MMBtu/hr boiler) has a 100-ft run prior to the baghouse from the injection point. Assuming GVEA maintains similar duct velocity as Chena, the GVEA DSI system operates with a reaction time of 1 or 2 seconds of mixing prior to entering the fabric filter housing. The mixing zone and residence time at the Chena plant would be very short (10 times less) in comparison and will potentially require additional sorbent be injected to achieve any sort of SO₂ removal. This will, in turn, reduce the cost effectiveness of a DSI system (i.e., increase the operating cost and reduce the removal rate).

Sorbent injection into individual boiler duct will eliminate the short mixing zone and residence time, but this equipment orientation may also

adversely impact NSR. The flue gas from each boiler goes through several turns (up to seven) prior to entering the fabric filter housing. While this duct orientation yields good mixing, it may also promote particle deposition and plating on to the inside of the duct work, thereby causing some of the injected sorbent to be wasted and unavailable for reaction.

Existing PM Collection and Storage Equipment – Similar to the issues introduced when discussing SDA, additional PM load to the fabric filter and silo would necessitate an increase in electricity consumption and operational maintenance.

Also, potential changes to the constituent loading and leaching characteristics of the ash due to sorbent use could render the ash unsuitable for beneficial use fill material. Aurora currently provides its collected ash to developers in the area for beneficial use as a fill material. The incorporation of sorbent to the ash could alter the properties of the ash such that it no longer meets the metric used to evaluate its benefit. If the ash from the Chena plant were to be treated as a waste product, significant disposal costs would be realized through either coal ash landfill development or tipping fees at the municipal solid waste landfill.

Facility Space Limitations – A DSI system is rather simple and requires lesser space for equipment than does a SDA system. Eielson Air Force Base (EAFB) recently installed new 120,000 lb/hr steam boilers which were designed with DSI to mitigate sulfate emissions. EAFB uses sodium bicarbonate as the sorbent, which they receive via rail from Solvay Chemical in Wyoming. The system includes two silos with storage capacity of 518 tons each for the sorbent. Each silo is 37 ft tall with a diameter of 21 ft and a 70 inch cone. The silos each hold a volume of 16,777 ft³. EAFB's current rate of sorbent utilization is 1 lb of sorbent/1,600 lb of steam. At that rate, Aurora could expect a maximum use of 220 lb of sorbent/hr (350,000 lb steam/hr). The location of the injection point is at the outlet breaching of the boiler and the temperature of the flue gas at that point is 450°F. As previously discussed, 500°F at the injection point is optimal. While the silos do not occupy an extremely large area, the only available area on the Chena site would be in the northwest corner of the property. An adequate space exists in the northwest portion of the Chena site, but space for truck traffic to deliver the sorbent is extremely limited and may prevent actual truck movement in this area of the facility. Sorbent receiving would likely be sited north of the Chena River along with the coal receiving facilities. Sorbent would have to be received by rail or truck and conveyed across the river to storage silos on the south side of the river.

1.4 REVIEW OF SO₂ BACT DATABASE

The RACT/BACT/LAER (RBLC) Clearinghouse was searched again for this addendum (an original search was conducted and reported in the original BACT report) to identify similar sources with SO₂ BACT determinations within the past 10 years. The RBLC Clearinghouse lists 23 facilities with large (i.e., greater than 250 MMBtu/hr) coal-fired boilers with SO_2 BACT determinations and two facilities with small (i.e., less than 100 MMBtu/hr) coal-fired boilers with SO₂ BACT determinations. Table 1 summarizes the projects in the database search that are pertinent to the Chena Power Plant BACT Analysis. One additional facility is included, the Healy Power Plant, but was not identified in the RBLC search. When looking at reported performance at existing operations, one must acknowledge that the level of control claimed at existing facilities using SDA and DSI or as reported in the Clearinghouse database may not have actually been demonstrated by the facility and may not be achievable at the Chena facility. Additionally, other systems may have been installed that are not yet included in the RBLC Clearinghouse.

Ten of the 23 determinations for large boilers were for SDA and/or DSI systems, and the range of control reported for these determinations was:

- SDA: 0.06 to 0.10 lb/MMBtu (five facilities)
- DSI: 0.035 to 0.3 lb/MMBtu (four facilities)
- Combination SDA/DSI: 0.055 to 0.075 lb/MMBtu (three facilities)

Table 1. Sur	nmary of SO ₂	BACT Permi	Reviews
--------------	--------------------------	------------	---------

							Cont	rol Me	ethod	Desc	riptio	n		
Search Criteria	Facility ID	Facility Name	Permit Issuance	Process Name	Combustion Practices	Low Sulfur Coal	Wet FGD	Limestone Forced Oxidation	Dry FGD	FGD - Scrubber	Dry FGD - Spray Dry Adsorber	Limestone Injection ⁽¹⁾	Circulating Dry Scrubber	
Permit Date = 1/1/2007 to 10/24/2017	AR-0094	John W. Turk Power Plant	11/5/2008	6,000 MMBtu/hr PRB sub-bituminous pulverized coal (PC) boiler							X			0.08 lb/MM
Process = coal-fired,														weight sulfu (PSD and Ca
>250 MMBtu/hr	AZ-0055	Navajo Generating Station	2/6/2012	3, 7,725 MMBtu/hr PC boilers						X				
Pollutant	CA-1206	Stockton Cogen Company	9/16/2011	730 MMBtu/hr coal-fired circulating fluidized bed (CFB) boiler								X		70% remova
Name = SO_2	IA-0091Ottumwa Generating Station2/27/2007			6,370 MMBtu/hr coal-fired Boiler #1		x								1.2 lb/MMB
	KY-0100	J.K. Smith Generating Station	4/9/2010	3,000 MMBtu/hr CFB boilers CFB1 and CFB2							x	x		0.075 lb/MM (Based on PF SO ₂ /MMBtu
	MI-0389	Karn Weadock Generating Complex	12/29/2009	8,190 MMBtu/hr PRB coal or 50/50 blend PC boiler		x		x						Permit termi 0.06 lb/MMI
	MI-0399	Detroit EdisonMonroe	12/21/2010	7,624 MMBtu/hr coal-fired Boiler Units 1, 2, 3 and 4			x							0.107 lb/MN
	MI-0400	Wolverine Power	6/29/2011	2, 3,030 MMBtu/hr, petcoke/coal-fired CFB Boilers (CFB1 & CFB2)							x			0.06 lb/MMI shutdown
	MO-0077	Norborne Power Plant	2/22/2008	(Excluding Startup & Shutdown) Supercritical PC boiler with steam turbine generator with a nominal net electric output of 689 MW					X					
	ND-0024	Spiritwood Station	9/14/2007	1,280 MMBtu/hr lignite coal-fired atmospheric CFB boiler							x	x		0.06 lb/MMI 98.7% remov 98.8% remov

Emission Limit
Btu, 30-day average
MBtu when burning coal <= 0.45% by r content.
se-by-Case MACT permit decision.)
· · · · · · · · · · · · · · · · · · ·
l (3-hr average)
tu, 3-hr rolling average
jected at \$29,797/ton (2007 dollar basis).) ⁄IBtu, 30-day average
RB coal - 0.54% S; bituminous coal - 1.58% S; and 1.4 lb 1 at wet FGD inlet.)
inated due to legal challenge.
Btu, 30-day rolling average
1Btu each, 24-hr rolling average
Btu, 30-day rolling average; excluding startup &
Btu, 30-day rolling average;
val for worst case 30-day lignite; val for worst case 24-br lignite

Table 1. Summary of SO2 BACT Permit Reviews (continued)

				Control Method Description										
Search Criteria	A Facility Facility Permit Process ID Name Issuance Name		Process Name	Combustion Practices	ow Sulfur Coal	Vet FGD	imestone Forced Dxidation	Dry FGD	GD - Scrubber	Dry FGD - Spray Dry Adsorber	imestone njection ⁽¹⁾	Circulating Dry Scrubber		
	OH-0310	American Municipal Power Generating Station	10/8/2009	2, 5,191 MMBtu/hr, PC boilers			x	IU	I					0.15 lb/MM 0.184 lb/MN 0.2400 lb/M
	OH-0314	Smart Papers Holdings, LLC	1/31/2008	420 MMBtu/hr coal-fired pulverized dry bottom boiler and 249 MMBtu/hr coal-fired spreader stoker coal-fired boiler										Admin perm 1.7 lb/MMB
	OK-0118	Hugo Generating Station	2/9/2007	750 MW coal-fired steam EGU boiler (HU-Unit 2)			Х							0.065 lb/MN
	PA-0257	Sunnyside Ethanol, LLC	5/7/2007	496.8 MMBtu/hr coal-fired CFB boiler					Х			Х		0.2 lb/MMB
	TX-0554	Coleto Creek Unit 2	5/3/2010	6,670 MMBtu/hr PRB coal-fired Boiler Unit 2							Х			0.06 lb/MM
	TX-0577	White Stallion Energy Center	12/16/2010	3,300 MMBtu/hr coal & pet coke-fired CFB Boiler							x			0.114 lb/MN 0.086 lb/MN 0.063 lb/MN
	TX-0585	Tenaska Trailblazer Energy Center	12/30/2010	8,307 MMBtu/hr sub-bituminous coal-fired boiler			x							0.06 lb/MM
	TX-0593	Texas Clean Energy Project	12/28/2010	400 MW PRB coal-fired Integrated Gasification Combined Cycle power plant	х									10 ppm sulft
	TX-0601	Gibbons Creek Steam Electric Station	10/28/2011	5,060 MMBtu/hr coal-fired boiler			X							1.2 lb/MMB
	UT-0070	Bonanza Power Plant Waste Coal Fired Unit	8/30/2007	2, 1,445 MMBtu/hr waste coal/bituminous blend-fired CFB boiler							X	Х		0.055 lb/MN
	VA-0311	Virginia City Hybrid Energy Center	6/30/2008	2, 3,132 MMBtu/hr coal and coal refuse-fired CFB boilers (Sulfur content of coal/coal refuse to CFB boilers not to exceed 2.28% as-fired and 1.5% on annual basis)								x		0.035 lb/MN 0.029 lb/MN 0.022 lb/MN
	WY-0063	Wygen 3	2/5/2007	1,300 MMBtu/hr sub-bituminous coal-fired PC boiler					Х					0.09 lb/MM
	WY-0064	Dry Fork Station	10/15/2007	Coal-fired PC Boiler (ES1-01)									X	0.07 lb/MM

Emission Limit
Btu, 30-day rolling average;
/Btu, 24-hr rolling average;
MBtu, 3-hr average
nit mod 10/09 to add Case-by-Case MACT for Boilers
tu
/Btu, 30-day rolling average
tu, 30-day rolling average
Btu, 30-day rolling average
/Btu pet coke, 30-day rolling average;
/Btu, pet coke 12-mo rolling average;
/Btu coal, 30-day and 12-mo rolling average
Btu, 30-day rolling average
ur in syngas
tu
ABtu, 30-day rolling average
/Btu, 3-hr average;
/Btu, 24-hr average;
/Btu, 30-day rolling average
Btu, 12-mo rolling average
Btu, 12-mo rolling average

Table 1. Summary of SO₂ BACT Permit Reviews (continued)

							Cont	rol Met	hod Des				
Search Criteria	Facility ID	Facility Name	Permit Issuance	Process Name	Combustion Practices	Low Sulfur Coal	Wet FGD	Limestone Forced Oxidation	Dry FGD FGD - Scrubber	Dry FGD - Spray Drv Adsorber	Limestone Injection ⁽¹⁾	Circulating Dry Scrubber	
	N/A (not in RBLC)	Golden Valley Electric Association – Healy Power Plant (HPP)	11/19/2012 Consent Decree and 4/14/2014	2, existing PC-fired steam generators: a 25 MW Foster-Wheeler Boiler (Unit #1) and a 50 MW TRW Entrained Combustion System PC-fired steam generator (Unit #2).							x		Unit #1 (DSI - Improve e after Unit #2 - After 1/1/ rolling avera
			Minor Permit							X			Unit #2 (SD. - SO ₂ emissi
Permit Date = 1/1/2007 to 10/24/2017 Process = coal-fired, <100 MMBtu/hr	OH-0315	New Steel International Inc., Haverhill	5/6/2008	6, 60 MMBtu/hr waste heat, PC boilers						x			0.1760 lb/M The facility i NOx, SO ₂ , ar furnaces was PM ₁₀ was us used for all I instead.
Pollutant Name = SO ₂	VA-0309	Georgia Pacific Wood Products - Jarratt	5/15/2008	86.6 MMBtu/hr coal-fired Keeler Boiler	x	Х							

1. Limestone Injection presumed to be equivalent to DSI.

Emission Limit

[system):

xisting DSI system no later than 9/30/2015 or 18 months 2 first fires coal after 11/19/2012 whichever is later. 2016, SO₂ emission limit of 0.30 lb/MMBtu, 30-day age A system):

ion limit of 0.10 lb/MMBtu, 30-day rolling average

/MBtu as a rolling 3-hour average

is non-attainment for $PM_{2.5}$ and PSD for PM, PM_{10} , CO, nd VOC. A production rate restriction on the electric arc as requested to keel lead below PSD and Title V thresholds. sed as the limit in the permit. However, since $PM_{2.5}$ was LAER determinations the limits were entered under PM_{2.5}

It should be noted that SDA or DSI were required only on circulating fluidized bed (CFB) or pulverized coal (PC) boilers. In contrast, the Chena boilers are stoker boilers for which the boiler operation is quite different than a CFB or PC boiler and present unique retrofit challenges. In addition, the sizes of these units range from approximately 2 to 25 times larger than the large Chena boiler.

One small boiler was identified with an SDA system required to meet 0.1760 lb SO_2/MMBtu.

1.5 SUMMARY OF TECHNICAL FEASIBILITY

Regardless of the achievable level of control afforded by a dry scrubbing system, this control technology (SDA and DSI) is considered technically feasible for controlling SO₂ emissions from coal fired boilers, and the RBLC identifies several in use on larger coal-fired boilers. A detailed evaluation of constraints posed by site-specific factors, however, is needed before either specific technology can be considered feasible for use at the Chena facility. These detailed site-specific evaluations/design factors are beyond the scope of the current BACT analysis.

In the absence of a detailed control system design for Chena, a level of 0.10 lb SO₂/MMBtu was selected for SDA for the BACT analysis, which is comparable with that required for the Healy Unit #2. This represents a 74% reduction from Aurora's actual SO₂emission rate of 0.39 lb/MMBtu. Independent discussions with SDA equipment vendors, however, indicate that vendors do not like to select design removal rates above 0.12 lb/MMBtu (equivalent to 70% removal). The Healy performance requirement is considered most relevant to Chena because the boilers at Healy are of similar size to Chena's and the coal feed is the same.

Selection of an appropriate design basis for a DSI system for Chena is much less straight forward. One primary reason is that DSI systems reported in the RBLC Clearinghouse are for lime injection into fluidized bed combustors, which are very different that the Chena stokers. A DSI system performance level of 0.30 lb SO₂/MMBtu has been specified for the Healy DSI system, representing a 23% reduction from average uncontrolled SO₂ emissions. Interestingly, the Technical Analysis Report (TAR) for Healy Permit AQ0173MSS0, which requires the facility to "improve" the DSI system performance currently on Healy Unit No. 1, specifies the improved emission rate of 0.30 lb SO₂/MMBtu. This statement in the TAR, therefore, suggests that the original Healy DSI system was achieving less than 23% reduction of SO₂. Literature, however, commonly reports a lower end of DSI system performance at 40%, and discussions with vendors indicate that this level of removal (without knowing the exact coal used) is generally achievable using DSI. Because of discrepancies in reported DSI system performance, therefore, one could easily define DSI system performance when using Usibelli coal as less than 23% removal. For the current assessment, DSI system performance was selected to be between 0.23 and 0.30 lb SO₂/MMBtu (i.e., between 23% and 40% removal).

2 ECONOMIC EVALUATION OF SO₂ CONTROL OPTIONS

Despite the technical challenges described in Section 1 associated with installation of SDA or DSI at the Chena Power Plant, an economic evaluation was prepared for each technology under the assumption that these challenges could possibly be mitigated during a detailed design.

2.1 SDA ECONOMIC EVALUATION

Capital and operating costs associated with the installation of a SDA system are based on cost estimating procedures developed by U.S. EPA in the Coal Utility Environmental Cost (CUECost) tool. The CUECost tool is an Excel workbook (an interrelated set of spreadsheets) that produces rough-order-of-magnitude (ROM) cost estimates (+/-30% accuracy) of the installed capital and annualized operating costs for air pollution control systems installed on coal-fired power plants, including those to control emissions of SO₂. The SO₂ emission control technologies currently in the workbook include: limestone FGD system with forced oxidation (i.e., wet scrubber) and lime spray drying FGD system (i.e., dry scrubber).

The wet scrubber portion of the CUECost tool was used in the original BACT Analysis. The spray drying portion of the tool was used for this addendum and was used for two scenarios – control of the combined boiler exhaust and control of the large boiler exhaust only. The CUECost tool included the following site-specific information:

- Net Plant Heat Rate (Btu/kWhr) = 11,571
- Retrofit Factor = 2.0 (difficult)
- Coal ultimate and proximate analysis data and ash analysis data obtained from http://www.usibelli.com/Coal-data.php
- Site specific SO₂ emission rate
 - Combined exhaust = 0.39 lb SO₂/MMBtu
 - Large boiler only = 0.32 lb SO₂/MMBtu
- Reagent price is \$215/ton delivered
- Cost basis = 2015
- SO₂ removal required = 74 percent
- Annual SO₂ removed based on full load at 8,760 hr/year

All other values used were default values.

No attempt was made to incorporate location-specific cost adjustment factors into the CUECost tool.

The cost-effectiveness of the SO₂ control system is calculated in the CUECost tool by dividing the total annual cost by the annual (potential) tons of pollutant removed. Costs were corrected to 2015 dollars using the Chemical Engineering Composite Price Index. Table 2 presents a summary of the CUECost inputs and calculation summary for the lime spray dryer scrubber.

Table 5 presents the cost effectiveness of the SDA technology (as well as the DSI technology discussed in the next section).

2.2 DSI ECONOMIC EVALUATION

Capital and operating costs associated with the installation of a DSI system are based on a DSI cost model developed by Sargent & Lundy and referred to as the IPM Model.¹² In developing the IPM Model, the authors reviewed cost data for several DSI systems and developed a relationship for the capital costs based on the sorbent feed rate. The Total Project Cost output by the IPM Model includes the base installed cost, the fixed operating and maintenance (O&M) cost, and the variable O&M cost. The base installed cost includes:

- All equipment
- Installation
- Buildings
- Foundations
- Electrical
- Retrofit difficulty factor
- Engineering and construction management

The Model uses 2012 pricing. Escalation is not included in the estimate.

¹² Ibid (Sargent & Lundy).

CUECost								
Coal Ut	tility Environmental Cost							
Version 1, November 25, 1998 (revised 2-9-00	as CUECost3.xls)							
APC Technology Choices								
m c rechnology choices								
Description	Ilmito	Combined Exhaust	Large Reiler only					
Description	Units	Combined Exhaust	Large boller only					
FCD Process	Integer	2	2					
(1 = ISFO, 2 = ISD)	Integer	2	2					
Particulate Control	Integer	1	1					
(1 = Fabric Filter, 2 = ESP)			_					
INPUTS								
Description	Units	Combined Exhaust	Large Boiler only					
General Plant Technical Innuts								
Senerus I mate Iteration Inputs								
Location - State	Abbrev.	AK	АК					
MW Equivalent of Flue Gas to Control System	MW	142.4	74.6					
Net Plant Heat Rate	Btu/kWhr	11.571	11.571					
Plant Capacity Factor	%	65%	65%					
Total Air Downstream of Economizer	%	120%	120%					
Air Heater Leakage	%	12%	12%					
Air Heater Outlet Gas Temperature	°F	350	350					
Inlet Air Temperature	°F	80	80					
Ambient Absolute Pressure	In. of Hg	29.4	29.4					
Pressure After Air Heater	In. of H2O	-12	-12					
Moisture in Air	lb/lb dry air	0.013	0.013					
Ash Split:								
Fly Ash	%	40%	40%					
Bottom Ash	%	60%	60%					
Seismic Zone	Integer	1	1					
Retrofit Factor	Integer	2	2					
(1.0 = new, 1.3 = medium, 1.6 = difficult)								
Select Coal	Integer	8	8					
Is Selected Coal a Powder River Basin Coal?	Yes / No	No	No					
Frances in Lucreto								
<u>Economic inputs</u>								
Cast Basis, Vaar Dellars	Vaar	2015	2015					
Sevice Life (levelization period)	Vors	10	10					
Inflation Rate	%	3%	3%					
After Tax Discount Rate (current \$'s)	%	9%	9%					
AFDC Rate (current \$'s)	%	11%	11%					
First-year Carrying Charge (current \$'s)	%	22%	22%					
Levelized Carrying Charge (current \$'s)	%	17%	17%					
First-year Carrying Charge (constant \$'s)	%	16%	16%					
Levelized Carrying Charge (constant \$'s)	%	12%	12%					
Sales Tax	%	6%	6%					
Escalation Rates:								
Consumables (O&M)	%	3%	3%					
Capital Costs:								
Is Chem. Eng. Cost Index available?	Yes / No	Yes	Yes					
If "Yes" input cost basis CE Plant Index.	Integer	578.4	578.4					
If "No" input escalation rate.	%	3%	3%					
Construction Labor Rate	\$/hr	\$60	\$60					
Prime Contractor's Markup	%	3%	3%					
Operating Labor Kate	\$/hr	\$63	\$63					
Power Cost	Mills/kWh	25	25					
Steam Cost	\$/1000 lbs	3.5	3.5					

Table 2. CUECost Input and Calculation Summary for SDA

Note: 'MW Equivalent of Flue Gas to Control System' is heat input capacity converted to MW.

	1		
Lime Snrau Druer (LSD) Innuts			
SO2 Removal Required (removal required to reach 0.1 lb/MMBtu)	%	74%	69%
Adiabatic Saturation Temperature	°F	127	127
Flue Gas Approach to Saturation	°F	20	20
Sprav Drver Outlet Temperature	°F	147	147
Reagent Feed Ratio	Factor	0.76	0.70
(Mole CaO / Mole Inlet SO2)			
Recycle Rate	Factor	30	30
(lb recvcle / lb lime feed)			
Recvcle Slurry Solids Concentration	Wt. %	35%	35%
Number of Absorbers	Integer	1	1
(Max. Capacity = 300 MW per spray dryer)			
Absorber Material	Integer	1	1
(1 = allov, 2 = RLCS)			
Spray Drver Pressure Drop	in. H2O	5	5
Reagent Bulk Storage	Days	60	60
Reagent Cost (delivered)	\$/ton	\$215	\$215
Dry Waste Disposal Cost	\$/ton	\$30	\$30
Maintenance Factors by Area (% of Installed Cost)			
Reagent Feed	%	5%	5%
SO2 Removal	%	5%	5%
Flue Gas Handling	%	5%	5%
Waste / Byproduct	%	5%	5%
Support Equipment	%	5%	5%
Contingency by Area (% of Installed Cost)			
Reagent Feed	%	20%	20%
SO2 Removal	%	20%	20%
Flue Gas Handling	%	20%	20%
Waste / Byproduct	%	20%	20%
Support Equipment	%	20%	20%
General Facilities by Area (% of Installed Cost)			
Reagent Feed	%	10%	10%
SO2 Removal	%	10%	10%
Flue Gas Handling	%	10%	10%
Waste / Byproduct	%	10%	10%
Support Equipment	%	10%	10%
Engineering Fees by Area (% of Installed Cost)			
Reagent Feed	%	10%	10%
SO2 Removal	%	10%	10%
Flue Gas Handling	%	10%	10%
Waste / Byproduct	%	10%	10%
Support Equipment	%	10%	10%

SUMMARY OF COSTS			
Develotion	Theire	Continuit	Lease Dellas entre
Description	Units	Combined Exhaust	Large boller only
ADC Technologies			
APC Technologies		ICD	ICD
SO2 Control		LSD	LSD
		Combined Exhaust	Large Poiler only
602 Combral Cooks		Combined Exhaust	Large Doner only
SU2 Control Costs			LSD
Total Capital Requirement (TCR)	\$ (1 1 4 7	\$74,161,357	\$62,173,057
First Veer Costs	\$/ KVV	\$521	\$833
First Tear Costs	¢	¢2 700 419	¢0.7(7.089
Fixea O&M	۵ ۵ (۱.۱۸۷ کرم	\$3,709,418	\$2,767,988
	۵/ ۲۷۷- ۱۲ Millo / ۱۹۸/۱۹	26.05	57.10
	f /tan 602 armana d	4.37	0.52 ¢17.251.0
Variable OSM	\$7 ton 502 removed	\$9,209.4 \$415.100	\$17,551.0
Variable 0.61vi	Φ ¢/LW/Vr	2 92	\$203,435
	φ/ KVV-11 Millo /LM/LI	0.51	0.48
	\$ /top SO2 removed	\$1.039.5	\$1 275 2
Fixed Charges	\$	\$1,039.5	\$1,275.2
Tixeu Churges	\$/LW_Vr	116.14	185.85
	Mills/kWH	20.40	32.64
	\$/ton SO2 removed	\$41,415,5	\$86,909,6
τοται	\$	\$20,662,501	\$16 836 015
TOTHE	\$/kW-Yr	145.10	225.68
	Mills/kWH	25.48	39.64
	\$/ton SO2 removed	\$51,744	\$105,536
Levelized Current Dollars	¢, ton 502 femo (cu	<i>401)/11</i>	\$100,000
Fixed O&M	\$/kW-Yr	30.11	42.89
	Mills/kWH	5.29	7.53
	\$/ton SO2 removed	\$10,737.6	\$20,056.1
Variable O&M	\$/kW-Yr	3.37	3.15
	Mills/kWH	0.59	0.55
	\$/ton SO2 removed	\$1,201.6	\$1,474.0
Fixed Charges	\$/kW-Yr	88.01	140.85
	Mills/kWH	15.46	24.74
	\$/ton SO2 removed	\$31,386.6	\$65,864.3
TOTAL	\$/kW-Yr	121.49	186.89
	Mills/kWH	21.34	32.82
	\$/ton SO2 removed	\$43,325.8	\$87,394.4
Levelized Constant Dollars			
Fixed O&M	\$/kW-Yr	26.05	37.10
	Mills/kWH	4.57	6.52
	\$/ton SO2 removed	\$9,289.4	\$17,351.0
Variable O&M	\$/kW-Yr	2.92	2.73
	Mills/kWH	0.51	0.48
	\$/ton SO2 removed	\$1,039.5	\$1,275.2
Fixed Charges	\$/kW-Yr	60.93	97.51
	Mills/kWH	15.20	24.32
TOTAL	\$/ton SO2 removed	\$30,863.7	\$64,767.1
IOIAL	\$/kW-Yr	89.90	137.34
	Mills/kWH	20.29	31.32
	\$/ton SO2 removed	\$41,192.6	\$83,393.3

The O&M cost includes:

- Fixed
 - Operating labor for the DSI system (two operators needed)
 - Maintenance materials and labor
 - o Administrative labor
- Variable
 - Sorbent use
 - Waste production and disposable cost
 - o Additional required power

The IPM Model used for this addendum included two equipment orientations: 1) sorbent injection into the combined boiler exhaust just immediately prior to the fabric filter, and 2) sorbent injection into the individual exhaust from the large boiler near the combustion zone. The IPM Model tool included the following site-specific information:

- Gross heat input
 - Combined = 486 MMBtu/hr
 - Large boiler = 255 MMBtu/hr
 - Small boilers = 77 MMBtu/hr each
- Retrofit Factor = 2.0 (difficult)
- Location Adjustment Factor = 2.2 (for Fairbanks, Alaska)
 - The location adjustment factor (LAF) is applied to the base installed cost and reflects the average statistical differences in normal labor, material, and equipment costs for similar facilities built in different geographical locations. The factor also makes allowances for weather, seismic, climatic, normal labor availability, labor productivity, life support/mobilization, and contractor's overhead and profit conditions. The factor does not reflect abnormal differences due to unique site consideration, such as historical preservation.¹³ (The CUECost model has no way to accommodate this factor, and LAF was not applied for SDA.)
- Site specific SO₂ emission rate
 - o 0.39 lb/MMBtu (combined)
 - o 0.32 lb/MMBtu (large boiler only)
 - o 0.49 lb/MMBtu (each small boiler)

¹³ Programming Cost Estimates for Military Construction, UFC3-370-01, 6 June 2011.

- Cost Basis = 2015
- SO₂ removal required = 40 percent
- Annual SO₂ removed based on full load at 8,760 hr/year
- Minimum Normalized Stoichiometric Ratio (NSR) = 1.5 (to account for less than optimum mixing and residence time in the combined orientation; deposition in the individual orientation; and breaking the filter cake in all orientations.
- Sorbent price based on delivered price paid by Healy in 2015/2016

All other values used were default values.

The cost-effectiveness of the SO₂ control system is calculated in the IPM Model by dividing the total annualized operating cost by the annual (potential) tons of pollutant removed. Costs were corrected to 2015 dollars using the Chemical Engineering Composite Price Index. Table 3 and Table 4 present summaries of the IPM Model inputs and cost effectiveness calculation summaries for the DSI system.

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	142.4	< User Input
Retrofit Factor	В		2	< User Input (An "average" retrofit has a factor of 1.0.)
Gross Heat Rate	C	(Btu/kWh)	3,415	< User Input
SO2 Rate	D	(lb/MMBtu)	0.39	< User Input
Type of Coal	E		sub-bituminous	< User Input
Particulate Capture	F		Bagnouse	< User Input
Milled Trona	G		TRUE	Based on in-line milling equipment
Removal Target	н	(%)	40	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with a Baghouse = 80% Milled Trona with Baghouse = 90%
Heat Input	.l	(Btu/hr)	486 000 000	A*C*1000 or User Input
NSR	ĸ	(810,111)	1.50	 to account for less than optimum mixing and residence time in the combined orientation and breaking the filter cake in all orientations)
Trona Feed Rate	м	(ton/br)	0.34	(1 2011x10\-06)*K*A*C*D
TIONA Feed Kale	IVI	(101711)	0.34	(0.7297.0.00072606*H/K)*M
Sorbent Waste Rate	Ν	(ton/hr)	0.246	Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3. Waste product adjusted for a maximum of 5% inert in the Trona sorbent.
Fly Ash Waste Rate Include in VOM?	Ρ	(ton/hr)	0.90	(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000 For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200 Usibelli Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,50
Aux Power	Q	(%)	0.05	=if Milled Trona M*20/A else M*18/A
Trona Cost	P	(\$/ton)	451	< User Input (based on delivered price paid by Healy)
Waste Disposal Cost	S	(\$/ton)	50	 Cost approximate an example prior p
Aux Power Cost	Т	(\$/kWh)	0.09385	< User Input
Operating Labor Rate	U	(\$/hr)	63	< User Input (Labor cost including all benefits)
Location Adjusment Factor	LAF		2.2	Factor applied to Base Module Cost - Location Adjusment Factor for Fairbanks, AK from DoD Facilities Pricing Guide\2V2/, UFC 3-701-01, Change 8, July 2015.
IPM Model - Updates to Cost and Performa Sargent & Lundy LLC for USEPA.	nce for APC Technologies -	Dry Sorbent In	jection for SO2 C	control Cost Development Methodology, March 2013, prepared by
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, building,	foundations, electrical, and	retrofit difficulty		
Base Module (BM) (\$) Unmilled Trona = IF(M>25,(745000*B*M Milled Trona = IF(M>25,(820000*B*M*L	1*LAF),(7500000*B*LAF*M^ AF),(8300000*B*LAF*M^0.2	= 0.284) 84)	\$ 26,915,857	Base DSI module includes all equipment from unloading to injection
Total Project Cost				
A1 = 5% of BM		=	\$ 1,345,793	Engineering and construction management costs
A2 = 5% of BM		=	\$ 1,345.793	Labor adjustment for 6 x 10 hour shift premium, per diem, etc.
A3 = 5% of BM		=	\$ 1,345,793	Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = B	M + A1 + A2 + A3	=	\$ 30,953,236	Capital, engineering, and construction costst subtotal
B1 = 5% of CECC		=	\$ 1,547,662	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CEC	C + B1	=	\$ 32,500,898	Total project cost without AFUDC
B2 = 0% of (CECC + B1)		=	0	AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2		-	\$ 32,500,898	Total project cost

Table 3. Annualized Cost Summary for DSI for the Combined Boiler Exhaust

Note: 'Unit Size (Gross)' is heat input capacity converted to MW.

Table 3. Annualized Cost Summary for DSI for the Combined BoilerExhaust (continued)

Direct Annual Costs					
Fixed O&M Cost					
FOMO (\$/kW yr) = (2 additional operators)	*(2080)*U/(A*1000)	=	\$	1.84	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.01/(B*A*1000)		=	\$	0.95	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOM)	A)	=	\$	0.07	Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	l .	-	\$	2.85	Total Fixed O&M costs
Variable O&M Cost					
VOMR (\$/MWh) = M*R/A		=	\$	1.08	Variable O&M costs for Trona reagent
VOMW (\$/MWh) = (N+P)*S/A		=	\$	0.40	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWh) = Q*T*10		=	\$	0.045	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + VOM	2	=	\$	1.53	
Indirect Annual Costs			-		
Overhead (80% of total operation and main	tenance labor)	=	\$	324,909	
Administrative charges (2% of total capital	nvestment)	=	\$	650,018	8
Insurance (1% of total capital investment)		=	\$	325,009	
Property tax (1% of total capital investment)	=	\$	325,009	
Capital recovery		=	\$	5,289,521	
(16.275% of total capital investment: 10	yr at 10% interest)				
TOTAL INDIRECT ANNUAL OPERATING	COSTS	=	\$	6,914,466	Image: Image and the second
TOTAL ANNUALIZED OPERATING COS	FS (2012 \$)	-	\$	9,227,624	
Composite CE Index for 2012 (cost year of	equation)	=		584.6	.
Composite CE Index for 2015 (cost year of	review)	=		578.4	
TOTAL ANNUALIZED OPERATING COS	FS (2015 \$)	-	\$	9,129,760	
	S tons	=		830	
SO ₂ REMOVAL EFFICIENCY, %	-,	=		40	
TOTAL SO ₂ REMOVED, tons		=		332	
SO2 COST-EFFECTIVENESS, \$/ton remo	oved	=	\$	27,493	
			1		

/ariable	Designation	Units	Value	Calculation				
Unit Size (Gross)	A	(MW)	74.6	< User Input				
Retrofit Factor	В		2	< User Input (An "average" retrofit has a factor of 1.0.)				
Gross Heat Rate	C	(Btu/kWh)	3,415	< User Input				
SO2 Rate	D	(lb/MMBtu)	0.32	< User Input				
Type of Coal	E		sub-bituminous	< User Input				
Particulate Capture	F		Baghouse	< User Input				
Milled Trona	G		TRUE	Based on in-line milling equipment				
Removal Target	н	(%)	40	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with a Baghouse = 80% Milled Trona with Baghouse = 90%				
Heat Input	J	(Btu/hr)	255,000,000	A*C*1000 or User Input				
NSR	К		1.50	1.5 (to account for deposition in the individual orientation)				
Trona Feed Rate	М	(ton/hr)	0 147	(1.2011x10^06)*K*A*C*D				
Sorbent Waste Rate	N	(ton/hr)	0.106	(0.7387-0.00073696'H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3. Waste product adjusted for a maximum of 5% inert in the Trona sorbent.				
Fly Ash Waste Rate nclude n VOM?	Ρ	(ton/hr)	0.47	(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV) For Biturninous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000 For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200 Usibelil Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,560				
Aux Power Include in VOM?	Q	(%)	0.04	=if Milled Trona M*20/A else M*18/A				
Trona Cost	R	(\$/ton)	451	< User Input (based on delivered price paid by Healy)				
Waste Disposal Cost	S	(\$/ton)	50	User Input (based on activities price pric				
Aux Power Cost	Т	(\$/kWh)	0.09385	< User Input				
Operating Labor Rate	U	(\$/hr)	63	< User Input (Labor cost including all benefits)				
Location Adjusment Factor	LAF	gies - Dry Sorbe	2.2 ent Injection for SO2	Factor applied to Base Module Cost - Location Adjusment Factor for Fairbanks, AK from DoD Facilities Pricing Guide\2\/2/, UFC 3-701-01, Change 8, July 2015. Control Cost Development Methodology, March 2013, prepared by				
Sargent & Lundy LLC for USEPA.								
Capital Cost Calculation (2012 dolla	rs)			Comments				
ncludes - Equipment, installation, build	ding, foundations, electrical,	and retrofit diff	culty					
Base Module (BM) (\$)		=	\$ 21 186 595	Base DSI module includes all equipment from unloading to injection				
Unmilled Trona = IF(M>25,(745000 Milled Trona = IF(M>25,(820000*B*	*B*M*LAF),(7500000*B*LAF *M*LAF),(8300000*B*LAF*N	- *M^0.284) 1^0.284)	φ 21,100,000					
Total Project Cost								
A1 = 5% of BM		=	\$ 1,059.330	Engineering and construction management costs				
A2 = 5% of BM		=	\$ 1,059,330	Labor adjustment for 6 x 10 hour shift premium, per diem, etc.				
A3 = 5% of BM		=	\$ 1,059,330	Contractor profit and fees				
			. ,,					
CECC (\$) - Excludes Owner's Costs	= BM + A1 + A2 + A3	=	\$ 24,364,585	Capital, engineering, and construction costst subtotal				
B1 = 5% of CECC		=	\$ 1,218,229	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)				
TPC (\$) - Includes Owners Costs = 0	CECC + B1	=	\$ 25,582,814	Total project cost without AFUDC				
B2 = 0% of (CECC + B1)		=	0	AFUDC (Zero for less than 1 year engineering and construction cycle)				
TPC (\$) = CECC + B1 + B2		=	\$ 25,582,814	Total project cost				

Table 4. Annualized Cost Summary for DSI for the Large BoilerExhaust

Note: 'Unit Size (Gross)' is heat input capacity converted to MW.

Direct Annual Costs					
Fixed O&M Cost					
FOMO (\$/kW vr) = (2 additional operational	ators)*(2080)*U/(A*1000)	=	\$	3.51	Fixed Q&M additional operating labor costs
FOMM (\$/kW vr) = BM*0.01/(B*A*1000)		=	\$	1.42	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW vr) = 0.03*(FOMO+0.4*	FOMM)	=	\$	0.12	Fixed O&M additional administrative labor costs
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	,				
FOM (\$/kW yr) = FOMO + FOMM +	FOMA	=	\$	5.06	Total Fixed O&M costs
Variable O&M Cost					
VOMR (\$/MWh) = M*R/A		=	\$	0.889	Variable O&M costs for Trona reagent
VOMM (CMM/b) = (N + D) * C/A		_	¢	0.20	Variable O&M costs for waste disposal that includes both the sorbent
00000 (\$/100001) = (14+P) 3/A		=	φ	0.39	and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWb) - 0*T*10		_	\$	0.037	Variable O&M costs for additional auxiliary power required (Refer to
		-	Ψ	0.037	Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + V	VOMP	=	\$	1.31	
Indirect Annual Costs					
Overhead (80% of total operation and	I maintenance labor)	=	\$	301,717	
Administrative charges (2% of total ca	ipital investment)	=	\$	511,656	
Insurance (1% of total capital investment)		=	\$	255,828	
Property tax (1% of total capital investment)		=	\$	255,828	
Capital recovery	10	=	\$	4,163,603	
(16.275% of total capital investment	nt: 10 yr at 10% Interest)				
				E 400 C22	
TOTAL INDIRECT ANNUAL OPERA		=	Þ	5,466,633	
	COSTS (2012 \$)	_		6 722 006	
TOTAL ANNOALIZED OF ERATING	CO313 (2012 \$)	-	ş	0,723,900	
Composite CE Index for 2012 (cost ve	par of equation)	=		584.6	
Composite CE Index for 2015 (cost year of review)		=		578.4	
				0.0.1	
TOTAL ANNUALIZED OPERATING COSTS (2015 \$)		-	\$	6.652.596	
			-	-,,	
TOTAL UNCONTROLLED SO ₂ EMIS	SIONS, tons	=		357	
SO, REMOVAL EFFICIENCY %		-		40	
		_		143	
SO COST EFFECTIVENESS		=		46 524	
SU ₂ COST-EFFECTIVENESS, \$/ton	removea	=	\$	46,534	
		1			

Table 5 presents a summary of the cost effectiveness of all SO₂ control options considered, including the wet scrubber considered in the original BACT Analysis. As seen in the individual cost model spreadsheets, the model-derived cost-effectiveness values are based on the potential SO₂ emissions from the Chena boilers. The combined SO₂ emission rate from all four boilers is equal to 814.5 tons/yr (potential) and 700 tons/yr (actual). The value for actual emissions is based 1.9 tons SO₂ per day as specified in the State Implementation Plan (SIP). Therefore, to derive cost-effectiveness values output by the cost models were adjusted by the ratio of actual emissions to potential emissions.

Table 5 presents the calculated SO_2 removal cost effectiveness on both a potential emission reduction and actual emission reduction basis. These values are not considered cost effective for the retrofit options at Chena Power Plant.

Rank	Control Option	Control Orientation	Cost Effe (\$ per ton per yea	Expected SO ₂ Emission Rate (lb/MMBtu)	
1	Low sulfur coal	combined exhaust	(alread	y used)	0.39
2	Dry scrubber – DSI	combined exhaust	27,493	31,990	0.23 (40% removal)
3	Dry scrubber – SDA	combined exhaust	41,193	47,931	0.10 (74% removal)
4	Dry scrubber – DSI	large boiler only	46,534	54,146	0.19 (40% removal)
5	Wet scrubber	combined exhaust	75,672	88,050	0.20 (50% removal)
6	Dry scrubber – SDA	large boiler only	83,393	97,034	0.10 (69% removal)

Table 5. Summary of Cost Effectiveness of SO₂ Control Options

3 DISCUSSION OF SITE-SPECIFIC TECHNICAL, ENVIRONMENTAL, AND ENERGY ASPECTS OF DRY SCRUBBING TECHNOLOGY USE AT CHENA POWER PLANT

3.1 SUMMARY OF TECHNICAL FEATURES AND CHALLENGES

Table 6 presents a summary of some technical features of SDA and DSI technologies evaluated herein and some challenges associated with their potential use at Chena. Section 1 of this report identified several SDA and DSI applications for coal-fired boilers. The quality of the information varies considerably, and the information acquired was used as best as possible to hypothesize performance expectations from each evaluated technology. Nonetheless, no true assurances exist that the evaluated technologies will actually perform as stated when applied to the Chena facility. While the technical concepts are valid, demonstration of the technology employed as retrofit technology on units and equipment orientations such as those observed at the Chena facility cannot reliably be predicted, thus raising doubts over the accuracy of technology transfer, particularly for sorbent injection. Perhaps the best example of this uncertainty can be found when reviewing the history of the DSI system operation at the Healy Power Plant in Healy, AK. The subject of a Consent Decree, Healy was ordered to "improve" the DSI system in use on Unit No. 1 to achieve a controlled SO₂ emission rate of 0.30 lb/MMBtu. Even with extensive testing under the US Department of Energy Clean Coal program, this marginal mandated performance level is indicative of technological uncertainties associated with retrofit technology applied to control coal-fired boiler emissions.

Coupled with the technological uncertainties associated with these technologies applied as a retrofit solution are other factors that obscure the practicality of applying retrofit dry scrubber technology at the Chena facility. One of these factors, the economics of the technologies, was discussed in detail in Section 2 of this report and led to the observation that application of SDA or DSI at Chena was not a cost-effective means to reduce SO₂ emissions. Other factors, discussed in the following sections, include:

- Facility location limitations
- Environmental considerations
- Energy considerations

Factor	Spray Dry Absorber Technology	Dry Sorbent Injection Technology
Demonstrated use under conditions similar to Chena Plant	 Spray dry absorber technology is available and used to reduce SO₂ emissions from coal- fired boiler flue gas streams. The U.S. EPA's air pollution control cost manual indicates that SDA technology can be reduce SO₂ by 50% up to over 90%. Finding a suitable outlet for the particulate captured in the fabric filter following dry scrubbing is an important consideration to the feasibility of this option. 	 Dry sorbent injection is becoming more prevalent for reducing acid gas concentrations in coal-fired boiler flue gas streams. Although DSI technology is discussed in the industry, the only DSI systems presented in the RBLC Clearinghouse are lime/limestone injection systems into fluidized bed combustors. No DSI systems are listed when the boiler is a stoker, as at Chena. Sorbent injection into the duct work downstream of the coal combustion zone is also becoming more prevalent in the industry, as reported by equipment vendors. No such systems, however, are presented in the RBLC Clearinghouse.
Technical considerations	 Depending on equipment orientation, a SDA system would lower the flue gas temperature, which could then cause plugging of the downstream fabric filter. A SDA system placed upstream of the fabric filters would potentially contaminate the ash and cause the loss of a useable by-product. A SDA system would require gas reheating to prevent plugging in the fabric filter, thus increasing station service load. The temperature of water used to prepare the lime slurry can impact the hydrated lime reactivity. Adequate facilities must be included (indoors) to prevent issues associated with slurry preparation, delivery, and use. The pulse jet cleaning system in the existing fabric filter will periodically break the filter cake, thus temporarily reducing the additional sorbent reaction time with SO₂ and ultimately reducing the overall SO₂ removal that can be achieved. 	 The existing duct work at Chena is very complicated and winding. Sorbent injection into a section of combined flue gas would have less than optimum mixing and less than 0.2 seconds of residence time prior to entering the fabric filter. These two situations will increase the sorbent consumption rate by reducing sorbent utilization. Sorbent injection into the large boiler alone would provide adequate mixing time, but the flue gas would continue through seven turns in which sorbent loss through deposition on the interior duct work could occur, thus increasing sorbent consumption. The pulse jet cleaning system in the existing fabric filter will periodically break the filter cake, thus temporarily reducing the additional sorbent reaction time with SO₂ and ultimately reducing the overall SO₂ removal that can be achieved. Use of sorbent materials may render the collected ash no longer suitable for use as a fill material. The current beneficial use of collected ash as a fill material would have to be replaced with landfill disposal of the collected PM.

Table 6. Summary of Technical Challenges Associated with Dry SO2Scrubbing at Chena Power Plant

Table 6. Summary of Technical Challenges Associated with Dry SO2Scrubbing at Chena Power Plant (continued)

Factor	Spray Dry Absorber Technology	Dry Sorbent Injection Technology	
Structural considerations	 The structural stability of the existing ash silo would have to be improved prior to storing any additional PM. Any system placed downstream of the existing fabric filter would necessitate major structural modifications to the existing filter housing to alter the exhaust configuration of the treated flue gas from a monovent, roof monitor arrangement to a gas duct section that delivers gas to the dry scrubber system. 		
	1. A SDA system would require additional fans to overcome the increased distance needed to convey the flue gas. The entire air emissions control systems would need to be rebalanced as well. The existing system potentially may not meet design requirements for baghouse air flow.	1. The history of DSI operation at the Healy facility of GVEA has been anything but stable. The need to retrofit the system on two different occasions draws into question the reliability of the DSI technology.	
Operational considerations	 The Chena boilers are reaching the end of their useful lives. A life extension study commissioned by Aurora determined that Chena operations could be extended to the year 2030 with expenditure of significant capital. An add-on emission control program aimed at reducing SO₂ emissions over a 10-year period represents an unwise capital expenditure at this time. The U.S. Corps of Engineers estimates that additional construction and operating costs are incurred for projects in Alaska when compared to mainland US. These considerations are difficult to assess in an analysis such as this BACT. A dry scrubber placed at the outlet of the existing fabric filter would require re-heating the exhaust gases to an optimum temperature; this would reduce steam available for power generation, heating, or station service. A second fabric filter would be then needed to remove the particulate matter formed during scrubbing. The Trona or sodium bicarbonate reagent mill would be required to produce a uniformly-sized sorbent particle prior to use. Reagent receiving and processing would likely require construction of building(s) north of the Chena River and a conveyor over the Chena River. Raw and processed materials would need to be conveyed over relatively long distances. The PM collected in the fabric filter may become a waste product and no longer able to be used as fill. 		

Factor	Spray Dry Absorber Technology	Dry Sorbent Injection Technology			
	1. A minimal amount of open space is available at the Chena facility to house additional equipment needed to support dry scrubbing technology.				
Availability of infrastructure and space for equipment	 The location of a reagent storage area for an SDA system will need to be determined. A preliminary estimate, based on a similarly-sized facility in Colorado, is that the spray tower will need to be at least 40 ft in diameter. The only available space at the Chena facility for this tower would be in the northwest corner of the facility. The flue gas would need to be rerouted approximately 250 ft to the location of the spray tower and then return another 250 ft to the inlet of the fabric filter. This gas rerouting would be needed whether the SDA was oriented as a combined flue gas treatment system or one devoted only to the large boiler. Space for additional fans would then be needed. Availability of land area for the reagent silos and slurry preparation is uncertain. 	 The short duct run after combination of flue gases makes sorbent inject extremely difficult and leads to poor mixing and short residence time. An area of approximately 50 ft x 50 ft would be needed to house the sorbent receiving and storage area. This area would need to be located in the northwest corner of the facility. This area of the facility has minimal truck traffic at present, and routine deliveries of sorbent by truck would disrupt the normal operations in the area. 			

Table 6. Summary of Technical Challenges Associated with Dry SO2Scrubbing at Chena Power Plant (continued)

These factors are discussed in the following sections. These factors also were discussed in the original BACT Analysis, and some of the discussion presented below is taken from the original analysis.

3.2 LOCATION CONSIDERATIONS

Several issues related to space limitations at Chena were presented in Section 1 or this report. An important aspect of operating on an older, small industrial site is the ability to actually place additional equipment needed to operate add-on control equipment. The SDA and DSI technologies require installation of silos for reagent storage, facilities for preparing the sorbent for treatment of the flue gas, and the technology itself must be erected in available space. The congested nature of the existing Chena Power Plant site is such that the retrofit installation costs are likely to be higher than those estimated and presented in the cost tables provided earlier. Additionally, lack of available space on site could make installation of additional equipment completely infeasible. This limitation would not be completely understood prior to preliminary design of any identified system. Each of the identified SO₂ technologies also requires routine delivery of reagents to operate the system and will require removal of residues produced by the process. The congested nature of the Chena facility makes on-site truck traffic patterns somewhat problematic. Additionally, Fairbanks is approximately 400 miles from Anchorage, which is a logical location for origination of raw materials. Delivery of necessary sorbents over potentially icy roadways may interrupt raw material deliveries to the point where interruptions in plant operations could occur. The hazardous driving conditions also may cause the transportation costs for raw materials or process equipment to be greater than presented in the cost sheets, thereby causing the cost effectiveness of control to be a larger value than calculated.

Climate considerations factor into the BACT evaluation in two ways: 1) climate causes the costs to become inflated due to the need for additional insulation, heated vessels, and heat tracing, and 2) climate affects the ability of the precursor emissions from the Chena Power Plant to react in the atmosphere and form PM_{2.5}. However, no site factors are included in the SDA control cost calculations. Thus, the SDA SO₂ control costs, while already extremely high, may be underestimated. The atmospheric factor, which may limit atmospheric reaction rates, is briefly discussed in the next section on environmental considerations.

3.3 ENVIRONMENTAL CONSIDERATIONS

Environmental factors must be considered in a BACT evaluation. With respect to nonattainment BACT, precursor control options that are determined to be economically feasible may not yield the desired objective of improving PM_{2.5} air quality. (This statement is true even though none of the control options evaluated in this BACT evaluation were found to be economically feasible.) A rash conclusion to implement a (economically feasible) precursor control as BACT may in fact produce insignificant environmental benefits and at the same time produce adverse energy or environmental impacts. The environmental topics are discussed below, and energy considerations in the following section. Much of the following discussion was presented in the original BACT Analysis.

The rationale for ensuring that benefits of a precursor control option are indeed real and significant is founded in the Clean Air Act (CAA). CAA section 189(e) explicitly requires that the control requirements applicable for major stationary sources of direct PM_{2.5} emissions must also apply to major stationary sources of PM_{2.5} precursors, unless the state provides a

demonstration that emissions of a particular precursor from major stationary sources do not contribute significantly to levels that exceed the standard in the nonattainment area of concern. Thus, the statute generally requires control of all $PM_{2.5}$ precursors in a nonattainment area, but it provides an express exception applicable to major stationary sources in such areas if an appropriate demonstration is made.¹⁴

A key conclusion derived by looking at the chemical mass balance (CMB) evaluations for PM filters collected in the Fairbanks North Star Borough (FNSB) is that control of Chena Power Plant PM_{2.5} precursors will not provide significant reduction of ambient PM_{2.5}. This conclusion can easily be validated by looking solely at the wood smoke contribution and comparing it to the PM_{2.5} standard. As is seen on many episode days, the standard is exceeded solely due to contribution from wood smoke, while the impact of sulfates on episode days is minor.

Although the CMB results included in the SIP provide some insight into establishing source contributions in the FNSB, no straightforward procedures can be used to determine a specific source contribution to ambient PM_{2.5} concentrations and, by extension, the air quality improvements in PM_{2.5} air quality should one or more control measures be implemented at the Chena Power Plant. Because no one procedure answers every question one may have, a variety of procedures are often employed. This is a key issue that relates the magnitude of reductions in daily precursor emissions to commensurate reductions in PM_{2.5} concentrations. In many cases, indirect procedures must be employed to estimate air quality benefits resulting from installation of precursor emission controls. For example, DSI (the SO₂ control option identified herein that has the best cost-effectiveness) was estimated to be able to achieve a 40 percent reduction in SO₂ emissions from the Chena Power Plant boilers. As provided in the background information for the ADEC SIP, on average, Chena Power Plant boilers emitted 1.9 ton/day of SO₂ in 2015 on days when the PM_{2.5} standard was exceeded.¹⁵ Thus, application of DSI at Chena would result in an average SO₂ reduction of 0.76 ton/day.

¹⁴ Federal Register, Volume 81, page 58091, August 24, 2016, 40 CFR Parts 50, 51, and 93, Fine Particulate Matter National Ambient Air Quality Standards: State Implementation Plan Requirements; Final Rule.

¹⁵ ADEC, Amendments to: State Air Quality Control Plan Volume II: Analysis of Problems, Control Actions; Section III: Area-wide Pollutant Control Program; D: Particulate Matter; 5: Fairbanks North Star Borough PM_{2.5} Control Plan, Section 5.06, page III.D.5.6-27.

This reduction represents only 6.2 percent of the estimated NOx and SO_2 nonattainment area-wide emissions, respectively, estimated to occur on $PM_{2.5}$ episode days in 2008.

ADEC included CMB results in the SIP to provide some insight into establishing source contributions in the FNSB.¹⁶ The CMB analysis estimated a maximum sulfate contribution of 28.8 micrograms per cubic meter (μ g/m³) (at most) in downtown Fairbanks on high PM_{2.5} concentration days between 2005 and 2013. Assuming that all of the precursor emission reductions noted above for Chena Power Plant culminate in the same level of ambient PM_{2.5} reductions, use of DSI technologies at Chena would benefit ambient air quality in downtown Fairbanks by only 1.8 μ g/m³ for sulfates (i.e., 28.8 μ g sulfate/m³ times 6.2 percent reduction in daily SO₂ emissions). The improvements on an average basis would be about half these amounts.

Another environmental factor impacting the true effectiveness of a control option is the atmospheric reaction process that leads to conversion of precursor emissions to PM_{2.5}. Three major issues must be considered when evaluating the Chena Power Plant's contribution to PM_{2.5} levels within the FNSB air basin: 1) precursor reaction chemistry in arctic wintertime conditions when exceedances of the PM_{2.5} NAAQS occur, 2) possible increases in nitrate formation as ammonium ions become available, and 3) transport and dispersion of the Chena Power Plant boiler stack plume above and beyond the capped inversion layer that encapsulates the FNSB air basin causing accumulation of ground-level PM_{2.5} within the air basin.

Formation of secondary $PM_{2.5}$ depends on numerous factors including the concentrations of precursors; the concentrations of other gaseous reactive species; atmospheric conditions including solar radiation, temperature, and relative humidity; and the interactions of precursors with preexisting particles and with cloud or fog droplets. The relative contribution to ambient $PM_{2.5}$ concentrations from each precursor pollutant varies by

¹⁶ ADEC, Amendments to: State Air Quality Control Plan SIP, Vol. III: Appendix III.D.5.7, Appendix to Volume II. Analysis of Problems, Control Actions; Section III. Area-wide Pollutant Control Program; D. Particulate Matter; 5. Fairbanks North Star Borough PM_{2.5} Control Plan, December 24, 2014, page III.D.5.7-66.

climatological area. The relative effect of reducing emissions of these pollutants is also highly variable.¹⁷

Sulfates are typically formed in the atmosphere by formation of sulfuric acid from SO_2 that subsequently reacts with ammonia to form ammonium sulfate. There are three different pathways for the transformation of SO_2 to sulfuric acid¹⁸:

- 1. Gaseous SO_2 can be oxidized by the hydroxyl radical (OH) to create sulfuric acid. This gaseous SO_2 oxidation reaction occurs slowly and only in the daytime.
- 2. SO₂ can dissolve in cloud water (or fog or rainwater), and there it can be oxidized to sulfuric acid by a variety of oxidants, or through catalysis by transition metals such as manganese or iron. If ammonia is present and taken up by the water droplet, then ammonium sulfate will form as a precipitate in the water droplet.
- 3. SO₂ can be oxidized in reactions in the particle-bound water in the aerosol particles themselves. This process takes place continuously, but only produces appreciable sulfate in alkaline (dust, sea salt) coarse particles.

These climatological conditions that are conducive to sulfate formation from transformation of SO_2 are not consistent with the conditions that typically generate high $PM_{2.5}$ concentrations in the FNSB.

Some researchers have reported an increase in nitrate formation associated with ambient SO₂ reductions. This association is strongest in low temperature areas of low humidity and exists because additional ammonium ions will become available for reaction with NOx emissions.¹⁹ Although the net PM_{2.5} concentration will likely be lower after SO₂ reductions, a linear reduction of the ambient PM_{2.5} concentration is not

 $^{^{17}}$ Federal Register, Volume 73, page 28325, May 16, 2008, 40 CFR Parts 51 and 52, Implementation of the New Source Review (NSR) Program for Particulate Matter Less Than 2.5 Micrometers (PM_{2.5}).

¹⁸ NARSTO (2004) Particulate Matter Science for Policy Makers: A NARSTO Assessment. P. McMurry, M. Shepherd, and J. Vickery, eds. Cambridge University Press, Cambridge, England. ISBN 0 52 1842875.

¹⁹ Ibid (NARSTO).

expected, and less $PM_{2.5}$ reduction will be observed than expected because of the increase in the nitrate concentration.

An issue also arises in the FNSB related to the dispersion of precursor emissions from the Chena Power Plant boiler stack and the ability of the dispersed emissions to actually impact the ambient air quality monitors. It has been observed, and it is reasonable to expect, that the boiler stack plume is carried above the winter inversion layer. As such, transport of the precursor pollutants occurs above the inversion layer, where the concentrations of the pollutants can be transported and dispersed by the stronger aloft winds. In addition, the Fairbanks PM_{2.5} Source Apportionment Research Study²⁰ concluded that dominant aloft wind direction during PM_{2.5} episodes is from the northeast, which would transport the Chena Power Plant emissions away from the ambient air quality monitors located in downtown Fairbanks and North Pole. Figure 2 presents a photograph showing the Chena Power Plant boiler stack exhaust plume height well above the inversion layer. The original BACT Analysis presented an evaluation of Chena coal consumption on high PM_{2.5} concentration days between 2013 and 2015 and revealed a very poor (or no) correlation between Chena Power Plant coal consumption and observed ambient PM_{2.5} levels. This poor correlation is believed to be due to plume entrapment above the wintertime inversion layer.

The poor correlations reported in the original BACT Analysis indicate that changes in Chena Power Plant emissions do not explain the majority of the changes in ambient $PM_{2.5}$ levels. Because the Chena Power Plant emissions are not seemingly influencing the ambient $PM_{2.5}$ concentrations to any significant extent, the ambient levels must be the result of other emission sources in the FNSB.

²⁰ The Fairbanks, Alaska PM_{2.5} Source Apportionment Research Study Winters 2005/2006-2012/2013, and Summer 2012; Final Report, Amendments 6 and 7, December 23, 2013, Tony J. Ward, Ph.D., University of Montana – Missoula, Center for Environmental Health Sciences.



Figure 2. Chena Power Plant exhaust plume.²¹

²¹ The exhaust from the Aurora Energy power plant breaks through an inversion layer as seen from the Hagelbarger Road pullout off the Steese Highway. Photo credits: Frank DeGenova, January 30, 2008, <u>http://marcvaldez.blogspot.com/2008/05/wintertime-smokestack-plumes-in.html</u>, accessed December 22, 2017.

This observation can be further illustrated using the following example for the highest $PM_{2.5}$ day (early January) in 2015 at downtown Fairbanks monitors when Chena Power Plant coal consumption was at its greatest rate (2.2 million pounds/day). If this was during one of the coldest days, then the Chena Power Plant impact at ground level would have been less than on other days because: 1) the buoyancy term for the Chena Power Plant boiler plume would be at its greatest because the temperature differential between stack and ambient air temperatures would have been greatest, and 2) the momentum term for the boiler plume would also have been at its greatest because the exhaust gas flow rate would be greater than at lesser coal combustion rates. Because the impact of Chena Power Plant emissions would likely have been less on this episode day than other days, the $PM_{2.5}$ mass on the filters in question would had to have been contributed by other sources in the FNSB.

To summarize these environmental considerations related to photochemistry and precursor transport within the FNSB, the U.S. EPA makes the following corroborating points:

"Major stationary sources with elevated stacks emit most of their precursors into the extremely stable atmosphere present during wintertime pollution events. Only a fraction of the elevated plumes returns to ground level in the FNSB where air quality monitors are located and much less than might be expected in most parts of the lower 48 states."²²

In conclusion, and as noted earlier herein, use of DSI technologies at Chena is estimated to benefit ambient $PM_{2.5}$ air quality in downtown Fairbanks by only $1.8 \ \mu g/m^3$ at the most due to reduction of ambient sulfates (i.e., $28.8 \ \mu g$ sulfate/m³ times 6.28 percent reduction in daily SO₂ emissions). The actual improvement will likely be less due to the environmental considerations noted herein. The maximum estimated sulfate improvements in $PM_{2.5}$ air quality presented here are only slightly above the U.S. EPA-recommended 24-hour significant level of $1.3 \ \mu g/m^3$ as presented in the recent Draft Precursor Guidance and could actually be less than the significant level. This reduction would possibly be accompanied by other increases in fuel combustion emissions, production

 $^{^{22}}$ Federal Register, Volume 82, page 9043, February 2, 2017, Air Plan Approval; AK, Fairbanks North Star Borough; 2006 $\rm PM_{2.5}$ Moderate Area Plan, Proposed Rule.
of a brown NOx cloud in the Chena plant stack, and elimination of the beneficial use of fly ash collected at the plant as fill material. These observations indicate that the environmental benefit of installing SO_2 controls at Chena Power Plant will produce no noticeable improvement in ambient $PM_{2.5}$ air quality and may produce negative associated environmental impacts.

3.4 ENERGY CONSIDERATIONS

Retrofit BACT as a means to reduce the pollutant load in an air basin must necessarily look at the effect that employing BACT on a specific source would have on other sources in the air basin and whether this effect would negatively impact the air quality improvement that is presumed to occur when BACT is employed. The original BACT Analysis presented a detailed discussion of energy considerations arises from the use of add-on air pollution control equipment. The reader is referred to that document for additional information regarding energy considerations for additional fuel and electricity consumption.

3.5 SUMMARY OF ENVIRONMENTAL AND ENERGY CONSIDERATIONS

The environmental considerations associated with installation of SO_2 controls on the Chena Power Plant produce uncertain assurances that any improvement in FNSB air quality will result. In fact, the data suggest that insignificant environmental improvements at best could occur. The energy considerations point to a likely lack of an air quality benefit in FNSB in the event that SO_2 controls are implemented at Chena Power Plant. In fact, such implementation could actually increase the air pollutant load in FNSB from sources more likely to produce a $PM_{2.5}$ ambient impact than Chena Power Plant.

Adopted

4 ANALYSIS OF ASPECTS RELATED TO BACT

The supplemental information presented herein supports and enhances the SO₂ BACT determination presented in the original BACT Analysis. The previous sections of this supplement analyzed the several aspects that must be considered in a BACT determination, those being technical feasibility, economics, environment, and energy. This analysis yielded the following findings:

- 1. The technical feasibility of employing add-on SO₂ controls at Chena is highly questionable due to lack of available space at the facility for the equipment needed to scrub the flue gas as well as raw material receiving and processing equipment. Furthermore, the degree of control afforded by SDA and DSI technology is highly variable and difficult to define for conditions existing at Chena.
- 2. The economic analysis shows that use of SDA or DSI technology for SO₂ control is does not make economic sense as a retrofit option at Chena Power Plant.
- 3. The environmental considerations demonstrated that no significant ambient $PM_{2.5}$ improvement would be obtained by requiring SO_2 controls on Chena Power Plant. ADEC also recognizes that controlling direct $PM_{2.5}$ emissions (such as from wood stoves) is 13 times more effective at reducing ambient $PM_{2.5}$ concentrations than controlling precursor air pollutants that produce secondary $PM_{2.5}$. Furthermore, the actual ambient $PM_{2.5}$ benefit that can be achieved by reducing SO_2 emissions is extremely uncertain and difficult to calculate.
- 4. From an energy standpoint, installing an add-on SO₂ control device would increase the parasitic load at the Chena Power Plant. Loss of this energy output would require supplemental energy consumption at other sources within the FNSB or acquired through the grid from Anchorage to compensate for this parasitic load. This supplemental energy consumption at other sources may actually produce an increase in direct PM_{2.5} emissions if the lost capacity were to be offset by fuel consumption for sources such as woodburning stoves or oil-fired boilers, which tend to emit more direct PM_{2.5} than Chena Power Plant, and at lower elevations. Furthermore, ADEC has already concluded, based on CMB

evaluations of PM filters in the FNSB, that these lower level sources are the more significant contributors to ambient $PM_{2.5}$ concentrations. Thus, the energy impacts of requiring SO₂ controls on Chena Power Plant could potentially have the exact opposite effect as desired and produce increases in ambient $PM_{2.5}$ concentrations in the FNSB.

4.1 DETERMINATION OF BACT FOR SO₂

Alaska coal has very low sulfur content, and uncontrolled sulfur emissions are four times lower than at a plant burning "low sulfur coal" in the lower 48 states.²³ The result is that the cost-effectiveness of SO₂ control technologies is poorer in Alaska than the lower 48 states. Current SO₂ emission rates from the Chena Power Plant are comparable to those identified as BACT in the most recent BACT determinations included in the RBLC database.

Therefore, as concluded in the original BACT Analysis, BACT for SO₂ emissions from Chena Power Plant is determined to be the continued use of low-sulfur coal.

²³ ADEC, Amendments to: State Air Quality Control Plan SIP, Vol. III: Appendix III.D.5.7, Appendix to Volume II. Analysis of Problems, Control Actions; Section III. Area-wide Pollutant Control Program; D. Particulate Matter; 5. Fairbanks North Star Borough PM_{2.5} Control Plan, December 24, 2014, page III.D.5.7-78.

ADEC Request for Additional Information Aurora Energy LLC. – Chena Power Plant BACT Analysis Review Environmental Resources Management Report, March 2017

September 10, 2018

Please address the following comments by providing the additional information identified by November 1, 2018. Following the receipt of the information the Alaska Department of Environmental Conservation (ADEC) intends to make its preliminary Best Available Control Technology (BACT) determination and release that determination for public review. In order to provide this additional review opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated. Additional requests for information may result from comments received during the public review period or based upon the new information provided in response to this information request.

This document does not represent a final BACT determination by ADEC. Please contact Aaron Simpson at <u>aaron.simpson@alaska.gov</u> with any questions regarding ADEC's comments.

- 1. <u>Alternative Fuel Source</u> Page 17 of the analysis indicates that it is assumed that use of another type of coal would not reduce NOx emissions, and use of an alternate fuel is considered technically infeasible, but did not include a substantive analysis. As indicated in the Approval and Promulgation of the State of Washington's Regional Haze State Implementation Plan¹, the use of SNCR and Flex Fuel² was selected as BART for the TransAlta coal-fired power plant. Evaluate alternative coal sources as a potential control option for the coal-fired boilers and identify energy, environmental, and economic impacts and other costs that would affect the selection of an alternative coal sources based on a comparison of the coal's heat content as well as nitrogen and sulfur content.
- 2. Low Excess Air (LEA) and Overfire Air (OFA) Operating at LEA involves reducing the amount of combustion air to the lowest possible level while maintaining efficient and environmentally compliant boiler operation. NOx formation is inhibited because less oxygen is available in the combustion zone. Overfire air is the injection of air above the main combustion zone. Implementation of these techniques may also reduce operational flexibility; however, they may reduce NOx by 10 to 20 percent from uncontrolled levels.³ Evaluate these technically feasible control technologies using EPA's top down approach.
- 3. <u>Additional SO₂ Control Technologies</u> The BACT analysis does not include a substantive analysis of spray-dry scrubbing, dry flue gas desulfurization, dry scrubbing, or dry sorbent injection (DSI). All of these technologies have the potential to offer SO₂ removal, and therefore must be included in the analysis. Page 32 of the analysis indicates that the combined exhaust from the Chena Power Plant is currently controlled by a common baghouse and that installation of a dry injection or spray drying operation would require the existing baghouse be retrofit with a new PM control system to accommodate the much greater PM loading produced by a dry injection or spray dry system. It further states that the installation of such technologies would

¹ EPA-R10-OAR-2012-0078, FRL-9675-5

² Flex Fuel is the "switch from Centralia, Washington coal to coal from the Power River Basin in Wyoming. Powder River Basin coal has a higher heat content requiring less fuel for the same heat extraction, as well as a lower nitrogen and sulfur content than coal from Centralia. Flex Fuel also required changes to boiler design to accommodate Powder River Basin coal."

³ https://www3.epa.gov/ttn/chief/ap42/ch01/final/c01s01.pdf

be cost-prohibitive and therefore technically infeasible. However, the BACT analysis must include rigorous site-specific evaluation of the technical feasibility and cost effectiveness of these technologies.

The EPA cost manual does not currently include a chapter covering DSI. However, as part of their Regional Haze FIP for Texas, EPA Region 6 developed cost estimates for DSI as applied to a large number of coal fired utility boilers. See the Technical Support Documents for the Cost of Controls Calculations for the Texas Regional Haze Federal Implementation Plan (Cost TSD) for additional information. The Cost TSD and associated spreadsheets are located at: https://www.regulations.gov/document?D=EPA-R06-OAR-2014-0754-0008. Please update the cost analysis for these technologies and provide technical justifications for all assumptions used in the analysis submitted as part of the BACT analysis (i.e., direct and indirect contingency costs, startup costs, initial performance test costs, electricity rate, and reagent costs). Provide in the analysis: the control efficiency associated with the technologies, captured emissions (tons per year), emissions reduction (tons per year), capital costs (2017 dollars), operating costs (dollars per year), and cost effectiveness (dollars per ton) using EPA's cost manual. Please see comments 5, 6, and 7 for additional information related to retrofit costs, baseline emissions, and factor of safety.

- 4. <u>BACT limits</u> BACT limits by definition, are numerical emission limits. However regulation allows a design, equipment, or work/operational practices if technological or economic limitations make a measurement methodology infeasible. Provide numerical emission limits (and averaging periods) for each proposed BACT selection, or justify why a measurement methodology is technically infeasible and provide the proposed design equipment, or work/operational practices for pollutant for each emission unit included in the analysis. Startup, Shutdown, and Malfunction (SSM) must be addressed in the BACT analysis. Measures to minimize the occurrence of these periods, or to minimize emissions during these periods are control options. Combinations of steady-state control options and SSM control options can be combined to create distinct control strategies. In no event shall application of BACT result in emissions of any pollutant which would exceed the emissions allowed by an applicable standard under 40 C.F.R. parts 60 (NSPS) and 61 (NESHAP).
- 5. <u>Retrofit Costs</u> EPA's Control Cost Manual indicates that study-level cost estimates (± 30 percent) should not include a retrofit factor greater than 30 percent, so detailed cost estimates (± 5 percent) are required for higher factors. High retrofit cost factors (50 percent or more) may be justified in unusual circumstances (e.g., long and unique ductwork and piping, site preparation, tight fits, helicopter or crane installation, additional engineering, and asbestos abatement). Provide detailed cost analyses and justification for difficult retrofit (1.6 1.9 times the capital costs) considerations used in the BACT analysis.
- 6. <u>Baseline Emissions</u> Include the baseline emissions for all emission units included in the analysis. Typically, the baseline emission rate represents a realistic scenario of upper bound uncontrolled emissions for the emissions unit (unrestricted potential to emit not actual emissions). NSPS and NESHAP requirements are not considered in calculating the baseline emissions. The baseline is usually the legal limit that would exist, but for the BACT determination. Baseline takes into account the effect of equipment that is part of the design of the unit (e.g., water injection and LNBs) because they are considered integral components to the unit's design. If the uncontrolled emission rate is 'soft,' run the cost effectiveness calculations using two or three different baselines.
- 7. <u>Factor of Safety</u> If warranted, include a factor of safety when setting BACT emission limitations. The safety factor is a legitimate method of deriving a specific emission limitation that may not be exceeded. These limits do not have to reflect the highest possible control

efficiencies, but rather, should allow the Permittee to achieve compliance with the numerical emission limit on a consistent basis.

- 8. <u>Good Combustion Practices</u> For each emission unit type (coal boilers, distillate boilers, engines, and material handling) for which good combustion practices was proposed as BACT, describe what constitutes good combustion practices. Include any work or operational practices that will be implemented and describe how continuous compliance with good combustion practices will be achieved.
- 9. <u>Interest Rate</u> All cost analyses must use the current bank prime interest rate. This can be found online at <u>https://www.federalreserve.gov/releases/h15/</u> (go to bank prime rate in the table). Please revise the cost analyses as appropriate.
- 10. Provide an economic analysis for circulating dry scrubber (CDS) SO₂ technology for the coal fired boilers (EUs 1-6). Provide in the analysis: the control efficiency associated with CDS, captured emissions (tons per year), emissions reduction (tons per year), capital costs (2017 dollars), operating costs (dollars per year), annualized costs (dollars per year), and cost effectiveness (dollars per ton) using EPA's cost manual. Please provide technical justifications for all assumptions used in the analysis submitted as part of the BACT analysis (i.e., direct and indirect contingency costs, startup costs, initial performance test costs, electricity rate, and reagent costs).
- 11. Review the cost effectiveness spreadsheet provided as a part of the preliminary SO₂ BACT determination which was originally developed by Sargent & Lundy (S&L) in 2010. The spreadsheet includes a link to the S&L white paper that provides a basis for the cost effectiveness calculations and indicates that the model is intended to calculate estimated total project cost (total capital cost of installation), as well as direct and indirect annual operating costs. These calculations are largely based on the estimated usage of sorbent and the gross generating capacity of the plant. Please use this spreadsheet to calculate the cost effectiveness of SO₂ removal in dollars per ton and identify all assumptions and technical justifications used in the analysis. In this analysis use a bottom-up cost estimating approach based on actual plant conditions. These conditions would include SO₂ emission rates based on current PTE, permit constraints (where applicable and enforceable), available space, ambient conditions, and local factors such as construction logistics, labor wage rates, and local sorbent costs.
- 12. Site-Specific Quotes Needed The cost analyses, particularly for SO₂ control technologies, must be based on emission unit-specific quotes for capital equipment purchase and installation costs at each facility. These are retrofit projects which must be considered individually in order to obtain reliable study/budget level (+/- 30%) cost estimates which are appropriate to use as the basis for decision making in determining BACT.

November 19, 2019

Adopted -

Department of Environmental Conservation

DIVISION OF AIR QUALITY Director's Office

410 Willoughby Avenue, Suite 303 PO Box 111800 Juneau, Alaska 99811-1800 Main: 907-465-5105 Toll Free: 866-241-2805 Fax: 907-465-5129 www.dec.alaska.gov

CERTIFIED MAIL: 7017 3040 0000 4359 5189 Return Receipt Requested

GOVERNOR BILL WALKER

September 13, 2018

David Fish, Environmental Manager Aurora Energy, LLC 100 Cushman St., Ste. 210 Fairbanks, AK 99701

THE STATE

Subject: Second request for additional information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant by November 1, 2018

Dear Mr. Fish:

A portion of the Fairbanks North Star Borough (FNSB) has been in nonattainment with the 24hour National Ambient Air Quality Standard for fine particulate matter (PM_{2.5}) since 2009. In a letter dated April 24, 2015, I requested that the Aurora Chena Power Plant and other affected stationary sources voluntarily provide the Alaska Department of Environmental Conservation (ADEC) with a Best Available Control Technology (BACT) analysis in advance of the nonattainment area being reclassified to Serious Non-Attainment Area. On May 10, 2017, the US Environmental Protection Agency (EPA) published their determination that the FNSB PM_{2.5} nonattainment area would be reclassified from a Moderate Area to a Serious Area effective June 9, 2017.¹

Once the nonattainment area was reclassified to Serious, it triggered the need for Best Available Control Measures (BACM)/BACT analyses. A BACM analysis requires that ADEC review potential control measure options for the various sectors that contribute to the PM₂₅ air pollution in the nonattainment area. A BACT analysis must be conducted for applicable stationary sources such as the Aurora Chena Power Plant. BACM and BACT are required to be evaluated regardless of the level of contribution by the source to the problem or its impact on the areas ability to attain.² The BACT analysis is a required component of a Serious State Implementation Plan (SIP).³ ADEC sent an email to Mr. Fish at Aurora on May 11, 2017 notifying him of the reclassification to Serious and

¹ Federal Register, Vol. 82, No. 89, Wednesday May 10, 2017 (https://dec.alaska.gov/air/anpms/comm/docs/2017-09391-CFR.pdf)

² <u>https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf</u>, Clean Air Act 189 (b)(1)(B) and 189 (e) and CFR 51.1010(4)(i) require the implementation of BACT for point sources and precursors emissions and BACM for area sources.

³ https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf, Clean Air Act 189 (b)(1)(B) and 189 (e) require the implementation of BACT for point sources and precursors emissions and BACM for area sources

Adopted_{ish} Aurora Energy, LLC

included a request for the BACT analysis to be completed by August 8, 2017. The BACT analysis from Aurora, which included emission units found in Operating Permits AQ0315TVP03 Revision 1, was submitted by email to the Department on March 20, 2017.

On March 22, 2018, ADEC released a preliminary draft of the BACT determination for the Chena Power Plant for public discussion on its website at:

http://dec.alaska.gov/air/anpms/communities/fbks-pm2-5-serious-sip-development. As indicated in the release, this document is a work in progress. ADEC received additional information from the EPA on the preliminary draft BACT determination and expects to make changes to the determination based upon this input. Therefore, ADEC is requesting additional information from Aurora to assist it in making a legally and practicably enforceable BACT determination for the source.

Specifically, ADEC requests that Aurora review the cost effectiveness spreadsheet provided as a part of the preliminary SO₂ BACT determination which was originally developed by Sargent & Lundy (S&L) in 2010. The spreadsheet includes a link to the S&L white paper that provides a basis for the cost effectiveness calculations and indicates that the model is intended to calculate estimated total project cost (total capital cost of installation), as well as direct and indirect annual operating costs. These calculations are largely based on the estimated usage of sorbent and the gross generating capacity of the plant. Please use this spreadsheet to calculate the cost effectiveness of SO₂ removal in dollars per ton and identify all assumptions and technical justifications used in the analysis.

If ADEC does not receive a response to this information request by November 1, 2018, ADEC will make a preliminary BACT determination based upon the information originally provided. However, ADEC does not have the in depth knowledge of your facility's infrastructure and without additional information, may select a more stringent BACT for your facility in order to be approvable by EPA. It is ADEC's intent to release the preliminary BACT determinations for public review along with any precursor demonstrations and BACM analyses before the required public comment process for the Serious SIP. In order to provide this additional comment opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated.

After ADEC makes a final BACT determination for Aurora, it must include the determination in Alaska's Serious SIP which ultimately requires approval by EPA.⁴ In addition, the BACT implementation 'clock' was also triggered by the EPA reclassification of the area to Serious on June 9, 2017. Therefore, the control measures that are included in the final BACT determination will be required to be fully implemented prior to June 9, 2021 - 4 years after reclassification.⁵

As indicated in a meeting on September 21, 2017 between ADEC Air Quality staff and the stationary sources affected by the BACT requirements, ADEC will also be using the information submitted or developed to support the BACT determinations for Most Stringent Measure (MSM) consideration. MSMs will be a required element of the state implementation plan if the State applies for an extension of the attainment date from EPA. Therefore, the information you submit will be used for both analyses.

⁴ https://www.gpo.gov/fdsys/pkg/USCODE-2013-title42/html/USCODE-2013-title42-chap85-subchapI-partDsubpart4-sec7513a

⁵ 40. CFR 51.1010(4)

Adopted David Fish Aurora Energy, LLC November 19, 2019 September 13, 2018 BACT Letter

ADEC appreciates the cooperation that we've received from Aurora. ADEC staff would like to continue periodic meetings to keep track of timelines and progress. If you have any questions related to this request, please feel free to contact us. Deanna Huff (email: <u>Deanna.huff@alaska.gov</u>) and Cindy Heil (email: <u>Cindy.heil@alaska.gov</u>) are the primary contacts for this effort within the Division of Air Quality.

Sincerely, West BY SIR Denise Koch, Director

Division of Air Quality

Enclosures:

September 10, 2018	ADEC Request for Additional Information for Chena Power Plant BACT Analysis
May 21, 2018	EPA Comments on ADEC Preliminary Draft Serious SIP Development Materials for the Fairbanks Serious PM-2.5 nonattainment Area
November 16, 2017	ADEC Request for Additional Information for Aurora Energy LLC, BACT Analysis
November 15, 2017	EPA Aurora Energy – Chena Power Plant BACT Analysis Review Comments
May 11, 2017	Serious SIP BACT due date email
April 24, 2015	Voluntary BACT Analysis for Aurora Energy, LLC

cc: Larry Hartig, ADEC/Commissioner's Office Alice Edwards, ADEC/Commissioner's Office Cindy Heil, ADEC/Air Quality Deanna Huff, ADEC/Air Quality Jim Plosay, ADEC/Air Quality Aaron Simpson, ADEC/Air Quality David Fish/Aurora Energy, LLC Tim Hamlin/EPA Region 10 Dan Brown/EPA Region 10 Zach Hedgpeth/EPA Region 10

Attachment: EPA comments on ADEC Preliminary Draft Serious SIP Development materials for the Fairbanks serious PM_{2.5} nonattainment area

<u>General</u>

The attached comments are intended to provide guidance on the preliminary drafts of SIP documents in development by ADEC. We expect that there will be further opportunities to review the more complete versions of the drafts and intend to provide more detailed comments at that point

 <u>Statutory Requirements</u> - This preliminary draft does not address all statutory requirements laid out in Title I, Part D of the Clean Air Act or 40 C.F.R. Part 51, Subpart Z. The submitted Serious Area SIP will need to address all statutory and regulatory requirements as identified in Title I, Part D of the Clean Air Act, 40 C.F.R. Part 51, Subpart Z, the August 24, 2016 PM_{2.5} SIP Requirements Rules (81 FR 58010, also referred to at the PM_{2.5} Implementation Rule), and any associated guidance.

In the preliminary drafts, notable missing elements included: Reasonable Further Progress, Quantitative Milestones, and Conformity. This is not an exhaustive list of required elements.

The NNSR program is a required element for the serious area SIP. We understand ADEC recently adopted rule changes to address the nonattainment new source review element of the Serious SIP, and that ADEC plans to submit them to the EPA separately in October 2018. Thank you for your work on this important plan element.

- 2. Extension Request This preliminary draft does not address the decision to request an attainment date extension and the associated impracticability demonstration. On September 15, 2017, ADEC sent a letter notifying the EPA that it intends to apply for an extension of the attainment date for the Fairbanks PM_{2.5} Serious nonattainment area. The Serious Area SIP submitted to EPA will need to include both an extension request and an impracticability demonstration that meet the requirements of Clean Air Act section 188(e). In order to process an extension request, the EPA requests timely submitted of your Serious Area SIP to allow for sufficient time to review and take action prior to the current December 2019 attainment date, so as to allow, if approvable, the extension of the attainment date as requested/appropriate. For additional guidance, please refer to 81 FR 58096.
- 3. <u>Split Request</u> We support the ADEC and the FNSB's decision to suspend their request to the EPA to split the nonattainment area. We support the effort to site a monitor in the Fairbanks area that is more representative of neighborhood conditions and thus more protective of community health. This would provide additional information on progress towards achieving clean air throughout the nonattainment area.
- 4. <u>BACM (and BACT), and MSM</u> Best Available Control Measures (including Best Available Control Technologies) and Most Stringent Measures are evaluative processes inclusive of steps to identify, adopt, and implement control measures. Their definitions are found in 51.1000, 51.1010(a).

All source categories, point sources – area sources – on-road sources – non-road sources, need to be evaluated for BACM/BACT and MSM. De minimis or minimal contribution are not an allowable rationale for not evaluating or selecting a control measure or technology.

The process for identifying and adopting MSM is separate from, yet builds upon, the process of selecting BACM. Given that Alaska is intent on applying for an extension to the attainment date, Alaska must identify BACM and MSM for all source categories. These processes are described in 51.1010(a) and 51.1010(b) and in the PM_{2.5} Implementation Rule preamble at 81 FR 58080 and 58096. We further discuss this process in the "BACM (and BACT), MSM" section that starts on page 3 below.

- 5. <u>Resources and Implementation</u> The serious area PM_{2.5} attainment plan will be best able to achieves its objectives when all components of the SIP, both the ADEC statewide and FNSB local measures, are sufficiently funded and fully implemented.
- 6. <u>Use of Consultants</u>- For the purpose of clarity, it will be important to identify that while contractors are providing support to ADEC, all analyses are the responsibility of the State.

Emissions Inventory

- 1. <u>Extension Request Emission Inventories</u> Emissions inventories associated with the attainment date extension request will need to be developed and submitted. Table 1 of the Emissions Inventory document is one example where the submittal will need to include the additional emissions inventories, including RFP inventories, extension year inventories for planning and modeling, and attainment year planning and modeling inventories, associated with the attainment date extension request.
- <u>Modeling Requirements</u> Related to emissions inventory requirements, the serious area SIP will need to model and inventory 2023 and 2024, at minimum. We recommend starting at 2024 and modeling earlier and earlier until there is a year where attainment is not possible. That would satisfy the requirement that attainment be reached as soon as practicable.
- 3. <u>Condensable Emissions</u> All emissions inventories and any associated planning, such as Reasonable Further Progress schedules, need to include condensable emissions as a separate column or line item, where available. Where condensable emissions are not available separately, provide condensable emissions as included (and noted as such) in the total number. The following are examples of where this would need to be incorporated in to the Emissions Inventory document:
 - *a.* Page 20, paragraph 5 (or 2^{nd} from the bottom).
 - b. Page 34, Table 8. Include templates.

Precursor Demonstration

- 1. <u>Ammonia Precursor Demonstration</u> The draft Concepts and Approaches document, Table 4 on page 9, states that a precursor demonstration was completed for ammonia and that the result was "Not significant for either point sources or comprehensively." The Precursor Demonstration chapter does not include an analysis for ammonia. Please include the precursor demonstration for ammonia in the Serious Plan or amend this table.
- 2. <u>Sulfur Dioxide Precursor Description</u> The draft Concepts and Approaches document, Table 4 on page 9, states that sulfur dioxide was found to be significant. All precursors are presumptively considered significant by default and the precursor demonstration can only show that controls on a precursor are not required for attainment. Suggested language is, "No precursor demonstration possible."

BACM (and BACT), MSM

Overall

The EPA appreciates ADECs efforts to identify and evaluate BACM for eventual incorporation into the Serious Area SIP. The documents clearly display significant effort on the part of the state and are a good first step in the SIP development process. In particular, we are supportive of ADECs efforts to evaluate BACT for the major stationary sources in the nonattainment area, as control of these sources is required by the CAA and PM_{2.5} SIP Requirements Rule.

- <u>BACM/BACT and MSM: Separate Analyses</u> The "Possible Concepts and Potential Approaches" document appears to conflate the terms BACM/BACT and MSM, as well as, the analyses for determining BACM/BACT and MSM. BACM and MSM have separate definitions in 40 CFR 51.1000. By extension, the processes for selecting BACM and MSM are laid out separately in the PM_{2.5} SIP Requirements Rule (compare 40 CFR 51.1010(a) for BACM and 40 CFR 51.1010(b) for MSM). Accordingly, the serious area SIP submission will need to have both a BACM/BACT analysis and an MSM analysis. We believe that there is flexibility in how these analyses can be presented, so long as the submission clearly satisfies the requirements of both evaluations, methodologies, and findings.
- Selection of Measures and Technologies The CAA and the PM_{2.5} SIP Requirements Rule requires that <u>all</u> available control measures and technologies that meet the BACM (including BACT) and MSM criteria need to be implemented. All source categories need to be evaluated including: point sources (including non-major sources), area sources, on-road sources, and non-road sources.
- 3. <u>Technological Feasibility</u> All available control measures and technologies include those that have been implemented in nonattainment areas or attainment areas, or those potential measures and technologies that are available or new but not yet implemented. Similarly, Alaska may not automatically eliminate a particular control measure because other sources or nonattainment areas have not implemented the measure. The regulations do not have a quantitative limit on number of controls that should be implemented.

For technological feasibility, a state may consider factors including local circumstances, the condition and extent of needed infrastructure, or population size or workforce type and habits, which may prohibit certain potential control measures from being implementable. However, in the instance where a given control measure has been applied in another NAAQS nonattainment area, the state will need to provide a detailed justification for rejecting any potential BACM or MSM measure as technologically infeasible (81 FR 58085).

A Borough referendum prohibiting regulation of home heating would not be an acceptable consideration to render potential measures technologically infeasible. The State would be responsible for implementing the regulations in the case that the Borough was not able. We believe that the most efficient path to clean air in the Borough is through a local, community effort.

- 4. <u>Economic Feasibility</u> The BACM (including BACT) and MSM analyses need to identify the basis for determining economic feasibility for both the BACM and MSM analyses. In general, the PM_{2.5} SIP Requirements Rule requires the state apply more stringent criteria for determining the feasibility of potential MSM than that used to determine the feasibility of BACM and BACT, including consideration of higher cost/ton values as cost effective.
- 5. <u>Timing</u> The evaluations will need to identify the time for selection, adoption, and implementation for all measures. BACT must be selected, adopted, and implemented no later than 4 years after reclassification (June 2021). MSM must be selected, adopted, and implemented no later than 1 year prior to the potentially extended attainment date (December 2023 at latest). The RFP section of the serious area plan will need to identify the BACM and MSM control measures, their time of implementation, and the time(s) of expected emissions reductions. Timing delays in selection, adoption, implementation are not considered for BACM and MSM.

As mentioned in the comment above in the "General" comment section, there are three criteria distinguishing between BACM and MSM, not one.

BACM - General

1. <u>BACM definition, evaluations</u> - The definition of BACM at 40 CFR 51.1000 describes BACM as any measure "that generally can achieve greater permanent and enforceable emissions reductions in direct PM_{2.5} and/or PM_{2.5} plan precursors from sources in the area than can be achieved through the implementation of RACM on the same sources." We believe that potential measures that are no more stringent than existing measures already implemented in FNSB, those that do not provide additional direct PM_{2.5} and/or PM_{2.5} precursors emissions reductions, do not meet the definition of BACM. These would need to be evaluated in the BACM and MSM analysis.

For measures that are currently being implemented in Fairbanks that provide equivalent or more stringent control, we recommend identifying the ADEC or Borough implemented measure as part of the BACM control strategy. These implemented measures should be listed in their BACM findings at the end of the document. This comment applies to all of the measures that were screened out from consideration due to not being more stringent than the already implemented measure.

The analyses for a number of measures (e.g., Measure 30, Distribution of Curtailment Program information at time of woodstove sale) conclude that the emission reductions would be insignificant and difficult to quantify and, therefore, the measure is not technologically feasible. These measures may be technologically feasible. However, if existing measures constitute a higher level of control or if implementation of the measures is economically infeasible those would be valid conclusions if properly documented. De minimis or minimal contribution is not a valid rationale for not considering or selecting a control measure or technology.

The conclusion "not eligible for consideration as BACM" is not valid as all assessments for BACM and MSM are part of the evaluation. More appropriate conclusions could include that existing measures qualify as BACM or MSM, or are more stringent. Additional conclusions could include that evaluated measures were not technologically feasible, economically feasible, or could not practically be adopted and implemented prior to the required timeframe for BACM or MSM.

- 2. <u>BACM and MSM, Ammonia</u> In the Approaches and Concepts document, Table 5 references that there are no applicable control measures or technologies for the PM_{2.5} precursor ammonia. No information to substantiate this claim are found in the preliminary draft documents. Unless NH₃ is demonstrated to be insignificant for this area, the serious area plan will need to include an evaluation of NH₃ and potential controls for all source categories including points sources.
- 3. <u>Backsliding Potential</u> When benchmarking the BACM and MSM analyses for stringency, ensure that the evaluation is based on the measures approved into the current Moderate SIP. This will relate primarily to the current ADEC/FNSB curtailment program but also other related rules. Many wood smoke control measures are interrelated, and changes to those measures may affect determinations on stringency of directly related and indirectly related measures. Examples of this can be found in multiple measures including, but not limited to Measures 5, 7, and 16.
- 4. <u>Transportation Control Measures</u> The Approaches and Concepts document, on Page 13, states that the MOVES2014 model does not estimate a PM benefit as a result of an I/M program, and therefore the I/M is not technologically feasible. This is not a valid conclusion given that the Fairbanks area operated an I/M program to reduce carbon monoxide and the Utah Cache Valley nonattainment areas has an I/M program for VOC control. This measure will need to be evaluated. Referring to the 110(l) analysis for the Fairbanks CO I/M program may provide insight into how to quantify the emissions associated with an I/M program.

With regard to control measures related to on-road sources, we have received inquiries from the community regarding idling vehicles and further evaluation emission benefits would be responsive to citizen concern and may provide additional air quality benefit.

BACM - Specific Measures

• Measure 16, page 34-35. Date certain Removal of Uncertified Devices. The "date certain" removal of uncertified woodstoves in Tacoma, Washington appears more stringent than the current Moderate SIP approved Fairbanks ordinance in terms of the regulation and in practice. While the current ordinance appears to provide similar protection during stage 1 alerts, this is dependent on 100% compliance and the curtailment program remaining in its current form. Removal of uncertified stoves guarantees reductions in emissions in the airshed during both the curtailment periods and throughout the heating season. The information provided does not support the conclusion that the Fairbanks controls provides equivalent or more stringent control. Date certain removal of uncertified wood stoves needs to be considered for the area.

Measures R4, R9, and R12, page 64, 68 and 71. These measures do not reference the Puget Sound Clean Air Agency (Section 13.07) requirement for removal of all uncertified stoves by September 30, 2015. This is equivalent to having all solid fuel burning appliances be certified and would be more stringent than the current SIP approved rules in Fairbanks. We believe that these measures need to be evaluated in the BACM and MSM analyses.

Measure R4 and R9, page 64 and 68. All Wood Stoves Must be Certified. These measure should be evaluated.

- Measure 19-20 and 25, page 36-38 and 39. Renewal and Inspection Requirements. ADEC has not adequately demonstrated their conclusion that Fairbanks has a more stringent measure than Missoula and San Joaquin. We believe that the renewal requirements and inspection/maintenance requirements associated with the Missoula alert permits and San Joaquin registrations allows the local air agency an opportunity to verify on a regular basis that the device operates properly over times. Wood burning appliances require regular maintenance in order to achieve the certified emissions ratings. The FNSB Stage 1 waivers do not have an expiration and do not have an inspection and maintenance component making it less stringent.
- Measure 31, page 43. While the Borough has SIP approved dry wood requirements that prohibit the burning of wet wood and moisture disclosure requirements by sellers, we believe that a measure limiting the sale of wet wood during the winter months should be further analyzed for BACM (and MSM) consideration.
- Measures 33, 35, 36, 37, 43. Multiple Measures identify that recreational fires have been exempted from existing regulations. Small unregulated recreational fires, bonfires, fire pits,

and warming fires have the potential to contribute emissions during a curtailment period. The FNSB and ADEC regulations should be re-evaluated for removing this exclusion.

- Measure 49, page 58. Ban on Coal Burning. We believe the regulations in Telluride are more stringent than in Fairbanks. Telluride prohibits coal burning all year whereas in Fairbanks an existing coal stove can burn when there is no curtailment which could contribute additional emissions to the airshed, especially during poor conditions when a curtailment may not have been called. We do not agree with the conclusion that the PM₁₀ controls are ineligible for consideration for control of PM_{2.5}.
- Measure R20, page 76. Transportation Control Measures related to Vehicle Idling. We have received multiple inquiries regarding community interest in controlling emissions from idling vehicles. These types of control measures should be further evaluated in the BACM and MSM analyses.
- Measure 1, page 79-81. Surcharge on Solid Fuel Burning Appliances. For purposes of implementing an effective program to reduce PM_{2.5} in the Borough we believe that a surcharge may be a helpful way to supplement limited funds. Implementation efforts within the nonattainment area could benefit from \$24,000 of additional funding whether used for a code enforcer or other support of the wood smoke programs.
- Additional controls that should be further evaluated for BACM and MSM include:
 - Measure R1, page 63: Natural gas fired kiln or regional kiln.
 - Measure R12, page 71: Replace uncertified stoves in rental units.
 - Measure R17, page 75: Ban use of wood stoves
 - Measure R6, page 65: Remove Hydronic Heaters at Time of Home Sale & Date certain removal of Hydronic heaters. We suggest evaluating these measures at the state and local level.
 - Weatherization / heat retention programs should be evaluated. These should be evaluated for existing homes through energy audits and increasing insulation and energy efficiency. For new construction, building codes (Fairbanks Energy Code) should be evaluated with reference to the IECC Compliance Guide for Homes in Alaska <u>http://insulationinstitute.org/wp-content/uploads/2015/12/AK_2009.pdf</u>, and the DOE R-value recommendations, <u>http://www.fairbanksalaska.us/wp-content/uploads/2011/07/ENERGY-CODE.pdf</u>. (Note: More recent information may be available.)
 - Fuel oil boiler upgrades / operation & maintenance programs should be evaluated.

BACM - Ultra-Low Sulfur Fuel

1. <u>Incomplete Analysis</u> - The report findings provide analysis of the demand curve over a relatively short (12 month) time frame. This analysis appears to be based on a partial equilibrium model. This is a misleading time frame given the volatility of demand side fuel oil pricing. Also, in order to determine the equilibrium price, the analysis must also analyze

the supply curve. The report does not include information about the future supply side costs but needs to in order to make conclusions about the cost to the community of ultra-low sulfur heating oil.

- <u>Analysis of Increased Supply, Consumption</u> The report does not address future change in the market nor potential economies of scale to be achieved by an increase in ultra-low sulfur fuel consumption. Page 3 of the report identifies that, "the additional premium to purchase ULS over HS, decreased significantly since 2008-2010. It is likely that, this can be attributed to increased ULS capacity." We believe that the report should further explore the supply side costs.
- 3. <u>Supply Cost Analysis</u> A supply side cost analysis is necessary to better understand the cost to the supplier to produce and provide ULS heating fuel. The BACM analysis must start with a transparent and detailed economic analysis of exclusively supplying ultra-low sulfur heating oil to the nonattainment area.
- 4. <u>BACM Assessment</u> The current analysis does not provide information needed to assess BACM economic feasibility. The report should analyze the total cost to industry of delivering ultra-low sulfur heating oil to the entire community in terms of standard BACM metrics, \$/ton.

BACT

General Comments

At this time, EPA is providing general comments based on review of the draft BACT analyses prepared by ADEC as well as addressing certain issues discussed in earlier BACT comments provided by EPA. Detailed comments regarding each individual analysis are not being provided at this time. While EPA appreciates the time and effort invested by ADEC staff in preparing the draft BACT analyses, the basic cost and technical feasibility information needed to form the basis for retrofit BACT analyses at the specific facilities has not been prepared. In other words, analyses which are adequate to guide decision making regarding control technology decisions for these rather complex retrofit projects cannot be prepared without site specific evaluation of capital control equipment purchase and installation costs, and site specific evaluation of retrofit considerations. EPA will conduct a thorough review of any future BACT or MSM analyses which are prepared based on adequate site specific information, and will provide detailed comments relative to each emission unit and pollutant at that time.

- 1. <u>Level of Analysis</u> The analyses are presented as "preliminary BACT/MSM analyses" on the website, but the documents themselves are titled only as BACT analyses and the conclusions only reflect BACT. Additionally, the determinations may not be stringent enough to be considered BACT given that better performing SO₂ control technologies have not been adequately analyzed. These analyses cannot be considered to provide sufficient basis to support a selection of MSM.
- 2. <u>Site-Specific Quotes Needed</u> The cost analyses, particularly for SO₂ control technologies, must be based on emission unit-specific quotes for capital equipment purchase and

installation costs at each facility. These are retrofit projects which must be considered individually in order to obtain reliable study/budget level (+/- 30%) cost estimates which are appropriate to use as the basis for decision making in determining BACT and potentially MSM. EPA believes that control decisions of this magnitude justify the relatively small expense of obtaining site-specific quotes.

- 3. <u>SO₂ Control Technologies</u> The analyses must include evaluation of circulating dry scrubber (CDS) SO₂ control technology. This demonstrated technology can achieve SO₂ removal rates comparable to wet flue gas desulfurization (FGD) at lower capital and annual costs, and is more amenable to smaller units and retrofits. Modular units are available.
- 4. <u>Control Equipment Lifetime</u> The analyses must use reasonable values for control equipment lifetime, according to the EPA control cost manual (EPA CCM). EPA believes that the following equipment lifetimes reflect reasonable assumptions for purposes of the cost analysis for each technology as stated in the EPA control cost manual and other EPA technical support documents. Use of shorter lifetimes for purposes of the cost analysis must include evidence to support the proposed shortened lifetime. One example where EPA agrees a shortened lifetime is appropriate would be where the subject emission unit has a federally enforceable shutdown date. Certain analyses submitted in the past have claimed shortened equipment lifetimes based on the harshness of the climate in Fairbanks. In order to use an equipment life that is shortened based on the harsh climate, evidence must be provided to support the claim. This evidence could include information regarding the actual age of currently operating control equipment, or design documents for associated process equipment such as boilers. Lacking adequate justification, all cost analyses must use the following values for control equipment lifetime:
 - a. SCR, Wet FGD, DSI, CDS, SDA 30 years
 - b. SNCR 20 years
- 5. <u>Availability of Control Technologies</u> Technologically feasible control technologies may only be eliminated based on lack of availability if the analysis includes documented information from multiple control equipment vendors (who provide the technology in question) which confirms the technology cannot be available within the appropriate implementation timeline for the emission unit in question.
- <u>Assumptions and Supporting Documents</u> All documents cited in the analyses which form the basis for costs used and assumptions made in the analyses must be provided. Assumptions made in the analyses must be reasonable and appropriate for the control technologies included in the cost analysis.
- <u>Interest Rate</u> All cost analyses must use the current bank prime interest rate according to the revised EPA CCM. As of May 10, 2018, this rate is 4.75%. See <u>https://www.federalreserve.gov/releases/h15/</u> (go to bank prime rate in the table).
- 8. <u>Space Constraints</u> In order to establish a control technology as not technologically feasible due to space constraints or other retrofit considerations, detailed site specific information must be submitted in order to establish the basis for such a determination, including detailed drawings, site plans and other information to substantiate the claim.
- 9. <u>Retrofit Factors</u> All factors that the facility believes complicate the retrofit installation of each technology should be described in detail, and detailed substantiating information must be submitted to allow reasonable determination of an appropriate retrofit factor or whether installation of a specific control technology is technologically infeasible. EPA Region 10

believes that installation factors which would complicate the retrofit installation of the control technology should be evaluated by a qualified control equipment vendor and be reflected in a site-specific capital equipment purchase and installation quote. Lacking site-specific cost information, all factors that the facility believes complicate the retrofit installation of each technology should be described in detail, and detailed substantiating information must be submitted to allow reasonable determination of an appropriate retrofit factor. One example of the many retrofit considerations that must be evaluated is the footprint required for each control technology. A vendor providing a wet scrubber will be able to estimate the physical space required for the technology, and evaluate the existing process equipment configuration and available space at each subject facility. The determination of whether a specific control technology is feasible and what the costs will be may be different at each facility based on this and other factors. Site-specific evaluation of these factors must be conducted in order to provide a reasonable basis for decision making.

- 10. <u>Control Efficiency</u> Cost effectiveness calculations for each control technology must be based on a reasonable and demonstrated high end control efficiency achievable by the technology in question at other emission units, or as stated in writing by a control equipment vendor. If a lower pollutant removal efficiency is used as the basis for the analysis, detailed technical justification must be provided. For example, the ability of SCR to achieve over 90% NOx reduction is well established, yet the ADEC draft analyses assume only 80% control. Use of this lower control efficiency requires robust technical justification.
- 11. <u>Condensable Particulate Matter</u> Although the existing control technology on the coal fired boilers may be evaluated as to whether it meets the requirement for BACT for particulate matter, baghouses primarily reduce emissions of filterable particulate matter rather than condensable PM. Given that all condensable PM emitted by the coal fired boilers would be classified as PM_{2.5}, the BACT analyses must include consideration of control options for these emissions. Where control technologies evaluated for control of other pollutants may provide a collateral benefit in reducing emissions of PM_{2.5}, this should be evaluated as well.
- <u>Guidance Reference</u> The steps followed to perform the BACT analysis mentioned in section 2 are from draft NSR/PSD guidance. The correct reference should be 81 FR 58080, 8/24/2016. As a result of this, some of the steps outlined in the BACT analysis need to be updated.
- 13. <u>Community Burden Estimate</u> The concepts and approaches document labels capital purchase and installation costs for air pollution control technology at the major source facilities as "community burden" (see Tables 7 and 8, pages 10-11). EPA believes it is important to properly label the cost numbers being used as capital purchase and installation costs, since presenting them as community burden appears to attribute the entire initial capital investment for the various control technologies to the community in a single year, and also ignores annual operation and maintenance costs. As described in the EPA CCM, the cost methodology used by EPA for determining the cost effectiveness of air pollution control technology amortizes the initial capital investment over the expected life of the control device, and includes expected annual operating and maintenance expenses. EPA believes presentation of this annualized cost over the life of the control technology more accurately represents the actual cost incurred and is consistent with how cost effectiveness is estimated in the context of a BACT analysis.
- 14. <u>Conversion to Natural Gas</u> For any emission units capable of converting to natural gas combustion (with the requisite changes to the burners, etc), the MSM analysis in particular

should thoroughly evaluate the feasibility of this option. For example, GVEA has stated the combustion turbines at its North Pole Expansion Power Plant have the ability to burn natural gas, and the IGU has indicated the intent to expand the supply of natural gas to Fairbanks and North Pole.

APPENDIX:

Additional Comments and Suggestions

Possible Concepts and Potential Approaches

Throughout all SIP documents references to design values should include a footnote to the source of the information (e.g., "downloaded from AQS on XX/XX/XXX" or "downloaded from [state system] on XX/XX/XXX") and how exceptional events were treated.

We suggest referencing the August 24, 2016 81 FR 58010 Fine Particulate Matter NAAQS: State Implementation Plan Requirements rule with one consistent term. We suggest the 2016 $PM_{2.5}$ Implementation Rule.

Page 4, Figure 1. The comparative degree days and heating related information is better suited for the sections evaluating BACM and economic feasibility. If intending on using this information to differentiate Fairbanks from other cold climates and/or nonattainment areas, depicting comparative home heating costs would be more supportive.

Page 4, Table 1. The design values in the table and in the discussion need to be updated for 2015-2017.

Page 6-7: The "Totals" row in Table 3 (non-attainment areas emissions by source sector) does not appear to be the sum of the individual source sector emissions.

Page 7: The statement about FNSB experiencing high heating energy demand per square foot needs to be referenced.

Page 7: The discussion of Eielson AFB growth needs a reference to the final EIS.

Page 9: Table 4's title should be changed to "Preliminary Precursor Demonstration Summary"

Page 9: Table 4 includes a column "Modeling Assessment". Not all precursors were assessed with modeling, and modeling is just one tool for the precursor demonstration. A suggestion for the column title is "Result of Precursor Demonstration."

Page 9: Table 5's title should be changed to "Preliminary BACT Summary." Table 5 also needs to update the title to reference "Precursor Demonstration" as the term "Precursor Significance Evaluation" is the incorrect terminology for this analysis.

Page 10: ADEC's proposal to only require one control measure per major stationary source to meet BACT and MSM for SO₂, is not consistent with the Act or rule. As discussed above, BACM and MSM have separate definitions in 40 CFR 51.1000. By extension, the processes for

selecting BACM and MSM are laid out separately in the PM2.5 SIP Requirements Rule (compare 40 CFR 51.1010(a) for BACM and 40 CFR 51.1010(b) for MSM).

Page 10: Table 6 should identify the specific dry sorbent injection selected as BACT.

Page 11: Suggest changing "less sources" to "fewer sources."

Page 13: The statement about an I/M program providing PM benefit needs to be clarified. Is this referring just to NOx and VOC precursor contribution to PM2.5, or also direct PM2.5 benefits?

Page 14: The statement "ADEC interprets the main difference between BACT/BACM and MSM as the time it takes to implement a control" is inaccurate. As discussed above, although the rule sets our different schedules for implementation of MSM and BACM, this is not the only major difference between those concepts. Notably, the rule contemplates a higher stringency for MSM as well as a higher cost/ton threshold for determining economic feasibility of the measure.

Technical Analysis Protocol

Page 2: The design values at the top of the page need to be updated to 2015-2017.

Page 2: Recommend removing the sentence "This site will be included in the Serious SIP's attainment plan…" as the North Pole Elementary will be involved in the redesignation to attainment in the sense that all past and current monitoring data will be a part of an unmonitored area analysis to show that the entire area has attained the standard in addition to the regulatory monitor locations.

Page 2: Remove the discussion of the nonattainment area split.

Page 2: Paragraph 2, sentence 3 should refer to the unmonitored area analysis.

Page 2: The timeline described at the bottom of the page needs to be modified to reflect a current schedule. No projected year modeling was included in the preliminary draft documents. Control scenario modeling will likely not be completed in Q2 2018.

Page 3: We suggest a sentence overview of the unmonitored area analysis in Section 3.1.

Page 3: Section 3.2 needs to refer to the SPM data and how that will be used in the Serious Plan unmonitored area analysis. This section should discuss current DEC efforts to site a new monitor in Fairbanks.

Page 3: Section 3.4 needs to describe the CMAQ domain in addition to the WRF domain. A figure (map) would help.

Page 4: Section 3.5 needs a more developed discussion of the WRF assessment, including describing the criteria that were used to assess the state-of-the-art, what the current version is, and what version was used.

Page 4: Section 3.6 needs to reference all emission inventories in development, including potential attainment date extension years and RFP years.

Page 4: In Section 4.1, the statement about the Moderate SIP covering the relevant monitors for the Serious SIP is inaccurate. The statement needs to qualify whether it is referring to regulatory monitors or non-regulatory monitors. In addition, the North Pole Fire Station, NCore, and North Pole Elementary monitors were not included in the Moderate SIP.

Page 5: Table 4.1-1's title suggests that all SPM sites are listed, but only sites with regulatory monitors are listed. Please list all the SPM sites used in the unmonitored area analysis in a separate table and modify this title of Table 4.1-1 to reflect that it lists sites that are regulatory.

Page 5: North Pole Elementary was a regulatory site for a part of the baseline period and was NAAQS comparable. Table 4.1-1 needs to be updated.

Page 8: Table 4.2-1 should be updated to include 2011-2017 98th percentiles. Table 4.2-2 should be updated to include 3-year design values for 2013-2017. For clarity, we recommend the 3-year design values include the full period in order to better distinguish from Table 4.2-1. For instance, "2013" would be "2011-2013".

Page 8: The statement starting, "a clear indication..." needs to be amended or removed. It is inaccurate. The prevalence of organic carbon does not indicate the dominance of wood burning, much less a clear indication. Many sources in Fairbanks emit organic carbon.

Page 8: The statement starting "The concentration share…" need to be amended or removed. Suggest removing "drastically". There is no scientific definition of a drastic change in percentages of PM_{2.5} species, nor does the different 56% to 80% appear "drastic."

Page 9: The detailed description of the Simpson and Nattinger analysis does not reflect that SANDWICH process and it is preliminary data. It should be included within the body of the Serious Plan appendix on monitoring, but is out of place in a summary TAP.

Page 9: there are two different tables with the same table number (Table 4.3-1).

Page 10: Please clarify Table 4.4-1. This appears to be the design value calculation for the 5-year baseline design value, 2011-2015. If correct, then please label the 3-year design values according to the three years (e.g., "2011-2013"), clarify the table heading as being the "Five Year Baseline Design Value, 2011-2015 (μ g/m3)", and clarify that the last column is the 5 Year Baseline Design Value associated with the table heading.

Page 11: At the end of section 5, please refer to the emission inventory chapter's meteorological discussion of the episodes.

Page 11: Section 6 needs to justify the extent, resolution, and vertical layer structure of the CMAQ domain (and the WRF domain) or refer to where that is included in the Moderate Plan.

Page 13: We suggest changing "PMNAA" to "NAA" to be consistent with the EI chapter.

Page 15, Section 8.1: There needs to be mention of how the F-35 deployment will be considered, with a reference to the final EIS.

Page 15-19: section 8.2-8.6 use the future tense for tasks that have been completed and are inconsistent with the schedule at the beginning of the TAP. Please adjust based on current status.

Page 20, section 9.2 states that "a BACT analysis is an evaluation of all technically available control technologies for equipment emitting the triggered pollutants and a process for selecting the best option based on feasibility, economics, energy, and other impacts." This sentence should be revised to reflect that the technological feasibility assessment occurs after identification of all potential control measures for each source and source category.

Page 20, section 9.3 the second sentence should read: "BACM measures found to be economically infeasible for BACM *must* be analyzed for MSM."

Page 21: Section 10.1 needs to be updated to reflect the current CMAQ version (5.2.1) and a discussion of why that model has not been used.

Page 21: Suggest sentence starting "There will be a gap…" be changed to "There is a gap in terms of assessing the performance at the North Pole Fire Station monitor for the Serious Plan because the State Office Building in Fairbanks was the only regulatory monitor at the time of the 2008 base case modeling episodes."

Page 23: Please explain the solid and dashed lines in the soccer plot.

Page 23: Please be sure to include a full discussion of North Pole performance in this section. Even though we lack measurements, we can discuss the ratio of the modeling results at NPFS versus SOB versus that ratio from more recent monitoring data (2011-2015 baseline design value period).

Page 23: Please clarify what is meant by "Moderate Area SIP requirements."

Page 24: The discussion of the 2013 base year discusses representative meteorological conditions without describing what the representative meteorological conditions are for high PM_{2.5}. Please reference the discussion of representative meteorological conditions that will be found elsewhere in the SIP.

Page 24: The discussion of the modeling years needs to be consistent and reflect the extension request past 2019. The attainment year cannot be earlier than 2019. Each extension year must be individually requested. For modeling efficiency, we recommend starting with 2024. If that year attains, then 2023 and so on until we have one year that attains and the year before that does not. This should give us the information about what is the earliest year for attainment.

Page 25: We suggest changing "modeling design value" to "design value for modeling"

Page 26: Please clarify the "SMAT" label in the tables. They may be the SANDWICH concentrations and the "5-yr DV" rows are the SMAT concentrations. Please clarify the units in the rows.

Emission Inventory

Clarification – In the EI document we would like to understand the functional difference between the base year, and baseline year

Please identify the methodology for generating ammonia and condensable PM emissions numbers.

Page 1: Please be consistent in "emission inventory" versus "emissions inventory".

Page 1: "CAA" to "Clean Air Act" for clarity

Page 3: It would be helpful to refer to 172(c)(3) in Section 1.2, bullet 1 as the planning and reporting requirements.

Page 5: Please include extension years and RFP years in Table 1's calendar years similar to what was done for Table 2. There should be one RFP projected inventory and QM beyond the extended attainment date. It would be helpful to include basic information about extension years and RFP years to better foreshadow Table 2.

Page 7: Please clarify the "winter season" inventory as the "seasonal" inventory that represents the daily average emissions across the baseline episodes.

Page 7, paragraph 1. Please include reference documentation for the following statement, "results in extremely high heating energy demand per square foot experienced in no other location in the lower-48."

Page 9: Please change "Violations" to "Exceedances." Exceedance is the term for concentrations over the standard. Violations is the term for dv over the standard.

Page 9: Add "No exceedances were recorded outside the months tabulated in Table 3 that were not otherwise flagged by Alaska DEC as Exceptional Events.", to the end of the last paragraph on the page.

Page 13: Please clarify the provenance of the BAM data (e.g., "downloaded from [state database or AQS] on XX/XX/XXXX). In particular, it is important to note if the data has been calibrated to the regulatory measurement (aka, corrected BAM).

Page 17-18. Sentence Unclear "For example, a planning inventory based on average daily emissions across the entire six-month nonattainment season will likely reflect a relatively lower fraction of wood use-based space heating emissions than one based on the modeling episode day average since wood use for space heating Fairbanks tends to occur as a secondary heating source on top of a "base" demand typically met by cleaner home heating oil when ambient temperatures get colder."

Page 19: Remove "Where appropriate,". All source sectors should be re-inventoried for 2013, even if the emissions for the sector ends up being the same as in 2008.

Page 19: Change "projected forward" to "re-inventoried", or similar wording. Reserve "project" for when the emission inventory is estimating emissions in a future year.

Page 20: Please refer to EPA's memo on the use of MOVES2014a for the plug in adjustment. As a reminder, this information is sufficient only for development of the emissions inventory, not for SIP credit.

Page 20: Please submit the technical appendix referenced on page 20. When that is submitted, we expect to provide additional comment. To allow for review, we request expedited submission.

Page 21: At bottom of page, "project" should be "re-inventoried" or something that refers to an inventory produced after the fact.

Page 22, paragraph 1, Space heating area sources. Please further explain how the combined survey data best represents 2013 emissions.

Page 23: Add information about how NH₃ was inventoried for this category.

Page 23, 2nd paragraph from bottom. Facilities need to provide direct PM and all precursors, whether directly submitted or calculated from emissions factors.

Page 23, last paragraph.

- Potential typo we believe that 2018 should be 2013.
- Question Does scaling emissions cause any point source to exceed its PTE?

Page 25, bullet 3, Laboratory – Measured Emissions Factors for Fairbanks Heating Devices. The statement "first and most comprehensive systematic" would be more credible if simplified.

Page 27: Clarify how data from the 2014 NEI was modified to reflect emissions in 2013. Were they assumed to be the same between the two years? Or adjusted based on population change, or some other information?

Page 33: Please include information on how the Speciate database was used to develop the modeling inventory (and perhaps elsewhere for the planning inventory, if appropriate).

Precursor Demonstration

Throughout the Serious Area SIP we recommend using the terminology, Precursor Demonstration, to be consistent with the PM_{2.5} Implementation Rule.

General: The overview of the nitrate chemistry is complicated. We suggest you combine the two discussions into one and organize it with the following logic:

- 1. Describe the two chemical environments: (1) daytime and (2) nighttime.
- 2. Describe the information that supports that daytime chemistry is not relevant here.
- 3. Describe the information that supports that nighttime chemistry is limited by excess NO.

- 4. Describe what happens if the entire emission inventory was increasing by a factor of 3.6 to get appropriate concentrations in the North Pole area. How does ammonium nitrate change?
- 5. Describe how increasing the emission inventory and then reducing all source sectors by 75% results in less of a reduction in $P_{M2.5}$ than reducing all source sectors by 75% in the original emission inventory.
- 6. NOTE: We are willing to provide a rough draft of this organization, if provided the original word document.

Title page: remove "com"

Page 2: Recommend using Section 188-190 instead of 7513-7513b.

Page 2: Recommend moving the last three sentences of the first paragraph to the end of the second paragraph.

Page 2: Please add "threshold" after 1.3 in the third paragraph.

Page 2: Please explain concentration-based and sensitivity-based before using the terms.

Page 2: Please add a footnote whether the numbers in the Executive Summary are SANDWICHed or not.

Page 3: Please change "has decided" to "decided."

Page 3: Make sure the concentrations listed for ammonia include ammonium sulfate and ammonium nitrate.

Page 5-7: The figure captions say that concentrations are presented but the images themselves have percentages. Please use concentrations for this analysis.

Page 9: The first paragraph says that the point sources are not responsible for the majority of sulfate at the monitors. Please substantiate that claim, or modify it.

Page 13: Please explain the relevance of referring to the VOC emissions of home heating in this summary of VOCs.

Page 14: Recommend adding "... and adjusted to reflect speciated concentrations for a total PM2.5 equal to the five year 2011-2015 design value" to the sentence that starts "The speciated PM2.5 data [were] analyzed.

Page 14: Please include the results of the concentration based analysis, perhaps as a table.

Page 14: Clarify that the concentration used for NH₃ is the ammonium sulfate and ammonium nitrate. See the draft EPA Precursor Demonstration Guidance.

Page 17: Recommend removing "slightly" and removing the sentence referring to rounding to the nearest tenth of a microgram.

Page 17-18: To help understand what is going on with the bounding run versus the normal run, it would be helpful to have the RRFs for the Modeled 75% scenario.

BACM

Page 9 and throughout: For clarity, please refer to the implementation rule as "PM_{2.5}" not "PM".

Page 14, Table 3. It would be helpful to include filter speciation data.

Page 16, Table 4: Please identify the RACM measures that were technologically and economically feasible but could not be implemented in the RACM timeline or note there were none.

Page 20 and 25, Table 6 and 7: For the final Table identifying the control measures evaluated, it would be helpful to identify the following: measure, cost/ton, BACM determination, MSM determination, and any additional comments.

Page 24: 12 measures were eliminated because they were determined to offer marginal or unquantifiable benefit. However, a measure may offer marginal benefit but may also cost very little. If there is another explanation for why these measures were not considered that follows the BACM steps, please include that in the Serious Area Plan.

Page 28: Stage 1 alerts are referred to multiple times including in Measure 2 on page 28 and Measure 33, pg 47 and pg 48. Please clarify in these analyses whether the measure applies during all stages of alerts and the associated level of control with each stage.

Page 33: Measure 13 identified that no SIPs existed or EPA guidance/requirements for the measure and incorrectly used that rationale as the conclusion for not considering the measure.

Page 34: The discussion of Measure 15 does not clearly state how Alaska and the Borough ensure that devices are taken out at the point of sale. It also does not clearly state the process for ensuring a NOASH application doesn't involve a stove that should have been taken out at the point of sale. It also states that stoves between 2.5 g/hr and 7.5 g/hr can get a NOASH, whereas page 37 implies that a stove must be <2.5 g/hr to be eligible for a NOASH.

Page 47: Measure 33 in Klamath County and Feather River is more stringent than what exists in Fairbanks now. Fairbanks allows open burning without a permit when there is no stage restriction. Alaska DEC prohibits open burning between November 1 and March 31, but the air quality plan makes it clear that the state relies on the Borough to carry out the air quality program in Fairbanks. The fact that the local borough does not require a permit for open burning outside of curtailments makes this measure less stringent in Fairbanks than in other locations. In addition, Fairbanks does not curtail warming fires during a Stage 1.

Page 48: Measure 34 is less stringent in Fairbanks than in Klamath County. Uncertainty in weather forecasting means that Stage 1 alerts are not called correctly all the time, and not

everyone is aware of when an alert is in effect. It is much simpler and less prone to error to prohibit burn barrels and outdoor burning devices entirely.

Page 57: Measure 46 review curtailment exemptions. The current Fairbanks curtailment exemption "These restrictions shall not apply during a power failure." should be reviewed to clarified that it only applies to homes reliant on electricity for heating. As currently written, it appears overly broad.

Page 68: Measure R7, Ban Use of Hydronic Heaters, incorrectly identifies that no other SIPs implemented the measure as rational for not evaluating.

Page 72: Measure R15 is technologically feasible.

Page 78: It may help to make a section break or Section 2 label for "Analysis of Marginal / Unquantifiable Benefit BACM Measures

Page 81-83: The discussion of Measure 6 may need additional documentation. Anecdotal evidence is that damping is common in Fairbanks and is potentially a bigger source of pollution than not having a damper at very cold conditions. If installation by a certified technician addresses this issue, that should be documented.

Page 84: The quote, "did not know if the rule had worked well" needs a reference. It is also not clear of how relevant that is. It could be implemented well in Fairbanks and the fact that it may not have worked well in another location does not make it technologically infeasible for this location.

Page 85-86: While qualitative assessments are helpful to provide context, a quantitative assessment will be necessary to evaluate the measures as BACM and MSM.

Page 88: There are references to Fairbanks in the conclusion for Measure 17, but the analysis refers to AAC code.

Page 89: There appears to be missing text in the Background section related to Method 9.

Page 91: Measure 23 could consider the solution that the decals could be reflective and would be seen by vehicle headlights. Measure 23 could also consider that the decals are used by neighbors to determine who is or is not in compliance. This may be helpful as citizen compliance assistance efforts could supplement the Borough enforcement program.

Page 98-100: Measure 40 needs to include a discussion of all the areas listed on page 22. In addition, if a date certain measure or if Measure 29 were instituted, Measure 40 would essentially be achieved.

Page 114: Measure R5 describes a similar rule in Utah but lists "none" under implementing jurisdictions. Please make consistent.

ULS Heating Oil

Page vii and Page 16: Please check your information on the percentage of households who have a central oil fired furnace. Please consult ADEC's contractor for the emissions inventory and home heating surveys about (1) the percentage of homes that heat only with an oil furnace, and (2) home with a central oil burner and a wood stove. We have seen different numbers than presented here.

Page 13: Please check the labels for Fairbanks HS #2 and Fairbanks HS #1. They may be switched.

Page 14: The statement that there is "a clear explanation" may not be correct, or at minimum is an overstatement. The difference in price between HS#1 and ULSD has varied over time, and the report did not include an explanation for the variations.

Page 14: The third paragraph assumes that the capital costs of shipping ULS would be more than exists today. However, all heating oil is shipped, regardless of sulfur content, and there is no justification for the report for why shipping ULS would be higher than for HS. Additionally, it is possible that the shipping cost per unit could go down marginally if only one product is being supplied to Fairbanks and/or if the quantity supplied increases.

Page 21: The text and Table 7 present inconsistent information. For instance, the text says that the discounted net-present value of scenario 2 is \$10,232 while the table says it is \$5,768.56.



3345 N. ARLINGTON HEIGHTS RD. SUITE B ARLINGTON HEIGHTS, IL 60004-1900 (847) 577-0950 FAX: (847) 577-6355 E-MAIL: bact_process@sbcglobal.net

November 1, 2018

Mr. John Solan, P.E. Senior Mechanical Engineer Stanley Consultants 8000 S. Chester Street, Suite 500 Centennial, CO 80112

RE: DSI for Aurora Energy / BACT Proposal No. 1899-R1

Dear John,

We are revising our proposal in the light of your comments. The Emissions and sorbent usage from the boiler is based on recent information from you: on 0.39 lbs. of SO2/MBTU these calculations are based on using a weight ratio of 2.6 lbs. of sodium bicarbonate to 1 lb. of sulfur and a NSR of 1.3; Sulphur at .28%; Heating Volume of 7,600; 80% removal of SO2.

BOILER	<u>MBTU/HR</u>	S02 <u>PPH</u>	SODIUM BICARBONATE PPH
1	76	29.64	100
2	76	29.64	100
3	76	29.64	100
4	269	<u>139.88</u>	<u>400</u>
	TOTAL 228 PPH		700 PPH
			0.35 Tons/Hr.
	Per Month:	8.4 Tons/Day	252 Tons

Bicarbonate Storage

For four months; we need 756 Tons of sorbent (2) Silos: 518 Tons capacity each TOTAL CAPACITY = 1,036 Tons Silo Size: Same as Eielsen

Cost of Sodium Bicarbonate = \$123,480 per month; this is based on estimate by Solvay for year 2000 delivery: \$250 plus, \$240 freight.

Scope of Supply

- 1. (2) Bolted Storage Silos 22' DIA x 100' tall with bin-vent level control and bin vibrators; capacity = 1,036 tons; storage silo complete.
- (1) Rail car unloading and diverters to fill silos located 500' away; rate = 33,000 PPH, blower = 200 HP; installed spare; backup blower.
- 3. (3) Day bins with pneumatic conveying from storage silos. Conveying distance 1,000', 6,000 PPH capacity, blower = 200 HP; blowers are spared.
- 4. (3) Classifier mills; 1,000 PPH capacity, 75 HP total, connected HP (for 2). The 75 HP is the sum of the grinding motor, classifier motor, brakes, and VFD.
- 5.&6. (3) Filter receivers with conveying blowers. Milled material conveying material from mill to filter receivers. (2) Blowers 75 HP total; total connected.
- 7. (4) Injector sets to be installed on duct work.
- 8. (1) Dedicated compressor.
- 9. (1) NEMA 6 control panel with microprocessor.
- 10. Integration to the boiler control panel.
- 11. CFD modeling and programing.
- 12. All pneumatic piping up to the reagent building. All piping within the sorbent prep building by BACT. Pipe from the building wall for the 4 pipes leading to each stack by customer. Air coolers are provided to minimize puffing of the reagent.
- 13. Sorbent building and foundation by customer.

Budget Sell Price: <u>\$4,900,000</u> Freight: \$200,000 F.O.B. Shipping Point Taxes Extra

If you have any questions, please let me know.

Best regards,

BACT PROCESS SYSTEMS, INC.

N.S. ("Bala") Balakrishnan

President





STANLEYCONSULTANTS, Inc

8000 South Chester Street > Suite 500 > Centennial, CO 80112 303.799.6806 > stanleyconsultants.com

October 30, 2018

David Fish Environmental Manager Aurora Energy, LLC 100 Cushman St. Suite 210 Fairbanks, AK 99701-4674

RE: Preliminary Opinion of Probable Cost for Addition of Dry Sorbent Injection

David,

This letter serves to document the preliminary results of our opinion of probable cost for the installation of a Dry Sorbent Injection (DSI) System at the Aurora Energy Chena Plant for the control of Sulfur Dioxide (SO₂) emissions.

Background

The US Environmental Protection Agency (EPA) has recently reclassified portions of the Fairbanks North Star Borough as a Serious PM 2.5 Non-Attainment Area. This reclassification triggers a requirement that all major sources within the non-attainment area perform a BACT analysis for particulate emissions and the emissions of any precursor pollutants. In response to this requirement Aurora Energy submitted the required BACT report to the Alaska Department of Environmental Conservation (ADEC) in March of 2017. An addendum to the report was submitted in December of that year.

After reviewing the data and conclusions presented in the BACT report, ADEC conducted their own analysis and presented their results as a Preliminary BACT Determination in March of 2018. The results developed by ADEC as a part of their analysis were significantly different from the results presented in the BACT report submitted by Aurora Energy.

Project Scope

Given the disparity in the results of the analyses, Aurora Energy has hired Stanley Consultants to develop a site-specific, third-party estimate of the costs to install SO₂ emissions control equipment on the four operating boilers at the Chena Combined Heat and Power Plant near downtown Fairbanks. Stanley Consultants will also provide an estimated sorbent consumption rate and a cost for the purchase and delivery of sorbent to site. Once these costs have been developed, Aurora Energy and their environmental consultants, ERM, will incorporate the estimated costs into a calculation to determine the cost effectiveness of the emissions control equipment on a Dollars/Tons of SO₂ removed basis.

This letter serves to document the preliminary Opinion of Probable Cost results so that Aurora Energy can submit a response to the BACT Determination ahead of a November 1, 2018 deadline. The information included herein relates only to the installation of a DSI system on the existing boilers. All performance information, quantities, and costs are preliminary and are



November 19, 2019 David Fish October 30, 2018

subject to revision as the cost estimate is refined and finalized. Additional clarifications as to the basis of the cost estimate and the anticipated performance are included below.

Design Basis

Boiler Performance and Flue Gas

Boiler heat input, flue gas flows, and uncontrolled SO₂ emissions rates from the previous reports were utilized to determine equipment sizes and required sorbent feed rates

Dry Sorbent Unloading, Storage, Preparation, and Injection System

Equipment and piping costs for the Dry Sorbent Injection Systems were developed by BACT Process Systems, Inc. BACT supplied the DSI system that was recently installed at Eielson AFB, and therefore was already familiar with the emissions from burning Healy coal in stoker-type boilers. The BACT proposal includes:

- Sorbent unloading equipment suitable for transporting sodium bicarbonate from a railcar to a bulk storage silo. This equipment includes unloading blowers, coolers, piping and piping components.
- Two bulk storage silos with a total storage capacity that is sufficient for four months of continuous full load operation.
- Sorbent transfer equipment for moving the sorbent from the bulk storage silos to the day bins located in a sorbent preparation building including transport blowers, coolers, and associated piping
- Sorbent mills for optimizing the particle size of the sorbent prior to injection into each boiler flue
- Sorbent injection equipment including filter receivers, airlock feeders, blowers, coolers, and piping up to the wall of the sorbent preparation building.
- Sorbent injection lances
- Dedicated PLC's for the control of all equipment included in the proposal
- Engineering to facilitate the integration of the sorbent control system into the plant control system
- Computational Fluid Dynamics (CFD) of each flue to confirm predicted sorbent effectiveness

Additional equipment or systems that are required for proper operation of the DSI system, but was not included in the BACT proposal have been included separately in the cost estimate. This includes:

- Piping between the sorbent preparation building and the injection lance on each flue
- Additional ductwork on Boiler 5 to increase sorbent resonance time prior to the baghouse
- Electrical feeds and equipment required to support the BACT equipment
- Foundations
- Sorbent preparation building and interior structures
- Miscellaneous steel and supports



November 19, 2019 David Fish October 30, 2018

Equipment Layout

The cost estimate is based on the following approximate equipment locations

- Unloading Equipment Adjacent to the unloading building on the north side of Phillips Field Road
- Bulk Storage and Transfer Equipment Adjacent to the existing coal pile on the south side of Phillips Field Road.
- Sorbent Preparation Building Adjacent to the existing baghouse

See the attached sketch for additional information on the proposed equipment locations and interconnecting piping.

Opinion of Probable Cost

Based on the information above, the current estimate of probable cost is as follows:

Total Installed Cost: \$20.682MM

Sorbent Cost: \$550/Ton, Delivered

Reference the attached spreadsheet for additional information relating to the equipment and construction costs used. Total installed costs include probable costs for engineering, procurement and construction of the DSI system. It also includes mobilization and indirect contractor costs such as bonding, overhead, and profit. Finally, the Total Installed Cost includes an escalation factor to account for inflation and other cost increases over the construction period.

Clarifications

- The estimated accuracy of this Opinion of Probable Costs is +50% and -30%. The accuracy is expected to improve as the cost estimate is refined.
- Sorbent consumption numbers and equipment sizing were developed based on typical performance characteristics. These characteristics are typical of a flue gas system that operates at or near 500 degrees F and has sufficient duct length ahead of a baghouse to ensure at least 2 to 3 seconds of resonance time for the sorbent. The flue gas streams from the Chena boilers operate at significantly lower temperatures (300 to 350 degrees F). The potential reduction in sorbent performance due to the existing flue gas temperatures has not yet been evaluated. Adjustments to the maximum capture rate or sorbent feed rate may be determined to be necessary as the preliminary design develops.
- The costs included in this estimate are based on the best information that we have been able to obtain to-date. The refinement of existing costs or the inclusion of additional direct or indirect costs may be determined to be necessary as the preliminary design develops.
- Sorbent pricing information provided by BACT in their equipment proposal was supplied by the sorbent vendor based on a proposal from the year 2000. Stanley Consultants is aware of sorbent pricing from other operators in the region, but we have not been given explicit permission to identify the price or the plant in question. The price identified above is our best estimate for current pricing based on the information that we have available today.


Conclusion

The preliminary Opinion of Probable Cost presented in this letter is our current best estimate for the costs associated with the procurement and installation of a DSI system at the Chena Combined Heat and Power Plant. The estimate attempts to account for many of the site-specific factors that may negatively impact the actual capital costs including, plant configuration, site layout, seismic considerations, existing infrastructure, and local construction cost factors.

We hope the information presented in this letter meets your immediate needs and we look forward to providing you with a final Opinion of Probable Costs along with supporting documentation in the near future.

Thank you for the opportunity to assist Aurora Energy in this matter.

Sincerely, John Solan

Senior Mechanical Engineer Stanley Consultants, Inc.

cc: File

Attachments: DSI Equipment Layout Sketch

Opinion of Probable Cost Tabulation



Adopted

			Rev. 0	Job No.	2870	9.01.00	Page No.	1
Stanley Consultants INC.	J Smith / S Worcester/ D Bacon	Date	10/29/2018	Subject	Aurora	Energy	Chena - Dry Sorben able Cost	t Injection
Checked by	J. Solan	Date	10/29/2018	Shoot No.		4	of	1
Approved by	C. Spooner	Date	10/30/2018	Sheet No.	antity	1	61	1
	Item Description			No. of Unit	U	IOM	Unit Cost	Total Cost
Engineering Services								
Engineering services provided throughout the project to assist with BOP design, technical specifications, procurement, bid evaluation, and construction observation.				1	I EA		\$1,880,200.00	\$1,880,200
Dry Sorbent Injection System Supply								
DSI	Includes Railcar offloading, long term storage silos, day storage							
DSI Installation DSI Equipment Freight	silos, milling, metering and feed. Field Installation FOB jobsite			1 1 1	EA EA EA		\$4,900,000.00 \$6,370,000.00 \$200,000.00	\$4,900,000 \$6,370,000 \$200,000
Structural								
Solio Foundation Sorbent Building Substructure Sorbent Building Superstructure Sorbent Building Exterior Closure Roofing Railcar Unloading Skid Foundation Transfer Skid Enclosure Foundation MCC Foundation				2 1 1 1 1 5 5 5 4	EA EA EA EA CY CY CY		\$244,304.00 \$247,047.00 \$160,334.00 \$161,334.00 \$12,149.00 \$650.00 \$650.00	\$488,608 \$247,047 \$183,067 \$160,334 \$12,149 \$3,250 \$3,250 \$2,600
Pipe Bridge by Silos - Steel	coal yard front end loader drive under.			4	TONS		\$9.000.00	\$36.000
Pipe Bridge by Silos - Foundations Outside Pipe Supports - Steel Outside Pipe Supports - Foundations Inside Pipe Supports - Steel				6 10.0 40 3.00	CY TONS CY TONS		\$650.00 \$9,000.00 \$650.00 \$9,000.00	\$3,900 \$90,000 \$26,000 \$27,000
Ductwork	100' Feet of Ductwork for Residence Time prior to PJFF			12.50	TONS		\$10,300.00	\$128,750
Mechanical								
Unit 1 Aggregate Piping Cost: 6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				300) LF		\$238.00	\$71,400
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				310	LF		\$239.00	\$74,090
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				280	LF		\$239.00	\$66,920
Unit 5 Aggregate Piping Cost: 6" Sch 80 Pipe/Flanges/Supports - Sorbent Prep to Injection Location				200	LF		\$239.00	\$47,800
Electrical				~			¢05 477 00	¢400.054
480V MCC 480V Panelboard and Xfmr	Mtl & Labor			2	2 EA		\$10,200.00	\$20,400
Cable - 480V - MCC, Loads Conduit - RGS	Mtl & Labor Mtl & Labor			9000 6800) LF) LF		\$14.83 \$20.26	\$133,436 \$137,748
Cable Terminations (Mat'l)	480V Material & Labor			496	6 EA		\$26.11	\$12,950
Light Fixtures Interior/Exterior	fixtures (Mtl & Labor)			20) EA		\$1,561.00	\$31,220
Ground Grid extension	Mtl & Labor			1050) LF		\$13.43	\$14,100
Instrumentation & Controls BOP DCS Aspects				1	EA		\$76,428.00	\$76,428
All Terrain Forklift	45' lift, 35' reach 9000 lb canacity						\$6 455 00	\$77 460
Hydraulic Crane	80-ton			12 90	WK DY		\$4,365.00	\$392,850
					Fi	urnish an	d Erection Subtotal	\$14.169.111
					Mobili-	ation & C	emobilization 5%	\$700 /50
					WODIIZ	Contracto Con	Bond - 2.5% or Overhead - 10% tractor Profit - 10%	\$708,430 \$354,228 \$1,416,911 \$1,416,911
	Escalation Percent	4.00%	Periods	14 Es	calation	Total (Nov 20	Construction Cost 18 - January 2020)	\$18,065,617 \$736,199
				PROBABLE EQUI	PMENT	& CONS	TRUCTION COST	\$18,802,000
Note: All costs presented in this document	t are Stanley Consultants' opinions of	PR probab	OBABLE EN	struction, and/or on	PMENT beration	& CONS and main	TRUCTION COST itenance costs. This	\$20,682,000 s estimate of probable
construction cost is based on our experien competitive bidding or market conditions. construction, and/or operation and mainter Construction Cost Index, and/or vendor qu	ce and represent our best judgment. Therefore, we do not guarantee that p nance costs presented. The costs ide otes.	We ha roposa ntified	ve no control o Ils, bids, or act are based on l	ver cost of labor, n ual construction cos Means Building Con	naterials sts will n structio	, equipm lot vary fr n Cost Da	ent, contractor's met rom estimates of pro ata, Engineering Net	thods, or over ject costs, ws Record



STANLEYCONSULTANTS, Inc

8000 South Chester Street > Suite 500 > Centennial, CO 80112 303.799.6806 > stanleyconsultants.com

October 30, 2018

David Fish Environmental Manager Aurora Energy, LLC 100 Cushman St. Suite 210 Fairbanks, AK 99701-4674

RE: Preliminary Opinion of Probable Cost for Addition of Dry Sorbent Injection

David,

This letter serves to document the preliminary results of our opinion of probable cost for the installation of a Dry Sorbent Injection (DSI) System at the Aurora Energy Chena Plant for the control of Sulfur Dioxide (SO₂) emissions.

Background

The US Environmental Protection Agency (EPA) has recently reclassified portions of the Fairbanks North Star Borough as a Serious PM 2.5 Non-Attainment Area. This reclassification triggers a requirement that all major sources within the non-attainment area perform a BACT analysis for particulate emissions and the emissions of any precursor pollutants. In response to this requirement Aurora Energy submitted the required BACT report to the Alaska Department of Environmental Conservation (ADEC) in March of 2017. An addendum to the report was submitted in December of that year.

After reviewing the data and conclusions presented in the BACT report, ADEC conducted their own analysis and presented their results as a Preliminary BACT Determination in March of 2018. The results developed by ADEC as a part of their analysis were significantly different from the results presented in the BACT report submitted by Aurora Energy.

Project Scope

Given the disparity in the results of the analyses, Aurora Energy has hired Stanley Consultants to develop a site-specific, third-party estimate of the costs to install SO₂ emissions control equipment on the four operating boilers at the Chena Combined Heat and Power Plant near downtown Fairbanks. Stanley Consultants will also provide an estimated sorbent consumption rate and a cost for the purchase and delivery of sorbent to site. Once these costs have been developed, Aurora Energy and their environmental consultants, ERM, will incorporate the estimated costs into a calculation to determine the cost effectiveness of the emissions control equipment on a Dollars/Tons of SO₂ removed basis.

This letter serves to document the preliminary Opinion of Probable Cost results so that Aurora Energy can submit a response to the BACT Determination ahead of a November 1, 2018 deadline. The information included herein relates only to the installation of a DSI system on the existing boilers. All performance information, quantities, and costs are preliminary and are



subject to revision as the cost estimate is refined and finalized. Additional clarifications as to the basis of the cost estimate and the anticipated performance are included below.

Design Basis

Boiler Performance and Flue Gas

Boiler heat input, flue gas flows, and uncontrolled SO₂ emissions rates from the previous reports were utilized to determine equipment sizes and required sorbent feed rates

Dry Sorbent Unloading, Storage, Preparation, and Injection System

Equipment and piping costs for the Dry Sorbent Injection Systems were developed by BACT Process Systems, Inc. BACT supplied the DSI system that was recently installed at Eielson AFB, and therefore was already familiar with the emissions from burning Healy coal in stoker-type boilers. The BACT proposal includes:

- Sorbent unloading equipment suitable for transporting sodium bicarbonate from a railcar to a bulk storage silo. This equipment includes unloading blowers, coolers, piping and piping components.
- Two bulk storage silos with a total storage capacity that is sufficient for four months of continuous full load operation.
- Sorbent transfer equipment for moving the sorbent from the bulk storage silos to the day bins located in a sorbent preparation building including transport blowers, coolers, and associated piping
- Sorbent mills for optimizing the particle size of the sorbent prior to injection into each boiler flue
- Sorbent injection equipment including filter receivers, airlock feeders, blowers, coolers, and piping up to the wall of the sorbent preparation building.
- Sorbent injection lances
- Dedicated PLC's for the control of all equipment included in the proposal
- Engineering to facilitate the integration of the sorbent control system into the plant control system
- Computational Fluid Dynamics (CFD) of each flue to confirm predicted sorbent effectiveness

Additional equipment or systems that are required for proper operation of the DSI system, but was not included in the BACT proposal have been included separately in the cost estimate. This includes:

- Piping between the sorbent preparation building and the injection lance on each flue
- Additional ductwork on Boiler 5 to increase sorbent resonance time prior to the baghouse
- Electrical feeds and equipment required to support the BACT equipment
- Foundations
- Sorbent preparation building and interior structures
- Miscellaneous steel and supports



Equipment Layout

The cost estimate is based on the following approximate equipment locations

- Unloading Equipment Adjacent to the unloading building on the north side of Phillips Field Road
- Bulk Storage and Transfer Equipment Adjacent to the existing coal pile on the south side of Phillips Field Road.
- Sorbent Preparation Building Adjacent to the existing baghouse

See the attached sketch for additional information on the proposed equipment locations and interconnecting piping.

Opinion of Probable Cost

Based on the information above, the current estimate of probable cost is as follows:

Total Installed Cost: \$20.682MM

Sorbent Cost: \$550/Ton, Delivered

Reference the attached spreadsheet for additional information relating to the equipment and construction costs used. Total installed costs include probable costs for engineering, procurement and construction of the DSI system. It also includes mobilization and indirect contractor costs such as bonding, overhead, and profit. Finally, the Total Installed Cost includes an escalation factor to account for inflation and other cost increases over the construction period.

Clarifications

- The estimated accuracy of this Opinion of Probable Costs is +50% and -30%. The accuracy is expected to improve as the cost estimate is refined.
- Sorbent consumption numbers and equipment sizing were developed based on typical performance characteristics. These characteristics are typical of a flue gas system that operates at or near 500 degrees F and has sufficient duct length ahead of a baghouse to ensure at least 2 to 3 seconds of resonance time for the sorbent. The flue gas streams from the Chena boilers operate at significantly lower temperatures (300 to 350 degrees F). The potential reduction in sorbent performance due to the existing flue gas temperatures has not yet been evaluated. Adjustments to the maximum capture rate or sorbent feed rate may be determined to be necessary as the preliminary design develops.
- The costs included in this estimate are based on the best information that we have been able to obtain to-date. The refinement of existing costs or the inclusion of additional direct or indirect costs may be determined to be necessary as the preliminary design develops.
- Sorbent pricing information provided by BACT in their equipment proposal was supplied by the sorbent vendor based on a proposal from the year 2000. Stanley Consultants is aware of sorbent pricing from other operators in the region, but we have not been given explicit permission to identify the price or the plant in question. The price identified above is our best estimate for current pricing based on the information that we have available today.



Conclusion

The preliminary Opinion of Probable Cost presented in this letter is our current best estimate for the costs associated with the procurement and installation of a DSI system at the Chena Combined Heat and Power Plant. The estimate attempts to account for many of the site-specific factors that may negatively impact the actual capital costs including, plant configuration, site layout, seismic considerations, existing infrastructure, and local construction cost factors.

We hope the information presented in this letter meets your immediate needs and we look forward to providing you with a final Opinion of Probable Costs along with supporting documentation in the near future.

Thank you for the opportunity to assist Aurora Energy in this matter.

Sincerely, John Solan

Senior Mechanical Engineer Stanley Consultants, Inc.

cc: File

Attachments: DSI Equipment Layout Sketch

Opinion of Probable Cost Tabulation

Adopted



November 1, 2018

Alaska Department of Environmental Conservation Division of Air Quality ATTN: Director 410 Wiloughby Avenue, Suite 303 Juneau, Alaska 99811-1800

Subject: Second Request for Additional Information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant.

Dear Ms. Koch,

Thank you for the opportunity to provide additional information to better characterize Aurora's operations for the Best Available Control Technology (BACT) Analysis which will be a part of the Serious Area State Implementation Plan.

The following is being provided in response to the information request letter dated September 13, 2018. The ADEC letter included an enclosure with twelve comments for which additional information was requested. Each comment is summarized below followed by a response from Aurora. The information is being submitted to the ADEC by November 1, 2018 as requested.

1. <u>Alternative Fuel Source</u> - Evaluate alternative coal sources as a potential control option for the coal-fired boilers and identify energy, environmental, and economic impacts and other costs that would affect the selection of an alternative source of coal as a technically feasible control option. Evaluate the control efficiency of alternative coal sources based on a comparison of the coal's heat content as well as nitrogen and sulfur content.

<u>Response</u>: There are no other economically viable coal options for Aurora. Usibelli Coal Mine is the state's only operating coal mine.

2. <u>Low Excess Air (LEA) and Overfire Air (OFA)</u> - Evaluate these technically feasible control technologies using EPA's top down approach.

<u>Response:</u> Aurora's BACT analysis dated March of 2017, Section 2.3.2, references the use of combustion controls, including OFA and LEA. The BACT analysis concludes that the Unit 5 (EU 7) is already equipped with OFA, LEA (i.e., oxygen trim system), and air preheaters. It is stated within the BACT that Units 1, 2, and 3 (EU 4-6) have OFA and air preheaters. Although the air preheater ductwork is installed, the preheaters have been removed from operation. The current

configuration of the traveling-grate boilers as installed, includes a 'partial' LEA (i.e., oxygen trim system). The fuel feed rate and oxygen for Boiler Units 1-3 (EU 4-6) are manually adjusted and tuned daily. The traveling-grate boilers have a knife gate which sets the bed thickness and the air-to-fuel ratio is manually adjusted to accommodate the boiler's performance. Once adjusted, the fuel-to-air ratio is maintained automatically.

Additional SO₂ Control Technologies - The BACT analysis does not include a substantive analysis of spray-dry scrubbing, dry flue gas desulfurization, dry scrubbing, or dry sorbent injection (DSI). All of these technologies have the potential to offer SO2 removal, and therefore must be included in the analysis.

<u>Response:</u> - An addendum to the initial BACT submittal was provided to the State on December 22, 2017. This addendum included a substantive analysis of Spray Dry Absorbers (SDA) and Dry Sorbent Injection (DSI) technologies.

4. <u>BACT Limits</u> - Provide numerical emission limits (and averaging periods) for each proposed BACT selection, or justify why a measurement methodology is technically infeasible and provide the proposed design equipment, or work/operational practices for pollutant for each emission unit included in the analysis. Startup, Shutdown, and Malfunction (SSM) must be addressed in the BACT analysis. In no event shall application of BACT result in emissions of any pollutant which would exceed the emissions allowed by an applicable standard under 40 C.F.R. parts 60 (NSPS) and 61 (NESHAP).

<u>Response</u>: Statements concerning applicable standards under 40 CFR Parts 60 (New Source Performance Standards—NSPS) and 61 (National Emission Standards for Hazardous Air Pollutants—NESHAP) are not relevant to the Chena boilers. The NESHAP do not regulate criteria air pollutants such as SO₂, and therefore, no SO₂ floor can be defined by any NESHAP. Furthermore, the Chena boilers are not subject to NSPS and therefore are not required to achieve the NSPS standard. In any case, the NSPS SO₂ emission limit of 1.2 lb/MM Btu (for units less than 75 MM Btu/hr) is achieved in the small boilers (the percent reduction is not a requirement for units less than 75 MM Btu/hr).

An NSPS or NESHAP standard must be considered as the floor for BACT only when a source is subject to one of the standards. In that case, a source must achieve compliance with the NSPS or NESHAP, and a less stringent emission limit cannot be considered BACT. As noted in a July 28, 1987 memo by Gary McCutchen, then Chief of the New Source Review Section of the US EPA:

"Since an *applicable* NSPS must always be met, it provides a legal "floor" for the BACT, which cannot be less stringent." (emphasis added). This statement implies that a source must first be subject to an NSPS for the standard to be considered the BACT floor.

The Chena plant operates four coal-fired boilers: three at 76.8 MM Btu/hr (22.5 megawatt, MW) heat input and one at 254.7 MM Btu/hr (74.6 MW) heat input. If newly-constructed today, the three smaller units would be subject to an NSPS Subpart Dc limit of 1.2 lb SO₂/MM Btu, and the larger unit would be subject to an NSPS Subpart Da limit of 0.15 lb SO₂/MM Btu. On a Btuweighted average basis, the overall NSPS limit would be 0.64 lb SO₂/MM Btu. The Chena boilers

currently combust low-sulfur coal, with emissions of 0.39 lb SO_2/MM Btu from the combined exhaust. This overall emission rate represents a 39% reduction from NSPS limits if the Chena boilers had been built today.

Regardless of the NSPS applicability to the Chena boilers, the history of rulemaking for small industrial, commercial, and institutional (ICI) boilers provides valuable insight into the definition of BACT for SO₂ from these units. The three smaller units, if constructed today, would be subject to NSPS Subpart Dc for small ICI boilers. As defined in the standard, ICI units smaller than 22 MW (75 MM Btu/hr) heat input are not subject to a percent reduction requirement in NSPS and instead may achieve compliance with NSPS through the use of low-sulfur fuel. The rationale for this "exemption" is provided in the preamble to the proposed rule (54 *Federal Register* (FR) 24806, June 9, 1989) and the Background Information Document for the Promulgated Standards. As discussed in the Background Document:

"Section 111 of the CAA requires standards to reflect application of the best demonstrated technology considering costs, nonair quality health and environmental impacts, and energy requirements. Section 111 also requires that for fossil fuel-fired steam generating units a percent reduction standard be established. Read together, this means that the Administrator is compelled to include a percent reduction standard unless the impacts associated with the requirements would be unreasonable....Imposing these high (capital and annualized) costs for the units (those less than 22 MW) was considered to be unreasonable when compared to the increase in emission reduction achievable be the percent reduction requirement on these units. Therefore, in keeping with the requirements of the CAA, the final standards will not require percent reduction for any units operating at less than a 55 percent annual capacity factor for coal or any unit with a heat input capacity of 22 MW (75 million Btu/hr) or less."

The passage presented above is the basis for the US EPA's definition of BACT for small ICI boilers less than 22 MW. This analysis therefore defines BACT for such units as an emission rate equal to or greater than 1.2 lb SO₂/MM Btu. In the proposed rule, US EPA further states that compliance with this NSPS limit/ BACT emission rate for units smaller than 22 MW (75 MM Btu/hr) can be achieved through use of low-sulfur fuels (see 54 FR 24793). For all practical purposes, the three smaller boilers at the Chena plant fall into this category, and therefore BACT is defined as an emission limit of 1.2 lb SO₂/MM Btu, achieved through combustion of low-sulfur coal. Furthermore, as illustrated above, the four boilers at the Chena plant collectively operate with an actual SO₂ emission level that is 39 percent less than the levels that would be required if all of the units were subject to NSPS.

5. <u>Retrofit Costs</u> - Provide detailed cost analyses and justification for difficult retrofit (1.6 – 1.9 times the capital costs) considerations used in the BACT analysis.

<u>Response</u>: The BACT cost analysis employed a retrofit factor of 2.0. The basis for this factor was the EPA Air Pollution Control Cost Manual, Sixth Edition. As discussed in the Cost Manual:

"To quantify the unanticipated additional costs of installation not directly related to the capital cost of the controls themselves, engineers and cost analysts typically multiply the

> cost of the system by a retrofit factor. The proper application of a retrofit factor is as much an art as it is a science, in that it requires a good deal of insight, experience, and intuition on the part of the analyst....The magnitude of the retrofit factor varies across the kinds of estimates made as well as across the spectrum of control devices. At the study level, analysts do not have sufficient information to fully assess the potential hidden costs of an installation. At this level, a retrofit factor of as much as 50 percent can be justified. Even at detailed cost level (± 5 percent accuracy), vendors will not be able to fully assess the uncertainty associated with a retrofit situation and will include a retrofit factor in their assessments." (see page 2-28 in EPA/452/B-02-001)

As noted in the above citation, US EPA notes that a retrofit factor can be as high as 1.5, this partially supports the value selected for the Chena BACT cost analysis. The cost model employed during the BACT analysis (i.e., CUECost) suggests the following retrofit factors: 1.0 factor for a new facility, a 1.3 factor for a moderately difficult retrofit, and a 1.6 factor for a difficult retrofit. The user is also given the option to input his own retrofit factor based on plant-specific information. As noted by the Northeast States for Coordinated Air Use Management (NESCAUM) in a in a report entitled "Applicability and Feasibility of NOx, SO2, and PM Emissions Control Technologies for industrial, Commercial, and Institutional (ICI) Boilers an independent researcher (Emmel) noted that:

"this range (of CUECost retrofit factors) significantly understated the cost of retrofit for FGD and SCR technologies when applied to EGUs (i.e., electric generating units) less than 100 MW. Emmel also noted that on average, a retrofit factor of 1.45 was more reasonable and that the factor should even be higher when CUECost is applied to ICI boilers."

Two main factors impact selection of the retrofit factor for the Chena plant: space availability and equipment congestion. These two factors will require additional efforts for installation, equipment staging, and maneuverability during construction.

6. <u>Baseline Emissions</u> - Include the baseline emissions for all emission units included in the analysis. Typically, the baseline emission rate represents a realistic scenario of upper bound uncontrolled emissions for the emissions unit (unrestricted potential to emit not actual emissions). The baseline is usually the legal limit that would exist, but for the BACT determination.

<u>Response</u>: The Baseline Emission rate is not a legal limit. As stated in the U.S. EPA 1990 New Source Review Workshop Manual:

"Calculating Baseline Emissions"

The baseline emissions rate represents a realistic scenario of upper boundary uncontrolled emissions for the source. *The NSPS/NESHAP requirements or the application of controls, including other controls necessary to comply with State or local air pollution regulations, are not considered in calculating the baseline emissions.* In other words, baseline emissions are essentially uncontrolled emissions, calculated using realistic upper boundary operating assumptions. (emphasis added)"

Based on this guidance, the Chena baseline emissions were properly calculated and applied to the BACT analysis.

7. <u>Factor of Safety</u> - If warranted, include a factor of safety when setting BACT emission limitations. The safety factor is a legitimate method of deriving a specific emission limitation that may not be exceeded. These limits do not have to reflect the highest possible control efficiencies, but rather, should allow the Permittee to achieve compliance with the numerical emission limit on a consistent basis.

<u>Response</u>: The current BACT analyses included operating as is, therefore a factor of safety was not included.

8. <u>Good Combustion Practices</u> - For each emission unit type (coal boilers, distillate boilers, engines, and material handling) for which good combustion practices was proposed as BACT, describe what constitutes good combustion practices.

<u>Response</u>: Good combustion practices were not proposed. The operation of existing combustion controls (OFA & LEA) were determined to be BACT for NOx.

 Interest Rate - All cost analyses must use the current bank prime interest rate. This can be found online at <u>https://www.federalreserve.gov/releases/h15/</u> (go to bank prime rate in the table). Please revise the cost analyses as appropriate.

<u>Response</u>: Suggest that the State revise interest rate to prime (currently 5.25%) and equipment life to 10 years, not 15, due to corresponding short remaining lifespan of associated boilers.

Economic Analysis for Circulating Dry Scrubber (CDS) - Provide in the analysis: the control
efficiency associated with CDS, captured emissions (tons per year), emissions reduction (tons
per year), capital costs (2017 dollars), operating costs (dollars per year), annualized costs
(dollars per year), and cost effectiveness (dollars per ton) using EPA's cost manual.

Response: See attached memo "CDS v SDA Cost Comparison.pdf" for CDS analysis.

11. <u>Review State's Spreadsheets</u> – Review cost effectiveness spreadsheet provided as a part of the preliminary SO₂ BACT determination which was originally developed by Sargent & Lundy (S&L) in 2010.

<u>Response</u>: Aurora has provided a review of the ADEC's cost effectiveness spreadsheets and inputs. Comments are included on the spreadsheets. Please reference documents "chena-so2-economic-analyses-adec--With ERM Comments.xlsm" and "chena-large-boiler-so2-economic-analyses-adec--With ERM Comments.xlsm".

12. <u>Site-Specific Quotes Needed</u> - The cost analyses, particularly for SO2 control technologies, must be based on emission unit-specific quotes for capital equipment purchase and installation costs at each facility. These are retrofit projects which must be considered individually in order to obtain reliable study/budget level (+/- 30%) cost estimates which are appropriate to use as the basis for decision making in determining BACT.

<u>Response</u>: Included as attachments within this response are vendor quotes as well as a cost analysis for Dry Sorbent Injection (DSI). Due to time constraints, the consultant was able to provide a +50/-30 cost estimate. Please reference the enclosed documents, to include: "Aurora Energy Preliminary Opinion of Probable Cost.pdf";

"Aurora_DSI_Opinion_of_Probable_Cost_rev0.pdf"; "BACT Proposal No. 1899-R1.pdf"; and "Aurora_Chena_DSI_General Arrangement.pdf".

Below are a list of documents that are being provided as enclosures which are referenced within the responses given above. If there are any questions pertaining to the information provided, please contact David Fish at <u>dfish@usibelli.com</u> or 907-457-0230.

Sincerely,

David Fish Environmental Manager

Enclosures:

- 1. CDS v SDA Cost Comparison.pdf
- 2. chena-so2-economic-analyses-adec--With ERM Comments.xlsm
- 3. chena-large-boiler-so2-economic-analyses-adec--With ERM Comments.xlsm
- 4. Aurora Energy Preliminary Opinion of Probable Cost.pdf
- 5. Aurora_DSI_Opinion_of_Probable_Cost_rev0.pdf
- 6. BACT Proposal No. 1899-R1.pdf
- 7. Aurora_Chena_DSI_General Arrangement.pdf
- 8. Unified Facilities Criteria (UFC) DoD Facilities Pricing Guide (ufc_3_701_01_c1_2018.pdf)
- 9. ufc_3_701_01_data_tables_may_2018.xlsx
- 10. NSPS ICI SO2 RE.docx
- 11. ICI Boilers 20081118 final_revised-Jan2009.pdf
- 12. EPA Air Pollution Cost Control Manual, sixth edition, January 2002, accessible at https://www3.epa.gov/ttncatc1/dir1/c_allchs.pdf.

Cc:

Larry Hartig, ADEC/Commissioner's Office Alice Edwards, ADEC/ Commissioner's Office Denise Koch, ADEC/ Air Quality Cindy Heil, ADEC/ Air Quality Deanna Huff, ADEC/ Air Quality Jim Plosay, ADEC/ Air Quality

Aaron Simpson, ADEC/ Air Quality Buki Wright/ Aurora Energy, LLC Rob Brown/ Usibelli Coal Mine, Inc. Tim Hamlin/ EPA Region 10 Dan Brown/ EPA Region 10 Zach Hedgpeth/ EPA Region 10



STANLEYCONSULTANTS, Inc

8000 South Chester Street > Suite 500 > Centennial, CO 80112 303.799.6806 > stanleyconsultants.com

November 1, 2018

David Fish Environmental Manager Aurora Energy, LLC 100 Cushman St. Suite 210 Fairbanks, AK 99701-4674

RE: Qualitative Cost Comparison of Circulating Dry Scrubber Technology Versus Spray Dryer Absorbers

David:

Per your request Jason Smith and I have developed a comparison between the Circulating Dry Scrubber and Spray Dry Absorption technologies and the expected differences in total installed cost. Jason is an expert in SO₂ scrubbers having participated in the construction, startup, and commissioning of several installations over the course of his career.

The two commercially available semi-dry acid gas scrubbing processes consist of Spray Dryer Absorption (SDA) and Circulating Dry Scrubber (CDS). Both technologies, for industrial coal fired applications, employ an alkaline reagent of calcium hydroxide and fly ash, which is collected from the combustion process. The calcium hydroxide reacts with sulfur dioxide (SO2) and sulfur trioxide (SO3) of the flue gas to form calcium sulfite and calcium sulfate. The calcium sulfite and calcium sulfate, unreacted calcium hydroxide, and fly ash is collected downstream of the acid gas scrubbing process by a baghouse, and a considerable portion is "recycled," back to the scrubber to offset reagent costs by utilizing available unreacted alkalinity of the fly ash. The fly ash particles also serve to increase the available surface area for reactions to occur. Both process also depend on the humidification of the flue gas. In general, the greater the humidification, the lower the alkalinity stoichiometry, which reduced reagent consumption. To prevent corrosion downstream of these scrubbers and promote the longevity of downstream equipment (namely fluework, particulate collection, and stack), the humidification is limited to operating above the saturation temperature, referred to as the approach temperature.

The humidification of the flue gas stream is an area where the SDA and CDS scrubbing processes diverge.

In the SDA process, water for humidification is delivered as a portion of the lime and ash constituents. The water, lime, and ash slurries are pumped through recirculation loops and fed to an atomization feed system. The slurry that is fed to the atomizer is then dispersed in a passing flue gas stream inside an absorber or scrubber vessel. Once dispersed in the flue gas, a chemical reaction occurs, and the gas stream is scrubbed of the SO₂ and SO₃ pollutants. Since the slurry reagent is pumped, the SDA process can sometimes leverage existing infrastructure such as existing particulate collection equipment. The ability to integrate a SDA system into an existing flue gas system serves to limit the capital outlay necessary for a targeted level of compliance. The potential to leverage existing infrastructure is dependent on



numerous factors such as existing equipment layout and condition, site spatial limitations, and original design parameters of the existing particulate collection equipment, just to name a few.

The humidification of the flue gas stream for a CDS scrubbing process is essentially decoupled from the hydrated lime and ash constituents. Water for gas humidification is mechanically atomized into the passing flue gas stream and the dry alkaline products are conveyed to the CDS vessel using air slide conveyors. Air slide conveyors utilize an air permeable fabric, which is stretched across a rectangular enclosure flow path, to aerate particulate material, and allow the force of gravity to covey the material down the sloped surface. The alkaline material and water injection typically occurs after a venturi assembly that increases the velocity of the passing gas stream to establish a fluidized bed of alkaline material. The flue gas then passes through this bed and is scrubbed of the SO_2 and SO_3 . The use of air slides to convey the fly ash from the particulate collection device (typically a baghouse) back to the scrubber necessitates that the collector be placed at higher elevations. This will ensure that the proper slope is maintained between the collector and the injection point on the absorber tower. It is technically challenging to take an existing collector and elevate it, so CDS technologies are typically purchased with an absorber vessel, air slides, particulate collection device, and waste ash systems. This allows the integration of the required elevation differences and the steel and foundations to accommodate the higher elevation construct to be handled under a single contract, thus limiting risk for the owner. Due to the additional equipment, steel, and deep foundations necessary, these factors typically increase the necessary capital outlay for the CDS technology.

Additional information on both SDA and CDS technology can be found in Chapter 34 of *STEAM, Its Generation and Use, 42nd Edition*, Babcock and Wilcox, Inc. Reference Figure 10 on Page 34-15 for an illustration of a typical SDA installation and Figure 17 on Page 34-21 for an illustration of a typical CDS installation.

The information above indicates that CDS and SDA technologies are similar in their nature and operation. However, the installation of a CDS frequently requires the installation of a new particulate collector, where the SDA system does not. The CDS equipment itself, along with the additional equipment needed for proper operation, will result in a significantly larger installation cost when compared to an equivalent SDA system. Given that the ADEC Preliminary BACT Determination for the Chena Plant (Dated March 22, 2018) has already established that a SDA system is not economically feasible (Table 4-3, Page 12), it can therefore be concluded that the CDS system is economically infeasible as well.

Please let me know if you have any questions or comments regarding the information presented in this letter.

Sincerely,

John P Solan

John P. Solan, P.E. Senior Mechanical Engineer Stanley Consultants, Inc.

cc: File



STANLEYCONSULTANTS, Inc

8000 South Chester Street > Suite 500 > Centennial, CO 80112 303.799.6806 > stanleyconsultants.com

October 30, 2018

David Fish Environmental Manager Aurora Energy, LLC 100 Cushman St. Suite 210 Fairbanks, AK 99701-4674

RE: Preliminary Opinion of Probable Cost for Addition of Dry Sorbent Injection

David,

This letter serves to document the preliminary results of our opinion of probable cost for the installation of a Dry Sorbent Injection (DSI) System at the Aurora Energy Chena Plant for the control of Sulfur Dioxide (SO₂) emissions.

Background

The US Environmental Protection Agency (EPA) has recently reclassified portions of the Fairbanks North Star Borough as a Serious PM 2.5 Non-Attainment Area. This reclassification triggers a requirement that all major sources within the non-attainment area perform a BACT analysis for particulate emissions and the emissions of any precursor pollutants. In response to this requirement Aurora Energy submitted the required BACT report to the Alaska Department of Environmental Conservation (ADEC) in March of 2017. An addendum to the report was submitted in December of that year.

After reviewing the data and conclusions presented in the BACT report, ADEC conducted their own analysis and presented their results as a Preliminary BACT Determination in March of 2018. The results developed by ADEC as a part of their analysis were significantly different from the results presented in the BACT report submitted by Aurora Energy.

Project Scope

Given the disparity in the results of the analyses, Aurora Energy has hired Stanley Consultants to develop a site-specific, third-party estimate of the costs to install SO₂ emissions control equipment on the four operating boilers at the Chena Combined Heat and Power Plant near downtown Fairbanks. Stanley Consultants will also provide an estimated sorbent consumption rate and a cost for the purchase and delivery of sorbent to site. Once these costs have been developed, Aurora Energy and their environmental consultants, ERM, will incorporate the estimated costs into a calculation to determine the cost effectiveness of the emissions control equipment on a Dollars/Tons of SO₂ removed basis.

This letter serves to document the preliminary Opinion of Probable Cost results so that Aurora Energy can submit a response to the BACT Determination ahead of a November 1, 2018 deadline. The information included herein relates only to the installation of a DSI system on the existing boilers. All performance information, quantities, and costs are preliminary and are



subject to revision as the cost estimate is refined and finalized. Additional clarifications as to the basis of the cost estimate and the anticipated performance are included below.

Design Basis

Boiler Performance and Flue Gas

Boiler heat input, flue gas flows, and uncontrolled SO₂ emissions rates from the previous reports were utilized to determine equipment sizes and required sorbent feed rates

Dry Sorbent Unloading, Storage, Preparation, and Injection System

Equipment and piping costs for the Dry Sorbent Injection Systems were developed by BACT Process Systems, Inc. BACT supplied the DSI system that was recently installed at Eielson AFB, and therefore was already familiar with the emissions from burning Healy coal in stoker-type boilers. The BACT proposal includes:

- Sorbent unloading equipment suitable for transporting sodium bicarbonate from a railcar to a bulk storage silo. This equipment includes unloading blowers, coolers, piping and piping components.
- Two bulk storage silos with a total storage capacity that is sufficient for four months of continuous full load operation.
- Sorbent transfer equipment for moving the sorbent from the bulk storage silos to the day bins located in a sorbent preparation building including transport blowers, coolers, and associated piping
- Sorbent mills for optimizing the particle size of the sorbent prior to injection into each boiler flue
- Sorbent injection equipment including filter receivers, airlock feeders, blowers, coolers, and piping up to the wall of the sorbent preparation building.
- Sorbent injection lances
- Dedicated PLC's for the control of all equipment included in the proposal
- Engineering to facilitate the integration of the sorbent control system into the plant control system
- Computational Fluid Dynamics (CFD) of each flue to confirm predicted sorbent effectiveness

Additional equipment or systems that are required for proper operation of the DSI system, but was not included in the BACT proposal have been included separately in the cost estimate. This includes:

- Piping between the sorbent preparation building and the injection lance on each flue
- Additional ductwork on Boiler 5 to increase sorbent resonance time prior to the baghouse
- Electrical feeds and equipment required to support the BACT equipment
- Foundations
- Sorbent preparation building and interior structures
- Miscellaneous steel and supports



Equipment Layout

The cost estimate is based on the following approximate equipment locations

- Unloading Equipment Adjacent to the unloading building on the north side of Phillips Field Road
- Bulk Storage and Transfer Equipment Adjacent to the existing coal pile on the south side of Phillips Field Road.
- Sorbent Preparation Building Adjacent to the existing baghouse

See the attached sketch for additional information on the proposed equipment locations and interconnecting piping.

Opinion of Probable Cost

Based on the information above, the current estimate of probable cost is as follows:

Total Installed Cost: \$20.682MM

Sorbent Cost: \$550/Ton, Delivered

Reference the attached spreadsheet for additional information relating to the equipment and construction costs used. Total installed costs include probable costs for engineering, procurement and construction of the DSI system. It also includes mobilization and indirect contractor costs such as bonding, overhead, and profit. Finally, the Total Installed Cost includes an escalation factor to account for inflation and other cost increases over the construction period.

Clarifications

- The estimated accuracy of this Opinion of Probable Costs is +50% and -30%. The accuracy is expected to improve as the cost estimate is refined.
- Sorbent consumption numbers and equipment sizing were developed based on typical performance characteristics. These characteristics are typical of a flue gas system that operates at or near 500 degrees F and has sufficient duct length ahead of a baghouse to ensure at least 2 to 3 seconds of resonance time for the sorbent. The flue gas streams from the Chena boilers operate at significantly lower temperatures (300 to 350 degrees F). The potential reduction in sorbent performance due to the existing flue gas temperatures has not yet been evaluated. Adjustments to the maximum capture rate or sorbent feed rate may be determined to be necessary as the preliminary design develops.
- The costs included in this estimate are based on the best information that we have been able to obtain to-date. The refinement of existing costs or the inclusion of additional direct or indirect costs may be determined to be necessary as the preliminary design develops.
- Sorbent pricing information provided by BACT in their equipment proposal was supplied by the sorbent vendor based on a proposal from the year 2000. Stanley Consultants is aware of sorbent pricing from other operators in the region, but we have not been given explicit permission to identify the price or the plant in question. The price identified above is our best estimate for current pricing based on the information that we have available today.



Conclusion

The preliminary Opinion of Probable Cost presented in this letter is our current best estimate for the costs associated with the procurement and installation of a DSI system at the Chena Combined Heat and Power Plant. The estimate attempts to account for many of the site-specific factors that may negatively impact the actual capital costs including, plant configuration, site layout, seismic considerations, existing infrastructure, and local construction cost factors.

We hope the information presented in this letter meets your immediate needs and we look forward to providing you with a final Opinion of Probable Costs along with supporting documentation in the near future.

Thank you for the opportunity to assist Aurora Energy in this matter.

Sincerely, John Solan

Senior Mechanical Engineer Stanley Consultants, Inc.

cc: File

Attachments: DSI Equipment Layout Sketch

Opinion of Probable Cost Tabulation

Adopted

			Rev. 0	Job No.	2870	9.01.00	Page No.	1
Stanley Consultants INC.	J Smith / S Worcester/ D Bacon	Date	10/29/2018	Subject	Aurora	Energy	Chena - Dry Sorben able Cost	t Injection
Checked by	J. Solan	Date	10/29/2018	Shoot No.		4	of	1
Approved by	C. Spooner	Date	10/30/2018	Sheet No.	antity	1	01	1
	Item Description			No. of Unit	U	IOM	Unit Cost	Total Cost
Engineering Services								
Engineering services provided throughout the project to assist with BOP design, technical specifications, procurement, bid evaluation, and construction observation.				1	I EA		\$1,880,200.00	\$1,880,200
Dry Sorbent Injection System Supply								
DSI	Includes Railcar offloading, long term storage silos, day storage							
DSI Installation DSI Equipment Freight	silos, milling, metering and feed. Field Installation FOB jobsite			1 1 1	EA EA EA		\$4,900,000.00 \$6,370,000.00 \$200,000.00	\$4,900,000 \$6,370,000 \$200,000
Structural								
Solio Foundation Sorbent Building Substructure Sorbent Building Superstructure Sorbent Building Exterior Closure Roofing Railcar Unloading Skid Foundation Transfer Skid Enclosure Foundation MCC Foundation				2 1 1 1 1 5 5 5 4	EA EA EA EA CY CY CY		\$244,304.00 \$247,047.00 \$160,334.00 \$161,334.00 \$12,149.00 \$650.00 \$650.00	\$488,608 \$247,047 \$183,067 \$160,334 \$12,149 \$3,250 \$3,250 \$2,600
Pipe Bridge by Silos - Steel	coal yard front end loader drive under.			4	TONS		\$9.000.00	\$36.000
Pipe Bridge by Silos - Foundations Outside Pipe Supports - Steel Outside Pipe Supports - Foundations Inside Pipe Supports - Steel				6 10.0 40 3.00	CY TONS CY TONS		\$650.00 \$9,000.00 \$650.00 \$9,000.00	\$3,900 \$90,000 \$26,000 \$27,000
Ductwork	100' Feet of Ductwork for Residence Time prior to PJFF			12.50	TONS		\$10,300.00	\$128,750
Mechanical								
Unit 1 Aggregate Piping Cost: 6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				300) LF		\$238.00	\$71,400
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				310	LF		\$239.00	\$74,090
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				280	LF		\$239.00	\$66,920
Unit 5 Aggregate Piping Cost: 6" Sch 80 Pipe/Flanges/Supports - Sorbent Prep to Injection Location				200	LF		\$239.00	\$47,800
Electrical				~			¢05 477 00	¢400.054
480V MCC 480V Panelboard and Xfmr	Mtl & Labor			2	2 EA		\$10,200.00	\$20,400
Cable - 480V - MCC, Loads Conduit - RGS	Mtl & Labor Mtl & Labor			9000 6800) LF) LF		\$14.83 \$20.26	\$133,436 \$137,748
Cable Terminations (Mat'l)	480V Material & Labor			496	6 EA		\$26.11	\$12,950
Light Fixtures Interior/Exterior	fixtures (Mtl & Labor)			20) EA		\$1,561.00	\$31,220
Ground Grid extension	Mtl & Labor			1050) LF		\$13.43	\$14,100
Instrumentation & Controls BOP DCS Aspects				1	EA		\$76,428.00	\$76,428
All Terrain Forklift	45' lift, 35' reach 9000 lb canacity						\$6 455 00	\$77 460
Hydraulic Crane	80-ton			12 90	WK DY		\$4,365.00	\$392,850
					Fi	urnish an	d Erection Subtotal	\$14.169.111
					Mobili-	ation & C	emobilization 5%	\$700 /50
					WODIIZ	Contracto Con	Bond - 2.5% or Overhead - 10% tractor Profit - 10%	\$708,430 \$354,228 \$1,416,911 \$1,416,911
	Escalation Percent	4.00%	Periods	14 Es	calation	Total (Nov 20	Construction Cost 18 - January 2020)	\$18,065,617 \$736,199
				PROBABLE EQUI	PMENT	& CONS	TRUCTION COST	\$18,802,000
Note: All costs presented in this document	t are Stanley Consultants' opinions of	PR probab	OBABLE EN	struction, and/or on	PMENT beration	& CONS and main	TRUCTION COST itenance costs. This	\$20,682,000 s estimate of probable
construction cost is based on our experien competitive bidding or market conditions. construction, and/or operation and mainter Construction Cost Index, and/or vendor qu	ce and represent our best judgment. Therefore, we do not guarantee that p nance costs presented. The costs ide otes.	We ha roposa ntified	ve no control o Ils, bids, or act are based on l	ver cost of labor, n ual construction cos Means Building Con	naterials sts will n structio	, equipm lot vary fr n Cost Da	ent, contractor's met rom estimates of pro ata, Engineering Net	thods, or over ject costs, ws Record



3345 N. ARLINGTON HEIGHTS RD. SUITE B ARLINGTON HEIGHTS, IL 60004-1900 (847) 577-0950 FAX: (847) 577-6355 E-MAIL: bact_process@sbcglobal.net

November 1, 2018

Mr. John Solan, P.E. Senior Mechanical Engineer Stanley Consultants 8000 S. Chester Street, Suite 500 Centennial, CO 80112

RE: DSI for Aurora Energy / BACT Proposal No. 1899-R1

Dear John,

We are revising our proposal in the light of your comments. The Emissions and sorbent usage from the boiler is based on recent information from you: on 0.39 lbs. of SO2/MBTU these calculations are based on using a weight ratio of 2.6 lbs. of sodium bicarbonate to 1 lb. of sulfur and a NSR of 1.3; Sulphur at .28%; Heating Volume of 7,600; 80% removal of SO2.

BOILER	<u>MBTU/HR</u>	S02 <u>PPH</u>	SODIUM BICARBONATE PPH
1	76	29.64	100
2	76	29.64	100
3	76	29.64	100
4	269	<u>139.88</u>	<u>400</u>
	TOTA	AL 228 PPH	700 PPH
			0.35 Tons/Hr.
	Per Month:	8.4 Tons/Day	252 Tons

Bicarbonate Storage

For four months; we need 756 Tons of sorbent (2) Silos: 518 Tons capacity each TOTAL CAPACITY = 1,036 Tons Silo Size: Same as Eielsen

Cost of Sodium Bicarbonate = \$123,480 per month; this is based on estimate by Solvay for year 2000 delivery: \$250 plus, \$240 freight.

Scope of Supply

- 1. (2) Bolted Storage Silos 22' DIA x 100' tall with bin-vent level control and bin vibrators; capacity = 1,036 tons; storage silo complete.
- (1) Rail car unloading and diverters to fill silos located 500' away; rate = 33,000 PPH, blower = 200 HP; installed spare; backup blower.
- 3. (3) Day bins with pneumatic conveying from storage silos. Conveying distance 1,000', 6,000 PPH capacity, blower = 200 HP; blowers are spared.
- 4. (3) Classifier mills; 1,000 PPH capacity, 75 HP total, connected HP (for 2). The 75 HP is the sum of the grinding motor, classifier motor, brakes, and VFD.
- 5.&6. (3) Filter receivers with conveying blowers. Milled material conveying material from mill to filter receivers. (2) Blowers 75 HP total; total connected.
- 7. (4) Injector sets to be installed on duct work.
- 8. (1) Dedicated compressor.
- 9. (1) NEMA 6 control panel with microprocessor.
- 10. Integration to the boiler control panel.
- 11. CFD modeling and programing.
- 12. All pneumatic piping up to the reagent building. All piping within the sorbent prep building by BACT. Pipe from the building wall for the 4 pipes leading to each stack by customer. Air coolers are provided to minimize puffing of the reagent.
- 13. Sorbent building and foundation by customer.

Budget Sell Price: <u>\$4,900,000</u> Freight: \$200,000 F.O.B. Shipping Point Taxes Extra

If you have any questions, please let me know.

Best regards,

BACT PROCESS SYSTEMS, INC.

N.S. ("Bala") Balakrishnan

President



November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

UNIFIED FACILITIES CRITERIA (UFC)

DoD FACILITIES PRICING GUIDE



APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED

Appendix III.D.7.7-4059

UNIFIED FACILITIES CRITERIA (UFC)

DoD FACILITIES PRICING GUIDE

Any copyrighted material included in this UFC is identified at its point of use. Use of the copyrighted material apart from this UFC must have the permission of the copyright holder.

Indicate the preparing activity beside the Service responsible for preparing the document.

U.S. ARMY CORPS OF ENGINEERS

NAVAL FACILITIES ENGINEERING COMMAND (Preparing Activity)

AIR FORCE CIVIL ENGINEER CENTER

Record of Changes (changes are indicated by $1 \dots /1$)

Change No.	Date	Location
1	6-25-18	Update Table 3 with RUC. Text update 3-2.

FOREWORD

The Unified Facilities Criteria (UFC) system is prescribed by MIL-STD 3007 and provides planning, design, construction, sustainment, restoration, and modernization criteria, and applies to the Military Departments, the Defense Agencies, and the DoD Field Activities in accordance with <u>USD (AT&L) Memorandum</u> dated 29 May 2002. UFC will be used for all DoD projects and work for other customers where appropriate. All construction outside of the United States is also governed by Status of Forces Agreements (SOFA), Host Nation Funded Construction Agreements (HNFA), and in some instances, Bilateral Infrastructure Agreements (BIA.) Therefore, the acquisition team must ensure compliance with the most stringent of the UFC, the SOFA, the HNFA, and the BIA, as applicable.

UFC are living documents and will be periodically reviewed, updated, and made available to users as part of the Services' responsibility for providing technical criteria for military construction. Headquarters, U.S. Army Corps of Engineers (HQUSACE), Naval Facilities Engineering Command (NAVFAC), and Air Force Civil Engineer Center (AFCEC) are responsible for administration of the UFC system. Defense agencies should contact the preparing service for document interpretation and improvements. Technical content of UFC is the responsibility of the cognizant DoD working group. Recommended changes with supporting rationale should be sent to the respective service proponent office by the following electronic form: <u>Criteria Change Request</u>. The form is also accessible from the Internet sites listed below.

UFC are effective upon issuance and are distributed only in electronic media from the following source:

• Whole Building Design Guide web site http://dod.wbdg.org/.

Refer to UFC 1-200-01, *DoD Building Code (General Building Requirements)*, for implementation of new issuances on projects.

AUTHORIZED BY:

an & M Willt

LARRY D. McCALLISTER, PhD, PE, PMP, SES Chief, Engineering and Construction Directorate of Civil Works U.S. Army Corps of Engineers

EDWIN H. OSHIBA, SES, DAF Deputy Director of Civil Engineers DCS/Logistics, Engineering & Force Protection

123

JOSEPH E. GOTT, P.E. Chief Engineer Naval Facilities Engineering Command

Mules M. and

MICHAEL McANDREW Deputy Assistant Secretary of Defense (Facilities Investment and Management) Office of the Assistant Secretary of Defense (Energy, Installations, and Environment)

UNIFIED FACILITIES CRITERIA (UFC) [REVISION] SUMMARY SHEET

Document: UFC 3-701-01, DoD Facilities Pricing Guide

Superseding: UFC 3-701-01, dated March 2011

Description: The document provides updated cost and pricing data in support of facility planning, investment and analysis needs.

Reasons for Document:

 This UFC provides updated cost and pricing data intended to support preparation of the DoD budget.

Impact:

• Provides consistency across the DoD for the development of budgets for military construction projects.

Unification Issues

None

TABLE OF CONTENTS

CHAPTER 1	INTRODUCTION	1
1-1	PURPOSE AND SCOPE	1
1-1.1	Chapter 2: Unit Costs for Military Construction Projects.	1
1-1.2	Chapter 3: Unit Costs for DoD Facilities Cost Models.	1
1-1.3	Chapter 4: Cost Adjustment Factors	1
1-2	APPLICABILITY	1
1-3	DATA TABLES	1
1-4	PROPONENT.	1
CHAPTER 2	UNIT COSTS FOR MILITARY CONSTRUCTION PROJECTS	3
2-1	OVERVIEW	3
2-2	FACILITY UNIT COST TABLE	3
2-3	GUIDANCE UNIT COST (GUC) DEVELOPMENT METHODOLOGY	3
2-3.1	Data Source	3
2-3.2	Business Rules	3
2-3.3	Data Normalization.	4
2-3.4	Primary Facility Included Costs	4
2-3.5	Primary Facility Excluded Costs.	5
2-3.6	Primary Facility Cost Considerations.	6
CHAPTER 3	UNIT COSTS FOR DOD FACILITIES COST MODELS	7
3-1	OVERVIEW	7
3-2	REPLACEMENT UNIT COSTS (RUC)	7
3-2.1	Definition	7
3-2.2	Use of Replacement Unit Costs	7
3-3	SUSTAINMENT UNIT COSTS (SUC).	8
3-3.1	Definition	8
3-3.2	Use of Sustainment Unit Costs	9
3-4	UNIT COST SOURCES1	0
3-4.1	Source 1 Published Data1	0
3-4.2	Source 2 Similar Data	0
3-4.3	Source 3 Derived Data1	0
3-5	REVISING UNIT COSTS1	1
CHAPTER 4	COST ADJUSTMENT FACTORS 1	3

4-1

4-1.1 4-1.2

4-1.3

4-1.4

4-1.5

4-2 4-2.1

4-2.2 4-2.3

LOCATION ADJUSTMENTS.	November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018 13
Application	
Data Source	
Survey	
Force Majeure	14
User Requested Revisions	14

ESCALATION.14

 Military Construction.
 14

 Plant Replacement Value Escalation Rates.
 14

CHAPTER 1 INTRODUCTION

1-1 PURPOSE AND SCOPE.

The DoD Facilities Pricing Guide supports a spectrum of facility planning, investment, and analysis needs. This version of the Guide reflects updated cost and pricing data for <u>FY 2018</u> intended to support preparation of the DoD budget for <u>FY 2020</u>. It includes reference information organized into three chapters, as follows:

1-1.1 Chapter 2: Unit Costs for Military Construction Projects.

Chapter 2 describes the usage of facility unit cost data for selected DoD facility types in support of preparing Military Construction (MILCON) project documentation (DD Forms 1391) and other program-level estimates in accordance with UFC 3-730-01, "Programming Cost Estimates for Military Construction."

1-1.2 Chapter 3: Unit Costs for DoD Facilities Cost Models.

Chapter 3 describes the usage of unit costs in support of DoD facilities cost models. These unit costs are based upon the reported average DoD facility size or an established benchmark size, as annotated for each Facility Analysis Category (FAC) in the DoD Real Property Classification System (published separately). These unit costs are intended for macro-level analysis and planning rather than individual facilities or projects.

1-1.3 Chapter 4: Cost Adjustment Factors.

Chapter 4 describes the usage of cost adjustment factors for location and price escalation that are applicable to the base unit costs in both Chapters 2 and 3.

1-2 APPLICABILITY.

This UFC applies to all projects in both the continental US (CONUS) and outside the continental US (OCONUS).

1-3 DATA TABLES.

All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: <u>https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.</u>

1-4 PROPONENT.

The Office of the Assistant Secretary of Defense for Energy, Installations, and Environment is the proponent for the Facilities Pricing Guide. Recommendations from users toward improving the usefulness of this reference are welcome. Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

Adopted

CHAPTER 2 UNIT COSTS FOR MILITARY CONSTRUCTION PROJECTS

2-1 OVERVIEW.

The facility unit costs in this chapter apply to preparation of programming-level cost estimates for constructing military facilities in accordance with the methodology described in UFC 3-730-01.

All data tables in this UFC are found under "Related Materials" in a combined file accompanying this UFC on the (WBDG) Web site: <u>https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.</u>

2-2 FACILITY UNIT COST TABLE.

Table 2 provides facility unit costs for various DoD facility types in dollars per square meter (\$/SM) and equivalent English unit cost data in dollars per square foot (\$/SF) as of <u>October 2017</u>. The listed facility types represent only those facilities most frequently constructed by the Military Services, and the application of a facility unit cost may not be directly applicable for those facilities with unique requirements. See UFC 3-730-01 for additional guidance on facility unit costs and their application.

The unit costs in Table 2 are average unit costs for new construction based on no less than three project awards per building type occurring since September 2014 for Army, Navy, Air Force, Defense Education Activities (for school projects) and Defense Health Agency (for medical projects) facilities as entered into the Historical Analysis Generator (HII) unit cost database prior to 1 Nov 2017. Facility additions which are less than 25% of the Reference Size of the listed facility type, and projects outside of the continental United States (OCONUS), are included only for Family Housing and DoD Schools. For additional information regarding how the facility unit costs are determined, refer to paragraph 2-3, Guidance Unit Cost Development.

2-3 GUIDANCE UNIT COST (GUC) DEVELOPMENT METHODOLOGY.

2-3.1 Data Source.

The data source for the facility unit costs is all reliable HII project records, after excluding records for reasons stated in paragraph 2-2. In general, all project records for the CONUS and projects from Alaska and Hawaii are included.

Facility level information from all three Services projects is entered into HII database for comparable service category codes (CATCODEs). Normalized project unit costs are statistically analyzed to eliminate outliers before calculating the guidance unit cost (GUC).

2-3.2 Business Rules.

The business rules are reviewed annually prior to updating Table 2 Facility Unit Costs for Military Construction. The business rules include the following components.

- The Tri-Service CATCODEs Cross-walk table groups like service CATCODEs to a common Office of the Secretary of Defense (OSD) Code. OSD Codes are not published and are only utilized for this task of segregating data. A minimum of three projects are required within those defined years to create a dataset. If there is insufficient data available within the above three-year period, the dataset search is extended to the last four years.
- Projects are new construction only.
- Projects are located within the CONUS, plus Hawaii and Alaska, except where noted otherwise in Table 2.
- Projects with extreme variation from the mean (50%) are excluded., and
- Exclusion of inappropriate data for cause.

2-3.3 Data Normalization.

Each facility-specific data set is normalized to the National Average Area Cost Factor (ACF=1) and number of bidders, and escalated to October of the year of interest, before unit costs are averaged.

- Escalation: The DoD Selling Price Index (DoD-SPI), which is an average of three commonly accepted national construction price escalation indices, is utilized to escalate actual project award cost data to October of 2017 for this UFC,
- Number of Bidders: Based on actual bid data for the data set,
- Location: Normalize each project award by the appropriate ACF to the national average of 1.0, and
- Facility Size: Normalize each facility award amount in the dataset for facility size, using a normalization process that looks at the facility size as compared to the average facility size of the selected dataset by OSD code.

2-3.4 Primary Facility Included Costs.

The facility unit costs include the following:

- Minimum antiterrorism design features (reference UFC 4-010-01, "DoD Minimum Antiterrorism Standards for Buildings") inside the building meeting Table B-1 standoff distance requirements,
- Sales tax on building materials,

- Building information system costs (e.g., conduits, racks, trays, telecommunication rooms) without any specialized communications requirements,
- Installed (built-in) building equipment and furnishings normally funded with MILCON funds,
- Energy Management Control System (EMCS) connections,
- Intrusion Detection System (IDS) infrastructure, including conduits, racks, and trays,
- Sustainable design and construction features energy consumption reduction requirements mandated before 6 November 2016; and all other sustainable design features for criteria in effect from September 2014 thru September 2017 with the exception of renewable energy generation elements,
- Progressive Collapse premiums for the following specific facility types: Inpatient Hospital/Medical Center, Primary Care Clinic (Attached), Major Command Headquarters Building, Barracks/Dormitory, and Recruit Open Bay (Barracks), and
- Standard foundation systems (e.g. strip/spread footings, thickened edge slab for slab on grade).

2-3.5 Primary Facility Excluded Costs.

The unit costs do not include the following:

- Gross receipt taxes or gross taxes, gross excise taxes, or state commerce taxes,
- "Acts of God" or unusual market conditions,
- Supporting facility costs,
- Equipment acquired with other fund sources, including pre-wired workstations or furnishing systems, intrusion detection systems,
- Sustainable design and construction features renewable energy generation elements; energy consumption reduction requirements mandated on or after 6 November 2016; and all other features mandated since September 2017; these will be estimated separately in accordance with component guidelines and documented on DD Form 1391 per DoD Instruction 4170.11, Installation Energy Management,
- Special foundations (e.g. pre-stressed concrete piles, caissons), intrusion detection system installation, base exterior architectural preservation guidelines,

- Enhanced Anti-Terrorism (AT) standards (exceeding the minimum in UFC 4-010-01, or when minimum standoff distances [Table B-1] are not achieved) construction contingency allowances,
- Cybersecurity costs,
- Supervision, inspection, and overhead (SIOH),
- Design costs (design-build contracts), and Construction cost growth resulting from user changes, unforeseen site conditions, or contract document errors and omissions.

2-3.6 Primary Facility Cost Considerations.

The following are cost considerations for primary facilities:

- <u>Medical facilities</u>: Unit costs <u>include</u> category A and category B equipment and building infrastructure for category C equipment,
- <u>Housing for Unaccompanied Military Personnel</u>: Unit costs for barracks, dormitories, and Unaccompanied Officers Quarters do not include freestanding kitchen equipment. In addition to using the size adjustment factors, use the project size adjustment factors in UFC 3-730-01,
- <u>Child Development Centers</u>: Unit costs <u>do not include</u> free-standing food service equipment or playground area and equipment,
- <u>Family housing</u>: Unit costs are based upon gross area and <u>include</u> sprinkler systems or fire-rated construction. Unit costs <u>include</u> post-award design costs,
- <u>Reserve facilities other than reserve centers</u>: Use the unit cost of the appropriate facility type, and
- Costs are independent of the acquisition strategy and are not specific to any single construction type.

Adopted

3-1 OVERVIEW.

This chapter describes the unit costs and related factors used in support of DoD facilities cost models. These unit costs are intended for macro-level analysis and planning and are not reliable for individual facilities or project estimates.

Unit costs and related factors are associated with FACs represented by a 4-digit code in the DoD Real Property Classification System (RPCS), which is a hierarchical scheme of real property types and functions that serves as the framework for identifying, categorizing, and modeling the DoD's inventory of land and facilities. FACs are common across the department and suitable for department-wide applications. For each FAC, Table 3 identifies the associated unit cost to be used in DoD facilities cost models and metrics.

Whenever possible, unit costs and factors have been based upon approved government or commercial benchmarks. Detailed supporting data for unit costs is available, and accompanies this UFC on the WBDG Web site. All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: <u>https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.</u>

3-2 REPLACEMENT UNIT COSTS (RUC).

3-2.1 \1\ Definition and Use of Replacement Unit Costs. /1/

\1\ Replacement unit costs form the basis of calculating Plant Replacement Value (PRV) in a consistent manner across DoD, representing a complete and useable facility built to current DoD design standards. Replacement unit costs can also support largescale program-level estimates for re-stationing plans with the addition of allowance for site preparation, earthwork, landscaping, and related factors. Replacement unit costs should not be used for individual project estimates. /1/

Replacement \1\ unit /1/ costs include construction of standard foundations, all interior and exterior walls and doors, the roof, utilities out to the 5-foot line, all built-in plumbing and lighting fixtures, security and fire protection systems, electrical distribution, wall and floor coverings, heating and air conditioning systems, and elevators. Replacement \1\ unit /1/ costs do not include project costs such as design, supporting facility costs, special foundations, equipment acquired with other funding sources (e.g. missionfunded components), contingency costs, or supervision, inspection, and overhead (SIOH). \1\ unit /1/ costs also do not include items that are generally considered personal property such as computer systems, and furniture. See paragraph 3-5, Revising Unit Costs, for guidance on requesting changes \1\ to replacement unit costs /1/in Table 3.

3-2.2 \1\ Plant Replacement Value (PRV). /1/
November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

DoDI 4165.14 defines PRV as the cost to design and construct a notional facility to current standards to replace an existing facility on the same site. The factor values are provided in the "Report of the Plant Replacement Value (PRV) Panel, August 2001-May 2003" published by the Office of the Deputy Under Secretary of Defense (Installations and Environment). The standard DoD formula for calculating PRV is:

Equation 3-2 Calculating PRV

PRV = Q x RUC x ACF x HF x PD x SIOH x CF

Where:

PRV is plant replacement value

Q is facility quantity, in the same unit of measure as the RUC

RUC is replacement unit cost found in Table 3 of this UFC

ACF is area cost factor found in Table 4 of this UFC, to account for geographical differences in the costs of labor, materials and equipment

HF is an adjustment of 1.05 to account for increased costs for replacement of historical facilities or for construction in a historic district. The factor is 1.0, should the facility not qualify as "historical".

PD is a factor to account for the planning and design of a facility; the current value of this factor is 1.09 for all but medical facilities, and 1.13 for medical facilities.

SIOH is the factor to account for the supervision, inspection, and overhead activities associated with the management of a construction project. The current value of the factor is 1.057 for facilities in the (CONUS), and 1.065 (USACE) or 1.062 (NAVFAC) for facilities in the (OCONUS).

CF is a factor of 1.05 to account for construction contingencies

3-3 SUSTAINMENT UNIT COSTS (SUC).

3-3.1 Definition.

Sustainment provides for maintenance and repair activities necessary to keep a typical inventory of facilities in good working order over its expected service life. It includes the following:

- Regularly scheduled adjustments and inspections, including maintenance inspections (e.g., fire sprinkler heads, HVAC systems) and regulatory inspections (e.g., elevators, bridges),
- Preventive maintenance tasks,
- Emergency response and service calls for minor repairs, and
- Major repair or replacement of facility components (usually accomplished by contract) that are expected to occur periodically throughout the facility service life.

Sustainment includes regular roof replacement, refinishing wall surfaces, repairing and replacing electrical, heating, and cooling systems, replacing tile and carpeting and similar types of work as well as overhead costs which include architectural and engineering services. It does not include repairing or replacing non-attached equipment or furniture, or building components that typically last more than 50 years (such as foundations and structural members). Sustainment does not include restoration, modernization, environmental compliance, facility leases, specialized historical preservation, general facility condition inspections and assessments, planning and design (other than shop drawings), or costs related to Acts of God, which are funded elsewhere. Other tasks associated with facilities operations (such as custodial services, grass cutting, landscaping, waste disposal, and the provision of central utilities) are also not included.

3-3.2 Use of Sustainment Unit Costs.

Sustainment unit costs represent the annual average sustainment cost for each FAC, and serve as the basis for calculating annual facilities sustainment requirements for DoD using the following formula:

Equation 3-3 Calculating Sustainment Requirement

$$SR = Q \times SUC \times SACF \times I$$

Where:

SR is sustainment requirement

Q is facility quantity, in the same unit of measure as the SUC

SUC is sustainment unit cost found in Table 3

SACF is sustainment area cost factor found in Table 4

I is the value(s) representing future-year escalation for operation and maintenance accounts, published in Table 4-4.

The Sustainment Requirement for each qualifying asset in the DoD inventory is aggregated by sustaining organization and sustainment fund type in the Facilities Sustainment Model (FSM), published annually.

3-4 UNIT COST SOURCES.

Unit costs for DoD cost models are developed using a variety of sources. These sources fall into the three categories described below, listed in order of preference of use. The source description and source group for each unit cost are identified in Table 3. Supporting documentation for each unit cost calculation is available in the "Supporting documentation" file download accompanying this UFC document on the WBDG website: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

3-4.1 Source 1 Published Data

Standard, easily-accessible published data that is highly applicable to the FAC. Source 1 is the most desirable due to ease of access, general applicability, and lack of bias. Examples include the DoD Tri-Service Committee on Cost Engineering, Service-specific cost guidance (USACE), commercial cost-estimating guidelines or models, or other Government-published cost guidance from federal, state, or local government agencies (e.g. Fairfax County (Virginia) Park Authority). Non-DoD source 1 data may require refinement for application in DoD, but is still considered source 1 if it closely matches the design attributes of the FAC.

3-4.2 Source 2 Similar Data

Data that is applied to facilities with similar but not identical characteristics (e.g., sewage waste treatment facilities and industrial waste treatment facilities). Source 2 also includes unpublished government or trade association cost data, and Component-validated costs for non-standard facilities that have no commercial counterparts (e.g. missile launch facilities or military ranges).

3-4.3 Source 3 Derived Data

Unpublished project-specific data derived from Component project documents (e.g. DD Forms 1391) or from calculating costs from reported Plant Replacement Value and inventory, or derived from using a ratio of sustainment to construction from a similar source 1 Facilities Analysis Category (e.g. FAC 2115, Aircraft Maintenance Hangar, Depot derived from FAC 2111, Aircraft Maintenance Hangar).

3-5 REVISING UNIT COSTS.

Users of this UFC are encouraged to suggest revisions to the published cost factors, particularly for facilities unique to their mission. Submit proposed changes to the proponent office in accordance with the following guidelines:

- Revised costs should come from an equivalent or superior source,
- Revised costs should be easily audited,
- Revised costs should be consistent with the functional definitions,
- Revised costs should be consistent with the FAC scope and
- Revised costs should be suitable for application throughout DoD.

Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

CHAPTER 4 COST ADJUSTMENT FACTORS

4-1 LOCATION ADJUSTMENTS.

Table 4-1 provides area cost factors (ACFs) to be used for adjusting "bare" unit costs to location-specific costs for the most common locations.

All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

4-1.1 Application

For military construction projects, use the MILCON ACFs with the primary facility unit costs from Chapter 2 or approved Air Force, Army, or Navy MILCON Pricing Guide. For calculating Plant Replacement Value, use the MILCON ACFs with the appropriate RUCs from Chapter 3. For calculating sustainment costs, use the sustainment ACFs with the appropriate SUCs from Chapter 3.

Do not use the MILCON ACFs to modify parametric cost estimates, detailed quantitytake-offs, unit price book (UPB) line items, commercial cost data, or user-generated unit costs. These cost estimating methods and databases have their own processes and factors for adjusting costs to different locations. MILCON ACFs or any component(s) that make up MILCON ACFs are only applicable to construction costs and should not be applied or utilized for any other purpose.

4-1.2 Data Source

In general, the Tri-Service Cost Engineering ACF software program evaluates the local costs for a United States market basket of eight labor crafts, 18 construction materials, and four equipment items. These labor, materials, and equipment (LME) items are representative of the types of products, services, and methods used to construct most military facilities in the United States. Each of the LME costs is normalized and weighted to represent its contribution to the total cost of a typical facility. The normalized LME is then modified by seven matrix factors that cover local conditions affecting construction costs. These matrix factors include weather, seismic, climatic (frost zone, wind loads, and HVAC systems), labor availability, contractor overhead and profit, logistics, and labor productivity and are relative to the U.S. standard. The resultant ACF for each location is normalized again by dividing by the 96-Base-City average to provide a final ACF that reflects the relative relationship of construction costs between that location and the 96-Base-City average as 1.00.

MILCON ACFs are calculated using a LME ratio of 35/63/2. Sustainment ACFs are calculated using a LME ratio of 53/46/1.

4-1.3 Survey

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

Both CONUS and OCONUS construction market surveys were conducted in 2017. The CONUS survey covered 300 locations that included 96 Base Cities (two per state in the continental U.S.). The OCONUS survey included 75 locations, and was based on a market basket of goods for typical U.S. labor, material, equipment, and construction methods.

CONUS and OCONUS surveys are performed annually. When local materials and construction methods differ from those represented by the published ACF, specific adjustments may need to be added to the project estimate to account for any differences. There is no easy correlation between the current MILCON ACFs and previous MILCON ACFs for specific locations. No common benchmarks exist because both the Base City average and the relationships between cities change with each survey. It is possible, however, to compare differences between several locations in this database with differences between the same locations in previous databases.

4-1.4 Force Majeure

The ACF is not intended to, or capable of, responding to rapid changes in the market place. Examples include Acts of God, accelerated construction schedules, changes in the demand and supply for construction materials, labor, and equipment. An increased demand for labor beyond what the local market can supply may require the enticement of premium pay, overtime hours, temporary living expenses, and travel expenses.

4-1.5 User Requested Revisions

Users may request revisions to published ACFs when market conditions unexpectedly change. Each request must be initiated by the USACE District senior cost engineer through HQUSACE or by the NAVFAC regional cost engineer to their corresponding NAVFAC Atlantic or Pacific Tri-Service Cost Engineering committee member. The local cost engineer shall provide updated market basket ACF software input factors with adequate backup documentation to HQUSACE or NAVFAC for them to update the Tri-Service Cost Engineering ACF software.

4-2 ESCALATION.

Tables 4-2, 4-3, and 4-4 provide escalation (inflation) factors used to adjust unit costs in Tables 2 and 3 (expressed in base-year dollars) to the desired year, as follows:

4-2.1 Military Construction.

Military construction project estimates that use unit costs from Table 2 should use the military construction escalation factor from table 4-2 for the expected midpoint of construction as described in UFC 3-730-01.

4-2.2 Plant Replacement Value Escalation Rates.

Plant Replacement Value (PRV) calculations that use replacement unit costs from Table 3 should use the escalation factor from Table 4-3 for the desired program year.

14

4-2.3 Facilities Sustainment.

Modeled facilities sustainment cost estimates that use unit costs from Table 3 should use the O&M escalation factor from Table 4-4 for the desired program year.

Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

APPENDIX A REFERENCES

UNIFIED FACILITIES CRITERIA

http://www.wbdg.org/ccb/browse_cat.php?o=29&c=4

UFC 3-730-01, Programming Cost Estimates for Military Construction

PLANT REPLACEMENT VALUE

https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01

Report of the Plant Replacement Value (PRV) Panel, August 2001 – May 2003, R&K Engineering, Inc. for the Office of the Deputy Under Secretary of Defense (Installations and Environment)



EPA-450/3-90-016

Small Industrial-Commercial-Institutional Steam Generating Units --Background Information for Promulgated Standards

Emission Standards Division

U.S. ENVIRONMENTAL PROTECTION AGENCY Office of Air and Radiation Office of Air Quality Planning and Standards Research Triangle Park, North Carolina 27711

August 1990

Appendix III.D.7.7-4083

2.3.3 Percent Reduction Standard

1. <u>Comment</u>: Two commenters (IV-D-08, IV-D-28) requested that the 90 percent SO₂ reduction requirement be eliminated and replaced with an emission limit of 520 ng/J (1.2 lb/million Btu) heat input. One commenter (IV-D-08) objected to applying the 90 percent SO₂ reduction requirement to all coal regardless of sulfur content. This commenter stated that the EPA's conclusion that no units will be built in the size range between 22 and 29 MW (75 and 100 million Btu/hr) heat input capacity and operating at greater than 55 percent capacity factor is flawed. This commenter stated that the SO₂ standard of 520 ng/J (1.2 lb/million Btu) heat input for coal-fired plants should apply to all steam generating units in this source category, regardless of size. This commenter further recommended that the full 90 percent SO₂ removal be required only when the 520 ng/J (1.2 lb/million Btu) limit could not be met by using low sulfur coals or by pretreating the coals.

Another commenter (IV-D-28) stated that the 90 percent SO_2 reduction requirement should be removed and that coal-fired steam generating units in the 8.7 to 29 MW (30 to 100 million Btu/hr) range should be required only to meet the 520 ng/J (1.2 lb/million Btu) SO_2 limit. The commenter stated that the percent reduction requirement would place an unjustified cost and performance burden on units in this range that either already meet or are close to meeting the 520 ng/J (1.2 lb/million Btu) SO_2 limit.

<u>Response</u>: Section 111 of the CAA requires standards to reflect application of the best demonstrated technology considering costs, nonair quality health and environmental impacts, and energy requirements. Section 111 also requires that for fossil fuel-fired steam generating units a percent reduction standard be established. Read together, this means that the

2-22

Administrator is compelled to include a percent reduction standard unless the impacts associated with the requirements would be unreasonable. As discussed in the background document, "Model Boiler Cost Analysis for Controlling Sulfur Dioxide (SO₂) Emissions from Small Steam Generating Units" (EPA-450/3-89-14), a small coal-fired steam generating unit of 22 MW (75 million Btu/hr) size and operating at a 55 percent capacity factor has an incremental cost-effectiveness value of about \$3,600/Mg (\$3,300/ton) relative to an emission limit standard of 520 ng/J (1.2 lb/million Btu). Capital and annualized costs are projected to increase by approximately 20 percent over the regulatory baseline for the percent reductions standard. However, these values increase significantly for units less than 22 MW (75 million Btu/hr) heat input capacity and for any unit less than 29 MW (100 million Btu/hr) operating at an annual capacity factor for coal of less than 55 percent. Imposing these high costs for these units was considered to be unreasonable when compared to the increase in emission reductions achievable by the percent reduction requirement on these units. Therefore, in keeping with the requirements of the CAA, the final standards will not require percent reduction for any units operating at less than a 55 percent annual capacity factor for coal or any unit with a heat input capacity of 22 MW (75 million Btu/hr) or less.

Finally, no conclusion was made that coal-fired steam generating units greater than 22 MW (75 million Btu/hr) heat input and greater than 55 percent capacity factor would not be built. Rather, this was a projection of sales over the next five years based on sales trends over the past several years. The sales projections for coal-fired units had no influence on the conclusion of the reasonableness of the percent reduction requirement. (The assumption was used in generating national impacts of the standards.) The model steam generating unit analysis examined the potential impacts of the percent reduction requirement on a coal-fired unit greater than 22 MW (75 million Btu/hr) and greater than 55 percent capacity factor. Therefore, should a unit be built, requiring 90 percent reduction of emissions would be reasonable.

2-23

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Northeast States for Coordinated Air Use Management (NESCAUM)

November 2008

(revised January 2009)

Appendix III.D.7.7-4086

Members of Northeast States for Coordinated Air Use Management

Arthur Marin, Executive Director Northeast States for Coordinated Air Use Management

Anne Gobin, Bureau Chief Connecticut Department of Environmental Protection, Bureau of Air Management

James P. Brooks, Bureau Director Maine Department of Environmental Protection, Bureau of Air Quality

Barbara Kwetz, Director Massachusetts Department of Environmental Protection, Bureau of Waste Prevention

Robert Scott, Director New Hampshire Department of Environmental Services, Air Resources Division

William O'Sullivan, Director New Jersey Department of Environmental Protection, Office of Air Quality Management

David Shaw, Director New York Department of Environmental Conservation, Division of Air Resources

Douglas L. McVay, Acting Chief Rhode Island Department of Environmental Management, Office of Air Resources

Richard A. Valentinetti, Director Vermont Department of Environmental Conservation, Air Pollution Control Division

UNITS, SPECIES, ACRONYMS

Acronyms

- APCD Air Pollution Control Device
- BACT -Best Available Control Technology
- BART Best Available Retrofit Technology
- BOOS Burners Out of Service
- CAA Clean Air Act
- CAAA Clean Air Act Amendments (of 1990)
- CFBA Circulating Fluidized-Bed Absorption
- CFR Code of Federal Regulations
- DI Dry Injection
- DSI Dry Sorbent Injection
- EGU Electricity Generating Unit
- ESP Electrostatic Precipitators
- FBC Fluidized Bed Combustion
- FF Fabric Filter (also known as baghouse)
- FGD Flue Gas Desulfurization (also known as SO₂ scrubber)
- FGR Flue Gas Recirculation
- FOM Fixed Operating and Maintenance Costs
- FSI Furnace Sorbent Injection
- GR Gas Reburn
- HHV Higher Heating Value
- ICI Industrial, Commercial, and Institutional (boilers)
- LAER Lowest Achievable Emission Rate
- LNB Low-NOx Burner
- LSDI Lime Slurry Duct Injection
- LSFO Limestone Forced Oxidation
- LSC Low-Sulfur Coal (also known as compliance coal)
- MACT Maximum Achievable Control Technology
- MANE-VU Mid-Atlantic-Northeast Visibility Union
- MC Mechanical Collector
- NAAQS National Ambient Air Quality Standard
- NCG Non-Condensable Gases
- NESCAUM Northeast States for Coordinated Air Use Management
- NSPS New Source Performance Standards
- NSR Normalized Stoichiometric Ratio
- OFA Overfire Air
- PC Pulverized Coal
- PRB Powder River Basin (coal)
- RACT Reasonably Available Control Technology
- RPO Regional Planning Organization
- SCA Specific Collection Area
- SCR Selective Catalytic Reduction

SD – Spray Dryer
SIP – State Implementation Plan
SNCR – Selective Non-Catalytic Reduction
TCR – Total Capital Requirement
TR – Transformer Rectifier
UBC – Unburned Carbon
US EIA – United States Energy Information Administration
US EPA – United States Environmental Protection Agency
ULNB – Ultra Low-NOx Burner
VOM – Variable Operating and Maintenance (costs)
WESP – Wet Electrostatic Precipitator
WFGD – Wet Flue Gas Desulfurization (also known as wet SO₂ scrubber)

Chemical Species

HCl – Hydrochloric Acid HF – Hydrofluoric Acid H₂SO₄ – Sulfuric Acid NOx – Oxides of Nitrogen (NO₂ and NO) NO – Nitric Oxide NO₂ – Nitrogen Dioxide NH₃ – Ammonia PM_{2.5} – Particulate Matter up to 2.5 μ m diameter in size PM₁₀ – Particulate Matter up to 10 μ m diameter in size S – Sulfur SO₂ – Sulfur Dioxide SO₄ – Sulfate VOC – Volatile Organic Compound

Units

<u>Length</u> m – meter μ m – micrometer or micron (0.000001 m; 10⁻⁶ m) km – kilometer (1000 m; 10³ m) Mm – Megameter (1,000,000 m; 10⁶ m)

<u>Flow Rate</u> acfm – actual cubic feet per minute

 $\frac{\text{Volume}}{\text{L} - \text{liter}}$ m³ - cubic meter

<u>Mass</u> lb – pound g – gram μ g – micrograms (0.000001 g; 10⁻⁶ g) Adopted

kg – kilograms (1000 g; 10^3 g)

<u>Force</u> psi – pounds per square inch

 $\label{eq:wer} \begin{array}{l} \underline{Power} \\ W-watt \mbox{ (Joules/sec)} \\ kW-kilowatt \mbox{ (1000 W; $10^3 W)} \\ MW-megawatt \mbox{ (1,000,000 W; $10^6 W)} \end{array}$

Energy Btu – British thermal unit (= 1055 Joules) MMBtu – million Btu MWhr – megawatt-hour kWhr – kilowatt-hour

 $\frac{Concentration}{\mu g/m^3 - micrograms per cubic meter}$

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Northeast States for Coordinated Air Use Management (NESCAUM)

November 2008

(revised January 2009)

iv

Appendix III.D.7.7-4091

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Project Director

Praveen Amar, Ph.D., P.E., Director, Science and Policy, NESCAUM

Principal Contributors

Constance L. Senior, Ph.D., Reaction Engineering International Rui Afonso, Energy and Environmental Strategies

Acknowledgments

NESCAUM gratefully acknowledges the funding support provided by the United States Environmental Protection Agency (Clean Air Markets Division (CAMD) and Office of Air Quality Planning and Standards (OAQPS)). Mr. Sikander Khan (CAMD) and Mr. Tim Smith (OAQPS) acted as the Project Managers and Mr. Gene Sun was the Grant Manager.

This report was managed and directed by NESCAUM (Dr. Praveen Amar). NESCAUM was very ably supported by its contractors, Reaction Engineering International (Dr. Constance L. Senior) and Energy and Environmental Strategies (Mr. Rui Afonso). Additionally, Mr. Addison Faler, a student intern at NESCAUM, did extensive data analysis of emission estimates from industrial, commercial, and institutional boilers in the Northeast and the US. Ms. Wendy Roy, Administrative Assistant, NESCAUM, was extremely helpful in final formatting of the report.

NESCAUM thanks the members of the NESCAUM Stationary Sources and Permitting Committee, who guided the design of this report in early stages and provided access to the operating permits data, included in this report. The following individuals provided strong technical support and comments on various draft versions of this report:

Andrew Bodnarik, New Hampshire Department of Environmental Services

Sunila Agrawal, New Jersey Department of Environmental Protection

NESCAUM is an association of the eight northeast state air pollution control programs and provides technical guidance and policy advice to its member states.

TABLE OF CONTENTS

UNITS, SPECIES, ACRONYMSi						
A	cknow	ledgn	nents	vi		
E	EXECUTIVE SUMMARYxii					
1	IN	TRODUCTION1-1				
	1.1	.1 Objectives				
	1.2	1.2 Regulatory Drivers		1-1		
	1.3	1.3 Characterization of Combustion Sources				
	1.3.1 Description of Combustion Sources			1-1		
	1.3.2 Emissions by Size, Fuel, and Industry Sector		1-2			
	1.3.3 Differences between EGU and ICI boilers		1-7			
	1.3.4 Control Technology Overview		Control Technology Overview	1-10		
	1.4	Cha	pter 1 References			
2	NC	Ox CO	NTROL TECHNOLOGIES	2-1		
	2.1	Intro	oduction	2-1		
	2.1	.1	ICI versus EGU Boilers	2-1		
	2.1	.2	Control Technologies' Impact on Efficiency and CO ₂ Emissions	2-2		
	2.2 Discussion of NOx Control Technologies		2-3			
	2.2.1 NOx Formation		2-3			
	2.2.2 NOx Reduction		2-3			
	2.2	2.2.3 Other Benefits of NOx Control Technologies		2-3		
	2.3 Summary of NOx Control Technologies		2-3			
	2.3.1 Combustion Modifications		Combustion Modifications	2-3		
	2.3	.2	Low-NOx Burners and Overfire Air	2-4		
2.3.3		.3	Reburn			
	2.3.4		Post-Combustion Controls	2-6		
2.3.5		.5	Technology Combinations	2-11		
	2.4	App	licability to ICI Boilers	2-12		
	2.5	Effic	ciency Impacts			
	2.6	NOx	x Control Costs	2-13		
	2.7	Cha	pter 2 References			
3	SO	$_2$ COI	NTROL TECHNOLOGIES			
	3.1	SO_2	Formation			
	3.2	SO_2	Reduction			

	3.3	Other FGD Benefits			
	3.4	Summary of FGD Technologies			
	3.4.1		Wet Processes		
	3.4	.2	Dry Processes		
	3.4	.3	Other SO ₂ Scrubbing Technologies		
	3.5	Use	of Fuel Oils with Lower Sulfur Content		
	3.6	App	licability of SO ₂ Control Technologies to ICI Boilers		
	3.7	Effic	ciency Impacts		
	3.8	SO_2	Control Costs		
	3.9	Cha	pter 3 References		
4	PM	I CON	NTROL TECHNOLOGIES		
	4.1	PM	Formation in Combustion Systems		
	4.2	PM	Control Technologies	4-1	
	4.3	Dese	cription of Control Technologies		
	4.3	.1	Fabric Filters		
4.3.2 4.3.3 4.3.4 4.3.5		.2	Electrostatic Precipitators		
		.3	Venturi Scrubbers		
		.4	Cyclones	4-7	
		.5	Core Separator		
	4.4	App	licability of PM Control Technologies to ICI Boilers		
	4.5	Effic	ciency Impacts		
	4.6	PM	Control Costs	4-10	
	4.7	Cha	pter 4 References		
5	AP	PLIC	ATION OF A COST MODEL TO ICI BOILERS	5-1	
	5.1	Cost	t Model Inputs and Assumptions		
	5.2	Con	nparison of the Cost Model Results with Literature		
	5.3	Sum	ımary	5-11	
	5.4	Cha	pter 5 References		
6	SU	MMA	ARY	6-1	
	6.1	NO	x Controls	6-1	
	6.2	SO_2	Controls		
	6.3	PM	Controls	6-3	
APPENDIX A : Survey of Title V Permits in NESCAUM Region					
A	APPENDIX B: CUECost-ICI Inputs				

LIST OF FIGURES

FIGURE 1-1.	TOTAL CAPACITY OF INDUSTRIAL BOILERS AS A FUNCTION OF SIZE [EEA, 2005]1-3
FIGURE 1-2.	TOTAL AND AVERAGE BOILER CAPACITY OF U.S. INDUSTRIAL BOILERS AS A FUNCTION
OF FUE	L FIRED [EAA, 2005]
FIGURE 1-3	TOTAL ANNUAL EMISSIONS OF NOX, SO ₂ , AND $PM_{2.5}$ from ICI boilers in the U.S.
AND IN	THE EIGHT-STATE REGION FROM EPA AIRDATA DATABASE
FIGURE 1-4.	Emissions of NOx, SO ₂ , and $PM_{2.5}$ from ICI boilers in the NESCAUM region
FROM N	MANEVU DATABASE AS A FUNCTION OF FUEL FIRED
FIGURE 1-5.	SOLID-FUEL BOILER INFORMATION FROM FOUR NORTHEAST STATES, BASED ON TITLE
V PERM	IIT INFORMATION 1-8
FIGURE 2-1.	LOW-NOX BURNER [TODD DYNASWIRL-LN ^{IM}]
FIGURE 2-2.	GAS REBURN APPLIED TO A STOKER BOILER [WWW.GASTECHNOLOGY.ORG]2-6
FIGURE 2-3.	SNCR SYSTEM SCHEMATIC [FUELTECH]
FIGURE 2-4.	3-D SCHEMATIC OF AN SCR SYSTEM [ALSTOM POWER]
FIGURE 2-5.	SCHEMATIC AND ACTUAL RSCR [TOUPIN, 2007]2-9
FIGURE 2-6.	BLOCK OF MONOLITH CERAMIC HEAT EXCHANGER [TOUPIN, 2007]2-10
FIGURE 2-7.	CAPITAL COST FOR NOX CONTROL FOR COMBUSTION MODIFICATION APPLIED TO ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 2-8.	CAPITAL COST FOR NOX CONTROL FOR SNCR APPLIED TO ICI BOILERS AS A
FUNCTI	ON OF BOILER CAPACITY
FIGURE 2-9.	CAPITAL COST FOR NOX CONTROL FOR SCR APPLIED TO ICI BOILERS AS A FUNCTION
OF BOII	LER CAPACITY
FIGURE 3-1.	SCHEMATIC OF A WFGD SCRUBBER [BOZZUTO, 2007]
FIGURE 3-2.	SCHEMATIC OF A SPRAY DRYER
[HTTP:/	//www.epa.gov/eogapti1/module6/sulfur/control/control.htm]
FIGURE 3-3.	DRY SORBENT INJECTION (DSI) SYSTEM DIAGRAM
[HTTP:/	//www.epa.gov/eogapti1/module6/sulfur/control/control.htm]
FIGURE 3-4.	FLOW DIAGRAM FOR TRONA DSI SYSTEM [DAY, 2006]
FIGURE 3-5.	SO ₂ REMOVAL TEST DATA [DAY, 2007]
FIGURE 3-6.	INDUSTRIAL ENERGY PRICES FOR NO. 6 OIL GREATER THAN 1 PERCENT S, NO. 6 OIL
LESS TH	HAN 1 PERCENT S, AND NO. 2 OIL [SOURCE: US EIA, 2008]
FIGURE 3-7.	INDUSTRIAL ENERGY PRICES FOR NO. 2 (DISTILLATE) OIL [SOURCE: US EIA, 2008]. 3-
10	
FIGURE 3-8.	CAPITAL COST FOR SO_2 control for dry sorbent injection applied to ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 3-9.	CAPITAL COST FOR SO_2 CONTROL FOR SPRAY DRYER ABSORBER APPLIED TO ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 3-10). CAPITAL COST FOR SO_2 CONTROL FOR WET FGD APPLIED TO ICI BOILERS AS A
FUNCTI	ON OF BOILER CAPACITY
FIGURE 4-1.	PHOTOGRAPH OF FABRIC FILTER COMPARTMENT WITH FILTER BAGS [SOURCE:
WWW.H	IAMON-RESEARCHCOTTRELL.COM]
FIGURE 4-2.	SIDE VIEW OF DRY ESP SCHEMATIC DIAGRAM [SOURCE: POWERSPAN]4-4
FIGURE 4-3.	WET ESP [CROLL REYNOLDS]
FIGURE 4-4.	VENTURI SCRUBBER [CROLL REYNOLDS]

1-8
1-9
5-8
5-9
5-9
10
11

LIST OF TABLES

TABLE ES-1. ICI BOILER CONTROL TECHNOLOGIES xvii
TABLE 1-1. CAPACITY OF INDUSTRIAL BOILERS [EEA, 2005] 1-3
TABLE 2-1. CO AND NOX REDUCTION USING RSCR [SOURCE: BPEI 2006]2-10
TABLE 2-2. RSCR COST EFFICIENCY [BPEI, 2008]2-11
TABLE 2-3. SUMMARY OF NOX CONTROL TECHNOLOGIES 2-13
TABLE 2-4. NOX CONTROL COSTS FOR COMBUSTION MODIFICATIONS APPLIED TO ICI BOILERS 2-14
TABLE 2-5. NOX CONTROL COSTS FOR SNCR APPLIED TO ICI BOILERS
TABLE 2-6. NOX CONTROL COSTS FOR SCR APPLIED TO ICI BOILERS 2-18
TABLE 3-1. COMPARISON OF PRICE FOR FSI AND LSDI SYSTEMS FOR A 100 MW COAL-FIRED
BOILER [DICKERMAN, 2006]
TABLE 3-2. COMPARISON OF ALTERNATIVE FGD TECHNOLOGIES [BOZZUTO, 2007]3-8
TABLE 3-3. COST ESTIMATES FOR ALTERNATIVE FGD TECHNOLOGIES [BOZZUTO, 2007]3-8
TABLE 3-4. DISTILLATE AND RESIDUAL OIL STOCKS IN 2006 (X1000 BARRELS) [US EIA, 2006]. 3-9
TABLE 3-5. EXAMPLE OF COSTS OF SWITCHING TO LOW-SULFUR FUEL OIL [FUEL PRICES FROM US
EIA, 2008]
TABLE 3-6. Summary of energy impacts for SO_2 control technologies
TABLE 3-7. SO ₂ control costs applied to ICI boilers
TABLE 4-1. AVAILABLE PM CONTROL OPTIONS FOR ICI BOILERS
TABLE 4-2. CORE SEPARATOR COLLECTION EFFICIENCY [USEPA, 2008; RESOURCE SYSTEMS
GROUP, 2001]
TABLE 4-3. CORE SEPARATOR COST ANALYSIS [B. H. EASON TO P. AMAR, 2008]4-9
TABLE 4-4. Summary of energy impacts for control technologies
TABLE 4-5. PM control costs applied to ICI boilers
TABLE 5-1. CUECOST GENERAL PLANT INPUTS 5-2
TABLE 5-2. FUEL CHARACTERISTICS AND ASSUMPTIONS FOR CUECOST CALCULATION OF HEAT
RATE AND FLUE GAS FLOW RATES
TABLE 5-3. EQUIVALENT HEAT INPUT RATE AND FLUE GAS FLOW RATES FOR 250 and 100
MMBTU/HR HEAT INPUT RATES
TABLE 5-4. CAPITAL AND OPERATING COSTS FOR NOX CONTROL TECHNOLOGIES (ASSUMING
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-5. CAPITAL AND OPERATING COSTS FOR SO_2 control technologies (assuming
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-6. CAPITAL AND OPERATING COSTS FOR PM CONTROL TECHNOLOGIES (ASSUMING
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-7. CAPITAL AND OPERATING COSTS FOR SNCR ON WOOD-FIRED BOILERS, COMPARISON
OF COST CALCULATIONS FROM AF&PA AND CUECOST

EXECUTIVE SUMMARY

ES-1 Objectives

The main objective of this study is to evaluate the viability of technologies for controlling emissions of nitrogen oxides (NOx), sulfur dioxide (SO₂), and particulate matter (PM) from industrial, commercial, and institutional (ICI) boilers. These pollutants contribute to the formation of ozone, fine particles, and regional haze, and to ecosystem acidification. This source sector is coming under increased scrutiny by air quality regulators needing emission reductions to meet Clean Air Act requirements.

This study also includes a literature review of emission control costs and develops methods for estimating the costs and cost effectiveness of air pollution controls for ICI boilers. The study concludes that ICI boilers are a significant source of emissions, are relatively uncontrolled compared to electricity-generating units (EGUs), and offer the potential to achieve cost effective reductions for all three pollutants. The results of this technical and economic evaluation are intended as a resource in assessing regulatory and compliance strategies for ICI boilers.

Most of the technologies considered in this report have been successfully applied to the larger EGU boilers. This study investigates both the feasibility of down-scaling such control technologies for ICI boiler applications and of certain technologies that have not been applied to EGUs, but show promise for the ICI boilers.

ES-2 Report Organization

Chapter One provides an overview of the ICI boiler fleet in terms of boiler size, applications, fuel type and associated emissions. Chapters Two, Three, and Four discuss control technology options for NOx, SO₂ and PM, respectively. Each chapter provides: (1) descriptions of available control technologies; (2) a discussion of the applicability of these technologies to ICI boilers; (3) published cost estimates; and (4) an assessment of the impact of control technologies on overall facility efficiency. Chapter Five summarizes information about air pollution control equipment costs for ICI boilers calculated with the Coal Utility Environmental Cost (CUECost) model.

ES-3 Differences between ICI and EGU Boilers

ICI and EGU boilers differ in size, application, design, and emissions. Most commercial and institutional boilers are relatively small, with an average capacity of 17 MMBtu/hour. Industrial boilers can be as large as 1,000 MMBtu/hr or as small as 0.5 MMBtu/hr. By contrast, the average size of a coal-fired EGU boiler in the U.S. is greater than 2,000 MMBtu/hr.

All coal-fired EGUs in the United States are equipped with PM control devices and many have SO_2 and NOx emission controls. ICI boilers are significantly less likely to have air pollution control devices.

As part of this study, NESCAUM conducted a preliminary survey of the use of emission controls on ICI boilers in the Northeast. Survey results revealed that more than half of the units surveyed in the region had no controls; about one-third had PM controls, while very few units

had NOx controls. None of the surveyed units had SO_2 controls, although some have wet venturi scrubbers for PM control, which minimally reduce SO_2 emissions.

Technical, operational, economic and regulatory factors impose different opportunities and constraints on the applicability of air pollution control devices (APCDs) for EGU and ICI boilers. The following technical and operational characteristics must be evaluated in determining the potential applicability of emission controls for specific ICI boilers.

- Fuel type and quality SO₂, PM, and NOx emissions from coal-fired boilers are typically higher than from those burning natural gas, oil, or wood waste. Some APCD technologies are not particularly sensitive to such variations. For example, an electrostatic precipitator (ESP) or a fabric filter (FF) can accommodate different PM concentrations, although the type and size of PM and gas temperatures will have an impact. Other controls that utilize reagents, such as SO₂ scrubbers and selective catalytic reduction or selective non-catalytic reduction (SCR/SNCR) technologies for NOx, are directly affected by fuel type and quality.
- Duty cycle APCD controls must be capable of accommodating significant variation or cycling of boiler loads. These variations affect flue gas flow rates and temperatures, which in turn may require different control capability. For example, an SCR or SNCR system must operate within a temperature window that may or may not exist across the load range for a particular ICI boiler.
- Design differences The presence of equipment such as economizers or air preheaters has a direct impact on flue gas temperatures. Temperature-sensitive technologies such as ESPs, SO₂ scrubbers, and SCR/SNCR that are widely used in EGUs may or may not be applicable to ICI boilers in certain cases.

ES-4 NOx Control Technologies

Emission control strategies for NOx can be divided into two basic categories: combustion modifications and post-combustion technologies. Control efficiency ranges and cost effectiveness (\$/ton of NOx removed) for various technologies are provided in Table ES-1. Combustion modification technologies, which minimize the formation of NOx during the combustion process, include: combustion tuning; low-NOx burners and overfire air (LNBs and OFA); and gas, oil, or coal reburn.

LNBs have minimal effect on overall operating costs, but may introduce higher carbon monoxide and/or carbon levels in the fly ash, which reflect lower plant efficiency. In the case of gas reburn, operating costs are primarily a function of the fuel cost differential; for coal or oil reburn, fuel preparation costs (pulverization and atomization, respectively) represent the primary operating and maintenance costs. While gas reburn is easier to implement, the fuel differential costs are often prohibitive. The overall cost of low-NOx combustion technology installation depends on the firing system, and this is reflected in the lack of a clear relationship between capital cost and boiler capacity.

Post-combustion technologies reduce the amount of NOx exiting the stack that was formed during combustion. This group includes SNCR, SCR, and regenerative SCR (RSCR) technologies. Because the reaction occurs without the need for catalysts, SNCR systems have

lower capital costs, but achieve lower NOx reduction. SCR, on the other hand, is capitalintensive, but offers the opportunity for significantly greater NOx reductions because a dedicated reactor and a reaction-promoting catalyst ensure a highly controlled, efficient reaction. RSCR combines a regenerative thermal oxidizer with SCR technology, making it suitable for facilities with lower gas temperatures, such as those found in some ICI boilers. RSCRs can also reduce carbon monoxide emissions by half.

ES-5 SO₂ Control Technologies

SO₂ emission control technologies are post-combustion devices that utilize a process involving SO₂ reacting in the exhaust gas with a reagent (usually calcium- or sodium-based) and removal of the resulting product (a sulfate/sulfite) for disposal or commercial use. SO₂ control technologies are commonly referred to as flue gas desulfurization (FGD) and/or "scrubbers" and are usually characterized in terms of the process conditions (wet vs. dry), byproduct utilization (throwaway vs. saleable), and reagent utilization (once-through vs. regenerable). Wet scrubbers provide much greater levels of SO₂ control. Conventional dry processes include spray dryers (SDs) and dry sorbent injection (DSI). The capital costs of wet scrubbers are higher than those of dry scrubbers, although the cost effectiveness values (in dollars per ton of SO₂ removed) of wet and dry processes are similar. DSI technology has a significantly lower capital cost than wet or dry scrubbers and should therefore be more attractive for ICI boilers than conventional scrubbers.

In the eight-state NESCAUM region, residual oil is a common fuel for ICI boilers. Switching to a lower sulfur residual oil (for example, from 3 percent to 1 percent sulfur residual oil) can provide cost-effective SO_2 reductions. The cost of switching to lower sulfur distillate oil is much higher than switching to low sulfur residual oil, because the cost of distillate oil has been about twice that of residual oil in recent years. The cost effectiveness (in dollars per ton of SO_2 removed) from switching from residual fuel oil to distillate fuel oil is not as attractive and falls in the range of the cost effectiveness of installing a FGD scrubber.

ES-6 PM Control Technologies

Combustion processes emit both primary and secondary particulate matter. Primary emissions consist mostly of fly ash (e.g., non-combustible inorganic matter and unburned solid carbon). Secondary emissions are the result of condensable particles such as nitrates and sulfates that typically make up the smaller fraction of the particulate matter. PM control technologies include: fabric filters or "baghouses," wet and dry ESPs, venturi scrubbers, cyclones, and core separators. While PM controls are not currently widely used on ICI boilers, there are no technical reasons why PM controls cannot be applied to solid-fueled and oil-fired ICI boilers.

ES-7 Impact of Control Technologies on Operational Efficiency and Carbon Dioxide Emissions

Air pollution control technologies and strategies (e.g., fuel switching) can have varying impacts on the overall efficiency of the host plant. This impact can be either positive or negative depending on technology and fuel choices.

Carbon dioxide (CO_2) emissions are primarily a function of the carbon content of fuels. However, the application of conventional pollutant control technologies can affect CO_2 emissions. This impact can vary widely among technologies within the same pollutant (e.g., LNB vs. SCR for NOx), as well as across different pollutants (e.g., fabric filter for PM vs. scrubbers for SO₂).

Combustion modification technologies for NOx have essentially no impact on the CO_2 emissions of the host boilers – with the noted exception of reburn when displacing coal or oil with natural gas – because the technologies do not impose any significant parasitic energy consumption (auxiliary power) requirements. With respect to the post-combustion technologies, both SNCR and SCR impose some degree of energy demand on the host boiler. These impacts include pressure, compressor, vaporization, and steam losses, and can range from 1–2 kW/1000 actual cubic feet per minute (acfm) for SNCR and up to about 4 kW/1000 acfm for SCR.

The major components affecting energy consumption for SO_2 systems include electrical power associated with material preparation (e.g., grinding) and handling (pumps/blowers), flue gas pressure loss across the scrubber vessel, and steam requirements. The power consumption of the SO_2 control technologies is further affected by the SO_2 control efficiency of the technology itself. SO_2 controls have a range of potential parasitic losses, from duct injection representing about 1–2 kW/1000 acfm to wet FGD at as high as 8 kW/1000 acfm.

PM control technologies will result in some parasitic energy loss due to pressure loss, power consumption, and ash handling. Dry ESPs and fabric filters have the lowest associated parasitic power consumption (<2 kW/1000 acfm), while high-energy venturi scrubbers can be up to 10 kW/1000 acfm or higher.

ES-8 Cost Analysis

Cost is an important factor in evaluating the viability of air pollution control technologies. Information on capital and operating costs is more readily available for EGU than ICI boilers. Operating costs may be different for ICI boilers than utility boilers because of their size and the fact that they are typically located on smaller sites. Operating costs also include waste disposal and reagent use. ICI boiler sites typically have higher contingency, general facility, engineering, and maintenance costs, as a percentage of total capital cost, than those for utility boilers.

Cost estimates for ICI boilers with capacities ranging from 100 to 250 MMBtu/hr were generated by the CUECost model. This model, created by Raytheon Engineers for US EPA, was originally developed for large coal-fired EGUs and calculates capital and operating costs for certain pre-defined air pollution control devices for NOx, SO₂, and PM. The CUECost model produces approximate estimates (\pm 30 percent accuracy) of installed capital and annualized operating costs. The CUECost model was adapted in this study for ICI boilers burning a variety of fuels by changing the fuel composition and heating value to simulate different fuels. This study represents the first attempt to utilize a comprehensive cost model specific to ICI boilers.

Chapter Two contains a detailed discussion of the literature values for NOx control costs for ICI boilers. The NOx control costs for ICI boilers computed with CUECost were largely consistent with values reported in the literature. In terms of NOx removal, reported values were in the range of \$1,000 to \$3,000 per ton for LNBs or SNCR, and \$2,000 to \$14,000 per ton for SCR. The SCR costs for coal-fired ICI boilers appear to be consistent with the literature, although the CUECost capital cost values for residual oil were higher than the literature values. The capital costs for SNCR calculated from the CUECost models were in good agreement with literature values, particularly their sensitivity to boiler capacity. The capital costs for LNBs

calculated from CUECost for coal-fired boilers were consistent with the literature values, although the costs for residual oil-fired boilers were higher in CUECost than the literature values.

Chapter Three contains a detailed discussion of the literature values for SO_2 control costs for ICI boilers. In terms of the cost per ton of SO_2 removed, reported values were in the range of \$1,600 to \$5,000 for spray dryers (SDs) and \$1,900 to \$5,200, for wet FGDs. The SO_2 capital costs computed with CUECost for SDs were in the range of the literature values at 250 MMBtu/hr. However, the capital costs computed by CUECost for wet FGDs were high compared to values reported in the literature.

Chapter Four contains a detailed discussion of the literature values for PM control costs. Literature values for capital costs for PM control were evaluated from EPA reports on PM controls applied to industrial boilers. The cost effectiveness of ESPs was in the range of \$50 to \$500 per ton of PM for coal, and up to \$20,000 per ton of PM for oil. The cost effectiveness of baghouses was in the range of \$50 to \$1,000 per ton of PM for coal and up to \$15,000 per ton of PM for oil.

The dry-ESP control costs computed with CUECost were consistent with the literature values, although the CUECost predicted slightly higher values than reported by EPA for dry, wire-plate ESPs. The baghouse/fabric filter costs computed with CUECost were higher than the literature values for pulse-jet fabric filters.

This adaptation of CUECost model from EGUs to ICI boilers was intended to investigate the feasibility of estimating costs of controlling emissions of NOx, SO_2 , and PM from ICI boilers. Further detailed work would be needed to validate this approach, but initial results included in this report are promising.

ES-9 Conclusion

ICI boilers are a significant source of NOx, SO₂, and PM emissions, which contribute to the formation of ozone, fine particles, and regional haze, and to ecosystem acidification. These boilers are relatively uncontrolled compared to EGUs and offer the potential to achieve cost-effective reductions for all three pollutants. A host of proven emission control technologies for EGUs can be scaled-down and deployed in industrial, commercial, and institutional settings to cost-effectively reduce emissions of concern. Other technologies that have not been applied to EGUs show promise for ICI boiler applications. Careful analysis will be needed to match the appropriate emission control technology for specific applications given: boiler size, fuel type/quality, duty-cycle, and design characteristics. Further, regulators will need to determine the level of emission reductions needed from this sector in order to inform the appropriate choice of controls.

Pollutant	Technology	Control Efficiency	Cost Effectiveness \$ per ton	
NOx				
Combustion Modifications	Tuning	5-15%	current data not available	
	LNB	25-55%	\$750-\$7,500	
	Reburn	35-60%	current data not available	
Post- Combustion	SNCR	30-70%	\$1,300-\$3,700	
	SCR	70-90%	\$2,200-\$14,400	
	RSCR	60-75%	\$4,500	
SO ₂	Wet Scrubbers	95+%	\$1,900-\$5,200	
	Spray Dryers	90-95%	\$1,600-\$5,200	
	Dry Sorbent Injection	40-90%	current data not available	
PM				
	Fabric Filters/Baghouses	99+%	\$400-\$1,000 – coal \$6,900-\$16,500- oil	
	Wet/Dry ESPs	99+%	\$160-\$2,600 – coal	
			\$2,300 to \$43,000 - oil	
	Venturi Scrubbers	50-90%	current data not available	
	Cyclones	70-90%	current data not available	
	Core Separators	60-75%	current data not available	

Table ES-1. ICI Boiler Control Technologies

1 INTRODUCTION

1.1 Objectives

The main objective of this study is to evaluate various available control technologies and their cost effectiveness in reducing emissions of three pollutants: oxides of nitrogen (NOx), sulfur dioxide (SO₂), and primary fine particulate matter ($PM_{2.5}$) from industrial, commercial, and institutional (ICI) boilers. The study results should provide a strong technical and economic basis for developing cost-effective regulations and strategies to reduce emissions of these three major pollutants from ICI boilers.

1.2 Regulatory Drivers

Federal, state and local governments regulate all major criteria air pollutants under the authority of the Clean Air Act (CAA). The CAA mandates control of pollutants such as NOx, SO₂, and PM_{2.5} to attain and maintain National Ambient Air Quality Standards (NAAQSs) for ozone and PM_{2.5}, reduce acidic deposition, and improve visibility under regional haze regulations. Emission standards for specific source categories, including ICI boilers, are also set by federal, state, and local governments to attain and maintain a NAAQS. Examples of these emission standards include New Source Performance Standards (NSPS), Best Available Control Technology (BACT), Lowest Achievable Emission Rate (LAER), Reasonably Available Control Technology (RACT), and Best Available Retrofit Technology (BART).

States must formulate State Implementation Plans (SIPs) that provide a framework for limiting air emissions from major sources as part of a strategy for demonstrating attainment and maintenance of NAAQS. Some individual SIPs (if allowed by the state law) may set more stringent limits on emissions of NOx, SO₂, and PM_{2.5} than required by the federal rules. However, states cannot set less stringent limits than required by federal rules and regulations. Generally, federal, state, and local permitting authorities rely upon available information on the latest advanced technologies for emission control when setting emission limits. Where applicable, permitting authorities require BACT and RACT in order to reduce air emissions from stationary sources. In areas that have not achieved a NAAQS (i.e., non-attainment areas), the CAA requires air pollution limits established by LAER for new major stationary sources and major modifications to existing stationary sources. BACT and RACT analyses consider the cost of controls. LAER control technologies, applicable to new major sources located in non-attainment areas, must be installed, operated and maintained without consideration of costs.

1.3 Characterization of Combustion Sources

1.3.1 Description of Combustion Sources

Boilers utilize the combustion of fuel to produce steam. The hot steam is then employed for space and water heating purposes or for power generation via steam-powered turbines.

Boiler size is typically represented in four ways: fuel input in units of MMBtu/hr, output of steam in lb steam/hr at a specified temperature and pressure, boiler horsepower (1 boiler hp = 33,475 MMBtu/hr), or electrical output in MWhr or MW (if electricity is generated).

The three main types of boilers are described below:

- *Firetube boilers*. Hot gases produced by the combustion of fuel are used to heat water. The hot gases are contained within metal tubes that run through a water bath. Heat transfer through thermal conduction heats the water bath and produces steam. Typically, firetube boilers are small, with capacity below 100 MMBtu/hr.
- *Watertube boilers*. Hot gases produced by fuel combustion heat the metal tubes containing water. Typically, there are several tubes configured as a "wall." Watertube boilers vary in size from less than 10 MMBtu/hr to10,000 MMBtu/hr.
- *Fuel-firing*. Fuel is fed into a furnace and the high gas temperatures generated are used to heat water. Fuel-firing boilers include stoker, cyclone, pulverized coal, and fluidized beds. Stokers burn solid fuel and generate heat either as flame or as hot gas. Pulverized coal (PC) enters the burner as fine particles. The combustion in the furnace produces hot gases. The ash (the unburned fraction) exits in molten or solid form. Fluidized beds utilize an inert material to "suspend" the fuel. The suspension allows for better mixing of the fuel and subsequently better combustion and heat transfer to tubes.

Boilers are also classified by the fuel they use – chiefly coal, oil, natural gas, wood, and waste byproducts.

1.3.2 Emissions by Size, Fuel, and Industry Sector

In 2005, Energy & Environmental Analysis, Inc. [EEA, 2005] estimated that there were 162,805 industrial and commercial boilers in the U.S., which had a total fuel input capacity of 2.7 million MMBtu/hr as summarized in Figure 1-1 and Table 1-1. This estimate included 43,015 industrial boilers with a total capacity of 1.6 million MMBtu/hr and 119,790 commercial boilers with a total capacity of 1.1 million MMBtu/hr. In addition, EEA estimated that there were approximately 16,000 industrial boilers in the non-manufacturing sector with a total capacity of 260,000 MMBtu/hr, but details on size distribution of these boilers were not provided because these units were not well characterized.

The EEA report divided boilers into two major categories (industrial and commercial) instead of the more common characterization as industrial, commercial, and institutional boilers. One segment of the ICI boiler population, identified as non-manufacturing industrial boilers, is not included in the EEA analyses due to a lack of sufficient data. The non-manufacturing segment accounted for only 11 percent of energy consumption in the industrial boiler population. The manufacturing and non-manufacturing segment of the population appear (from EEA's description) to correspond to what would be called industrial boilers. The commercial segment of the population includes what are designated in this report as commercial and institutional boilers. For example, there are several large boilers located at major institutions such as universities (e.g., Notre Dame, Cornell, etc.) and also several large boilers located at major hospitals (e.g., Massachusetts General Hospital) that belong in the institutional category instead

of the commercial sector. Thus, EEA's analysis appears to apply to most of the ICI boiler population, representing 89 percent of energy use by ICI boilers.

Industrial boilers were generally larger than commercial units. Sixty percent of the boilers in the manufacturing sector were greater than 100 MMBtu/hr in capacity, whereas 60 percent of the boilers in the commercial sector were in the range of 10 to 100 MMBtu/hr. The average capacity of the commercial boilers was 10 MMBtu/hr, with most less than 10 MMBtu/hr; the capacity of the average industrial boiler was 36 MMBtu/hr. Non-manufacturing boilers fell in between, at an average capacity of 16 MMBtu/hr. For industrial boilers, the average capacity factor was 47 percent (capacity factor is defined as the ratio of actual heat input in MMBtu to the maximum heat input based on nameplate capacity of the unit, calculated for a period of one year).

	Manufacturing	Non-Mfg	Commercial	
Unit Capacity	Boilers	Boilers*	Boilers	Total
<10 MMBtu/hr	102,306		301,202	403,508
10-50 MMBtu/hr	277,810		463,685	741,495
50-100 MMBtu/hr	243,128		208,980	452,108
100-250 MMBtu/hr	327,327		140,110	467,437
>250 MMBtu/hr	616,209		33,639	649,848
Total Capacity, MMBtu/hr	1,566,780	260,000	1,147,617	2,714,397
Total Capacity >10 MMBtu/hr	1,464,474		846,415	2,310,889**
Total number of units	43,015	16,000	119,790	162,805
Average Capacity, MMBtu/hr	36	16	10	17

*No details provided on range of capacities

**Total does not include non-manufacturing boilers



Figure 1-1. Total capacity of industrial boilers as a function of size [EEA, 2005]

1-3 Appendix III.D.7.7-4107
Five major steam-intensive industries accounted for more than 70 percent of the boiler units and more than 80 percent of the boiler capacity of the manufacturing segment of industrial boilers: food, paper, chemicals, petroleum refining, and primary metals. The non-manufacturing segment of the industrial sector included agriculture, mining and construction. The largest categories in the commercial sector, by capacity, were schools, hospitals, lodgings, and office buildings.

Industrial boilers in the manufacturing sector are used to generate process steam and electricity. The fuels used in manufacturing boilers are related to the size of the boilers and, in some cases, the byproducts generated in the particular manufacturing process.

In the food production subsector, the average boiler capacity was 20 MMBtu/hr. The relatively small average capacity was reflected in the higher percentage (58 percent) of natural gas-fired boilers in the food industry than in any other major subsector, since very small boilers tend to burn natural gas.

The paper industry included some of the largest industrial boilers, with an average boiler size of 109 MMBtu/hr. The paper industry represented more than half (230,000 MMBtu/hr) of the total capacity of the manufacturing sector. More than 60 percent of the fuel used in paper industry boilers was wood (bark, wood chips, etc.) or black liquor, a waste product from the chemical pulping process.

The chemical industry employed both large and small boilers, with about seven percent of the units with capacities smaller than 10 MMBtu/hr, and a significant number (about 350 or 37 percent of total capacity) larger than 250 MMBtu/hr. The primary fuels for chemical industry boilers were natural gas (43 percent), process off-gas (39 percent), and coke (15 percent).

The refining industry had an average boiler size of 143 MMBtu/hr, the largest of any of the major industries, with over 200 boilers with capacities above 250 MMBtu/hr. By-product fuels (refinery gas or carbon monoxide) were the most common fuel source for boilers (58 percent), followed by natural gas (29 percent) and residual oil (11 percent).

About half of the total boiler capacity in the primary metals industry was from boilers larger than 100 MMBtu/hr. By-product fuels, like coke oven gas and blast furnace gas, provided the largest share (63 percent) of boiler fuel in the primary metals industry.

The remaining industries accounted for about 29 percent of manufacturing boilers (12,000 units) or about 18 percent of industrial boiler capacity. The average capacity for the rest of the manufacturing subsector was 23 MMBtu/hr. Approximately 100 boilers at other manufacturing facilities had capacities larger than 250 MMBtu/hr.

Unlike industrial boilers, which serve production processes, commercial boilers provide space heating and hot water for buildings. Natural gas fired the vast majority of commercial boilers, including 85 percent of commercial boiler units and 87 percent of the total commercial boiler capacity. About 10 percent of the commercial boilers were fired by oil. Coal was fired at about one percent of the commercial boilers, but represented five percent of the capacity, reflecting the larger size of commercial coal-fired boilers.

Figure 1-2 summarizes the total US boiler capacity in the manufacturing and commercial sectors as a function of fuel fired (left side of figure) and shows the average capacity per boiler (right side of figure) by fuel type. Coal-fired boilers were the largest in size on average. As discussed above, natural gas accounted for 70 percent of the total industrial boiler capacity in the

EEA survey. Coal and byproduct fuels accounted for about 10 percent each, with lesser capacity in oil- and wood-fired boilers.

In the manufacturing sector, the average coal-fired boiler capacity was about 180 MMBtu/hr, but the average capacity in both sectors combined was about 125 MMBtu/hr. Wood- and byproduct-fired boilers in the manufacturing sector were also large on average (120 and 110 MMBtu/hr, respectively). On the other hand, oil- and natural gas-fired boilers were small, on the order of 20 MMBtu/hr in the manufacturing sector and less than 10 MMBtu/hr in the commercial sector.





From EEA's 2005 study, the following general conclusions about boiler size for the entire U.S. ICI boiler population can be drawn:

- natural gas is the fuel fired at most ICI boilers;
- natural gas- and oil-fired boilers tend to be small, less than 20 MMBtu/hr in capacity;
- boilers fired with coal, wood, or process byproducts are larger in size, greater than 100 MMBtu/hr on average;
- although natural gas fired most of the ICI boilers in the U.S., coal, oil, and wood contribute substantially more to the emissions of SO₂ and PM; and
- all fuels are sources of NOx emissions.

One needs to be careful drawing conclusions for the eight-state NESCAUM region based on the national data in the EEA 2005 study because there are large region-to-region and state-tostate differences in boiler populations. For example, fuel oil is an important fuel in the Northeast, especially in rural areas where natural gas may not be available, while natural gas is predominant in other areas of the country. A preliminary assessment of emissions from ICI boilers by pollutant in the U.S. and in the eight-state NESCAUM region was carried out using data from the AirData database via the EPA website (www.epa.gov/air/data). In this database, stationary sources, such as electric generating plants and factories, are identified individually by name and location. Figure 1-3 compares the annual emission of NOx, SO₂, and PM_{2.5} in the U.S. with the eight-state NESCAUM region for 2002. Emissions in the NESCAUM region are about 5 percent of the US total emissions.



Figure 1-3 Total annual emissions of NOx, SO₂, and PM_{2.5} from ICI boilers in the U.S. and in the eight-state region from EPA AirData database

Another set of data from the eight-state region was extracted from the MANEVU 2002 non-road inventory (<u>www.manevu.org</u>). In this data set, oil-fired boilers were divided into distillate oil and residual oil-fired boilers (Figure 1-4).

NOx emissions in the eight-state NESCAUM region are mostly from oil- and gas-fired boilers. Because these are generally small boilers, combustion controls are good candidates for NOx control. For larger, coal- or wood-fired boilers, SNCR or SCR might also be applicable.

PM emissions are relatively low from coal-fired sources in the eight-state region, which suggests that most of the coal-fired sources already have particulate control devices. Oil- and wood-fired units have higher PM emissions, and PM emissions attributed to natural gas are quite small.

As might be expected, most of the SO_2 emissions from oil-fired boilers come from residual oil-fired boilers because of residual oil's higher sulfur content.



Figure 1-4. Emissions of NOx, SO₂, and PM_{2.5} from ICI boilers in the NESCAUM region from MANEVU database as a function of fuel fired

1.3.3 Differences between EGU and ICI boilers

EGU boilers produce steam in order to generate power. While ICI boilers do in some cases generate steam for electricity production, ICI boilers differ from EGUs in size, steam application, design, and emissions. Most commercial and institutional boilers are small, with an average capacity of 17 MMBtu/hour (Table 1-1). Industrial boilers can be as large as 1,000 MMBtu/hr or as small as 0.5 MMBtu/hr. The average size of a coal-fired EGU boiler in the U.S. is over 200 MW or over 2,000 MMBtu/hr.

All coal-fired EGUs in the United States use control devices to reduce PM emissions. Additionally, many of the EGU boilers are required to use controls for SO_2 and NOx emissions, depending on site-specific factors such as the properties of the fuel burned, when the power plant was built, and the area where the power plant is located.

According to 1999 EPA Information Collection Request (ICR) responses from coal-fired EGUs, 77.4 percent of EGUs had PM post-combustion control only, 18.6 percent had both PM and SO₂ controls, 2.5 percent had PM and NOx controls, and 1.3 percent had all three post-combustion control devices [Kilgroe *et al.*, 2001]. Information from 2004 indicated that the fractions of total capacity of large coal-fired EGUs that have flue gas desulfurization (FGD) to control SO₂ and selective catalytic reduction (SCR) to reduce NOx controls were 38 percent and 37 percent, respectively [NESCAUM, 2005]. Since the 1999 ICR survey, additional NOx and SO₂ controls have been added at a rapid pace to coal-fired EGUs. It is presently not clear how

the implementation of NOx and SO_2 control technologies for EGUs would evolve as a consequence of the recent vacatur of Clean Air Interstate Rule (CAIR) by the U.S. D.C. Circuit.

In contrast to EGUs, ICI boilers are substantially less likely to have air pollution control devices. A study of industrial boilers and process heaters [USEPA, 2004] that looked at 22,117 industrial boilers and process heaters, which burned natural gas, distillate oil, residual oil, and coal, found that 88 percent had no air pollution control equipment.

A preliminary survey was undertaken as part of this study to evaluate the extent to which various emission controls were currently being applied to ICI boilers in the Northeast. These data were acquired from State Title V permits for solid-fueled (coal and wood) boilers as well as additional information from state personnel. The survey collected data in four states: Massachusetts, Vermont, New Hampshire, and New York. The data set was composed of 64 boilers – 47 wood-fired and 17 coal-fired. *Figure 1-5* illustrates the distribution of boiler capacity (by size) and the air pollution control devices (APCDs) in this data set. The full data set is summarized in Appendix A. As can be seen in *Figure 1-5(b)*, more than half of the units had no controls, about one-third had controls only for PM, and very few units had controls for NOx. There were no units with SO₂ controls, although some of the PM controls were wet venturi scrubbers, which might have a limited impact on SO₂ emissions.





There are several factors that directly or indirectly affect the reasons for the discrepancy in APCD deployment between EGU and ICI boilers. Technical and operational as well as business, economic, and regulatory factors impose different constraints and provide different opportunities for the applicability of APCDs for these two categories of boilers. The following discussion summarizes some of the important technical and operational issues.

Large, base-loaded EGUs operate mainly near maximum capacity or steam production. Industrial boilers typically do not run at maximum capacity, although this varies from one industry to another [EEA, 2005]. EGUs produce steam for electricity generation, while ICIs may produce steam for a variety of applications. The type of manufacturing is often more important in determining boiler operation, or duty cycle (load vs. time) than manufacturing demand in general.

ICI boilers generate steam for processing operations for paper, chemical, refinery, and primary metals industries. Commercial boilers produce steam for a variety of processes, while institutional boilers are normally used to produce steam and hot water for space heating in office buildings, hotels, apartment buildings, hospitals, universities, and similar facilities.

Another difference between EGU and ICI boilers is fuel diversity. EGU boilers are mostly single-fuel (coal, No. 6 oil, natural gas), while ICI boilers tend to be designed for and use a more diverse mix of fuels (e.g., fuel by-products, waste, wood) in addition to the three conventional fuels above.

These differences in operational and fuel usage not only affect a boiler's duty cycle, but its design, which is equally important from the perspective of APCD applicability. Examples that directly affect APCD choice and applicability include equipment such as economizers or air preheaters, which affect the temperature of the flue gas at the stack. The differentiation in fuel usage also leads to different design parameters for emissions controls. For example, the iron and steel industry generates blast furnace gas or coke-oven gas, which is used in boilers, resulting in sulfur emissions. Pulp and paper boilers may use wood waste as a fuel, resulting in high PM emissions. Units with short duty cycles may utilize oil or natural gas as a fuel. The use of a wide variety of fuels is an important characteristic of the ICI boiler category.

These factors relate directly to APCD equipment choices and applicability. The following examples should help explain some of these impacts.

- Fuel quality different fuels have different emission characteristics. SO₂, PM, and NOx emissions from coal fired boilers are different from those burning natural gas, oil, or wood waste. Some APCD technologies are not very sensitive to fuel quality variations (e.g., an electrostatic precipitator (ESP) may accommodate different levels of PM concentration, although the type and size of particles and gas temperatures will have an impact). However, others can be directly affected by changes in fuel quality and the resulting changes in pollutant concentrations in the flue gas to be treated (e.g., SO₂ and NOx controls that utilize reagents such as scrubbers for SO₂ and SCR/SNCR for NOx).
- Duty cycle significant variation or cycling of boiler load requires APCD controls capable of accommodating such variations. These variations affect flue gas flow rates and temperatures, which in turn may require different control capability. For example, an SCR or SNCR system must operate within a temperature window that may or may not exist across the load range for a particular ICI boiler.
- Design differences the use of equipment such as economizers or air preheaters has direct impact on the resulting flue gas temperature. Temperature-sensitive technologies such as ESPs, SO₂ scrubbers (wet and dry), and SCR /SNCR that are widely used in EGUs may or may not be applicable for some ICI boilers in such cases.

1.3.4 Control Technology Overview

A variety of emission control technologies are employed to reduce emissions of NOx, SO₂, and primary PM emissions. Technical details of control technologies for NOx, SO₂, and PM are discussed in Chapters Two, Three, and Four, respectively. Pollutant emission controls are generally divided into three major types given in the following list.

- *Pre-combustion Controls*. Control measures in which fuel substitutions are made or fuel pre-processing is performed to reduce pollutant formation in the combustion unit.
- *Combustion Controls.* Control measures in which operating and equipment modifications are made to reduce the amount of pollutants formed during the combustion process; or in which a material is introduced into the combustion unit along with the fuel to capture the pollutants formed before the combustion gases exit the unit.
- *Post-combustion Controls*: Control measures in which one or more air pollution control devices are used at a point downstream of the furnace combustion zone to remove the pollutants from the post-combustion gases.

Data on costs of pollution control equipment taken from the literature are reviewed in the individual technology chapters. In Chapter Five, an existing model for the estimation of air pollution control equipment costs for coal-fired EGUs (CUECost) is applied to ICI boilers burning different fuels (coal, oil, wood) with appropriate caveats and assumptions to provide reasonable and approximate control costs for ICI boilers.

1.4 Chapter 1 References

Energy & Environmental Analysis, Inc. (EEA). *Characterization of the U.S. Industrial Commercial Boiler Population*. May 2005.

Kilgroe, J.D. et al. Control of Mercury Emissions from Coal-Fired Electric Utility Boilers: Interim Report, EPA-600/R-01-109, December 2001.

MACTEC. Assessing Reasonable Progress for Regional Haze in the Mid-Atlantic North Eastern Class I Area - Revised Final Draft; MACTEC Federal Programs: Research Triangle Park, NC, March 8, 2007.

NESCAUM. Assessment of Control Technology Options for BART-Eligible Sources; 2005.

Ozone Transport Commission (OTC). *Identification and Evaluation of Candidate Control Measures – Technical Support Document*. February 28, 2007.

Sabo, E.; Toothman, D. *Identification and Evaluation of Candidate Control Measures Final Technical Support Document*; MACTEC Federal Programs, Inc.: Herndon, VA, February 28, 2007.

Sliwinski, R. "ICI Boiler Control Recommendations," Ozone Transport Commission Fall Meeting, November 15, 2006.

State and Territorial Air Pollution Program Administrators/Association of Local Air Pollution Control Officials (STAPPA/ALAPCO), now known as National Association of Clean Air

Agencies (NACAA). Controlling Fine Particulate Matter under the Clean Air Act: A Menu of Options, March 2006.

US EPA. Alternative Control Techniques Document--NO Emissions from Industrial/Commercial/Institutional (ICI) Boilers; EPA-453/R-94-022; 1994.

US EPA. Regulatory Impact Analysis for the Industrial Boilers and Process Heaters NESHAP, EPA EPA-452/R-04-002, February, 2004.

2 NOx CONTROL TECHNOLOGIES

2.1 Introduction

This brief introduction applies to chapters Two, Three, and Four, which discuss control technology options for ICI boilers for NOx, SO₂, and PM, respectively. However, these chapters are not intended to provide detailed descriptions of the many available technologies for each pollutant. Significant literature is available for that purpose; in the context of this report, these chapters are intended to provide the reader with a general understanding of concepts, performance, applicability, and costs of the main technologies available. Further, in recognition of the concern with climate change, a brief discussion of energy consumption (parasitic power) associated with major technologies is included.

Specifically with respect to the deployment and applicability of air pollution controls, comparisons between ICI boilers and EGUs are relevant because of the more widespread application of pollution control equipment in the EGU sector. This was discussed in some detail in Chapter One. In addition, a few considerations specific to certain technologies and strategies are discussed, as appropriate.

2.1.1 ICI versus EGU Boilers

In general, the greater proliferation of air pollution control technologies in the EGU sector, as opposed to the industrial sector, seems to be driven by three dominant, differentiating factors.

- Size difference and associated emissions between the two: Because EGUs are much larger than ICI boilers, they have been targeted for environmental regulatory controls more heavily over the years.
- Technology costs: While not universally true, ICI boilers often have constraints due to their smaller sizes, diversity of plant layouts, and urban settings, all of which can have a negative impact on the costs of applying some of the control technologies. Conversely, and equally important, opportunities for lower-cost applications to ICI boilers do exist as a result of the smaller sizes, such as in the ability to have systems pre-fabricated and ready to erect onsite, as opposed to on-site construction requirements often needed with larger systems for EGUs.
- Cost recovery: The two sectors are significantly different from a fundamental business view, with EGUs being regulated entities, as opposed to openly competitive markets that exist within the ICI boiler population. This is important in that it affects how business decisions are made in the two sectors, how capital equipment purchases are funded, and also how ICI plants are designed and operated.

2.1.2 Control Technologies' Impact on Efficiency and CO₂ Emissions

Air pollution control technologies and strategies can have varying impacts on the overall efficiency of the host plant. This impact can be either positive or negative and it is a function of the type of technology, as well as fuel choices.

An extreme example of this is the control of SO_2 from a coal-fired unit by two significantly different approaches: in one case, the use of an energy–intensive FGD "scrubber" penalizes the efficiency of such unit by up to 2 percent, resulting in a corresponding increase in CO_2 emissions; a very different and contrasting case, in which the unit chooses to reduce its SO_2 generation by switching from coal to natural gas, yields a corresponding and substantial decrease in its CO_2 emissions. Similarly, an efficient Low-NOx Burner (LNB) may replace an older burner and increase unit efficiency, while reducing NOx emissions, whereas a SNCR or SCR also reduces NOx, but will have some inherent parasitic power requirement that will have a negative impact on overall efficiency (and emissions of CO_2).

These chapters primarily address control technology options, as opposed to fuel switching strategies, except for SO₂. Switching from high-sulfur oil to low-sulfur oil is also discussed in Chapter 3. CO_2 impacts are well established as a function of the carbon content of fuels. The same applies in the case of renewable, carbon-based fuels (biomass). However, with control technologies, the impacts can vary widely among technologies for the same pollutant (e.g., LNB vs. SCR for NOx), as well as across different pollutants (e.g., fabric filter for PM vs. wet and dry scrubbers for SO₂).

In general, efficiency impacts from application of air pollution control technologies can be divided into two major general areas:

- Direct impact (positive or negative) on the combustion process itself (e.g., changes in concentrations of O₂ or CO and in the amount of unburned carbon (UBC) in ash)
- Parasitic power associated with the particular technology or its components (e.g., increased gas pressure loss, power requirements for pumps/fans)

This parasitic power is given here in terms of electric power (kW) per flue gas flow rate (acfm) or kW/1000 acfm. These units are appropriate for several reasons:

- Most ICI boilers do not produce electricity, hence, size is more universally characterized by a parameter other than electrical generation (e.g., flow rate);
- Most control technology suppliers rank their equipment size in terms of gas flow rate as this is the dominant parameter for gas handling equipment sizing;
- If the objective is to "correlate" this parasitic power loss to an equivalent CO₂ impact, it can be done simply by knowing the size (acfm) of the technology application and the CO₂ emission profile of the equivalent kW generation (or savings) to offset the parasitic power loss.

2.2 Discussion of NOx Control Technologies

2.2.1 NOx Formation

The formation of NOx is a byproduct of the combustion of fossil fuels. Nitrogen contained in fuels such as coal and oil, as well as the harmless nitrogen in the air, will react with oxygen during combustion to form NOx. The degree to which this formation evolves depends on many factors including both the combustion process itself and the properties of the particular fuel being burned. This is why similar boilers firing different fuels or similar fuels burned in different boilers can yield different NOx emissions.

2.2.2 NOx Reduction

As a result of complex interactions in the formation of NOx, a variety of approaches to minimize or reduce its emissions into the atmosphere have been and continue to be developed. A relatively simple way of understanding the many technologies available for NOx emission control is to divide them into two major categories: (1) those that minimize the formation of NOx itself during the combustion process (e.g., smaller quantities of NOx are formed); and (2) those that reduce the amount of NOx after it is formed during combustion, but prior to exiting the stack into the atmosphere. It is common to refer to the first approach under the "umbrella" of combustion modifications whereas technologies in the second category are termed post-combustion controls. Within each of these two categories, several technologies and variations of the same technology exist. Finally, combinations of some of these technologies are not only possible, but also often desirable as they may produce more effective NOx control than the application of a stand-alone technology.

2.2.3 Other Benefits of NOx Control Technologies

Some NOx control technologies have shown the potential to promote the capture of mercury (Hg) from the flue gas. Examples include combustion modification technologies (e.g., Low-NOx Burners and Overfire Air – though potentially with higher levels of unburned carbon) and post-combustion technologies (SCR – through the oxidation of mercury, making it more soluble and amenable to capture in a downstream process such as a scrubber for SO₂). This suggests that strategic and economic analyses for NOx controls need to also consider the potential impacts on mercury removal.

2.3 Summary of NOx Control Technologies

2.3.1 Combustion Modifications

Combustion modifications can vary from simple "tuning" or optimization efforts to the deployment of dedicated technologies such as LNBs, Overfire Air (OFA) or reburn (most often done with natural gas and called Gas Reburn - GR).

Boiler Tuning or Optimization

Combustion optimization efforts can lead to reductions in NOx emissions of 5 to 15 percent or even higher in cases where a unit was originally badly "de-tuned." It is important to remember that optimization results are truly a function of the "pre-optimization" condition of the power plant or unit (just as the improvement in an automobile from a tune-up depends on how badly it was running prior to it), and as such have limited opportunity for substantial emission reductions.

Development of "intelligent controls" – software-based systems that "learn" to operate a unit and then maintain its performance during normal operation, can also go a long way towards keeping plants well tuned, as they gain acceptance and become common features in combustion control systems.

2.3.2 Low-NOx Burners and Overfire Air

LNBs and OFA represent practical approaches to minimizing the formation of NOx during combustion. Simply, this is accomplished by controlling the quantities and the way in which fuel and air are introduced and mixed in the boiler (usually referred to as "fuel or air staging").



Figure 2-1. Low-NOx burner [TODD Dynaswirl-LNTM]

Figure 2-1 shows a gas/oil Low-NOx burner. These technologies are prevalent in the electric power industry as well as in ICI boilers at present and increasingly used by ICIs, even at small sizes (less than 10 MMBtu/hr). Competing manufacturers have proprietary designs, geared towards application for different fuels and boiler types, as well as reflecting their own design philosophies. LNBs and OFA, which can be used separately or as a system, are capable of NOx reductions of 30 to 65 percent from uncontrolled baseline levels. Again, the type of boiler and the type of fuel will influence the actual emission reduction achieved.

Particularly for gas-fired applications, as in the majority of ICI boilers, advanced Low-NOx Burners, often referred to as ultra Low-NOx Burners (ULNBs), are commercially offered by several companies. Ultra Low-NOx Burners are capable of achieving NOx emission levels on the order of single digits in ppm. As with all technologies, "pushing the envelope" on emission levels requires increasingly more careful suitability analyses as well as a good understanding of operational constraints. Conversely, the advent of these very low-emission burners (less than 10 ppm NOx), allows units to achieve very low emission rates at costs well below post-combustion alternatives like SCR.

All combustion modification approaches face a common challenge of striking a balance between NOx reduction and decrease in fuel efficiency. The concern is exemplified by typically higher CO and/or carbon levels in the fly ash, which reflect lower efficiency and also the contamination of the fly ash itself, possibly making it unsuitable for reutilization such as in concrete manufacturing. This is a bigger concern for large EGUs than for ICI boilers due to the much larger quantities of ash produced and the associated costs of disposal.

LNBs/OFA have little or no impact on operating costs (other than by the potential for the above-mentioned efficiency loss). Low-NOx Burners are applicable to most ICI boiler types, excluding stoker types and Fluidized Bed Combustion units (FBCs).

2.3.3 Reburn

Reburn, while generically included in the "Combustion Modification" category, is different from the other technologies in this group (LNBs/OFA) in that it "destroys" (or chemically reduces) NOx shortly after it is formed rather than minimizing its formation as discussed previously. From a practical standpoint, this is accomplished by introducing the reburn fuel (theoretically any fossil fuel can be used, however, natural gas is the most common) into the boiler above the main burner region. A portion of the heat input from the primary fuel is replaced by the reburn fuel. Subsequently, this "fuel-rich" environment reacts with and destroys the NOx formed in the main burners. This technology has been implemented in the U.S. and overseas, and while not as popular as LNB/OFA, it is commercial at this time. Owing to stricter compatibility criteria, reburn is not as universal as LNB/OFA in its applicability to the overall boiler population. *Figure 2-2* shows a typical reburn system applied to a stoker boiler.



Figure 2-2. Gas reburn applied to a stoker boiler [www.gastechnology.org]

Specific criteria such as boiler size, availability of natural gas, type and quality of the main fuel, are all important in determining the suitability of a unit for this technology. One important feature of reburn is its compatibility with a particular type of boiler – "Cyclone," – for which the previously mentioned technologies are not particularly well suited. However, this technology has been used only in large EGUs and is not a typical option for ICI boilers. Cyclone boilers are inherently high NOx emitters and are not an attractive option for new or retrofit units with increasingly lower NOx emission limits requirements.

Reburn performance has been shown to range from 30 to 60 percent reduction in NOx emissions, depending on such factors as reburn fuel type and quantity, initial NOx levels, boiler design, etc. Similar to the other combustion modification options, reburn can affect efficiency and fly-ash quality. As such, it requires the same optimum balance between NOx reduction and avoidance of negative impacts. On the other hand, reburn can be thought of as a "dial-in" NOx technology in that NOx reductions are, to a degree, a function of the amount of reburn fuel.

Operating costs are primarily driven by the fuel cost differential in the case of gas reburn, while for coal or oil reburn fuel preparation costs (pulverization and atomization, respectively) represent the dominating O&M costs. Reburn using coal or oil as the reburn fuel does not seem like a very attractive option for ICI boilers for technical reasons (boiler size, residence times), as well as the wider availability of similar performance options simpler to implement, such as LNBs. Gas reburn, while easier to implement, often has a prohibitive operating cost if, for example, natural gas is partially substituted for a less expensive primary fuel. Reburn is therefore an option for larger watertube-type boilers, including stokers, but require appropriate technical and economic analyses to determine suitability. Gas reburn has an impact on CO_2 emissions that is proportional to the type and quantity of fuels displaced (gas vs. coal or oil).

2.3.4 Post-Combustion Controls

Conventional, commercial post-combustion NOx controls include Selective Non-Catalytic Reduction (SNCR) and Selective Catalytic Reduction (SCR). They are fundamentally similar, in that they use an ammonia-containing reagent to react with the NOx produced in the boiler to convert the NOx to harmless nitrogen and water. SNCR accomplishes this at higher temperatures (1700°F-2000°F) in the upper furnace region of the boiler, while SCR operates at lower temperatures (about 700°F) and hence, needs a catalyst to produce the desired reaction between ammonia and NOx. As noted below, SCR technology is capable of achieving much larger reductions in NOx emissions, higher than 90 percent, compared to the 30 to 60 percent reductions achievable by SNCR. *Figure 2-3* and *Figure 2-4* depict views of these two systems.



Figure 2-3. SNCR system schematic [FuelTech]



Figure 2-4. 3-D schematic of an SCR system [Alstom Power]

While the difference between the SNCR and SCR may seem minor, it yields significant differences in performance and costs. In the case of SNCR, the reaction occurs in a somewhat uncontrolled fashion (e.g., the existing upper furnace becomes the reaction vessel, which is not what it was originally designed to be), while in the SCR case, a dedicated reactor and the reaction-promoting catalyst ensure a highly controlled, efficient reaction. In practice, this means that SNCR has lower capital costs (no need for a reactor/catalyst); higher operating costs (lower efficiency means that more reagent is needed to accomplish a given reduction in NOx); and finally, has lower NOx reduction capability (typically 30 to 50 percent, with some units achieving reductions in the 60 percent range). SCR, on the other hand, is capital intensive, but offers lower reagent costs and the opportunity for very high NOx reductions (90 percent or higher).

Costs are driven primarily by the consumption of the chemical reagent – usually (but not necessarily) urea for SNCR and ammonia for SCR, which in turn is dependent upon the efficiency of the process (usually referred to in terms of reagent utilization) as well as the initial NOx level and the desired percent reduction. It is also important to consider possible contamination of fly ash (in the case of coal firing) by ammonia making it potentially unable to be sold. This is, again, a bigger issue for larger EGU plants than for ICI boilers due to the size and quantities involved; as already stated, ICIs burning solid fuel do not typically sell their fly ash.

2.3.4.1 RSCR

Commonly, EGU boilers utilize SCR systems to reduce NOx emissions. However, a conventional SCR may not be cost-effective to retrofit into smaller units like ICI boilers because of the extensive modifications required to accommodate the unit. For some applications, the SCR may be located downstream of the particulate control equipment, where the flue gas temperature is much lower than the range of 650-750°F required for a conventional SCR (Toupin, 2007). These conditions are encountered in some ICI boilers firing a variety of fuels, including biomass.

If it is necessary to compensate for the reduction of flue gas temperatures, a regenerative selective catalytic reduction ($RSCR^{TM}$) system allows the efficient use of an SCR downstream of a particulate control device. The primary application of an RSCR system is the reduction of NOx emissions where the flue gas is typically at 300-400°F (Toupin, 2007). *Figure 2-5* illustrates the schematic and the actual RSCR system. *Figure 2-6* shows a block of ceramic heat exchanger.



Figure 2-5. Schematic and actual RSCR [Toupin, 2007]

A direct-contact regenerative heater technology (i.e., burner), coupled with cycling beds of ceramic heat exchangers, is used to transfer heat to the flue gas. Additionally, some oxidation of CO to CO_2 in the flue gas occurs. The NOx reduction portion of the RSCR takes place on a conventional SCR catalyst. Either anhydrous or aqueous ammonia can be used.

Figure 2-5 (left side) shows the working principles of the RSCR. Essentially, the flue gas in the space between the two canisters (called the retention chamber) is heated by the burner to make up for heat loss through the walls of the canisters and inefficiency in the ceramic heat transfer modules. This raises the temperature in the retention chamber by about 10-15°F. The gas flows into the second canister, through the catalyst, and passes through the second ceramic module, which absorbs heat from the hot flue gas. Once this cycle is completed, the flow reverses, so that the second canister (which was just heated) becomes the inlet canister and the first canister becomes the outlet canister. The cycling between canisters accomplishes a similar function to the continuously rotating heating elements of a conventional regenerative air/gas heater.

Other components of the RSCR include the ductwork, fans, and the ammonia delivery system. Ductwork must be adequately sized to provide sufficient distance for ammonia mixing

and to minimize pressure drop. For the ceramic heat exchanger, factors that need to be taken into consideration during the design process are gas-side pressure drop, thermal efficiency, and cost. A large bed face area reduces the pressure drop and operating cost but increases capital cost. The ammonia delivery system consists of ammonia pumps, storage tanks, interconnecting piping, and a control system. The pump typically does not exceed one horsepower and often a redundant pump is provided to assure continuity in system operation [Toupin, 2007].



Figure 2-6. Block of monolith ceramic heat exchanger [Toupin, 2007]

The RSCR combines a regenerative thermal oxidizer (RTO) (e.g., retention chamber burner) with SCR technology. This ability to control flue gas temperatures allows for high NOx reduction under varying temperature conditions. *Table 2-1* shows the expected reduction in NOx and CO emissions [BPEI, 2006]. This study indicated that the RSCR is able to reduce NOx by 60 to 75 percent and CO by about 50 percent.

	Typical Stoker Design	CO and NOx Reductions from Baseline
Steam Flow lbs/hr x 10 ³	100 - 500	
Steam Press, psi	600 - 900	
Steam Temp., °F	955 - 1000	
Unburned Combustibles Boiler	1.0 - 1.5	
Efficiency Loss (%)		
Furnace Retention sec. ⁽¹⁾	3.0	
Grate Heat Release Btu/hr-ft	850,000 maximum	
Emissions:		
CO lbs/10 ⁶ Btu @ 3.0% O ₂ (ppm)	0.10 - 0.30	Base
	(122 – 370)	
CO w/RSCR lbs/ 10^6 Btu @ 3.0% O ₂	0.05 - 0.15	(-50%)
(ppm)	(61 - 185)	
NOx lbs/10 ⁶ Btu @ 3.0% O ₂ (ppm)	0.15 - 0.25	Base
	(112 – 186)	
NOx w/SNCR lbs/10 ⁶ Btu @ 3.0%	0.10 - 0.17	(-30 to 40%)
O ₂ (ppm)	(75 - 130)	
NOx w/RSCR lbs/10 ⁶ Btu @ 3.0%	0.06 - 0.075	(-60 to 75%)
O ₂ (ppm)	(45 – 56)	

Table 2-1.	CO and NOx	reduction	using RSCR	[Source:	BPEI 2006]
------------	------------	-----------	------------	----------	------------

Additionally, the heat exchanger part of the RSCR has a thermal efficiency of about 95 percent, which translates to fuel savings. Traditional technologies that utilize Ljungstrom or plate type heat exchangers for heat recovery and duct burners to reach the catalyst operating temperature are typically in the range of 70 to 75 percent thermal efficiency.

An analysis performed by BPEI on a typical 25 MW plant with a 75 percent reduction in NOx shows a cost effectiveness of \$4,514 per ton of NOx removed. The cost breakdown is tabulated below in *Table 2-2*.

Plant Overview:	
Plant Gross MW	25
GROSS HEAT INPUT, MMBTU/HR	321
TYPICAL UNCONTROLLED NOx, LB/MMBTU	0.25
TYPICAL CONTROLLED NOx, LB/MMBTU	0.065
NOx REMOVED, TONS/YEAR	249.4
RSCR Cost:	
AMMONIA COST, \$/TON NOx	\$ 419
NATURAL GAS, \$/ton NOx	\$ 404
POWER COST, \$/TON NOx	\$ 589
CATALYST COST, \$/TON	\$ 555
CAPITAL COST, \$/TON	\$ 2,546
TOTAL COST PER TON NOx REMOVED	\$ 4,514

Table 2-2.	RSCR	cost efficiency	[BPEI, 2008]
------------	------	-----------------	--------------

Two RSCR installations (15 and 50MW) are currently in operation in the Northeast. The 15 MW plant uses whole tree chips as fuel; the 50 MW plant uses whole tree chips, waste wood, and construction and demolition wood as fuel for the boilers. The goal of the two installations was to qualify for the Massachusetts Renewable Energy Credits (RECs). The state requirement for qualifying for RECs imposed a NOx level of 0.075 lb/MMBtu or less on a quarterly average basis.

2.3.5 Technology Combinations

In theory, most of the technologies described above can be used together. However, NOx reductions are not necessarily additive, and more importantly, the economics of the combined technologies may or may not be cost-effective. Such analyses are highly specific to the site and strategy. However, several such technology combinations are considered attractive and have gained acceptance. For example, the combination of LNB/OFA with either SCR or SNCR is more prevalent than the application of the post-combustion technologies alone. The economics of this approach are justified by the reduced chemical (SNCR) and capital costs (SCR – smaller reactor/catalyst) due to lower NOx levels entering the SCR/SNCR system. Another combination offered commercially is the hybrid SNCR/SCR concept, which uses the excess ammonia (ammonia "slip") of the SNCR to promote additional NOx reduction in a downstream SCR catalyst.

2.4 Applicability to ICI Boilers

The NOx control technologies previously described are commercially available and are used extensively in EGUs, but most are also applicable to ICI boilers. Because conventional fuels (e.g., coal, oil, gas) as well as alternative fuels (e.g., wood, petroleum coke, process offgases) emit NOx, these technologies are applicable to most boilers using various fuels. With the exception of FBC and Stoker boilers, LNBs are available and widely used for most combinations of boiler types and fuels. OFA and reburn as well as SNCR and SCR technologies require sitespecific suitability analyses, as several important parameters can have substantial impact on their performance or even retrofit feasibility. As already stated, these include available space, residence times and gas temperatures. Conversely, other than firetube type boilers, these technologies are potential candidates for the other boiler types including stokers and FBCs. Finally, the RSCR may offer advantages for applications where low flue gas temperatures are present and a conventional SCR may be more costly to implement.

2.5 Efficiency Impacts

The NOx control technologies involving combustion modification have essentially no impact on the CO_2 emissions of the host boilers, with the noted exception for reburn when displacing coal or oil with natural gas. This is because combustion modification technologies do not impose any significant parasitic energy consumption (auxiliary power). Note that combustion modification technologies can affect the resulting combustion conditions in addition to the desired reduction in NOx emissions. These impacts are reflected in varying temperatures, oxygen levels, and CO/UBC, all of which affect combustion efficiency as discussed previously. However, we do not attempt to quantify these impacts. The overriding assumption is that these NOx control technologies, once deployed, are optimized such that the resulting NOx emissions are achieved without compromising the above parameters (or at least their combined effects).

With respect to the post-combustion technologies, both SNCR and SCR impose some degree of energy impact on the host boiler. The losses attributable to these technologies include the following:

- For SNCR
 - o compressor power (air atomization/mixing)
 - o steam (if steam atomization/mixing)
 - o dry gas loss (air injection into furnace)
 - o water evaporation loss
- For SCR
 - o compressor
 - reactor pressure loss
 - o steam (sootblowing)

Table 2-3 summarizes the key parameters for major NOx control technologies.

Technology	Applicability	Performance (% Reduction)	Energy Impacts (kW/1000 acfm)	Comments
LNB	All except Stokers, FBC	30 – 60 (<10ppm possible on gas)	NA	Assumed not to have negative impact on CO/UBC/O ₂
OFA	All except firetube/FBC	30 - 60	NA	Assumed not to have negative impact on CO/UBC/O ₂
Reburn	All except firetube/FBC	30 - 60	NA	Assumed not to have negative impact on CO/UBC/O ₂
SNCR	All except firetube (Must have adequate temperature window)	30 - 70	1 - 2	Compressor/va porization losses
SCR	All (Most likely for larger coal units where LNBs cannot reach very low NOx levels)	60 - 90	0.5 – 1 (gas) 2 - 4 (oil/coal)	Pressure loss/steam

Table 2-3.	Summary	of NOx	control	technologies
------------	---------	--------	---------	--------------

2.6 NOx Control Costs

The following tables summarize published NOx control costs for ICI boilers reported in the literature [US EPA, 1996; NESCAUM, 2000; Khan, 2003; US EPA, 2003; MACTEC, 2005; Whiteman, 2006]. Literature values of capital cost have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness in dollars per ton of NOx removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs. Reagents or consumables can make up a large portion of some operating costs. Costs of reagents and fuels (e.g., ammonia, natural gas) and consumables (e.g., SCR catalyst) change with time, but not always at the general rate of inflation. Some of these costs have increased at rates higher than the general rate of inflation. Thus, cost effectiveness values (or operating costs) from before 2005 have not been reported.

Table 2-4 summarizes the published NOx control costs for combustion modification technologies. The cost of the installation of low-NOx combustion technology depends on the firing system, and this is reflected in the lack of a clear relationship between capital cost and boiler capacity (*Figure 2-7*). Smaller boilers (10 to 50 MMBtu/hr) are often firetube or packaged watertube, whereas larger oil and gas boilers are more likely to be field-erected watertube boilers. Coal-fired boilers can be stokers, pulverized coal (PC), or cyclones. Combustion modification technologies therefore need to be evaluated on a case-by-case basis, taking into account both the fuel and the design of the combustion system. For the substantial majority of the estimates for ICI boilers, capital costs are in the range of \$1,000 to \$6,000 per MMBtu/hr. Cost effectiveness values, where available, are generally in the range of \$1,000 to \$7,000 per ton of NOx removed.

	NOx		Size of	Capital Costs	Base yr.	Cost (\$/ton	
Tashasalasan	Reduction	E	Boiler	@2006\$	for or	NOx @ base	D.f
Technology	Range	Fuel Type	(MMBtu/hr)	(\$/MMBtu/hr)	Ref. yr	year)	Ker
Overfire Air	15-30	Coal	500	\$2,682	1996		1
Fuel-Lean	35%	Coal	350	\$1 302	1000		2
Cos Poburn	55%	Coal	500	\$1,502	1999		2
	25%	Coal	250	\$2,004	1999		2
	25%	Coal	350	\$0,578 \$6,278	1999		2
	50.0%	Coal	500	\$0,378 \$9,464	1999		2
	50%	Coal	500	\$8,404 \$0,297	1996		
	51%	Coal	100	\$9,287 #7.055	1999		6
	51%	Coal	250	\$7,055	1999		6
LNB	51%	Coal	1000	\$4,654	1999	#2.202	6
LNB	42.6%	Coal (Tangent.)	250	\$5,088	2005	\$3,383	3
LNB	42.6%	Coal (Tangent.)	250	\$5,088	2005	\$3,988	3
LNB	49%	Coal (Wall)	250	\$5,088	2005	\$2,636	3
LNB	49%	Coal (Wall)	250	\$5,088	2005	\$3,101	3
LNB	40%	Pulv. Coal	250	\$346-\$3,610	2005	\$749-\$3,393	3
LNB	45.0%	Resid. Oil	250-FT	\$5,088	2005	\$6,361-\$7,483	3
LNB	50%	Resid. Oil	250-WT	\$5,088	2005	\$4,691-\$5,519	3
LNB	40%	Resid. Oil	250	\$346-\$5,088	2005?	\$1,505-\$6,813	3
LNB	45%	Resid. Oil	10	\$7,617	1996		1
LNB	45%	Resid. Oil	50	\$3,021	1996		1
LNB	45%	Resid. Oil	150	\$1,563	1996		1
LNB	45%	Dist. Oil	10	\$7,617	1996		1
LNB	45%	Dist. Oil	50	\$3,021	1996		1
LNB	45%	Dist. Oil	150	\$1,563	1996		1
LNB	25%	Gas	350	\$6,378	1999		2
LNB	40%-55%	Gas	10	\$7,617	1996		1
LNB	40%-55%	Gas	50	\$3,021	1996		1
LNB	40%-55%	Gas	150	\$1,563	1996		1
LNB+FGR	50%	Pulv. Coal	250	\$930-6,629	2005	\$1,482-\$3,582	3
LNB+FGR	72%	Pulv. Coal	250	\$930-6,629	2005	\$1,029-\$2,488	3
LNB+FGR	50%	Resid. Oil	250	\$930-6,629	2005	\$2,977-\$7,197	3
LNB+FGR	72%	Resid. Oil	250	\$930-6,629	2005	\$2,068-\$4,998	3
LNB+OFA	51%-65%	Coal	100	\$9,287	1999		6
LNB+OFA	51%-65%	Coal	250	\$7,055	1999		6
LNB+OFA	51%-65%	Coal	1000	\$4,654	1999		6
LNB+OFA	30%-50%	Oil	100	\$3,258	1999		6
LNB+OFA	30%-50%	Oil	250	\$2,474	1999		6
LNB+OFA	30%-60%	Oil	1000	\$1,633	1999		6
LNB+OFA	60%	Gas	100	\$3,258	1999		6
LNB+OFA	60%	Gas	250	\$2,474	1999		6
LNB+OFA	60%	Gas	1000	\$1,633	1999		6

Table 2-4. NOx control costs for	or combustion modifications	applied to ICI boilers
----------------------------------	-----------------------------	------------------------

Technology	NOx Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs @2006\$ (\$/MMBtu/hr)	Base yr. for or Ref. yr	Cost (\$/ton NOx @ base year)	Ref
ULNB	46%	Pulv. Coal	250	\$1,364	2005	\$1,876	3
ULNB	63%	Pulv. Coal	250	\$1,364	2005	\$933	3
ULNB	72%	Pulv. Coal	250	\$1,364	2005	\$619	3
ULNB	75%	Pulv. Coal	250	\$1,364	2005	\$784	3
ULNB	85%	Pulv. Coal	250	\$1,364	2005	\$692	3
ULNB	75%	Resid. Oil	250	\$1,364	2005	1575	3
ULNB	85%	Resid. Oil	250	\$1,364	2005	1390	3
ULNB	80%	Dist. Oil	24.5	\$8,619	2005	17954	3
ULNB	80%	Dist. Oil	70	\$2,280	2005	5756	3
ULNB	94%	Dist. Oil	68	\$1,987	2005	4751	3
ULNB	94%	Dist. Oil	68	\$1,987	2005	4564	3

Table 2-4 [continued]

References:

1. US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/

2. NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.





Technology	NOx Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs @2006\$ (\$/MMBtu/hr)	Base yr. for or Ref. yr	Cost (\$/ton NOx @ base year)	Ref.
SNCR	30%-70%	Coal	500	\$2,044	1996		1
SNCR	40%	Coal	100	\$6,717	1999		6
SNCR	40%	Coal	250	\$5,102	1999		6
SNCR	40%	Coal	1000	\$3,366	1999		6
SNCR	30%-70%	Resid. Oil	50	\$4,297	1996		1
SNCR	30%-70%	Resid. Oil	150	\$4,297	1996		1
SNCR	35%		350	\$2,862	1999		2
SNCR			21	\$17,101	2006	\$3,718	4
SNCR			120	\$6,377	2006	\$2,231	4
SNCR			240	\$4,493	2006	\$1,821	4
SNCR			387	\$2,899	2006	\$1,564	4
SNCR			543	\$2,319	2006	\$1,538	4
SNCR			844	\$1,449	2006	\$1,346	4
SNCR	40%	Oil	100	\$5,205	1999		6
SNCR	40%	Oil	250	\$3,954	1999		6
SNCR	40%	Oil	1000	\$2,608	1999		6
SNCR	30%-70%	Dist. Oil	50	\$4,297	1996		1
SNCR	30%-60%	Natural Gas	50	\$4,297	1996		1
SNCR	40%	Gas	100	\$5,372	1999		6
SNCR	40%	Gas	250	\$4,082	1999		6
SNCR	40%	Gas	1000	\$2,693	1999		6
LNB+SNCR	50%-89%	Pulv. Coal	250	\$2,064-6,829	2005	\$1,409-\$4,473	3
LNB+SNCR	50%-89%	Resid. Oil	250	\$2,064-6,829	2005	\$2,229-\$7,909	3

Table 2-5.	NOx control	costs for SNCR	applied to	ICI boilers
	1 COA COHELOI	CODED TOT DITCH	upplieu to	ICI boners

References:

US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/
 NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost

Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

Table 2-5 summarizes the published NOx control costs for SNCR applied to ICI boilers. As with combustion modifications, the capital cost of SNCR systems is sensitive to the type of combustion system. As long as the boiler has sufficient space for installation of injection lances and mixing of reagent and flue gas (at the appropriate temperature), the capital costs should not depend on the fuel burned. The relationship between capital cost and boiler capacity is shown in *Figure 2-8*. Except for the 1996 EPA estimates for gas and oil boilers, there is a pronounced effect of boiler capacity on capital cost. The graph shows that fuel type is probably secondary to boiler capacity, although there will be an indirect effect of fuel, because fuel type influences the design of the combustion system. The cost effectiveness for SNCR was given by ICAC [Whiteman, 2006] without regard to fuel type and by MACTEC [2005] for coal and residual oil.



Figure 2-8. Capital cost for NOx control for SNCR applied to ICI boilers as a function of boiler capacity

Table 2-6 summarizes the published NOx control costs for SCR. The relationship between capital cost and boiler capacity is shown in *Figure 2-9*. The capital cost of SCR systems is sensitive to the type of fuel and to the level of NOx reduction desired, but not to the combustion system. The volume of catalyst required for an SCR installation depends on the level of desired NOx reduction and on the fuel. Coal-fired power plant applications are the most expensive, since the flue gas entering the SCR contains fly ash, which affects the design of the catalyst. The capital cost for a given fuel and boiler size can vary (see, for example, the variation in capital costs reported for coal application). When an SCR must be retrofit, the cost of the installation depends on the configuration of the specific system. Because the amount of

ductwork required, significant variation in installed capital cost can occur for a given boiler size. Upgrades like rebuilding the air preheater also affect the installed capital cost. MACTEC [2005] gave the cost effectiveness (in dollars per ton of NOx removed) for SCR for coal and residual oil; these costs showed a wide range, because of the wide range in assumed capital costs.

	NOx			Capital Costs			
	Reduction		Size of Boiler	@2006\$	Base yr. for	Cost (\$/ton NOx	
Technology	Range	Fuel Type	(MMBtu/hr)	(\$/MMBtu/hr)	or Ref. yr	@ base year)	Ref.
SCR	80%	Coal	350	\$12,755-19,133	1999		2
SCR	80%-90%	Coal	500	\$15,365-16,145	1996		1
SCR	70%-90%	Pulv. Coal	250	\$1,666-13,881	2005	\$2,233-\$7,280	3
SCR	80%	Coal	100	\$18,574	1999		6
SCR	80%	Coal	250	\$14,110	1999		6
SCR	80%	Coal	1000	\$9,309	1999		6
SCR	80%	Oil	100	\$14,116	1999		6
SCR	80%	Oil	250	\$10,723	1999		6
SCR	80%	Oil	1000	\$7,075	1999		6
SCR		Oil		\$5,102-7,653	1999		5
SCR	70%-90%	Resid. Oil	250	\$1,666-13,881	2005	\$4,363-\$14,431	3
SCR	80%-90%	Resid. Oil	50	\$8,359	1996		1
SCR	80%-90%	Resid. Oil	150	\$4,909	1996		1
SCR	80%-90%	Dist.	50	\$8,359	1996		1
SCR	80%-90%	Dist.	150	\$4,909	1996		1
SCR	80%	Gas	100	\$10,216	1999		6
SCR	80%	Gas	250	\$7,760	1999		6
SCR	80%	Gas	1000	\$5,120	1999		6
SCR	80%	Gas	100	\$9,566	1999		2
SCR	80%	Gas	350	\$7,015	1999		2
SCR	80%-90%	Natural Gas	50	\$8,359	1996		1
SCR	80%-90%	Natural Gas	150	\$4,909	1996		1
SCR	80%	Wood	350	\$6,378-7,653	1999		2
SCR	74%	Wood	321	\$1,978	2006	\$4,514	7

Table 2-6. NOx control costs for SCR applied to ICI boilers

References:

1. US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/

2. NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

7. BPEI. (2008, February). RSCR Cost Effective Analysis.



Figure 2-9. Capital cost for NOx control for SCR applied to ICI boilers as a function of boiler capacity

2.7 Chapter 2 References

Albanese, Vince (2006). "Applications, Issues, & Answer for SNCR." NACAA Fall Meeting in San Antonio, TX.

Babcock Power Environmental Inc. (2006). Regenerative SCR. Worcester: Babcock Power Environmental Inc.

Bodnarik, Andrew M. New Hampshire Department of Environmental Services, "ICI Boiler NOx Control Cost Estimates from the OTC Methodology," presented at the OTC Control Strategy/SAS Committee Meeting, November 2, 2006.

Babcock Power Environmental Inc. (2008). RSCR Cost Effective Analysis.

Khan, Sikander. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

MACTEC. Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

STAPPA/ALAPCO (2006). "Controlling Fine Particulate Matter under the Clean Air Act: A Menu of Options."

Toupin, R. F. (2007). Efficient and Low Emission Stoker Fired Biomass Boiler Technology in Today's Marketplace. Worcester: Babcock Power Environmental Inc.

US EPA. Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. <u>http://www.epa.gov/ttn/catc/dir1/fscr.pdf</u>.

US EPA. OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. <u>http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/</u>.

Whiteman, C. ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

3 SO₂ CONTROL TECHNOLOGIES

3.1 SO₂ Formation

 SO_2 is an undesirable byproduct of the combustion of sulfur-containing fossil fuels. SO_2 , like NOx, is a precursor to ambient fine particles: Thirty to 50 percent of ambient fine PM mass in the eastern U.S. is attributable to sulfate derived from SO_2 . SO_2 is a significant contributor to wet and dry acid deposition on various ecosystems (lakes, streams, soils, and forests). Various coals in the U.S. can have 1 to 3 percent (by mass) sulfur; residual oil (No. 6 oil) can have sulfur contents of 2 percent and higher. Distillate oils are generally lower in sulfur content (less than 0.5 percent by mass). Natural gas has essentially zero sulfur content. However, unlike nitrogen in coal or oil, essentially all of the sulfur in the fuel is oxidized to form SO_2 (a very small percentage is further oxidized to SO_3 depending on fuel and boiler characteristics). This means that the relationship between sulfur content in the fuel and SO_2 emissions is much more direct and linear than that between fuel nitrogen and NOx emissions, and as such, the emission reduction benefits of fuel switching (for example from higher- to lower-sulfur coal or from higher-sulfur oils to lower-sulfur oils) are directly proportional to the difference in sulfur contents of fuels.

Another important difference is that this relationship is, for all practical purposes, independent of the type of boiler technology. Two exceptions to this include the high–alkaline nature of ash in some sub bituminous coals, which causes a portion of the sulfur in the coal to react and form various sulfate salts (mostly calcium sulfate); another is the combustion of coal in fluidized bed combustion (FBC) boilers where the lower temperatures of combustion and the use of alkaline material (e.g., limestone) in the "bed" promote the reaction of SO₂ with calcium to form sulfate, thereby reducing the net emissions of SO₂. In practical terms, this means that most solid- and liquid-fuel-fired systems produce SO₂ emissions proportional to their sulfur content, whereas natural gas combustion produces essentially no SO₂.

Additionally, despite the much smaller quantities of SO_3 formed in comparison to SO_2 , as noted above, SO_3 presents both operational and environmental challenges. Operationally, SO_3 is a concern because if the temperature of the back-end flue gas handling equipment (e.g., ducts, particulate control devices, scrubbers) falls below the acid dew point, corrosion and material deterioration can result. From an environmental perspective, nucleation and condensation of ultra-fine sulfuric acid particles formed from the SO_3 present in the flue gas can contribute to the primary emissions of fine PM from the stack into the atmosphere.

3.2 SO₂ Reduction

As a result of the relationship between fuel sulfur content and SO_2 , SO_2 emission control technologies fall in the category of reducing SO_2 after its formation, as opposed to minimizing its formation during combustion. This is accomplished by reacting the SO_2 in the flue gas with a reagent (usually calcium- or sodium-based) and removing the resulting product (a sulfate/sulfite) for disposal or commercial use, depending on the technology used. SO_2 reduction technologies are commonly referred to as Flue Gas Desulfurization (FGD) or SO_2 "scrubbers" and are usually

described in terms of the process conditions (wet vs. dry), methods for gas-sorbent contact (e.g., absorber vessel vs. duct for dry sorbent injection), byproduct utilization (throwaway vs. saleable), and reagent utilization (once-through vs. regenerable).

Within each technology category, multiple variations are possible and typically involve the type and preparation of the reagent, the temperature of the reaction, and the use of enhancing additives. Because these variations mostly involve complex process chemistry, but are fundamentally similar, this summary focuses on the major categories of SO_2 control technologies, their applicability to ICI boilers, and data on performance and cost. For a more detailed description of FGD technologies, see Srivastava [2000].

As noted earlier, SO_2 control strategies can also include fuel switching (from high-sulfur coal to low-sulfur coal or from high-sulfur oil to low-sulfur oil/natural gas). While not considered a "technology," switching from a higher-sulfur fuel to a lower-sulfur one requires considerable cost and operational analysis. Major issues include price, availability, transportation, and suitability of the boiler or plant to accommodate the new fuel.

3.3 Other FGD Benefits

Significant attention has been given recently to the issue of mercury emissions from EGUs and ICI boilers. It is relevant to note that some FGD technologies have been shown to capture mercury from the flue gas [Jones and Feeley, 2008] by absorbing the water-soluble oxidized forms of mercury from the flue gas. Both wet and dry SO_2 control processes have been and are being tested to determine their mercury capture potential. This suggests that strategic and economic analyses for SO_2 control technologies need to consider the potential side-benefit of mercury removal as well.

3.4 Summary of FGD Technologies

A brief overview of FGD technologies is provided here to give the reader a broad perspective on SO_2 controls.

3.4.1 Wet Processes

Wet FGD (WFGD) or "wet scrubbers" date back to the 1960s with commercial applications in Japan and the U.S. in the early 1970s [NESCAUM 2000]. They represent the predominant SO_2 control technology in use today with over 80 percent of the controlled EGUs capacity in the world and the U.S. [EPA 2000].

In a wet scrubber, the SO₂-containing flue gas passes through a vessel or tower where it contacts an alkaline slurry, usually in a counterflow arrangement. The intensive contact between the gas and the liquid droplets ensures rapid and effective reactions that can yield >90 percent SO₂ capture. Currently, advanced scrubber designs for EGUs have eliminated not only many of the early operational problems, primarily related to reliability, but have also demonstrated very high SO₂ reduction capabilities with the technology being capable of well over 95 percent SO₂ control [Dene *et al.*, 2008]. *Figure 3-1* provides a schematic view of a wet scrubber.



Figure 3-1. Schematic of a WFGD scrubber [Bozzuto, 2007]

Variations of the basic technology, in addition to equipment improvements made over the years, include reagent and byproduct differences. Limestone, lime, sodium carbonate, ammonia, and even seawater-based processes are all commercially available. Limestone is by far the most widely used with commercial-grade gypsum (wallboard quality) being produced in the so-called Limestone Forced Oxidation (LSFO) process. The use of other reagents, as mentioned, is driven by site-specific criteria, such as local reagent availability, economics, and efficiency targets.

Technology costs have changed over time, as expected, reflecting changes in market conditions, labor and raw material costs, local, state, regional, and federal regulatory drivers, and site-specific considerations. Recently, capital costs have trended upward after a downward trend in the mid-late 1990s. These fluctuations have in large part, been driven by labor and material costs, the global nature of technology markets, and regulatory changes within the electric power sector [Sharp, 2007; Cichanowicz, 2007].

3.4.2 Dry Processes

Conventional dry processes include spray dryers (SDs) or "dry scrubbers" and Dry Sorbent Injection (DSI) technologies, and are shown in *Figure 3-2* and *Figure 3-3*, respectively. The technologies are referred to as "dry" because the SO₂ sorbent, while it may be injected as a slurry or a dry powder, is finally dried and collected in a conventional particulate control device, a fabric filter, or an ESP.

SD refers to a configuration where the reaction between SO_2 and the sorbent takes place in a dedicated reactor or scrubber vessel. DSI technology does not require a dedicated reactor and instead uses the existing boiler and duct system as the "reactor," and several configurations are possible based on the temperature window desired. This can occur at the furnace (1800-2200°F), economizer (800-900°F), or in a low-temperature duct (250-300°F). In addition, another common feature of dry scrubbing systems is the need for the particulate control equipment downstream of the sorbent injection. Usually this is accomplished through the use of fabric filters (although, depending on the application, ESPs may be used) that are not only efficient collectors of fine particulates, but can also provide some additional SO₂ removal as the flue gas passes through unreacted sorbent collected on the bags. Dry processes are more compatible with low- to medium-sulfur coals because of the need to limit solid concentrations in the slurry below a threshold for adequate atomization and the need to limit the amount of solids collected in an existing particulate control device. This requirement precludes higher sulfur fuel applications where the required amount of reagent would be above that threshold. Therefore, high-sulfur applications are more typically associated with wet FGDs.



Figure 3-2. Schematic of a spray dryer [http://www.epa.gov/eogapti1/module6/sulfur/control.htm]

It is relevant to note that DSI technology did not gain any meaningful market penetration as part of the EGU compliance options to meet the requirements of the 1990 CAAA (Title IV) "acid rain" legislation for reducing emissions of SO₂. The large number of wet FGD installations in response to the Clean Air Act of 1970, and creation of "emission allowances," combined with the trend to switch fuels (mostly to low-sulfur Powder River Basin or PRB coal) in response to the 1990 CAAA, help explain this situation. However, more recently, interest in DSI technology applications for ICI boilers has been renewed and companies are "revamping" the knowledge base for DSI.



Figure 3-3. Dry Sorbent Injection (DSI) system diagram [http://www.epa.gov/eogapti1/module6/sulfur/control/control.htm]

DSI technologies include calcium (lime) and sodium (trona) reagents and are currently being tested or demonstrated within the ICI boiler sector. Companies such as O'Brien and Gere [Day, 2006; Day, 2007] and Siemens Environmental [Siemens, 2007] are marketing and deploying duct injection systems, and Nalco Mobotec [Haddad *et al.*, 2003] offers furnace sorbent injection (FSI) systems for ICI boilers. O'Brien and Gere, for example, have conducted over 5,000 hours of demonstrations at 15 different boilers since January 2005 to evaluate the viability, performance, and economics of DSI [Day, 2007]. These processes require relatively little new equipment and are thus suitable candidates for ICI boiler retrofit applications, where site constraints (e.g., space) are often critical.

Two examples of DSI systems are Furnace Sorbent Injection (FSI) in which hydrated lime is injected into the upper furnace of the boiler, and Lime Slurry Duct injection (LSDI) where atomized lime slurry is sprayed into the gas stream in the duct. FSI systems were first demonstrated in the 1980s on EGU boilers and are currently operating at ICI boilers [Dickerman, 2006].

FSI systems are capable of removing between 20 to 60 percent of the SO_2 and have shown removal percentages of as high as 90 to 99 percent for HCl and SO_3 [Haddad *et al.*, 2003]. The FSI systems also offer a low capital cost option and the attractiveness of quick cost recovery for ICI boiler sector [Dickerman, 2006].

The LSDI utilizes an atomized spray of lime slurry. The particles are subsequently captured in the downstream particulate collector. Sorbent particle size distribution is important for maximizing SO_2 capture while minimizing operational problems such as duct fallout and deposition.

LSDI systems have been utilized to mitigate plume generation from cement plants, and are capable of SO₂ reductions of up to 90 percent for industrial applications and ICI boilers, as well as HCl and HF reductions of greater than 95 percent [Dickerman, 2006].

In either case, both dry sorbent injection technologies offer an economical method for reducing emissions of SO₂. *Table 3-1* compares the FSI and LSDI systems for a 100 MW boiler, burning coal with one percent sulfur.

Parameter	FSI (Hydrated Lime)	LSDI
SO ₂ Removal	35%	50%
Reagent Cost (\$10 ³ /yr)	\$1,400	\$370
Parasitic Power (\$10 ³ /yr)	\$182	\$182
Disposal Cost (\$10 ³ /yr)	\$168	\$93
Subtotal (\$10 ³ /yr)	\$1,750	\$645
Capital Cost (\$/kW)	\$1,000,000 (10 \$/kW)	\$2,500,000 (25 \$/kW)
Annual Capital Charge (\$10 ³ /yr)	\$100	\$250
Total Operating Cost (\$10 ³ /yr)	\$1,850	\$895
\$/ton SO ₂ Removed	\$1,070	\$311

Table 3-1.	Comparison of	price for FSI	and LSDI s	vstems for a	100 MW	coal-fired boiler	[Dickerman.	20061
I ubic o Ii	Comparison of	price for 1 br		jotenno ioi u	100 101 00	cour mea boner	[Dicker many	=0000j

Trona (sodium sesquicarbonate) is another reagent that has shown potential to reduce SO_2 emissions. A typical flow diagram is shown in *Figure 3-4* for injection of trona into a duct.



Figure 3-4. Flow diagram for trona DSI system [Day, 2006]

Trona's higher reactivity compared to lime helps it to offset the reaction stoichiometry advantage of lime. More importantly, due to the ability of trona to capture SO_2 when injected at higher temperatures [Cremer *et al.*, 2008], it is potentially applicable to many ICI boilers where flue gas temperatures may be higher that the desired ~300°F required for lime. *Figure 3-5* gives

some test data showing percent SO_2 reduction, [Day, 2006], averaged over several applications for units with ESPs.



Figure 3-5. SO₂ removal test data [Day, 2007]

Figure 3-5 presents results for SO₂ reduction as a function of normalized stoichiometric ratio (NSR), which is the ratio of the reagent (trona in this case) to SO₂ in the flue gas. The two lines depict SO₂ reduction potential for two different sizes of trona at the same flue gas temperature of 700°F. Larger particles (unmilled) result in lower SO₂ reductions, as expected, relative to the milled condition (smaller particle size).

3.4.3 Other SO₂ Scrubbing Technologies

A number of other scrubber technologies have been developed for control of SO₂, but have not to date received significant market share. Among them are sodium- and ammonia-based wet scrubbing technologies. Some of these technologies, like the activated coke process [Dene, 2008], are regenerable (meaning the reagent can be regenerated and used repeatedly) and may produce useful byproducts, such as sulfuric acid, elemental sulfur, and ammonium sulfate. *Table 3-2* and *Table 3-3* present a comparison of the key performance characteristics and attributes for several alternative scrubbing technologies compared with conventional wet and dry scrubbers [Bozzuto, 2007].

	Limestone WFGD	Spray Dryer	Ammonia WFGD	Sodium WFGD
Features	 High Efficiency 	• Low	 High value 	• Low investment cost
	 Low cost reagent 	investment cost	byproduct	 Operational
	 Byproduct 	 Dry byproduct 	 Economics 	simplicity
	flexibility	 Small footprint 	improved at high	
		 No liquid 	sulfur levels	
		waste	 Low operating cost 	
Pros	 Small flue gas 	 Low/medium 	 High sulfur fuel 	 High sulfur fuel
	flow	sulfur fuel	 Larger flue gas 	 Larger flue gas flow
	 Operational 	 Smaller flue 	flow	 Fertilizer market
	simplicity required	gas flow	 Gypsum market 	
	 Acute capital cost 	Short	 Medium cost 	
	 Short evaluation 	evaluation period	evaluation period	
	period			
Cons	 Effluent discharge 	 Limited 	 Acute capital cost 	 Acute capital cost
	issue	landfill area	sensitivity	sensitivity
		 High 	 Ultra-low PM 	
		lime/limestone	emission	
		cost ratio	requirements	
Reagent	Limestone	Lime	Ammonia	Caustic, soda ash
Byproduct	Marketable gypsum	Landfill	Fertilizer	Sodium sulfate
	or landfill			
SO ₂ inlet	High	Low/medium	High	High
Removal	>98%	90 - 95%	>98%	>98%
Efficiency				

Table 3-2. Comparison of alternative FGD technologies [Bozzuto, 2007]

 Table 3-3. Cost estimates for alternative FGD technologies [Bozzuto, 2007]

	Limestone WFGD	Spray Dryer	Ammonia WFGD	Sodium WFGD
Capital Cost	25 - 45	15-25	35 - 60	10 - 20
(\$/acfm)				
Power	3-6	2	3-6	2-3
Consumption				
(kW/acfm)				
Reagent Cost	\$15 – 25/ton	\$60 - 75/ton	\$80 - 105/ton	\$100-130/ton
(\$/ton SO ₂				
removed.)				
Byproduct Cost	\$12 - 20/ton -	\$12 - 20/ton	\$150 - 250/ton	??
(\$/ton SO ₂	disposal (\$15/ton)			
removed.)	- sale			

3.5 Use of Fuel Oils with Lower Sulfur Content

Distillate fuel (No. 2 oil) is used in combustion systems in which an atomizer sprays droplets of oil into a combustion chamber and the droplets burn in suspension. Residual fuel oil (No. 6 oil) is also atomized and burned in ICI boilers. No. 6 oil is more viscous and has a higher boiling point range than distillate oil. Preheating is required for metering and atomization of No. 6 oil in industrial combustion systems. A wide range of sulfur contents are available, from less than 0.3 wt% to greater than 3 wt%.
For oil-fired ICI boilers, switching to lower-sulfur oil can provide significant reductions in emissions of SO₂. There is also an additional and important benefit of reduced emissions of $PM_{2.5}$. There are generally costs associated with switching to lower-sulfur fuels, which will undoubtedly vary from region to region.

Table 3-4 shows an example of the stocks of the fuel oils available on the East Coast and in the U.S. in 2006, taken from the Energy Information Administration (EIA) Petroleum Supply Annual [US EIA, 2006]. Substantial stocks of low-sulfur No. 6 fuel oil (less than 0.3 percent sulfur) and of ultra-low-sulfur No. 2 fuel oil (less than 0.0015 percent sulfur) were available both in the U.S. and on the East Coast.

	East	Coast	U. S.	Total
Distillate Fuel Oil	4,174		31,318	
0.0015% sulfur and under	1,856	(44%)	16,531	(53%)
Greater than 0.0015% to 0.05% sulfur	560	(13%)	6,223	(20%)
Greater than 0.05% sulfur	1,758	(42%)	8,564	(27%)
Residual Fuel Oil	2,486		11,936	
Less than 0.31% sulfur	869	(35%)	1,291	(11%)
0.31 to 1% sulfur	975	(39%)	2,544	(21%)
Greater than 1% sulfur	642	(26%)	8,101	(68%)

Table 3-4. Distillate and residual oil stocks in 2006 (x1000 barrels) [US EIA, 2006]

Figure 3-6 shows the prices for residual oil and distillate oil from 1983 through 2007. The differential between low (less than 1 percent sulfur) and high (greater than 1 percent sulfur) sulfur residual oil has been narrowing in recent years. The price of distillate oil in recent years, however, has been at times twice as much as the price of residual oil. The EIA prices for residual oil do not include a breakdown for very low sulfur residual oil (less than 0.31 percent sulfur). However, the prices for No. 2 (distillate) oil are broken out by ultra-low (<15 ppm S), low-sulfur (15-500 ppm S), and high-sulfur (>500 ppm S). These prices, shown in *Figure 3-7*, do not show much difference in price as a function of sulfur content of No. 2 oil.



Figure 3-6. Industrial energy prices for No. 6 oil greater than 1 percent S, No. 6 oil less than 1 percent S, and No. 2 oil [Source: US EIA, 2008]



Figure 3-7. Industrial energy prices for No. 2 (distillate) oil [Source: US EIA, 2008]

3-10 Appendix III.D.7.7-4145 The potential increased costs (in fuel only) for switching to lower-sulfur fuel oil can be estimated as shown in the following example, in which December 2007 fuel prices are used. If the high-sulfur residual oil is assumed to be 3 percent S, the low-sulfur residual oil is assumed to be 1 percent S, and the distillate oil is assumed to be 0.2 percent S, then the cost for fuel switching is shown in *Table 3-5*. These costs are only fuel costs, and do not include any equipment costs needed to switch fuels (for example, burner changes when switching from residual to distillate oil).

The cost estimates in *Table 3-5* suggest that switching from a 3 percent sulfur residual fuel oil to a low-sulfur residual oil (1 percent S) would provide a cost-effective sulfur removal strategy at about \$771 per ton of SO₂ removed. The cost of switching to distillate oil is estimated to be much higher than switching to low-sulfur residual oil, because the cost of distillate oil has been as much as twice that of residual oil in recent years. The cost effectiveness of a wet FGD for 90 to 99 percent SO₂ removal is in the range of \$2,000 to \$5,200/ton SO₂ (see Section 3.8). Thus, a switch to lower-sulfur fuel represents a cost-effective sulfur-compliance strategy for residual oil-fired boilers. The cost effectiveness (in dollars per ton of SO₂ removed) of switching from residual fuel oil to distillate fuel oil is not as attractive and is in the range of the cost effectiveness of installing a FGD or scrubber.

Fuel Switch	SO ₂ reduction	\$/ton SO ₂ removed (2007\$)
From 3% S to 1% Residual Oil*	66.7%	\$771
From 3% S Residual to 0.2% Distillate**	93.6%	\$5,335

 Table 3-5. Example of costs of switching to low-sulfur fuel oil [Fuel Prices from US EIA, 2008]

*Assuming December 2007 prices for <1%S and >1%S residual oil **Assuming December 2007 prices for >1%S and distillate oil

3.6 Applicability of SO₂ Control Technologies to ICI Boilers

The technologies described above are commercially available and are used extensively throughout the electric utility industry for coal-firing applications. The EGUs have deployed SO₂ controls (mostly wet and dry scrubbers) since the 1970s. ICI boilers firing coal are good candidates for the application of SO₂ control technologies. At least one oil-fired installation of a wet FGD has been noted in the literature [Caine and Shah, 2008]. Economics, however, will dictate preferred options on a case-by-case basis. It is likely that the higher capital-cost intensive technologies (e.g., wet and dry scrubbers) will be most attractive to larger ICI boilers, whereas the injection technologies (such as DSI) would likely be favored at smaller ICI boilers. The annualized cost of a wet FGD scrubber using wet sodium or alkaline waste can be lower relative to lime and limestone FGD, especially if low-cost waste disposal is available and the amount of SO₂ to be removed is small [Emmel, 2006]. This would suggest that smaller ICI boilers may not be good candidates for high capital-cost FGD systems. However, they should be good candidates for application of lower capital cost technologies such as DSI.

In terms of applicability, it is also important to recognize the impact of sulfur content of coal. Dry scrubbing has been typically restricted to low and medium sulfur coals (less than 2 wt% S) due to economic and technical considerations, including constraints associated with sorbent slurry concentration and adequate atomization performance. Lastly, while theoretically feasible, fluidized bed combustion (FBC) boilers are low emitters of SO_2 due to their inherent combustion process (bed temperature and composition), and are not likely candidates for SO_2 scrubber systems.

3.7 Efficiency Impacts

From the brief descriptions above, it should be clear that the common thread among the major SO_2 control technologies involves the reaction of SO_2 in the flue gas with a sorbent or reagent. The chemical reaction occurs either in a dedicated vessel (scrubber), or in the existing flue gas duct system. The major components affecting energy consumption for these systems include electrical power associated with material preparation (e.g., grinding) and handling (pumps/blowers), flue gas pressure loss across the scrubber vessel, and steam requirements. As expected, the energy penalties associated with a highly efficient (99 percent SO_2 reduction) wet scrubber are higher than for a less energy-intensive technology such as DSI.

The power consumption of SO_2 control technologies is further affected by the SO_2 control efficiency of the technology itself. In other words, SO_2 control performance is related to reagent utilization, commonly referred to as liquid-to-gas (L/G) ratio for wet systems and normalized stoichiometric ratio or reagent (Ca or Na) to-sulfur ratio for dry technologies. This can be explained based on the fact that for a given SO_2 reduction level, lower quantities of reagent not only translate to lower reagent costs, but also to lower energy costs.

Table 3-6 summarizes performance and energy efficiency impacts for the three general SO_2 technologies discussed. It is important to note the values shown in the table, specifically in the "Energy Impact" column, represent nominal ranges based on generic combustion calculations and parasitic energy consumption for each technology. They are not site- or fuel-specific calculations, which are generally dependent on many variables, such as fuel composition, combustion and steam efficiencies, and operating conditions (e.g., excess air). However, these values represent broad, industry-wide averages for impacts of SO_2 control technologies on efficiency.

Technology	Applicability	Performance (% Reduction)	Energy Impact (kW/1000 acfm)
WFGD	Larger coal units, high sulfur coals, excluding FBC	90 - 95+	4 – 8+
Dry Scrubbers (SDs)	Larger units w/ low/medium sulfur coals, excluding FBC	70 – 90+	2 - 4
Duct Injection	Larger units w/ low/medium sulfur coals (FBC applications possible for additional "SO ₂ trim")	30 – 60+	1 - 2

Table 3-6	Summary	of energy	impacts	for SO.	control	technologies
1 able 3-0.	Summary	or energy	impacts	101° 50_{2}	control	technologies

3.8 SO₂ Control Costs

Table 3-7 summarizes published SO₂ control costs for ICI boilers, as reported in the literature [Khan, 2003; US EPA, 2003; Whiteman, 2003; MACTEC, 2005]. Literature values of capital costs have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness in dollars/ton of SO₂ removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs, and reagents or consumables can make up a large portion of some of the operating costs. Costs of reagents and fuels (e.g., limestone, trona) change with time, but not always at the general rate of inflation. Thus, cost effectiveness values (or operating costs) from years before 2005 are not shown in the table. *Table 3-7* summarizes the published SO₂ control costs for a number of SO₂ control technologies.

A range of capital costs has been reported for sorbent injection technologies. *Figure 3-8* shows costs for dry duct injection (e.g., trona injection), wet duct injection (e.g., LSDI), and furnace sorbent injection (FSI). There was a large range of capital costs reported for dry sorbent injection. Wet sorbent injection (e.g., injection of hydrated lime slurry) was reported to have a significantly lower capital cost than dry sorbent injection. FSI capital costs were between dry and wet duct injection. The cost effectiveness (cost in dollars per ton of SO₂ removed) depends on the specific sorbent used and the stoichiometric ratio of sorbent to SO₂.

						Cost	
	SO_2			Capital Costs,	Base	Effectiveness	
	Reductio		Size of Boiler	\$2006 per	year for	(\$/ton	-
Technology	n Range	Fuel Type	(MMBtu/hr)	MMBTU/hr	Costs	@Base Yr)	Ref
In-Duct Dry Sorbent Inj.	40%	High-S Coal	100	\$34,228	1999		1
In-Duct Dry Sorbent Inj.	40%	High-S Coal	250	\$24,028	1999		1
In-Duct Dry Sorbent Inj.	40%	High-S Coal	1000	\$15,954	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	100	\$22,953	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	250	\$16,565	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	1000	\$11,031	1999		1
In-Duct Dry Sorbent Inj.	50 - 90%	Coal	100	\$17,327	2003		3
In-Duct Dry Sorbent Inj.	50 - 90%	Coal	250	\$12,624	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	100	\$8,663	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	250	\$4,703	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	1000	\$4,641	2003		3
Furnace Sorbent Inj.	70%	Coal	100	\$26,609	2003		3
Furnace Sorbent Inj.	70%	Coal	250	\$14,851	2003		3
Furnace Sorbent Inj.	70%	Coal	1000	\$7,054	2003		3
Spray Dryer	90%	Coal	100	\$69,744	1999		1
Spray Dryer	90%	Coal	250	\$46,209	1999		1
Spray Dryer	90%	Coal	1000	\$25,861	1999		1
Spray Dryer	90%	Coal	250	\$13,300-188,820	2005	\$1,712-3,578	4
Spray Dryer	95%	Coal	250	\$13,300-188,820	2005	\$1,622-3,390	4
Spray Dryer	90%	Oil	250	\$13,300-188,820	2005	\$1,944-5,219	4
Spray Dryer	95%	Oil	250	\$13,300-188,820	2005	\$1,841-4,945	4

Table 3-7. SO₂ control costs applied to ICI boilers

Tashnalagu	Reduction	Evol Type	Size of Boiler (MMBty (br)	Capital Costs, \$2006 per	Base year for	Cost Effectiveness (\$/ton	Dof
Technology	Kange	Fuel Type			Costs	(Dase Ir)	Kei
Wet FGD	90%	High-S Coal	100	\$81,939	1999		1
Wet FGD	90%	High-S Coal	250	\$62,318	1999		1
Wet FGD	90%	High-S Coal	1000	\$41,216	1999		1
Wet FGD	90%	Low-S Coal	100	\$76,018	1999		1
Wet FGD	90%	Low-S Coal	250	\$57,759	1999		1
Wet FGD	90%	Low-S Coal	1000	\$38,122	1999		1
Wet FGD	90%	Coal	250	\$11,507-172,672	2005	\$2,089-3,822	4
Wet FGD	99%	Coal	250	\$11,507-172,672	2005	\$1,881-3,440	4
Wet FGD	90%	Oil	100	\$69,848	1999		1
Wet FGD	90%	Oil	250	\$53,066	1999		1
Wet FGD	90%	Oil	1000	\$35,019	1999		1
Wet FGD	90%	Oil	250	\$11,507-172,672	2005	\$2,173-5,215	4
Wet FGD	99%	Oil	250	\$11,507-172,672	2005	\$1,956-4,694	4

Table 3-7 [continued]

References

Khan, S. Methodology, Assumptions, and References Preliminary SO₂ Controls Cost Estimates for Industrial Boilers; US EPA: 2003.
 US EPA, Air Pollution Control Technology Fact Sheet: Flue Gas Desulfurization (FGD - Wet, Spray Dry, and Dry Scrubbers; EPA-452/F-03-034, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ffdg.pdf

3. Whiteman, C., ICAC, "SO₂ Control Technology Cost Estimates for Industrial Boilers" memo to John Robbins, US EPA, December 12, 2003.

4. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.





Spray dryer (SD) technology has been widely applied to coal-fired EGUs. Estimates in the literature for SD technology for ICI boilers give the same capital costs for coal- and oil-fired boilers [ICAC, 2003; MACTEC, 2005]. *Figure 3-9* summarizes these capital costs for ICI boilers. Note that the MACTEC estimates at 250 MMBtu/hr boiler size assumed high and low equipment cost, but a detailed cost breakdown was not given.



Figure 3-9. Capital cost for SO₂ control for Spray Dryer Absorber applied to ICI boilers as a function of boiler capacity

Wet FGD technology has been widely applied to coal-fired EGU boilers but rarely to ICI boilers, although at least one oil-fired installation has been noted in the literature [Caine and Shah, 2008]. The relationship between FGD capital cost and boiler capacity is shown in *Figure 3-10*. Estimates in the literature give the same capital costs for coal- and oil-fired boilers [ICAC, 2003; MACTEC, 2005], although these estimates are not always based on actual field installation data because installations of wet FGD technology on ICI boilers are few at present.



Figure 3-10. Capital cost for SO₂ control for wet FGD applied to ICI boilers as a function of boiler capacity

3.9 Chapter 3 References

Bozzuto, C. "SO₂ Scrubber Systems," CIBO Industrial Emissions Conference, Portland, ME 2007.

Caine, John, Shah, Hardik. "Next Generation Wet Electrostatic Precipitators," presented at 101st Air & Waste Management Association Annual Meeting, Portland, OR, June 24-26, 2008.

Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emission Control Systems," prepared for UARG, 2007.

Cremer, Marc, Wang, David H., Senior, Connie L. "Testing and Model Based Optimization of SO₂ Removal with Trona in Coal Fired Utility Boilers," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Day, Keith. "Use of Dry Sorbent Injection Systems for Controlling Hg, HCL, SO₂/SO₃, NOx," CIBO 2007.

Day, Keith. *Duct Injection for Controlling SO*₂, *SO*₃, *Hg*, and *HCl*; O'Brien and Gere: Jan. 3, 2006.

Dene, Chuck, Baker, Lesley A., Keeth, Robert J. "FGD Performance Capability," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Dene, Chuck. "ReACT Process Demonstration at Valmy Generating Station," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Dickerman, Jim (2006). "SO₂ Emission Controls for Older and Smaller Boilers," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 25-28, 2006.

Emmel, T. "Use of CUECost Model for Developing Cost Estimates for Industrial Size Boilers," memorandum to CIBO, March 2006.

Haddad, E., Ralston, J., Freen, G., Castagnero, S. "Full-Scale Evaluation of a Multi-Pollutant Reduction Technology: SO₂, Hg, and NOx," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Washington, DC, May 19-22, 2003.

Jones, Andrew P., Feeley, Thomas J. (2008) *Preliminary Economic Analysis of Wet FGD Co-Benefit Enhancement Technologies*. National Energy Technology Laboratory, Pittsburgh, PA, May 2008, http://www.netl.doe.gov/energy-analyses/pubs/Enhanced FGD Hg Capture Economics FINAL May2008.pdf.

Khan, Sikander. *Methodology, Assumptions, and References Preliminary SO*₂ Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

MACTEC. *Boiler Best Available Retrofit Technology (BART) Engineering Analysis*; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Environmental Regulation and Technology Innovation: Controlling Mercury Emissions from Coal-Fired Boilers (Praveen Amar, Project Director), September 2000.

NJ DEP. Workgroup Recommendations and Other Potential Control Measures, Stationary Combustion Sources Workgroup, SCS003 – ICI Boilers, May 2, 2006. www.nj.gov/dep/airworkgroups/docs/wps/scs003_fin.pdf.

Nichols, B. "Air Pollution Control Systems at Virginia Tech's Power Plant," CIBO 2007.

Siemens Environmental Systems and Services. "Dry Scrubbing for Industrial Facilities," CIBO2007.

Sharp, G. Power Magazine, 2007.

Srivistava, R. "Controlling SO₂ Emissions – A Review of Technologies," EPA/600/R-00/093, November 2000.

US EIA. *Petroleum Price Data and Analysis*, accessed March 20, 2008. <u>http://tonto.eia.doe.gov/dnav/pet/pet_pri_top.asp</u>.

US EIA. *Petroleum Supply Annual 2006*, Volume 1, 2006. <u>http://www.eia.doe.gov/oil_gas/petroleum/data_publications/petroleum_supply_annual/psa_volume1/psa_volume1.html</u>.

US EPA. *Integrated Planning Model*, Documentation for EPA Base Case 2006 (v3.0), Section 8, Fuel Assumptions. <u>http://www.epa.gov/airmarkt/progsregs/epa-ipm/docs/Section-8.pdf</u>.

US EPA. *Integrated Planning Model*, Documentations for EPA Base Case 2006 (v3.0), Attachment O. <u>http://www.epa.gov/airmarkt/progsregs/epa-ipm/docs/attachment-o.pdf</u>.

US EPA. Air Pollution Control Technology Fact Sheet: Flue Gas Desulfurization (FGD - Wet, Spray Dry, and Dry Scrubbers; EPA-452/F-03-034, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ffdg.pdf. Whiteman, C. ICAC, "SO₂ Control Technology Cost Estimates for Industrial Boilers," memo to John Robbins, US EPA, December 12, 2003.

4 PM CONTROL TECHNOLOGIES

4.1 PM Formation in Combustion Systems

PM emissions from combustion processes include primary and secondary emissions. Primary emissions consist mostly of fly ash. Secondary emissions are the result of condensable particles such as nitrates and sulfates that typically make up the smaller fraction of the particulate matter (PM_{10} and $PM_{2.5}$). Fly ash refers to the mineral matter of the fuel, which typically includes some level of unburned carbon. ICI boilers burn a variety of fuels that contain ash and, as such, have PM emissions. Therefore, ICI boilers are candidates for PM controls.

Coal and oil contain non-combustible ash material. Other liquid or solid fuels (e.g., petroleum coke, wood) also contain ash. The quantity of ash in the flue gas depends on many factors, such as fuel properties, boiler design, and operating conditions. In dry-bottom, pulverized-coal-fired boilers, approximately 80 percent of the total ash in the as-fired coal exits the boiler as fly ash, and the remaining ash is collected as bottom ash. However, in wet-bottom, pulverized-coal-fired boilers, about 50 percent of the total ash exits the boiler as fly ash. In cyclone boilers (common in the EGU sector but not in the ICI population), most of the ash is retained as liquid slag, and the fly ash is only about 20 percent of the total ash. Fluidized-bed combustors (FBC) emit high levels of fly ash because the coal is fired in suspension and the ash is present in dry form. Stoker-fired boilers can also emit high levels of fly ash. However, overfeed and underfeed stokers emit less fly ash than spreader stokers because combustion takes place in a relatively quiescent fuel bed.

In addition to the nitrates and sulfates mentioned as secondary PM, NOx control technologies that inject ammonia or amine-based reagents (SNCR and SCR) yield a certain amount of ammonia "slip," which can also form fine particulate (ammonium sulfate) as the flue gas temperatures decrease towards the stack.

This section presents a brief description of the major primary PM technologies.

4.2 PM Control Technologies

PM control technologies have been commercially available and widely used in ICI and EGU boilers for many years. *Table 4-1* summarizes the main types of commercially available technologies.

Technology	Description	Applicability	Performance
Fabric filters (Baghouse)	"Baghouses" made of close-knit fabrics remove particulates through filtration.	Primarily used in coal/wood fired industrial/utility boilers. Not used with oil boilers due to clogging.	>99% total and PM _{2.5} removal
ESPs (Dry/Wet)	Charged particles attracted to oppositely charged plates. Collection method either wet/dry.	Widely used in coal applications. Suitable for oil, pet coke and waste solid fuels. Wet ESPs suitable for saturated flue gas.	Effectiveness depends on resistivity of particulates. Low sulfur can reduce performance of dry ESP. >99% reduction of total PM (dry/wet) and sulfuric acid mist and PM _{2.5} (wet)
Venturi Scrubbers	Scrubbers work on the principle of rapid mixing and impingement of the particulate with the liquid droplets and subsequent removal with the liquid waste.	High pressure required for significant removal. Applicable to a wide range of fuels.	50% removal for fine particulates, 99% removal for large (>5 micron) particulates
Cyclones	Cyclones use aerodynamic forces to separate particles from the gas stream.	Widely applicable to all fuels.	70%-90% total PM potential

Table 4-1.	Available	РМ	control	options	for	ICI boilers
1 abic 4-1.	11 vanabic	T TAT	control	options	101	ICI boncis

4.3 Description of Control Technologies

4.3.1 Fabric Filters

Fabric filters (also called baghouses) are essentially giant vacuum cleaners and very effective devices for collecting dry PM from flue gas. They are used in ICI and EGU applications, although less widely than ESPs. Separation occurs when the ash-laden flue gas passes through a porous layer of filter material. As the individual particles accumulate on the surface of the filter, they gradually form a layer of ash known as the "dust cake." Once formed, the dust cake provides most of the filtration. However, they are not particularly well suited for wet gas applications due to the negative impact of wet gas on the bag filters. *Figure 4-1* shows a photograph of the internal components of a fabric filter compartment with several individual bags and mounting mechanisms.



Figure 4-1. Photograph of fabric filter compartment with filter bags [Source: <u>www.hamon-researchcottrell.com</u>]

As shown in *Figure 4-1*, multiple bags are assembled in compartments to provide a large surface area for filtration. The large surface area is required to maintain acceptable pressure loss across the fabric. Groups of bags are placed in compartments, which can be isolated from one another to allow cleaning of the bags (see below), or to allow replacement of some of the bags without shutting down the entire baghouse.

Baghouse size is typically defined in terms of "air-to-cloth" ratio, expressed in the units of velocity in feet per minute (cubic feet per minute of flow divided by square feet of fabric area). The size of the baghouse depends on the particulate loading and characteristics, and the cleaning method used.

The type of bag cleaning method employed characterizes baghouses. Cleaning intensity and frequency are important because the dust cake provides a significant fraction of the fine particulate removal capability of a fabric. Hence, too frequent or too intense a cleaning method may lower the removal efficiency. Conversely, if removal of this dust cake happens infrequently or inefficiently, the pressure drop will increase to unacceptable levels. The major cleaning methods are as follows.

- Reverse-air baghouse In this case, the flue gas flows upward through the vertical bags, which open downward. The fly ash thus collects on the insides of the bags, and the gas flow keeps the bags inflated. To clean the bags, a compartment of the baghouse is taken off-line, and the gas flow in this compartment reversed. This causes the bags to collapse, and collected dust to fall from the bags into hoppers.
- Pulse-jet baghouse In this case, the dust is collected on the outside of the bags, which are mounted on cages to keep them from collapsing. Dust is removed by a reverse pulse of high-pressure air. This cleaning does not require isolation of the bags from the flue gas flow, allowing it to be done on-line. Because pulse-jet cleaning is more intensive than in reverse-air baghouses, the bags in a pulse-jet baghouse remain relatively clean, resulting in the ability to use a higher air-to-cloth ratio or a smaller baghouse compared to the reverse-air type.

Additionally, fabric filters can also be used in applications where fly-ash resistivity makes it difficult for collection with ESPs. Further, baghouses are capable of 99.9 percent removal efficiencies, as well as being able to remove the smaller size PM fraction ($PM_{2.5}$) more efficiently.

4.3.2 Electrostatic Precipitators

ESP's operate on the principle of electrophoresis by imparting a charge to the particulates and collecting them on opposed charged surfaces. Dry vs. wet ESPs refer to whether the gas is water-cooled and saturated prior to entering the charged collection area or is dry. *Figure 4-2* and *Figure 4-3* show schematic views of dry and wet ESPs, respectively. Older ESPs are often of the wire-pipe design, in which the collecting surface consists of one or more tubes (operated wet or dry). The wire-plate design is the other commonly used ESP design, as illustrated in the schematic in *Figure 4-2*.

In gases with high moisture content, dry ESPs are not suitable because the wet gas would severely limit the ability to collect the "sticky" particulates from the plates. The wet ESP technology is capable of very high removal efficiencies and is well suited for the wet gas environments. Both types of ESPs are capable of greater than 99 percent removal of particle sizes above 1 μ m on a mass basis with wet ESPs being capable of such reductions well into the sub-micron level (0.01 μ m) [Altman, 2001].



Figure 4-2. Side view of dry ESP schematic diagram [Source: Powerspan]



Figure 4-3. Wet ESP [Croll Reynolds]

Compared to fabric filters, ESPs affect the flue gas flow minimally, resulting in much lower pressure drops then an equivalent baghouse (typically less than two inches H_2O vs. greater than six inches H_2O for the fabric filter).

An electric field between high-voltage discharge electrodes and grounded collecting electrodes produces a corona discharge from the discharge electrodes, which ionizes the gas passing through the precipitator, and gas ions subsequently ionize fly ash (or other) particles. The negatively charged particles are attracted to the collecting electrodes. To remove the collected fly ash, the collecting electrodes are rapped mechanically, causing the fly ash to fall into hoppers for removal.

A balance generally needs to be struck between higher voltages for higher particulate removal efficiency and excessive sparking which will have the opposite effect. Larger ESPs are sectionalized (see *Figure 4-2*) such that higher voltages can be used in the first sections of the precipitator, where there is more particulate to be removed. Lower voltages are then used in the last, cleaner precipitator sections to avoid excessive sparking between the discharge and collecting electrodes. This has the added advantage that particles re-entrained in the flue gas stream by rapping (striking the electrode to dislodge the dust) may be collected in the downstream sections of the ESP.

Precipitator size is a major variable affecting overall performance or collection efficiency. Size determines residence time (the time a particle spends in the precipitator). Precipitator size also is typically defined in terms of the specific collection area (SCA), the ratio of the surface area of the collection electrodes to the gas flow. Higher SCA leads to higher removal efficiencies. Collection areas can range from as low as 200 to as high as 800 ft²/1000 acfm. In order to achieve collection efficiencies of 99.5 percent, SCA of 350-400 ft²/1000 acfm is typically used. The overall (mass) collection efficiencies of ESPs can exceed 99.9 percent, and efficiencies in excess of 99.5 percent are common. Precipitators with high overall collection efficiencies can achieve high efficiencies across a range of particle sizes so that good control of PM_{10} and $PM_{2.5}$ is possible with well designed and operated electrostatic precipitators.

Unlike dry ESPs, which use rapping to remove particulates from the collecting electrodes, wet ESPs use a water spray to remove the particulates. By continually wetting the collection surface, the collecting walls never build up a layer of particulate matter. This means that there is little or no deterioration of the electrical field due to resistivity, and power levels within a wet ESP can therefore be higher than in a dry ESP. The ability to inject greater electrical power within the wet ESP and elimination of secondary re-entrainment are the main reasons a wet ESP can collect sub-micron particulate more efficiently.

Overall, ESPs have historically been the collection device of choice for many applications in the ICI boiler and EGU boiler sectors. High removal efficiencies are possible and the units are rugged and relatively insensitive to operating upsets. Wet ESPs offer performance characteristics for capturing $PM_{2.5}$ similar to fabric filters and are well suited for applications such as oil firing, for which fabric filters are less attractive, because the sticky ash particles produced from oil combustion can blind the bags.

4.3.3 Venturi Scrubbers

Venturi scrubbers for PM control operate on the principle of rapid mixing and impingement of PM with liquid droplets and subsequent removal with the liquid waste. For particulate controls, the venturi scrubber is an effective technology whose performance is directly related to the pressure loss across the venturi section of the scrubber. However, for higher collecting efficiencies and a wider range of particulate sizes, higher pressure drops are required. High-energy scrubbers operate at pressure losses of 50 to 70 inches of water. Higher pressure drop translates to higher energy consumption. Performance of scrubbers varies significantly across particle size range with as little as 50 percent capture for small (<2 microns) sizes to 99 percent for larger (>5 microns) sizes, on a mass basis. However, venturi scrubbers are seldom used as the primary PM collection device because of excessive pressure drop and associated energy penalties. *Figure 4-4* depicts a venturi scrubber.



Figure 4-4. Venturi scrubber [Croll Reynolds]

4.3.4 Cyclones

Cyclones are devices that separate particulates from the gas stream through inertial forces. As ash-laden gas enters the cyclone near the top, a high-velocity vortex is created inside the device. Heavy particles move outward due to centrifugal force and begin accumulating on the wall of the cyclone. Gravity continuously forces these particles to move downward where they collect in the lower, hopper region of the cyclone. The collected particles eventually discharge through an opening in the bottom of the hopper into a system that transports the particles to a storage area. Smaller and lighter particles that remain suspended in the flue gas move toward the center of the vortex before being discharged through the clean-gas outlet located near the top of the cyclone (see *Figure 4-5*).

Cyclones are comparatively simple devices in design and construction, with no moving parts. Cyclones can operate over a wide range of temperatures, which makes them attractive for smaller ICI boilers that do not have economizers and/or air preheaters (and thus higher stack temperatures than in EGU boilers). Pressure drops across cyclones are typically in the range of 2 to 8 inches of water for a single cyclone. Cyclones can be arranged in arrays (multi-cyclones) and have overall mass removal efficiencies of 70 to 90 percent with the corresponding increase in pressure drop. However, cyclone collection efficiencies are very sensitive to particle size, and control efficiency for fine particulate ($PM_{2.5}$) is poor [Licht, 1988].

Cyclones are most effective at high boiler loads, where flue gas flow rates are highest. From an operational perspective, cyclones have no moving parts, are not sensitive to fuel quality or gas temperature, and require only regular cleaning to avoid plugging. These characteristics have made them good options in the past, particularly in the absence of regulatory PM $_{2.5}$ requirements.



Figure 4-5. Schematic of a cyclone collector [www.dustcollectorexperts.com/cyclone]

Due to the limited potential for $PM_{2.5}$ capture, use of cyclones in new combustion applications is primarily limited to fluidized-bed boilers where they are used to re-circulate the bed material – and not as primary PM control devices.

4.3.5 Core Separator

The core separator is a mechanical device that operates based on aerodynamic separation (like cyclones), but also utilizes a "core separator." The separator portion of the device consists of multiple cylindrical tubes with one inlet and two outlets. One outlet allows for a clean gas stream to exit, while the other outlet is used for recirculating the concentrated stream. This recirculation stream then passes through the cyclone unit (see *Figure 4-6* [Resource Systems Group, 2001]), where it is further cleaned and returned to the separator. This sequential process enhances its overall control efficiency as compared to single or multiple cyclones.



Figure 4-6. Schematic (left) and actual (right) core separator system [EPA, 2003]

The core separator capability for PM removal falls between that of an ESP and a cyclone. Several systems are currently installed on coal- and wood-fired boilers. The core separator unit is capable of overall PM reductions of up to the 90 percent range. Its collection efficiency, however, diminishes to about 50 percent for $PM_{2.5}$. *Table 4-2* displays inlet and outlet PM concentrations and removal efficiency of a core separator at two different plants. *Table 4-3* presents estimated costs for the core separator for two different sizes and gas flow conditions.

Core Separator Inlet Loading (lb/million Btu)	Core Separator Outlet Loading (lb/million Btu)	Removal Efficiency	Boiler Type
0.17	0.07	59%	Wood Fired
0.846	0.214	75%	Stoker – Coal

Table 4-2. Core separator collection efficiency [USEPA, 2008; Resource Systems Group, 2001]

Boiler Size	MMBtu/hr	8	10
	Estimated gas temperature (°F)	500	500
	Estimated gas flow rate (acfm)	4979	5996
Core Separator Size and	Gas Flow per 12" module	660	660
Estimated Price (uninstalled)			
	Number of 12" Modules	7	9
	Estimated price	\$110,000	\$130,000
	Gas Flow per 24" Module	2640	2640
	Number of 24" Modules	1	2
	Estimated Price	\$55,000	\$83,000

Table 4-3. Core separator cost analysis [B. H. Eason to P. Amar, 2008]

4.4 Applicability of PM Control Technologies to ICI Boilers

The PM control technologies described in this section are widely available and are used in both ICI and EGU applications. Because all these PM controls are based on the collection of particulates from the flue gas, they are applicable to a variety of boiler types and ash-containing fuels, including coal, oil, wood, petroleum coke, and other waste fuels. Determining the most attractive option for individual applications is a case-by-case decision that needs to account for technical, economic, and regulatory considerations. One exception, as mentioned, is that fabric filters are not suitable for fuel oil applications due to the "stickiness" and composition of the ash.

4.5 Efficiency Impacts

PM control technologies do result in some parasitic energy loss as can be deduced from the brief descriptions of technologies above (see *Table 4-1*). The inherent energy losses associated with each technology are given below and summarized in *Table 4-4*.

- For Fabric Filters
 - o compressor (bag cleaning)
 - o flue gas pressure loss
 - electric power (heaters, ash handling)
- For ESPs
 - o transformer-rectifier (TR) power
 - o flue gas pressure loss
 - o electric power (heaters, ash handling)
- For Venturi Scrubber and Cyclone
 - o flue gas pressure loss

16	Table 4-4. Summary of energy impacts for control technologies							
Technology	Applicability	Performance (% Reduction)	Energy Impact (kW/1000 acfm)	Comments				
Fabric Filter	Coal, Wood	99+	1 – 2	Pressure loss / compressor / ash handling				
Dry ESP	Coal, Oil, Wood	99	0.5 – 1.5	Pressure loss / TR power / ash handling				
Wet ESP	Coal, Oil, Wood	99+	3 - 6	Pressure loss / TR power / ash handling				
Venturi Scrubber	Coal, Oil, Wood	70-90 (Not efficient for PM _{2.5})	5 - 11	Pressure loss				
Cyclone	Coal, Wood	70-90 (Not efficient for PM _{2.5})	0.5 – 1.5	Pressure loss				

Table 4-4. Summary of energy impacts for control technologies

4.6 PM Control Costs

The following tables summarize published PM control costs for ICI boilers reported in the literature [US EPA, 2003a; US EPA, 2003b; US EPA, 2003c; US EPA, 2003d; US EPA, 2003e; US EPA, 2003f; MACTEC, 2005]. Literature values of capital cost have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness

in dollars per ton of PM removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs. Reagents or consumables can make up a large portion of some of the operating costs, but these items do not always increase with the rate of inflation for chemical plant equipment. Thus, cost effectiveness values (or operating costs) from years before 2005 have not been reported.

Table 4-5 summarizes the published PM control costs for several different PM control technologies. In the EPA references, the capital costs were given in terms of dollars/scfm (2002 dollars). These costs were converted to dollars per MMBtu/hr using the flow rates given in Chapter Five and then converted to 2006 dollars, using the Chemical Engineering Plant Cost Index values.

The MACTEC capital costs [MACTEC, 2005] span a large range, because high and low estimates for capital equipment were used in the calculation. The EPA capital costs are much higher for the wire-pipe ESP (also known as a tubular ESP) than the wire-plate ESP. Note that a size was not given in the EPA cost estimate, so a range is shown. The capital cost comparison is similar for wet ESPs although the capital costs themselves (in dollars/MMBtu/hr) are higher for wet ESPs as compared to dry ESPs.

For fabric filters, pulse-jet and reverse-air fabric filters were considered. These types of equipment have similar collection efficiencies, but the capital costs and effectiveness of pulse-jet fabric filters are lower than that of reverse-air fabric filters.

	Table -		i oi costs ap	plica to ICI bollers			1
Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu /hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Dry ESP	90%	Coal	250	\$12 365-\$160 754	2005	\$171-\$1 300	7
Dry ESP	99%	Coal	250	\$12,365-\$160,754	2005	\$171 \$1,500 \$156-\$1 172	7
Dry ESP	90%	Oil	250	\$6 713-\$87 275	2005	\$2 584-\$21 009	7
Dry ESP	99%	Oil	250	\$6,713-\$87,275	2005	\$2,328-\$18,912	7
Dry ESP (Wire-Pipe)	2270	Coal		\$6.571-\$41.070	2002	\$ _, 0 _ 0 \$10,91 _	1
Dry ESP (Wire-Plate)	90%-99%	Coal		\$3,286-\$10,843	2002		2
Dry ESP (Wire-Pipe)		Resid.Oil		\$5,198-\$32,486	2002		1
Dry ESP (Wire-Plate)	90%-99%	Resid.Oil		\$2,599-\$8,576	2002		2
Dry ESP (Wire-Pipe)		Dist.Oil		\$5,117-\$31,983	2002		1
Dry ESP (Wire-Plate)	90%-99%	Dist.Oil		\$2,559-\$8,443	2002		2
Dry ESP (Wire-Pipe)		Wood		\$7,560-\$47,249	2002		1
Dry ESP (Wire-Plate)	90%-99%	Wood		\$3,780-\$12,474	2002		2
ESP	99.50%	Wood	Small		2005	\$594	8
ESP	99.50%	Wood	Medium		2005	\$203-\$292	8
ESP	99.50%	Wood	Large		2005	\$114-130	8
Fabric Filter	90%	Coal	250	\$7,453-\$93,158	2005	\$444-\$1,006	7
Fabric Filter	99%	Coal	250	\$7,453-\$93,158	2005	\$423-\$957	7
Pulse-Jet Fabric Filter	95%-99.9%	Coal		\$1,971-\$8,543	2002		5
Reverse-Air FF	95%-99.9%	Coal		\$3,286-\$28,585	2002		6
Fabric Filter	90%	Oil	250	\$4,046-\$50,577	2005	\$7,277-\$16,464	7
Fabric Filter	99%	Oil	250	\$4,046-\$50,577	2005	\$6,915-\$15,643	7
Pulse-Jet Fabric Filter	95%-99.9%	Resid.Oil		\$1,559-\$6,757	2002		5
Reverse-Air FF	95%-99.9%	Resid.Oil		\$2,559-\$22,260	2002		6
Pulse-Jet Fabric Filter	95%-99.9%	Dist.Oil		\$1,535-\$6,652	2002		5
Reverse-Air FF	95%-99.9%	Dist.Oil		\$2,599-\$22,610	2002		6
Fabric Filter	99.50%	Wood	Small		2005	\$958	8
Fabric Filter	99.50%	Wood	Medium		2005	\$147-249	8
Fabric Filter	99.50%	Wood	Large		2005	\$91-\$107	8
Pulse-Jet Fabric Filter	95%-99.9%	Wood		\$2,268-\$9,829	2002		5
Reverse-Air FF	95%-99.9%	Wood		\$3,780-\$32,886	2002		6

Table 4-5. PM control costs applied to ICI boilers

Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Wet ESP	90%	Coal	250	\$25,968-\$252,260	2005	\$906-\$2,627	7
Wet ESP	99.9%	Coal	250	\$25,968-\$252,260	2005	\$815-2,365	7
Wet ESP (Wire-						. ,	
Pipe)	90%-99.9%	Coal		\$13,142-\$65,712	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Coal		\$6,571-\$13,142	2002		4
Wet ESP	90%	Oil	250	\$14,098-\$136,955	2005	\$14,938-\$43,036	7
Wet ESP	99.9%	Oil	250	\$14,098-\$136,955	2005	\$13,446-\$38,736	7
Wet ESP (Wire-							
Pipe)	90%-99.9%	Resid.Oil		\$10,395-\$51,977	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Resid.Oil		\$5,198-\$10,395	2002		4
Wet ESP (Wire-							
Pipe)	90%-99.9%	Dist.Oil		\$10,235-\$51,172	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Dist.Oil		\$5,117-\$10,234	2002		4
Wet ESP (Wire-							
Pipe)	90%-99.9%	Wood		\$15,120-\$75,599	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Wood		\$7,560-\$15,120	2002		4

Table 4-5 [continued]

References

1. US EPA, Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) - Wire-Pipe Type; EPA-452/F-03-027, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fdespwpi.pdf

2. US EPA, Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) - Wire-Plate Type; EPA-452/F-03-028, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf

3. US EPA, Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) - Wire-Pipe Type; EPA-452/F-03-029, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fwespwpi.pdf

4. US EPA, Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) - Wire-Plate Type; EPA-452/F-03-030, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fwespwpl.pdf

5. US EPA, Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type; EPA-452/F-03-025, July 15, 2003.

http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf

6. US EPA, Air Pollution Control Technology Fact Sheet: Fabric Filter - Reverse-Air Cleaned Type; EPA-452/F-03-026, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ff-revar.pdf

7. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

8. STAPPA. Controlling PM2.5 Under the Clean Air Act: A Menu of Options; STAPPA/ALAPCO: March 2006.

4.7 Chapter 4 References

Caine, John, Shah, Hardik. "Next Generation Wet Electrostatic Precipitators," presented at 101st Air & Waste Management Association Annual Meeting, Portland, OR, June 24-26, 2008.

Licht, William (1988). *Air Pollution Control Engineering*, 2nd Edition. New York: Marcel Dekker.

Eason, B. "Core Separator Field Performance Data Summary 080118," personal communication to P. Amar, NESCAUM, September 2008.

MACTEC. Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

Resource Systems Group (2001). "An Evaluation of Air Pollution Control Technologies for Small Wood-Fired Boilers." Prepared for Vermont Department of Public Service, Vermont Department of Environmental Conservation (Air Pollution Control Division), New Hampshire Governor's Office of Energy Resources and Community Services, and Massachusetts Division of Energy Resources.

STAPPA. Controlling PM2.5 under the Clean Air Act: A Menu of Options; STAPPA/ALAPCO: March 2006.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) – Wire-Pipe Type; EPA-452/F-03-027, July 15, 2003a. http://www.epa.gov/ttn/catc/dir1/fdespwpi.pdf.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) – Wire-Plate Type; EPA-452/F-03-028, July 15, 2003b. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) – Wire-Pipe Type*; EPA-452/F-03-029, July 15, 2003c. http://www.epa.gov/ttn/catc/dir1/fwespwpi.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) – Wire-Plate Type*; EPA-452/F-03-030, July 15, 2003d. http://www.epa.gov/ttn/catc/dir1/fwespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003e. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter – Reverse-Air Cleaned Type*; EPA-452/F-03-026, July 15, 2003f. <u>http://www.epa.gov/ttn/catc/dir1/ff-revar.pdf</u>.

US EPA. *LSR Success Stories*; Acton, MA, December 16, 2003. http://es.epa.gov/ncer/sbir/success/pdf/lsr_success.pdf.

5 APPLICATION OF A COST MODEL TO ICI BOILERS

When evaluating the applicability of pollution control equipment to a specific ICI boiler, cost and performance capability need to be considered. A number of cost estimation models have been created for estimation of capital and operating costs of retrofit technology for air pollutants. However, most of the cost models have been developed for and applied to EGUs burning coal. Much less work has been carried out on cost estimation models for ICI boilers. In this Chapter, a cost modeling approach currently used for estimating control costs for coal-burning EGUs is modified and then investigated for its applicability to ICI boilers burning coal as well as other fuels. The purpose of this Chapter is to present this modified cost model (CUECost-ICI) and resulting cost calculations. The strengths and weaknesses of this approach are also discussed. However, the purpose of this effort is not to carry out an exhaustive calculation of costs, but to generate a set of reasonable cost estimates for ICI boilers burning different fuels and compare them with published cost information.

5.1 Cost Model Inputs and Assumptions

The Coal Utility Environmental Cost (CUECost) model was developed by Raytheon Engineers for EPA; version 3, and is available on EPA's website at <u>http://www.epa.gov/ttn/catc/products.html</u>. The model calculates capital and operating costs for certain predefined air pollution control devices for control of NOx, SO₂, and PM as applied to coal-fired power plants. The CUECost model produces approximate cost estimates (±30 percent accuracy) of the installed capital and annualized operating costs. The CUECost model was originally designed for and is intended for use on coal-fired boilers greater in size than 100 MW (about 1,000 MMBtu/hr heat input).

Table 5-1 gives the general plant inputs that are needed to set up the model; more inputs are needed for specific air pollution control devices (see Appendix B).

Input Parameter	Comment
Location - State	
	This was designed for EGUs, but can be scaled to
MW Equivalent of Flue Gas to Control System	generate the appropriate gas flow for ICIs
Net Plant Heat Rate	Function of the efficiency of the plant
Plant Capacity Factor	Use averages from EEA study, parametric variations
Percent Excess Air in Boiler	Assume 3% O_2 for NG and oil, 7% O_2 for coal, wood
	Determines the flow rate for downstream devices such as
Air Heater In-leakage	scrubbers and particulate control devices
Air Heater Outlet Gas Temperature	
Inlet Air Temperature	
Ambient Absolute Pressure	
Pressure After Air Heater	
Moisture in Air	
Ash Split:	Depends on firing system
Fly Ash	
Bottom Ash	
Seismic Zone	
Retrofit Factor	Moderate effect on total capital requirement (TCR)
(1.0 = new, 1.3 = medium, 1.6 = difficult)	
Select Fuel	User can define "coal" with respect to HHV, %S, %ash

Tabla 5 1	CUECost	gonorol	nlant	innuta
1 able 5-1.	CUECOSI	general	plant	inputs

The EPA version of CUECost contains the following modules for specific air pollution control devices:

- Limestone forced-oxidation, wet FGD scrubber
- Lime spray dryer
- FF
- ESP
- SCR
- SNCR
- LNB
- Natural Gas Reburn

CUECost bases the costs of equipment and operation on the generating capacity (in MW of electricity generated) of a given boiler. Industrial boilers are usually rated by the heat input (in MMBtu/hr); the boiler heat rate is used to convert from heat input to the equivalent size in MW. In order to use CUECost in its present form for ICI boilers, an equivalent size in MW needs to be estimated, although this could be modified in a dedicated ICI boiler version of CUECost (which was not developed in this effort).

Industrial boilers are operated differently from utility boilers, and the inputs for CUECost-ICI must be adjusted accordingly, including:

- Heat rate
- Excess air level

- Flue gas temperatures
- Capacity factor

The default values in the current version of CUECost for EGUs generally do not describe ICI boilers well. Fuel compositions vary widely for ICI boilers, while the EGU version of CUECost includes coal as the only fuel option (with different compositions). However, the user can define other fuels, as described below.

An important factor in determining total installed capital cost is the choice of appropriate retrofit factor, which expresses the difficulty of installing a control technology in an existing plant. In CUECost a retrofit factor of 1.0 denotes a new plant (corresponding to the lowest capital cost), and retrofit factors of 1.3 and 1.6 denote medium and difficult retrofits, respectively. Emmel [2006] noted that this range of retrofit factors significantly understated the cost of retrofit for FGD and SCR technologies when applied to EGUs less than 100 MW. Emmel also noted that on average a retrofit factor of 1.45 was more reasonable and that the factor should be even higher when CUECost is applied to ICI boilers.

The technology options in CUECost are also fixed, and the user cannot create a new technology option without supplying formulae for calculating the capital equipment cost. The technology options for SO_2 control in CUECost, in particular, have been noted to be more appropriate for larger utility boilers than for ICI boilers. Wet FGD and spray dryer technology – the SO_2 scrubbing options in CUECost – are based on lime or limestone reagents and have high capital and operating costs compared to alkaline scrubbers or duct injection. The latter scrubbing options might be more attractive for ICI boilers, but would have to be added to the current version of CUECost.

Finally, Emmel [2006] notes that most ICI boiler sites will have higher contingency, general facility, engineering, and maintenance costs (on a percentage of capital cost basis) than those identified for EGUs in CUECost in order to take into account necessary upgrades or demolition of existing facilities that are less likely to be needed at sites.

In this effort, the CUECost model was adapted for ICI boilers burning a variety of fuels by changing the fuel composition and heating value to simulate different fuels. Capital and operating costs in the model were based on correlations derived from coal-fired power plant experience since no reliable field data were available for the ICI boilers. It is not clear how robust the correlations for capital equipment are for small (≤ 25 MW equivalent) boilers.

The CUECost model is based on the electrical generating capacity. A combustion calculation was used to relate heat input rate to equivalent MW for five different fuels.

Table 5-2 gives the properties of these fuels. Boiler efficiency was specified, and heat rate was calculated from boiler efficiency. The uncontrolled or baseline emissions were based on fuel composition (in the case of SO_2 and PM) or on industry operating experience (in the case of NOx).

Table 5-3 shows the results (in terms of calculated flue gas flow rates) of the combustion calculations for a fixed heat input rate of 250 MMBtu/hr or 100 MMBtu/hr. Flue gas flow rate is an important parameter or input to the cost model, because the size of capital equipment is often related to the flue gas flow rate.

	Bituminous	Wood	No.2 Oil	No.6 Oil	Gas
C, wt%	76.2	27.6	86.4	85.8	75
S, wt%	2.5	0.04	0.6	2.5	0
H wt%	4.6	3.3	12.7	10.6	25
Moisture, wt%	1.4	45	0.02	0.02	0
N _, wt%	1.4	0.3	0.1	0.5	0
O, wt%	7	22.86	0.1	0.5	0
Ash, wt%	6.9	0.9	0.08	0.08	0
Fuel heating value, BTU/lb	13,630	4,633	19,563	18,273	20,800
Unburned carbon, wt% in ash	5	1	75	75	0
Boiler efficiency*	34%	30%	39%	39%	45%
Stack O ₂ , vol% dry	7%	7%	3%	3%	3%
Boiler heat rate, Btu/kWh	10,000	11,370	8,750	8,750	7,600
Uncontrolled or Baseline					
emissions					
NOx, lb NO ₂ /MMBtu	0.60	0.26	0.20	0.40	0.40
SO ₂ , lb/MMBtu	3.67	0.17	0.61	2.74	0.00
PM, lb/MMBtu	5.06	1.94	0.04	0.04	0.00

Table 5-2. Fuel characteristics and assumptions for CUECost calculation of heat rate and flue gas flow rates

*Fuel to MW

Table 5-3.	Equivalent	heat input ra	te and flue gas	flow rates t	for 250 and	100 MMBtu/hr	· heat input rates
I dole e et	Equivalence	neue mpue ru	te una mae gus	no n naves i	tor aco una		near mpar races

	MW	MMBtu/hr	Flue gas, scfm
Bituminous coal (34% efficiency, 7% O_2)	25.0	250	65,305
Wood (30% efficiency, 7% O ₂)	22.0	250	81,184
No.2 oil (39% efficiency, 3% O ₂)	28.6	250	50,622
No.6 oil (39% efficiency, 3% O_2)	28.6	250	51,117
Natural gas (45% efficiency, 3% O ₂)	32.9	250	59,336
Bituminous coal (34% efficiency, 7% O ₂)	10.0	100	26,122
Wood (30% efficiency, 7% O ₂)	8.8	100	32,474
No.2 oil (39% efficiency, 3% O ₂)	11.4	100	20,178
No.6 oil (39% efficiency, 3% O ₂)	11.4	100	20,375
Natural gas (45% efficiency, 3% O ₂)	13.2	100	23,806

5.2 Comparison of the Cost Model Results with Literature

A comparison was made of the CUECost-ICI model with other published information for a selection of fuels and air pollution control devices applied to ICI boilers. Where possible, the inputs for the model were set to be the same as information cited in the literature.

Using the appropriate fuel composition and boiler heat rates, the modified ICI version of the original CUECost (CUECost-ICI) model was run for a number of ICI boiler cases. *Table 5-4*, *Table 5-5*, and *Table 5-6* show the installed capital costs, first-year annual operating costs, and cost per ton of pollutant removed for NOx, SO₂, and PM, respectively. Capital and operating costs were calculated on 2006 dollars basis in the CUECost-ICI model. A complete

list of inputs to CUECost-ICI is included in Appendix B. For the NOx and SO_2 control technologies, percentage reduction of the pollutant was used as an input, so that the CUECost-ICI results could be easily compared to published literature results. For PM controls, a specific emission limit (in lb/MMBtu) was used as an input and the percentage PM reduction was calculated from the fuel ash content.

	Pollutant				Installed		
	removal			-	Capital	Annual	~ /
MMBtu/hr	efficiency	Fuel	Technology	Reagent	Cost, \$M	Cost, \$M	Cost/ton
250	80.0%	Coal	SCR	Ammonia	\$4.394	\$1.253	\$4,763
100	80.0%	Coal	SCR	Ammonia	\$2.585	\$0.702	\$6,668
250	80.0%	No.6 Oil	SCR	Ammonia	\$2.923	\$0.790	\$3,972
100	80.0%	No.6 Oil	SCR	Ammonia	\$1.760	\$0.460	\$5,805
250	80.0%	Nat.Gas	SCR	Ammonia	\$3.005	\$0.811	\$4,673
100	80.0%	Nat.Gas	SCR	Ammonia	\$1.805	\$0.472	\$6,777
250	50.0%	Coal	SNCR	Ammonia	\$1.142	\$0.398	\$2,422
100	50.0%	Coal	SNCR	Ammonia	\$0.969	\$0.317	\$4,817
250	50.0%	No.6 Oil	SNCR	Ammonia	\$0.724	\$0.338	\$2,722
100	50.0%	No.6 Oil	SNCR	Ammonia	\$0.407	\$0.196	\$3,961
250	50.0%	Nat.Gas	SNCR	Ammonia	\$0.785	\$0.362	\$3,335
100	50.0%	Nat.Gas	SNCR	Ammonia	\$0.443	\$0.209	\$4,798
250	40.0%	Coal	LNB		\$1.227	\$0.301	\$2,290
100	40.0%	Coal	LNB		\$0.677	\$0.166	\$3,155
250	40.0%	No.6 Oil	LNB		\$1.339	\$0.329	\$3,305
100	40.0%	No.6 Oil	LNB		\$0.737	\$0.181	\$4,559
250	40.0%	Nat.Gas	LNB		\$1.467	\$0.360	\$4,151
100	40.0%	Nat.Gas	LNB		\$0.810	\$0.199	\$5,715

 Table 5-4. Capital and operating costs for NOx control technologies (assuming 7.5 percent interest and 15-year project life)

							Cost
	Pollutant				Installed		Effectiveness
	removal				Capital	Annual	(dollars per
MMBtu/hr	efficiency	Fuel	Technology	Reagent	Cost, \$M	Cost, \$M	ton)
250	95%	Coal	wFGD	Limestone	\$38.096	\$11.137	\$4,427
100	95%	Coal	wFGD	Limestone	\$33.680	\$9.608	\$9,547
250	95%	No.6 Oil	wFGD	Limestone	\$36.642	\$10.733	\$5,713
100	95%	No.6 Oil	wFGD	Limestone	\$32.805	\$9.368	\$12,510
250	90%	Coal	SD	Lime	\$29.598	\$8.806	\$3,694
100	90%	Coal	SD	Lime	\$26.263	\$7.540	\$7,909
250	90%	No.6 Oil	SD	Lime	\$28.463	\$8.371	\$4,704
100	90%	No.6 Oil	SD	Lime	\$25.723	\$7.344	\$10,352

Table 5-5. Capital and operating costs for SO₂ control technologies (assuming 7.5 percent interest and 15-year project life)

 Table 5-6. Capital and operating costs for PM control technologies (assuming 7.5 percent interest and 15-year project life)

									Cost
									Effective
	Pollutant			PM	Installed	Capital	Capital	Annua	ness (
	removal			Emission,	Capital	cost,	cost,	l Cost,	dollars
MMBtu/hr	efficiency	Fuel	Technology	lb/MMBtu	Cost, \$M	\$/scfm	\$/acfm	\$M	per ton)
250	99.3%	Coal	ESP	0.03	\$4.05	\$62.00	\$43.00	\$1.11	\$342
100	99.3%	Coal	ESP	0.03	\$2.31	\$88.50	\$61.50	\$0.63	\$485
250	99.3%	Coal	FF	0.03	\$4.77	\$73.00	\$50.70	\$1.32	\$406
100	99.3%	Coal	FF	0.03	\$2.88	\$110.20	\$76.60	\$0.78	\$592
250	95.8%	No.6 Oil	ESP	0.01	\$3.40	\$66.60	\$46.30	\$0.93	\$5,689
100	95.8%	No.6 Oil	ESP	0.01	\$2.02	\$99.00	\$68.80	\$0.55	\$8,410
250	95.8%	No.6 Oil	FF	0.01	\$4.09	\$80.00	\$55.60	\$1.14	\$6,940
100	95.8%	No.6 Oil	FF	0.01	\$2.50	\$122.80	\$85.30	\$0.68	\$10,354

For comparison, the American Forest & Paper Association (AF&PA) calculated SNCR control costs in 2006 for wood-fired boilers ranging in size from 88 to 265 MMBtu/hr [Hunt, 2006]. *Table 5-7* below compares the AF&PA costs with the CUECost-ICI costs for wood-fired boilers. The installed capital cost values agree well between CUECost-ICI and the AF&PA estimates, although the CUECost-ICI values for cost effectiveness (dollars per ton of NOx removed) are 20 to 25 percent lower than the AF&PA estimates.

MMBtu/hr	Pollutant removal efficiency	Fuel	Technology	Reagent	Installed Capital Cost, \$M	Annual Cost, \$M	Cost, \$/ton
AF&PA							
88.5	70.0%	Wood	SNCR	Urea	\$0.924	\$0.250	\$11,283
176.9	70.0%	Wood	SNCR	Urea	\$1.400	\$0.384	\$8,574
285.4	70.0%	Wood	SNCR	Urea	\$1.786	\$0.502	\$7,480
CUECost							
88.5	70.0%	Wood	SNCR	Urea	\$0.923	\$0.289	\$9,239
176.9	70.0%	Wood	SNCR	Urea	\$1.025	\$0.324	\$5,174
285.4	70.0%	Wood	SNCR	Urea	\$1.130	\$0.361	\$5,011

Table 5-7.	Capital and operating costs for SNCR on wood-fired boilers, comparison of cost calculations from
AF&PA and	nd CUECost

Finally, the CUECost-ICI model results for capital cost were compared with some of the values reported in the literature [US EPA, 1996; NESCAUM, 2000; US EPA, 2003a; US EPA, 2003b; Whiteman, 2006], where available. Literature values of capital costs have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using Chemical Engineering Plant Cost Index values.

The NOx capital costs computed with CUECost-ICI were largely consistent with the literature values. (Chapter Two contains a detailed discussion of the literature values for NOx control costs.)

Figure 5-1 compares capital costs for SCR for boilers burning coal, residual (No. 6) oil, and natural gas. The SCR costs appear to be consistent with the literature values. The literature value for SCR as reported by the Ozone Transport Assessment Group (OTAG) [US EPA, 1996] did not describe its basis in any detail, so it is difficult to determine if the OTAG cost estimates assumed a significantly different space velocity or different equipment than assumed in the CUECost-ICI model.



Figure 5-1. Comparison of CUECost-ICI model and reported literature values for capital cost of SCR for NOx control

The capital costs for SNCR (*Figure 5-2*) calculated from the CUECost-ICI model are in good agreement with literature values, particularly the sensitivity of capital cost to boiler capacity, which was also noted by ICAC [Whiteman, 2006].

The capital costs for LNB (*Figure 5-3*) calculated from the CUECost-ICI model for coalfired boilers were consistent with the literature values, although the capital costs for residual oilfired boilers were higher in the CUECost-ICI model than the literature values. Again, no details were provided in the literature references.



Figure 5-2. Comparison of CUECost-ICI model and reported literature values for capital cost of SNCR for NOx control





5-9 Appendix III.D.7.7-4176 Chapter Three contains a detailed discussion of the literature values for SO_2 control costs. The SO_2 capital costs computed with CUECost-ICI for spray dryers (SDs) were in the range of the literature values at boiler size of 250 MMBtu/hr (*Figure 5-4*). No literature data were available for residual oil-fired boilers and spray dryers. However, the capital costs calculated by CUECost –ICI for wet FGDs (*Figure 5-5*) were high when compared to the literature values.



Figure 5-4. Comparison of CUECost-ICI model and reported literature values for capital cost of Spray Dryer for SO₂ control



Figure 5-5. Comparison of CUECost-ICI model and reported literature values for capital cost of wet FGD for SO₂ control

Literature values for capital costs for PM control were evaluated from EPA reports on PM controls applied to ICI boilers [US EPA, 2003a; US EPA, 2003b]. In these references, the capital costs were given in terms of dollars/scfm (2002\$). These costs were converted to dollars per MMBtu/hr using the flow rates in *Table 5-3* and then converted to 2006 dollars, using the Chemical Engineering Plant Cost Index values. Chapter Four contains a detailed discussion of the literature values for PM control costs.

The dry ESP control costs computed with CUECost-ICI were consistent with the literature values, although the CUECost-ICI predicted slightly higher values than reported by EPA for dry, wire-plate ESPs [US EPA, 2003a]. Note that a size was not given in the EPA cost-estimate. The FF costs computed with CUECost-ICI were higher than the literature values for pulse-jet fabric filters [US EPA 2003b].

5.3 Summary

An existing EPA model for estimating costs of selected control technology for NOx, SO₂, and PM for coal-fired EGU boilers greater than 1,000 MMBtu/hr was adapted for ICI boilers. Inputs were modified to allow a wider variety of fuels and to express boiler capacity in MMBtu/hr instead of MW. Modification of the correlations used for the coal-fired EGU model to calculate capital and operating costs for ICI boilers was outside the scope of this work. The new model, CUECost-ICI provided good agreement with published values of capital cost of APCD equipment for small boiler sizes for coal-, oil- and natural gas-fueled boilers. The resulting model provided a quick and flexible means to estimate capital and operating costs of

specific control technologies as applied to ICI boilers. Further detailed and extensive work will be needed to validate and refine the model's calculation framework for ICI boilers, and to add other APCD technologies to the model.

5.4 Chapter 5 References

Emmel, Thomas. RTP Environmental Associates, "Use of CUECost Model for Developing Cost Estimates for Industrial Size Boilers," memorandum to Pat Dennis, Archer Daniels Midland Company, Robert Bessett, Council of Industrial Boiler Owners, March 22, 2006.

Hunt, T. American Forest & Paper Association, "AF&PA Comments on Draft NOx Model Rule and Related 6.7.06 OTC Resolution," letter to Christopher Recchia, Executive Director, Ozone Transport Commission, November 1, 2006.

MACTEC. *Boiler Best Available Retrofit Technology (BART) Engineering Analysis*; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness (Praveen Amar, Project Director), December 2000.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) -Wire-Plate Type; EPA-452/F-03-028, July 15, 2003a. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003b. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

US EPA. *OTAG Technical Supporting Document*, Chapter 5, Appendix C, 1996. <u>http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/</u>.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003b. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

Whiteman, C. ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.
6 SUMMARY

ICI boilers are a significant source of NO_x , SO_2 , and PM emissions, and are relatively uncontrolled, compared to EGUs. More than half of the surveyed ICI boilers in the Northeast have no controls, approximately one-third have PM controls, very few units have NOx controls, and no units have SO_2 controls.

There are a range of technology options for cost-effectively reducing emissions of NOx, SO₂, and PM emissions from ICI boilers in the U.S. Operating costs may differ for ICI boilers than utility boilers, primarily because of their size and location. ICI boiler sites typically have higher contingency, general facility, engineering, and maintenance costs as a percentage of total capital cost than do utility boilers. While ICI boilers often have cost constraints due to their sizes and diversity of plant layout and settings, these factors also provide opportunities for low-cost applications. It is critical to conduct site-specific suitability analyses to assess performance potential or retrofit feasibility, and match the appropriate emission control technology for specific applications given boiler size, fuel type/quality, duty-cycle, and design characteristics.

This study adapted the CUECost model -- initially developed by EPA to estimate costs of selected control technology for NOx, SO₂, and PM for large coal-fired EGU boilers -- to assess ICI boiler control costs. The modeling results were consistent with published values of capital cost of APCD equipment for small boiler sizes for coal-, oil- and natural gas-fueled boilers.

6.1 NOx Controls

Most of the commercially available NOx control technologies used extensively in EGUs may also apply to ICI boilers. Some technologies have potential to capture mercury from the flue gas. Employing a combination of technologies can be more effective in reducing emissions than a stand-alone technology. While most of these technologies can be used together, some combinations may be more cost-effective. This should be assessed on a site- and strategy-specific basis. Options include:

- Boiler Tuning or Optimization, which can yield reductions of five to 15 percent or more;
- *Low-NOx Burner (LNB) and Overfire Air (OFA)*, which can be used separately or as a system, and can reduce NOx emissions by 40 to 60 percent. LNBs are applicable to most ICI boiler types, and are being increasingly used at ICI boilers less than 10 MMBtu/hr. These technologies require site-specific suitability analyses, as several important parameters can have substantial impact on their performance or even retrofit feasibility.
- *Ultra Low-NOx Burners (ULNB)*, which can achieve NOx emission levels on the order of single digits in ppm.
- *Reburn*, which has been used only in large EGU applications, but is an option for larger watertube-type boilers, including stokers. It requires appropriate technical and economic analyses to determine suitability. Reburn may yield 35 to 60 percent reductions in NOx emissions.
- *Selective Catalytic Reduction (SCR)*, which can achieve reductions higher than 90 percent.

- *Selective Non-Catalytic Reduction (SNCR)*, which can achieve between a 30 to 60 percent reduction in NOx.
- *Regenerative Selective Catalytic Reduction (RSCRTM)*, which is able to reduce NOx by 60 to 75 percent and CO by about 50 percent. These systems allow efficient use of an SCR downstream of a particulate control device, where the flue gas typically has a lower temperature than what is required for a conventional SCR. Such conditions are encountered in some ICI boilers firing a variety of fuels, including biomass.

NOx control technologies involving combustion modification have essentially no impact on the CO₂ emissions of the host boilers, with the exception of reburn. SNCR and SCR impose some degree of energy demand on the host boiler, including pressure, compressor, vaporization, and steam losses.

Most estimates for ICI boilers indicate capital costs in the range of \$1,000 to \$6,000 per MMBtu/hr and \$1,000 to \$7,000 per ton of NOx removed. LNBs and SNCR costs range from \$1,000 to \$3,000 per ton. For SCR, costs are between \$2,000 and \$14,000 per ton. SCR and SNCR costs are driven primarily by the consumption of the chemical reagent.

6.2 SO₂ Controls

ICI boilers firing coal are good candidates for employing SO_2 control technologies. Options include:

- Flue Gas Desulfurization (FGD) or Scrubbers. These technologies are commercially • available, and have been used extensively on EGUs since the 1970s. Wet scrubbers (Wet FGD) are the predominant SO_2 control technology currently in use for EGUs, and are typically associated with high-sulfur applications. Dry scrubbers include Spray Dryers (SD) and Dry Sorbent Injection (DSI) technologies, and are more compatible with lowto medium-sulfur coals. Some dry scrubber systems can remove 20 to 60 percent of the SO₂, and in some cases up to 90 to 99 percent for HCl and SO₃. DSI technologies are currently being demonstrated on ICI boilers. Furnace Sorbent Injection systems used on cement plants are capable of SO₂ reductions of up to 90 percent for industrial applications and ICI boilers, as well as HCl and HF reductions of greater than 95 percent. For SDs, cost per ton of SO₂ removed was in the range of \$1,600 to \$5,000. Costs were between \$1,900 and \$3,800 per ton of SO₂ for wet FGDs. While the SO₂ capital costs computed with CUECost for SDs were consistent with the literature at 250 MMBtu/hr, the capital costs computed for wet FGDs were high compared to values reported in the literature.
- *Fuel switching*. While not a control technology *per se*, the emission reduction benefits of fuel switching are directly proportional to the difference in sulfur contents of the fuels. Fuel switching requires considerable cost and operational analyses. In the NESCAUM region, residual oil is commonly used in ICI boilers. Switching from a 3 to a 1 percent sulfur residual oil can provide cost-effective SO₂ reductions at about \$771 per ton of SO₂ removed. For oil-fired ICI boilers, switching to lower-sulfur oil can provide significant reductions in emissions of SO₂, as well as in PM_{2.5}. The cost of switching to distillate oil is estimated to be much higher than for residual oil, because the higher cost of distillate oil.

6.3 PM Controls

ICI boilers burn a variety of fuels that contain fly ash and thus emit PM. PM control technologies have been commercially available and widely used in EGU boilers for many years. While PM controls are not currently widely used on ICI boilers, there are no technical reasons why PM controls cannot be applied to solid-fueled and oil-fired boilers. They are very effective in removing total PM and $PM_{2.5}$, with most options removing greater than 99 percent. The options include: (1) fabric filters or baghouses; (2) wet and dry electrostatic precipitators (ESPs); (3) venturi scrubbers; (4) cyclones; and (5) core separators. Control technology decisions should be made on a case-by-case basis that accounts for technical, economic, and regulatory considerations. Fabric filters are not suitable for fuel oil applications due to the "stickiness" and composition of the ash. The cost effectiveness of baghouses was in the range of \$50 to \$1,000 per ton of PM removed for coal and up to \$15,000 per ton of PM removed for oil. The cost effectiveness of ESPs was in the range of \$50 to \$500 per ton of PM for coal, and up to \$20,000 per ton of PM for oil. PM control technologies will result in some parasitic energy loss due to pressure loss, power consumption, and ash handling. Dry ESPs and fabric filters have the lowest associated parasitic power consumption (<2 kW/1000 acfm), while high-energy venturi scrubbers can have a larger parasitic consumption – up to 10 kW/1000 acfm or higher.

APPENDIX A: Survey of Title V Permits in NESCAUM Region

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,N	IJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Solutia Incorporated	MA	Foster Wheeler	249	Coal (Bit. 0.7%S)	-	0.027	baghouse (Carborundum Environmental Systems)	1.2	-	0.525	OFA (Foster wheeler)	-
St. Gobain Abrasives	MA	Riley	230	Coal (Subbit. 0.63%S)	-	0.1	Dust Collector	1.1	-	0.45	LNB	-
UMASS Amherst	МА	Union Iron Works	80	Coal	-	0.12	baghouse	1.1	-	0.43	-	Convert to CHP No. 2 (9/07)
Cooley Dickinson Hospital	МА	Early 1980s	-	Wood	-	-	-	0.008	-	0.16	-	-
Cooley Dickinson Hospital	MA	2006/ AFS Energy Systems	29.88	Wood	-	0.01	Cyclone, Baghouse	0.025	-	0.15	FGR	-
Seaman Paper	МА	2006/ Hurst Boiler	29.88	Wood	-	0.01	Baghouse	0.025	-	0.15	FGR	-

ICI Coal and W	ood Fire	d in NESCAUM	Region (CT,M	A,ME,NH,N	J,NY,RI,VT)	F	M	s	02	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Cornell University	NY	-	248	Coal	-	0.3	Fabric Filter	Coal 1% S by weight	-	0.4	-	
Cornell University	NY	-	117	Coal	-	0.35	Fabric Filter	Coal 1% S by weight	-	0.4	-	-
Commonwealth Plywood	NY	-	16	Wood	-	-	Multi- Cyclone w/o Fly ash injection	-	-	-	-	-
Crawford Furniture	NY	-	6	Wood	-	-	Single Cyclone	-	-	-	-	-
Deferiet Paper Company	NY	1945/ Combustion Engineering	190	Coal	-	0.46	Multi- Cyclone w/o Fly ash injection, and wet Venturi scrubber	2.5	-	0.5	-	-
Eastman Kodak	NY	-	265	Coal (Bit.)	-	0.26	ESP	2.5 (coal)	-	0.53	-	Boiler # 13

ICI Coal and	l Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	- M	S	O ₂	N	Ox	l. I
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Eastman Kodak	NY	-	265	Coal (Bit.)	-	0.26	ESP	2.5 (coal)	-	0.53	-	Boiler # 14
Eastman Kodak	NY	-	478	Coal (Bit.)	#2 Oil	0.26	ESP	-	-	-	-	Boiler # 15
Eastman Kodak	NY	-	500	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 41
Eastman Kodak	NY	-	500	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 42
Eastman Kodak	NY	-	640	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 43
Eastman Kodak	NY	-	705	Coal (Bit.)	#2 Oil	0.035	ESP	.6 (coal)	-	0.42	-	Boiler # 44

ICI Coal and	Wood Fi	red in NESC/	AUM Region (C	ſ,MA,ME,NH,	NJ,NY,RI,VT)	F	PM	s	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Gunlocke Co.	NY	E. Keeler	18	Wood	Oil #2	0.53	Fly Ash Cyclone	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	14.6	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	41.54	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	27.6	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Lyonsdale Biomass	NY	Zurn	290	Wood	-	0.1	-	-	-	0.2	-	
Morton International	NY	-	138	Coal	-	0.34	Fabric Filter, ESP	1.7	-	0.5	-	

ICI Coal	and Woo	d Fired in NES	CAUM Region	(CT,MA,ME,NH,NJ,N	IY,RI,VT)	F	PM	S	D ₂	N	Ox	l l
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
SUNY at Binghamton	NY	International Boiler Works	100	Coal	Coal/Wood Mix	0.6	Multi- Cyclone w/o Fly ash injection	1.7	-	-	-	Х3
SUNY at Binghamton	NY	International Boiler Works	50	Coal	Coal/Wood Mix	0.6	Multi- Cyclone w/o Fly ash injection	1.7	-	-	-	
US Salt - Watkins Glen Refinery	NY	2000?	160	Coal and/or Wood	NG and/or Coal, Wood	0.051	Fabric Filter	1.2	-	0.18	SNCR	
Dirigo Paper	VT	1977	180	Wood	-	0.20 gr/dscf	multiclone	-	-	0.3	none	-
Ethan Allen	VT	1950	59.5	Wood	-	0.45 gr/dscf	multiclone	-	-	1.94lb/ton wet wood 7.45lb/ton dry wood	none	-
Fraser	NH	1981, Zurn	324	Wood/Bark/Paper	# 6 Oil	0.1	Multi-cyclone + Venturi scrubber	0.8	-	0.25	-	

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Tillotson Rubber	NH	1978	41	Wood	-	0.43	Multi-cyclone	-	-	-	-	
Allen Rogers Limited	NH		5	Wood								
Allen Rogers Limited	NH		5	Wood								
Forest Products Processing Center	NH		47	Wood								
Madison Lumber Mill	NH		13	Wood								
Chick Packaging	NH		10	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	s	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Ossipee Mountain Land Company	NH		4	Wood								
Ossipee Mountain Land Company	NH		4	Wood								
Tommila Brothers	NH		11	Wood								
Monadnock Forest Products	NH		30	Wood								
Whitney Brothers Company	NH		2	Wood								
HG Wood Industries	NH		9	Wood								

ICI Coal and W	ood Fire	d in NESCA	UM Region (CT	,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Design Contempo	NH		19	Wood								
Design Contempo	NH		13	Wood								
Solon Manufacturing	NH		9	Wood								
Rochester Shoe Tree/Ashland	NH		4	Wood								
Precision Lumber	NH		9	Wood								
King Forest Industries - Wentworth	NH		29	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	M	S	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Peterboro Basket Company	NH		3	Wood								
Souhegan Wood Products	NH		8	Wood								
Souhegan Wood Products	NH		1	Wood								
Souhegan Wood Products	NH		1	Wood								
Concord Steam Corporation	NH		40	Wood								
Concord Steam Corporation	NH		40	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	s	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Boyce Highlands	NH		4	Wood								
Herrick Millwork	NH		5	Wood								
Northland Forest Products	NH		5	Wood								
Anthony Galluzzo Corporation	NH		4	Wood								
Cousineau Wood Products	NH		14	Wood								
Newport Mills Inc	NH		6	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Newport Mills Inc	NH		6	Wood								
Catamount Pellet Corporation	NH		40	Wood								
Durgin & Crowell Lumber Company	NH		10	Wood								
GH Evarts & Company	NH		7	Wood								
References:	State Title	V Permits, C	oal SO ₂ Databas	se, ICI Coal Da	atabase, MA IC	I 100-250 Boiler	Database, VT IC	I Boiler Databas	e	<u>.</u>		

APPENDIX B: CUECost-ICI Inputs

INPUTS

Description	Units	Input 1	Input 2	Input 3	Input 4	Input 5
<u>^</u>		•	•	•	•	•
General Plant Technical Inputs						
Location - State	Abbrev.	PA	PA	PA	PA	PA
Combustion Configuration	Abbrev.	PC	PC	PC	PC	PC
MW Equivalent of Flue Gas to Control System	MW	25	25.1	28.6	28.6	32.9
Net Plant Heat Rate	Btu/kWhr	10,000	11,370	8,750	8,750	7,600
Plant Capacity Factor	%	66%	66%	66%	66%	66%
Total Air Downstream of Economizer	%	154%	169%	118%	118%	119%
Air Heater Leakage	%	12%	12%	12%	12%	12%
Air Heater Outlet Gas Temperature	°F	350	350	350	350	350
Inlet Air Temperature	°F	80	80	80	80	80
Ambient Absolute Pressure	In. of Hg	29.4	29.4	29.4	29.4	29.4
Pressure After Air Heater	In. of H2O	-12	-12	-12	-12	-12
Moisture in Air	lb/lb dry air	0.013	0.013	0.013	0.013	0.013
Ash Split:						
Fly Ash	%	85%	85%	85%	85%	85%
Bottom Ash	%	15%	15%	15%	15%	15%
Seismic Zone	Integer	1.0	1.0	1.0	1.0	1.0
Retrofit Factor	Integer	1.0	1.0	1.0	1.0	1.0
(1.0 = new, 1.3 = medium, 1.6 = difficult)						
Select Coal	Integer	2	3	4	5	6
s Selected Coal a Powder River Basin Coal?	Yes / No	No	No	No	No	No
Economic Inputs						
Cost Basis - Year Dollars	Year	2006	2006	2006	2006	2006
Service Life (levelization period)	Years	15	15	15	15	15
Inflation Rate	%	3%	3%	3%	3%	3%
After Tax Discount Rate (current \$'s)	%	8%	8%	8%	8%	8%
AFDC Rate (current \$'s)	%	8%	8%	8%	8%	8%
First-year Carrying Charge (current \$'s)	%	22%	22%	22%	22%	22%
Levelized Carrying Charge (current \$'s)	%	17%	17%	17%	17%	17%
First-year Carrying Charge (constant \$'s)	%	16%	16%	16%	16%	16%
Levelized Carrying Charge (constant \$'s)	%	12%	12%	12%	12%	12%
Sales Tax	%	6%	6%	6%	6%	6%
Escalation Rates:						
Consumables (O&M)	%	3%	3%	3%	3%	3%
Capital Costs:						
Is Chem. Eng. Cost Index available? If "Yes" input cost basis CE Plant	Yes / No	Yes	Yes	Yes	Yes	Yes
ndex.	Integer	478.7	478.7	478.7	478.7	478.7
If "No" input escalation rate.	%	3%	3%	3%	3%	3%
Construction Labor Rate	\$/hr	\$35	\$35	\$35	\$35	\$35
Prime Contractor's Markup	%	3%	3%	3%	3%	3%

Operating Labor Rate	\$/hr	\$25	\$25	\$25	\$25	\$25
Power Cost	Mills/kWh	47	47	47	47	47
Steam Cost	\$/1000 lbs	3.5	3.5	3.5	3.5	3.5
Limestone Forced Oxidation (LSFO) Inputs						
SO ₂ Removal Required	%	95%	95%	95%	95%	95%
L/G Ratio	gal / 1000 acf	125	125	125	125	125
Design Scrubber with Dibasic Acid Addition?	Integer	2	2	2	2	2
(1 = yes, 2 = no)						
Adiabatic Saturation Temperature	°F	127	127	127	127	127
Reagent Feed Ratio	Factor	1.05	1.05	1.05	1.05	1.05
(Mole CaCO3 / Mole SO ₂ removed)						
Scrubber Slurry Solids Concentration	Wt. %	15%	15%	15%	15%	15%
Stacking, Landfill, Wallboard	Integer	1	1	1	1	1
(1 = stacking, 2 = landfill, 3 = wallboard)						
Number of Absorbers	Integer	1	1	1	1	1
(Max. Capacity = 700 MW per absorber)						
Absorber Material	Integer	1	1	1	1	1
(1 = alloy, 2 = RLCS)						
Absorber Pressure Drop	in. H2O	6	6	6	6	6
Reheat Required ?	Integer	1	1	1	1	1
(1 = yes, 2 = no)						
Amount of Reheat	°F	25	25	25	25	25
Reagent Bulk Storage	Days	60	60	60	60	60
Reagent Cost (delivered)	\$/ton	\$15	\$15	\$15	\$15	\$15
Landfill Disposal Cost	\$/ton	\$25	\$25	\$25	\$25	\$25
Stacking Disposal Cost	\$/ton	\$6	\$6	\$6	\$6	\$6
Credit for Gypsum Byproduct	\$/ton	\$2	\$2	\$2	\$2	\$2
Maintenance Factors by Area (% of Installed Co	st)					
Reagent Feed	%	5%	5%	5%	5%	5%
SO ₂ Removal	%	5%	5%	5%	5%	5%
Flue Gas Handling	%	5%	5%	5%	5%	5%
Waste / Byproduct	%	5%	5%	5%	5%	5%
Support Equipment	%	5%	5%	5%	5%	5%
Contingency by Area (% of Installed Cost)						
Reagent Feed	%	20%	20%	20%	20%	20%
SO ₂ Removal	%	20%	20%	20%	20%	20%
Flue Gas Handling	%	20%	20%	20%	20%	20%
Waste / Byproduct	%	20%	20%	20%	20%	20%
Support Equipment	%	20%	20%	20%	20%	20%
General Facilities by Area (% of Installed Cost)						
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Engineering Fees by Area (% of Installed Cost)						
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%

Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Lime Spray Dryer (LSD) Inputs						
SO ₂ Removal Required	%	90%	90%	90%	90%	90%
Adiabatic Saturation Temperature	°F	127	127	127	127	127
Flue Gas Approach to Saturation	°F	20	20	20	20	20
Spray Dryer Outlet Temperature	°F	147	147	147	147	147
Reagent Feed Ratio	Factor	0.90	0.90	0.90	0.90	0.90
(Mole CaO / Mole Inlet SO ₂)						
Recycle Rate	Factor	30	30	30	30	30
(lb recycle / lb lime feed)						
Recycle Slurry Solids Concentration	Wt. %	35%	35%	35%	35%	35%
Number of Absorbers	Integer	2	2	2	2	2
(Max. Capacity = 300 MW per spray drye	r)					
Absorber Material	Integer	1	1	1	1	1
(1 = alloy, 2 = RLCS)						
Spray Dryer Pressure Drop	in. H2O	5	5	5	5	5
Reagent Bulk Storage	Days	60	60	60	60	60
Reagent Cost (delivered)	\$/ton	\$60	\$60	\$60	\$60	\$60
Dry Waste Disposal Cost	\$/ton	\$25	\$25	\$25	\$25	\$25
Maintenance Factors by Area (% of Installed	Cost)					
Reagent Feed	%	5%	5%	5%	5%	5%
SO ₂ Removal	%	5%	5%	5%	5%	5%
Flue Gas Handling	%	5%	5%	5%	5%	5%
Waste / Byproduct	%	5%	5%	5%	5%	5%
Support Equipment	%	5%	5%	5%	5%	5%
Contingency by Area (% of Installed Cost)						
Reagent Feed	%	20%	20%	20%	20%	20%
SO ₂ Removal	%	20%	20%	20%	20%	20%
Flue Gas Handling	%	20%	20%	20%	20%	20%
Waste / Byproduct	%	20%	20%	20%	20%	20%
Support Equipment	%	20%	20%	20%	20%	20%
General Facilities by Area (% of Installed Cos	it)					
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Engineering Fees by Area (% of Installed Cos	t)					
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%

Particulate Control Inputs

Number of Air Preheaters

Outlet Particulate Emission Limit	lbs/MMBtu	0.03	0.03	0.01	0.01	0
Fabric Filter:						
Pressure Drop	in. H2O	6	6	6	6	6
Type (1 = Reverse Gas, 2 = Pulse Jet)	Integer	2	2	2	2	2
Gas-to-Cloth Ratio	acfm/ft ²	5.5	5.5	5.5	5.5	5.5
Bag Material (RGFF fiberglass only)	Integer	1	1	1	1	1
(1 = Fiberglass, 2 = Nomex, 3 = Ryton)						
Bag Diameter	inches	6	6	6	6	6
Bag Length	feet	20	20	20	20	20
Bag Reach		3	3	3	3	3
Compartments Out of Service	%	10%	10%	10%	10%	10%
Bag Life	Years	2	2	2	2	2
Maintenance (% of installed cost)	%	5%	5%	5%	5%	5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	10%	10%	10%	10%	10%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
ESP:						
Strength of the electric field in the $ESP = E$	kV/cm	10.0	10.0	10.0	10.0	10.0
Plate Spacing	in.	12	12	12	12	12
Plate Height	ft.	36	36	36	36	36
Pressure Drop	in. H2O	3	3	3	3	3
Maintenance (% of installed cost)	%	5%	5%	5%	5%	5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	10%	10%	10%	10%	10%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
NOx Control Inputs						
Selective Catalytic Reduction (SCR) Inputs						
NH3/NOx Stoichiometric Ratio	NH3/NOx	0.9	0.9	0.9	0.9	0.9
NOx Reduction Efficiency	Fraction	0.70	0.70	0.70	0.70	0.70
Inlet NOx	lbs/MMBtu	0.6	0.26	0.2	0.4	0.4
Space Velocity (Calculated if zero)	1/hr	3000	3000	11800	11800	16800
Overall Catalyst Life	years	4	4	4	4	4
Ammonia Cost	\$/ton	411.17	411.17	411.17	411.17	411.17
Catalyst Cost	\$/ft3	356.34	356.34	356.34	356.34	356.34
Solid Waste Disposal Cost	\$/ton	25.38	25.38	25.38	25.38	25.38
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	5%	5%	5%	5%	5%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
Number of Reactors	integer	1	1	1	1	1

1

integer

1

1

1

1

Adopted

Selective NonCatalytic Reduction (SNCR) Inputs

Reagent	1:Urea 2:Ammonia	1	1	1	1	1
Number of Injector Levels	integer	3	3	3	3	3
Number of Injectors	integer	18	18	18	18	18
Number of Lance Levels	integer	0	0	0	0	0
Number of Lances	integer	0	0	0	0	0
Steam or Air Injection for Ammonia	integer	1	1	1	1	1
NOx Reduction Efficiency	Fraction	0.50	0.50	0.50	0.50	0.50
Inlet NOx	lbs/MMBtu	0.6	0.26	0.2	0.4	0.2
NH3/NOx Stoichiometric Ratio	NH3/NOx	1.2	1.2	1.2	1.2	1.2
Urea/NOx Stoichiometric Ratio	Urea/NOx	1.2	1.2	1.2	1.2	1.2
Urea Cost	\$/ton	200	200	200	200	200
Ammonia Cost	\$/ton	411.17	411.17	411.17	411.17	411.17
Water Cost	\$/1,000 gal	0.22	0.22	0.22	0.22	0.22
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	5%	5%	5%	5%	5%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
Low-NOx Burner Technology Inputs						
NOx Reduction Efficiency	fraction	0.40	0.40	0.40	0.40	0.40
Boiler Type	T:T-fired, W:Wall	W	W	W	W	W
Retrofit Difficulty	L:Low, A:Average, H:High	А	А	А	А	А
Maintenance Labor (% of installed cost)	%	0.8%	0.8%	0.8%	0.8%	0.8%
Maintenance Materials (% of installed cost)	%	1.2%	1.2%	1.2%	1.2%	1.2%
Natural Gas Reburning Inputs						
NOx Reduction Efficiency	fraction	0.61	0.61	0.61	0.61	0.61
Gas Reburn Fraction	fraction	0.15	0.15	0.15	0.15	0.15
Waste Disposal Cost	\$/ton	11.48	11.48	11.48	11.48	11.48
Natural Gas Cost	\$/MMBtu	4.24	4.24	4.24	4.24	4.24
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	2%	2%	2%	2%	2%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%

Adopted



November 1, 2018

Alaska Department of Environmental Conservation Division of Air Quality ATTN: Director 410 Wiloughby Avenue, Suite 303 Juneau, Alaska 99811-1800

Subject: Second Request for Additional Information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant.

Dear Ms. Koch,

Thank you for the opportunity to provide additional information to better characterize Aurora's operations for the Best Available Control Technology (BACT) Analysis which will be a part of the Serious Area State Implementation Plan.

The following is being provided in response to the information request letter dated September 13, 2018. The ADEC letter included an enclosure with twelve comments for which additional information was requested. Each comment is summarized below followed by a response from Aurora. The information is being submitted to the ADEC by November 1, 2018 as requested.

1. <u>Alternative Fuel Source</u> - Evaluate alternative coal sources as a potential control option for the coal-fired boilers and identify energy, environmental, and economic impacts and other costs that would affect the selection of an alternative source of coal as a technically feasible control option. Evaluate the control efficiency of alternative coal sources based on a comparison of the coal's heat content as well as nitrogen and sulfur content.

<u>Response</u>: There are no other economically viable coal options for Aurora. Usibelli Coal Mine is the state's only operating coal mine.

2. <u>Low Excess Air (LEA) and Overfire Air (OFA)</u> - Evaluate these technically feasible control technologies using EPA's top down approach.

<u>Response:</u> Aurora's BACT analysis dated March of 2017, Section 2.3.2, references the use of combustion controls, including OFA and LEA. The BACT analysis concludes that the Unit 5 (EU 7) is already equipped with OFA, LEA (i.e., oxygen trim system), and air preheaters. It is stated within the BACT that Units 1, 2, and 3 (EU 4-6) have OFA and air preheaters. Although the air preheater ductwork is installed, the preheaters have been removed from operation. The current

configuration of the traveling-grate boilers as installed, includes a 'partial' LEA (i.e., oxygen trim system). The fuel feed rate and oxygen for Boiler Units 1-3 (EU 4-6) are manually adjusted and tuned daily. The traveling-grate boilers have a knife gate which sets the bed thickness and the air-to-fuel ratio is manually adjusted to accommodate the boiler's performance. Once adjusted, the fuel-to-air ratio is maintained automatically.

Additional SO₂ Control Technologies - The BACT analysis does not include a substantive analysis of spray-dry scrubbing, dry flue gas desulfurization, dry scrubbing, or dry sorbent injection (DSI). All of these technologies have the potential to offer SO2 removal, and therefore must be included in the analysis.

<u>Response:</u> - An addendum to the initial BACT submittal was provided to the State on December 22, 2017. This addendum included a substantive analysis of Spray Dry Absorbers (SDA) and Dry Sorbent Injection (DSI) technologies.

4. <u>BACT Limits</u> - Provide numerical emission limits (and averaging periods) for each proposed BACT selection, or justify why a measurement methodology is technically infeasible and provide the proposed design equipment, or work/operational practices for pollutant for each emission unit included in the analysis. Startup, Shutdown, and Malfunction (SSM) must be addressed in the BACT analysis. In no event shall application of BACT result in emissions of any pollutant which would exceed the emissions allowed by an applicable standard under 40 C.F.R. parts 60 (NSPS) and 61 (NESHAP).

<u>Response</u>: Statements concerning applicable standards under 40 CFR Parts 60 (New Source Performance Standards—NSPS) and 61 (National Emission Standards for Hazardous Air Pollutants—NESHAP) are not relevant to the Chena boilers. The NESHAP do not regulate criteria air pollutants such as SO₂, and therefore, no SO₂ floor can be defined by any NESHAP. Furthermore, the Chena boilers are not subject to NSPS and therefore are not required to achieve the NSPS standard. In any case, the NSPS SO₂ emission limit of 1.2 lb/MM Btu (for units less than 75 MM Btu/hr) is achieved in the small boilers (the percent reduction is not a requirement for units less than 75 MM Btu/hr).

An NSPS or NESHAP standard must be considered as the floor for BACT only when a source is subject to one of the standards. In that case, a source must achieve compliance with the NSPS or NESHAP, and a less stringent emission limit cannot be considered BACT. As noted in a July 28, 1987 memo by Gary McCutchen, then Chief of the New Source Review Section of the US EPA:

"Since an *applicable* NSPS must always be met, it provides a legal "floor" for the BACT, which cannot be less stringent." (emphasis added). This statement implies that a source must first be subject to an NSPS for the standard to be considered the BACT floor.

The Chena plant operates four coal-fired boilers: three at 76.8 MM Btu/hr (22.5 megawatt, MW) heat input and one at 254.7 MM Btu/hr (74.6 MW) heat input. If newly-constructed today, the three smaller units would be subject to an NSPS Subpart Dc limit of 1.2 lb SO₂/MM Btu, and the larger unit would be subject to an NSPS Subpart Da limit of 0.15 lb SO₂/MM Btu. On a Btuweighted average basis, the overall NSPS limit would be 0.64 lb SO₂/MM Btu. The Chena boilers

currently combust low-sulfur coal, with emissions of 0.39 lb SO_2/MM Btu from the combined exhaust. This overall emission rate represents a 39% reduction from NSPS limits if the Chena boilers had been built today.

Regardless of the NSPS applicability to the Chena boilers, the history of rulemaking for small industrial, commercial, and institutional (ICI) boilers provides valuable insight into the definition of BACT for SO₂ from these units. The three smaller units, if constructed today, would be subject to NSPS Subpart Dc for small ICI boilers. As defined in the standard, ICI units smaller than 22 MW (75 MM Btu/hr) heat input are not subject to a percent reduction requirement in NSPS and instead may achieve compliance with NSPS through the use of low-sulfur fuel. The rationale for this "exemption" is provided in the preamble to the proposed rule (54 *Federal Register* (FR) 24806, June 9, 1989) and the Background Information Document for the Promulgated Standards. As discussed in the Background Document:

"Section 111 of the CAA requires standards to reflect application of the best demonstrated technology considering costs, nonair quality health and environmental impacts, and energy requirements. Section 111 also requires that for fossil fuel-fired steam generating units a percent reduction standard be established. Read together, this means that the Administrator is compelled to include a percent reduction standard unless the impacts associated with the requirements would be unreasonable....Imposing these high (capital and annualized) costs for the units (those less than 22 MW) was considered to be unreasonable when compared to the increase in emission reduction achievable be the percent reduction requirement on these units. Therefore, in keeping with the requirements of the CAA, the final standards will not require percent reduction for any units operating at less than a 55 percent annual capacity factor for coal or any unit with a heat input capacity of 22 MW (75 million Btu/hr) or less."

The passage presented above is the basis for the US EPA's definition of BACT for small ICI boilers less than 22 MW. This analysis therefore defines BACT for such units as an emission rate equal to or greater than 1.2 lb SO₂/MM Btu. In the proposed rule, US EPA further states that compliance with this NSPS limit/ BACT emission rate for units smaller than 22 MW (75 MM Btu/hr) can be achieved through use of low-sulfur fuels (see 54 FR 24793). For all practical purposes, the three smaller boilers at the Chena plant fall into this category, and therefore BACT is defined as an emission limit of 1.2 lb SO₂/MM Btu, achieved through combustion of low-sulfur coal. Furthermore, as illustrated above, the four boilers at the Chena plant collectively operate with an actual SO₂ emission level that is 39 percent less than the levels that would be required if all of the units were subject to NSPS.

5. <u>Retrofit Costs</u> - Provide detailed cost analyses and justification for difficult retrofit (1.6 – 1.9 times the capital costs) considerations used in the BACT analysis.

<u>Response</u>: The BACT cost analysis employed a retrofit factor of 2.0. The basis for this factor was the EPA Air Pollution Control Cost Manual, Sixth Edition. As discussed in the Cost Manual:

"To quantify the unanticipated additional costs of installation not directly related to the capital cost of the controls themselves, engineers and cost analysts typically multiply the

> cost of the system by a retrofit factor. The proper application of a retrofit factor is as much an art as it is a science, in that it requires a good deal of insight, experience, and intuition on the part of the analyst....The magnitude of the retrofit factor varies across the kinds of estimates made as well as across the spectrum of control devices. At the study level, analysts do not have sufficient information to fully assess the potential hidden costs of an installation. At this level, a retrofit factor of as much as 50 percent can be justified. Even at detailed cost level (± 5 percent accuracy), vendors will not be able to fully assess the uncertainty associated with a retrofit situation and will include a retrofit factor in their assessments." (see page 2-28 in EPA/452/B-02-001)

As noted in the above citation, US EPA notes that a retrofit factor can be as high as 1.5, this partially supports the value selected for the Chena BACT cost analysis. The cost model employed during the BACT analysis (i.e., CUECost) suggests the following retrofit factors: 1.0 factor for a new facility, a 1.3 factor for a moderately difficult retrofit, and a 1.6 factor for a difficult retrofit. The user is also given the option to input his own retrofit factor based on plant-specific information. As noted by the Northeast States for Coordinated Air Use Management (NESCAUM) in a in a report entitled "Applicability and Feasibility of NOx, SO2, and PM Emissions Control Technologies for industrial, Commercial, and Institutional (ICI) Boilers an independent researcher (Emmel) noted that:

"this range (of CUECost retrofit factors) significantly understated the cost of retrofit for FGD and SCR technologies when applied to EGUs (i.e., electric generating units) less than 100 MW. Emmel also noted that on average, a retrofit factor of 1.45 was more reasonable and that the factor should even be higher when CUECost is applied to ICI boilers."

Two main factors impact selection of the retrofit factor for the Chena plant: space availability and equipment congestion. These two factors will require additional efforts for installation, equipment staging, and maneuverability during construction.

6. <u>Baseline Emissions</u> - Include the baseline emissions for all emission units included in the analysis. Typically, the baseline emission rate represents a realistic scenario of upper bound uncontrolled emissions for the emissions unit (unrestricted potential to emit not actual emissions). The baseline is usually the legal limit that would exist, but for the BACT determination.

<u>Response</u>: The Baseline Emission rate is not a legal limit. As stated in the U.S. EPA 1990 New Source Review Workshop Manual:

"Calculating Baseline Emissions"

The baseline emissions rate represents a realistic scenario of upper boundary uncontrolled emissions for the source. *The NSPS/NESHAP requirements or the application of controls, including other controls necessary to comply with State or local air pollution regulations, are not considered in calculating the baseline emissions.* In other words, baseline emissions are essentially uncontrolled emissions, calculated using realistic upper boundary operating assumptions. (emphasis added)"

Based on this guidance, the Chena baseline emissions were properly calculated and applied to the BACT analysis.

7. <u>Factor of Safety</u> - If warranted, include a factor of safety when setting BACT emission limitations. The safety factor is a legitimate method of deriving a specific emission limitation that may not be exceeded. These limits do not have to reflect the highest possible control efficiencies, but rather, should allow the Permittee to achieve compliance with the numerical emission limit on a consistent basis.

<u>Response</u>: The current BACT analyses included operating as is, therefore a factor of safety was not included.

8. <u>Good Combustion Practices</u> - For each emission unit type (coal boilers, distillate boilers, engines, and material handling) for which good combustion practices was proposed as BACT, describe what constitutes good combustion practices.

<u>Response</u>: Good combustion practices were not proposed. The operation of existing combustion controls (OFA & LEA) were determined to be BACT for NOx.

 Interest Rate - All cost analyses must use the current bank prime interest rate. This can be found online at <u>https://www.federalreserve.gov/releases/h15/</u> (go to bank prime rate in the table). Please revise the cost analyses as appropriate.

<u>Response</u>: Suggest that the State revise interest rate to prime (currently 5.25%) and equipment life to 10 years, not 15, due to corresponding short remaining lifespan of associated boilers.

Economic Analysis for Circulating Dry Scrubber (CDS) - Provide in the analysis: the control
efficiency associated with CDS, captured emissions (tons per year), emissions reduction (tons
per year), capital costs (2017 dollars), operating costs (dollars per year), annualized costs
(dollars per year), and cost effectiveness (dollars per ton) using EPA's cost manual.

Response: See attached memo "CDS v SDA Cost Comparison.pdf" for CDS analysis.

11. <u>Review State's Spreadsheets</u> – Review cost effectiveness spreadsheet provided as a part of the preliminary SO₂ BACT determination which was originally developed by Sargent & Lundy (S&L) in 2010.

<u>Response</u>: Aurora has provided a review of the ADEC's cost effectiveness spreadsheets and inputs. Comments are included on the spreadsheets. Please reference documents "chena-so2-economic-analyses-adec--With ERM Comments.xlsm" and "chena-large-boiler-so2-economic-analyses-adec--With ERM Comments.xlsm".

12. <u>Site-Specific Quotes Needed</u> - The cost analyses, particularly for SO2 control technologies, must be based on emission unit-specific quotes for capital equipment purchase and installation costs at each facility. These are retrofit projects which must be considered individually in order to obtain reliable study/budget level (+/- 30%) cost estimates which are appropriate to use as the basis for decision making in determining BACT.

<u>Response</u>: Included as attachments within this response are vendor quotes as well as a cost analysis for Dry Sorbent Injection (DSI). Due to time constraints, the consultant was able to provide a +50/-30 cost estimate. Please reference the enclosed documents, to include: "Aurora Energy Preliminary Opinion of Probable Cost.pdf";

"Aurora_DSI_Opinion_of_Probable_Cost_rev0.pdf"; "BACT Proposal No. 1899-R1.pdf"; and "Aurora_Chena_DSI_General Arrangement.pdf".

Below are a list of documents that are being provided as enclosures which are referenced within the responses given above. If there are any questions pertaining to the information provided, please contact David Fish at <u>dfish@usibelli.com</u> or 907-457-0230.

Sincerely,

David Fish Environmental Manager

Enclosures:

- 1. CDS v SDA Cost Comparison.pdf
- 2. chena-so2-economic-analyses-adec--With ERM Comments.xlsm
- 3. chena-large-boiler-so2-economic-analyses-adec--With ERM Comments.xlsm
- 4. Aurora Energy Preliminary Opinion of Probable Cost.pdf
- 5. Aurora_DSI_Opinion_of_Probable_Cost_rev0.pdf
- 6. BACT Proposal No. 1899-R1.pdf
- 7. Aurora_Chena_DSI_General Arrangement.pdf
- 8. Unified Facilities Criteria (UFC) DoD Facilities Pricing Guide (ufc_3_701_01_c1_2018.pdf)
- 9. ufc_3_701_01_data_tables_may_2018.xlsx
- 10. NSPS ICI SO2 RE.docx
- 11. ICI Boilers 20081118 final_revised-Jan2009.pdf
- 12. EPA Air Pollution Cost Control Manual, sixth edition, January 2002, accessible at https://www3.epa.gov/ttncatc1/dir1/c_allchs.pdf.

Cc:

Larry Hartig, ADEC/Commissioner's Office Alice Edwards, ADEC/ Commissioner's Office Denise Koch, ADEC/ Air Quality Cindy Heil, ADEC/ Air Quality Deanna Huff, ADEC/ Air Quality Jim Plosay, ADEC/ Air Quality

Aaron Simpson, ADEC/ Air Quality Buki Wright/ Aurora Energy, LLC Rob Brown/ Usibelli Coal Mine, Inc. Tim Hamlin/ EPA Region 10 Dan Brown/ EPA Region 10 Zach Hedgpeth/ EPA Region 10

Adopted

			Rev. 0	Job No.	28709.01.00	Page No.	1
	J Smith / S Worcester/ D Bacon	Date	10/29/2018	Subject	Aurora Energy	Chena - Dry Sorbent	Injection
Checked by	J. Solan	Date	10/29/2018			bable cost	
Approved by	C. Spooner	Date	10/30/2018	Sheet No.	1	of	1
	Item Description			Qu No. of Unit		Unit Cost	Total Cost
Engineering Services				NO. OF OTHE	UOIW		
Engineering services provided throughout the project to assist with BOP design, technical specifications, procurement, bid evaluation, and construction observation.				1	I EA	\$1,880,200.00	\$1,880,200
Dry Sorbent Injection System Supply							
DSI	Includes Railcar offloading, long term storage silos, day storage						
DSI Installation DSI Equipment Freight	silos, milling, metering and feed. Field Installation FOB jobsite			1 1 1	EA EA EA	\$4,900,000.00 \$6,370,000.00 \$200,000.00	\$4,900,000 \$6,370,000 \$200,000
Structural Silo Foundation Sorbent Building Substructure Sorbent Building Superstructure Sorbent Building Exterior Closure Roofing Railcar Unloading Skid Foundation Transfer Skid Enclosure Foundation				2 1 1 1 1 5 5	EA EA EA EA CY CY	\$244,304.00 \$247,047.00 \$183,067.00 \$160,334.00 \$12,149.00 \$650.00	\$488,608 \$247,047 \$160,334 \$12,149 \$3,250 \$3,250
MCC Foundation	coal vard front end loader drive			4	CY	\$650.00	\$2,600
Pipe Bridge by Silos - Steel Pipe Bridge by Silos - Foundations Outside Pipe Supports - Steel Outside Pipe Supports - Foundations Inside Pipe Supports - Steel Ductwork	100' Feet of Ductwork for			4 6 10.0 40 3.00	TONS CY TONS CY TONS	\$9,000.00 \$650.00 \$9,000.00 \$650.00 \$9,000.00	\$36,000 \$3,900 \$90,000 \$26,000 \$27,000
	Residence Time prior to PJFF			12.50	IUNS	\$10,300.00	\$128,750
Mechanical Unit 1 Aggregate Piping Cost: 6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location Unit 2 Aggregate Piping Cost:				300) LF	\$238.00	\$71,400
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location Unit 3 Aggregate Piping Cost:				310	LF	\$239.00	\$74,090
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location Unit 5 Aggregate Piping Cost:				280	LF	\$239.00	\$66,920
6" Sch 80 Pipe/Flanges/Supports - Sorbent Prep to Injection Location				200	LF	\$239.00	\$47,800
Electrical 480V MCC 480V Panelboard and Xfmr Cable - 480V - MCC, Loads Conduit - RGS Cable Terminations (Mat'I) Light Fixtures Interior/Exterior Ground Grid extension Instrumentation & Controls BOP DCS Aspects	Mtl & Labor Mtl & Labor Mtl & Labor Mtl & Labor 480V Material & Labor Surface mounted LED light fixtures (Mtl & Labor) Mtl & Labor			2 2 9000 6800 496 20 1050	2 EA 2 EA 0 LF 0 LF 0 EA 0 LF	\$65,177.00 \$10,200.00 \$14.83 \$20.26 \$26.11 \$1,561.00 \$13.43 \$76.428.00	\$130,354 \$20,400 \$133,436 \$137,748 \$12,950 \$31,220 \$14,100 \$76,428
BOF DOS Aspects					LA	φ70,420.00	ψ/0, 4 20
All Terrain Forklift Hydraulic Crane	45' lift, 35' reach, 9000 lb. capacity 80-ton			12 90	WK DY	\$6,455.00 \$4,365.00	\$77,460 \$392,850
					Furnish a	nd Erection Subtotal	\$14,169,111
					Mobilization & Contrac Co	Demobilization - 5% Bond - 2.5% tor Overhead - 10% ntractor Profit - 10%	\$708,456 \$354,228 \$1,416,911 \$1,416,911
	Escalation Percent	4.00%	Periods	14 Es	Tota calation (Nov 20	al Construction Cost 018 - January 2020)	\$18,065,617 \$736,199
		PR	OBABLE ENG	PROBABLE EQUI	PMENT & CON	STRUCTION COST	\$18,802,000 \$20,682,000
Note: All costs presented in this document construction cost is based on our experien competitive bidding or market conditions. Construction, and/or operation and mainter Construction Cost Index, and/or vendor qu	t are stanley Consultants' opinions of ce and represent our best judgment. Therefore, we do not guarantee that p ance costs presented. The costs ide otes.	probabl We hav roposal ntified a	ie project, con ve no control d ls, bids, or act are based on l	struction, and/or op over cost of labor, n ual construction cos Means Building Con	peration and main naterials, equipr sts will not vary istruction Cost [nienance costs. This nent, contractor's meti from estimates of proj Data, Engineering Nev	esumate of probable hods, or over ect costs, vs Record



STANLEYCONSULTANTS, Inc

8000 South Chester Street > Suite 500 > Centennial, CO 80112 303.799.6806 > stanleyconsultants.com

November 1, 2018

David Fish Environmental Manager Aurora Energy, LLC 100 Cushman St. Suite 210 Fairbanks, AK 99701-4674

RE: Qualitative Cost Comparison of Circulating Dry Scrubber Technology Versus Spray Dryer Absorbers

David:

Per your request Jason Smith and I have developed a comparison between the Circulating Dry Scrubber and Spray Dry Absorption technologies and the expected differences in total installed cost. Jason is an expert in SO₂ scrubbers having participated in the construction, startup, and commissioning of several installations over the course of his career.

The two commercially available semi-dry acid gas scrubbing processes consist of Spray Dryer Absorption (SDA) and Circulating Dry Scrubber (CDS). Both technologies, for industrial coal fired applications, employ an alkaline reagent of calcium hydroxide and fly ash, which is collected from the combustion process. The calcium hydroxide reacts with sulfur dioxide (SO2) and sulfur trioxide (SO3) of the flue gas to form calcium sulfite and calcium sulfate. The calcium sulfite and calcium sulfate, unreacted calcium hydroxide, and fly ash is collected downstream of the acid gas scrubbing process by a baghouse, and a considerable portion is "recycled," back to the scrubber to offset reagent costs by utilizing available unreacted alkalinity of the fly ash. The fly ash particles also serve to increase the available surface area for reactions to occur. Both process also depend on the humidification of the flue gas. In general, the greater the humidification, the lower the alkalinity stoichiometry, which reduced reagent consumption. To prevent corrosion downstream of these scrubbers and promote the longevity of downstream equipment (namely fluework, particulate collection, and stack), the humidification is limited to operating above the saturation temperature, referred to as the approach temperature.

The humidification of the flue gas stream is an area where the SDA and CDS scrubbing processes diverge.

In the SDA process, water for humidification is delivered as a portion of the lime and ash constituents. The water, lime, and ash slurries are pumped through recirculation loops and fed to an atomization feed system. The slurry that is fed to the atomizer is then dispersed in a passing flue gas stream inside an absorber or scrubber vessel. Once dispersed in the flue gas, a chemical reaction occurs, and the gas stream is scrubbed of the SO₂ and SO₃ pollutants. Since the slurry reagent is pumped, the SDA process can sometimes leverage existing infrastructure such as existing particulate collection equipment. The ability to integrate a SDA system into an existing flue gas system serves to limit the capital outlay necessary for a targeted level of compliance. The potential to leverage existing infrastructure is dependent on



numerous factors such as existing equipment layout and condition, site spatial limitations, and original design parameters of the existing particulate collection equipment, just to name a few.

The humidification of the flue gas stream for a CDS scrubbing process is essentially decoupled from the hydrated lime and ash constituents. Water for gas humidification is mechanically atomized into the passing flue gas stream and the dry alkaline products are conveyed to the CDS vessel using air slide conveyors. Air slide conveyors utilize an air permeable fabric, which is stretched across a rectangular enclosure flow path, to aerate particulate material, and allow the force of gravity to covey the material down the sloped surface. The alkaline material and water injection typically occurs after a venturi assembly that increases the velocity of the passing gas stream to establish a fluidized bed of alkaline material. The flue gas then passes through this bed and is scrubbed of the SO_2 and SO_3 . The use of air slides to convey the fly ash from the particulate collection device (typically a baghouse) back to the scrubber necessitates that the collector be placed at higher elevations. This will ensure that the proper slope is maintained between the collector and the injection point on the absorber tower. It is technically challenging to take an existing collector and elevate it, so CDS technologies are typically purchased with an absorber vessel, air slides, particulate collection device, and waste ash systems. This allows the integration of the required elevation differences and the steel and foundations to accommodate the higher elevation construct to be handled under a single contract, thus limiting risk for the owner. Due to the additional equipment, steel, and deep foundations necessary, these factors typically increase the necessary capital outlay for the CDS technology.

Additional information on both SDA and CDS technology can be found in Chapter 34 of *STEAM, Its Generation and Use, 42nd Edition*, Babcock and Wilcox, Inc. Reference Figure 10 on Page 34-15 for an illustration of a typical SDA installation and Figure 17 on Page 34-21 for an illustration of a typical CDS installation.

The information above indicates that CDS and SDA technologies are similar in their nature and operation. However, the installation of a CDS frequently requires the installation of a new particulate collector, where the SDA system does not. The CDS equipment itself, along with the additional equipment needed for proper operation, will result in a significantly larger installation cost when compared to an equivalent SDA system. Given that the ADEC Preliminary BACT Determination for the Chena Plant (Dated March 22, 2018) has already established that a SDA system is not economically feasible (Table 4-3, Page 12), it can therefore be concluded that the CDS system is economically infeasible as well.

Please let me know if you have any questions or comments regarding the information presented in this letter.

Sincerely,

John P Solan

John P. Solan, P.E. Senior Mechanical Engineer Stanley Consultants, Inc.

cc: File

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Northeast States for Coordinated Air Use Management (NESCAUM)

November 2008

(revised January 2009)

Appendix III.D.7.7-4210

Members of Northeast States for Coordinated Air Use Management

Arthur Marin, Executive Director Northeast States for Coordinated Air Use Management

Anne Gobin, Bureau Chief Connecticut Department of Environmental Protection, Bureau of Air Management

James P. Brooks, Bureau Director Maine Department of Environmental Protection, Bureau of Air Quality

Barbara Kwetz, Director Massachusetts Department of Environmental Protection, Bureau of Waste Prevention

Robert Scott, Director New Hampshire Department of Environmental Services, Air Resources Division

William O'Sullivan, Director New Jersey Department of Environmental Protection, Office of Air Quality Management

David Shaw, Director New York Department of Environmental Conservation, Division of Air Resources

Douglas L. McVay, Acting Chief Rhode Island Department of Environmental Management, Office of Air Resources

Richard A. Valentinetti, Director Vermont Department of Environmental Conservation, Air Pollution Control Division

UNITS, SPECIES, ACRONYMS

Acronyms

- APCD Air Pollution Control Device
- BACT -Best Available Control Technology
- BART Best Available Retrofit Technology
- BOOS Burners Out of Service
- CAA Clean Air Act
- CAAA Clean Air Act Amendments (of 1990)
- CFBA Circulating Fluidized-Bed Absorption
- CFR Code of Federal Regulations
- DI Dry Injection
- DSI Dry Sorbent Injection
- EGU Electricity Generating Unit
- ESP Electrostatic Precipitators
- FBC Fluidized Bed Combustion
- FF Fabric Filter (also known as baghouse)
- FGD Flue Gas Desulfurization (also known as SO₂ scrubber)
- FGR Flue Gas Recirculation
- FOM Fixed Operating and Maintenance Costs
- FSI Furnace Sorbent Injection
- GR Gas Reburn
- HHV Higher Heating Value
- ICI Industrial, Commercial, and Institutional (boilers)
- LAER Lowest Achievable Emission Rate
- LNB Low-NOx Burner
- LSDI Lime Slurry Duct Injection
- LSFO Limestone Forced Oxidation
- LSC Low-Sulfur Coal (also known as compliance coal)
- MACT Maximum Achievable Control Technology
- MANE-VU Mid-Atlantic-Northeast Visibility Union
- MC Mechanical Collector
- NAAQS National Ambient Air Quality Standard
- NCG Non-Condensable Gases
- NESCAUM Northeast States for Coordinated Air Use Management
- NSPS New Source Performance Standards
- NSR Normalized Stoichiometric Ratio
- OFA Overfire Air
- PC Pulverized Coal
- PRB Powder River Basin (coal)
- RACT Reasonably Available Control Technology
- RPO Regional Planning Organization
- SCA Specific Collection Area
- SCR Selective Catalytic Reduction

SD – Spray Dryer
SIP – State Implementation Plan
SNCR – Selective Non-Catalytic Reduction
TCR – Total Capital Requirement
TR – Transformer Rectifier
UBC – Unburned Carbon
US EIA – United States Energy Information Administration
US EPA – United States Environmental Protection Agency
ULNB – Ultra Low-NOx Burner
VOM – Variable Operating and Maintenance (costs)
WESP – Wet Electrostatic Precipitator
WFGD – Wet Flue Gas Desulfurization (also known as wet SO₂ scrubber)

Chemical Species

HCl – Hydrochloric Acid HF – Hydrofluoric Acid H₂SO₄ – Sulfuric Acid NOx – Oxides of Nitrogen (NO₂ and NO) NO – Nitric Oxide NO₂ – Nitrogen Dioxide NH₃ – Ammonia PM_{2.5} – Particulate Matter up to 2.5 μ m diameter in size PM₁₀ – Particulate Matter up to 10 μ m diameter in size S – Sulfur SO₂ – Sulfur Dioxide SO₄ – Sulfate VOC – Volatile Organic Compound

Units

<u>Length</u> m – meter μ m – micrometer or micron (0.000001 m; 10⁻⁶ m) km – kilometer (1000 m; 10³ m) Mm – Megameter (1,000,000 m; 10⁶ m)

<u>Flow Rate</u> acfm – actual cubic feet per minute

 $\frac{\text{Volume}}{\text{L} - \text{liter}}$ m³ - cubic meter

<u>Mass</u> lb – pound g – gram μ g – micrograms (0.000001 g; 10⁻⁶ g) Adopted

kg – kilograms (1000 g; 10^3 g)

<u>Force</u> psi – pounds per square inch

 $\label{eq:wer} \begin{array}{l} \underline{Power} \\ \overline{W} - watt \mbox{ (Joules/sec)} \\ kW - kilowatt \mbox{ (1000 W; $10^3 W)} \\ MW - megawatt \mbox{ (1,000,000 W; $10^6 W)} \end{array}$

Energy Btu – British thermal unit (= 1055 Joules) MMBtu – million Btu MWhr – megawatt-hour kWhr – kilowatt-hour

 $\frac{Concentration}{\mu g/m^3 - micrograms per cubic meter}$

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Northeast States for Coordinated Air Use Management (NESCAUM)

November 2008

(revised January 2009)

iv

Appendix III.D.7.7-4215
Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Project Director

Praveen Amar, Ph.D., P.E., Director, Science and Policy, NESCAUM

Principal Contributors

Constance L. Senior, Ph.D., Reaction Engineering International Rui Afonso, Energy and Environmental Strategies

Acknowledgments

NESCAUM gratefully acknowledges the funding support provided by the United States Environmental Protection Agency (Clean Air Markets Division (CAMD) and Office of Air Quality Planning and Standards (OAQPS)). Mr. Sikander Khan (CAMD) and Mr. Tim Smith (OAQPS) acted as the Project Managers and Mr. Gene Sun was the Grant Manager.

This report was managed and directed by NESCAUM (Dr. Praveen Amar). NESCAUM was very ably supported by its contractors, Reaction Engineering International (Dr. Constance L. Senior) and Energy and Environmental Strategies (Mr. Rui Afonso). Additionally, Mr. Addison Faler, a student intern at NESCAUM, did extensive data analysis of emission estimates from industrial, commercial, and institutional boilers in the Northeast and the US. Ms. Wendy Roy, Administrative Assistant, NESCAUM, was extremely helpful in final formatting of the report.

NESCAUM thanks the members of the NESCAUM Stationary Sources and Permitting Committee, who guided the design of this report in early stages and provided access to the operating permits data, included in this report. The following individuals provided strong technical support and comments on various draft versions of this report:

Andrew Bodnarik, New Hampshire Department of Environmental Services

Sunila Agrawal, New Jersey Department of Environmental Protection

NESCAUM is an association of the eight northeast state air pollution control programs and provides technical guidance and policy advice to its member states.

TABLE OF CONTENTS

U	NITS,	SPEC	CIES, ACRONYMS	i		
A	cknow	ledgn	nents	vi		
E	EXECUTIVE SUMMARYxii					
1	IN	INTRODUCTION				
	1.1	Obje	ectives	1-1		
	1.2	Reg	ulatory Drivers	1-1		
	1.3	Cha	racterization of Combustion Sources	1-1		
	1.3	.1	Description of Combustion Sources	1-1		
	1.3	.2	Emissions by Size, Fuel, and Industry Sector	1-2		
	1.3	.3	Differences between EGU and ICI boilers	1-7		
	1.3	.4	Control Technology Overview	1-10		
	1.4	Cha	pter 1 References			
2	NC	Ox CO	NTROL TECHNOLOGIES	2-1		
	2.1	Intro	oduction			
	2.1	.1	ICI versus EGU Boilers	2-1		
	2.1	.2	Control Technologies' Impact on Efficiency and CO ₂ Emissions	2-2		
	2.2	Disc	cussion of NOx Control Technologies	2-3		
	2.2	.1	NOx Formation	2-3		
	2.2	.2	NOx Reduction	2-3		
	2.2	.3	Other Benefits of NOx Control Technologies	2-3		
	2.3	Sum	mary of NOx Control Technologies	2-3		
	2.3	.1	Combustion Modifications	2-3		
	2.3	.2	Low-NOx Burners and Overfire Air	2-4		
	2.3	.3	Reburn			
	2.3	.4	Post-Combustion Controls	2-6		
	2.3	.5	Technology Combinations	2-11		
	2.4	App	licability to ICI Boilers	2-12		
	2.5	Effic	ciency Impacts	2-12		
	2.6	NOx	x Control Costs	2-13		
	2.7	Cha	pter 2 References			
3	SO	$_2$ COI	NTROL TECHNOLOGIES			
	3.1	SO_2	Formation			
	3.2	SO_2	Reduction			

	3.3	Other FGD Benefits		
	3.4	Summary of FGD Technologies		
	3.4.1 Wet Processes		Wet Processes	
	3.4	.2	Dry Processes	
	3.4	.3	Other SO ₂ Scrubbing Technologies	
	3.5	Use	of Fuel Oils with Lower Sulfur Content	
	3.6	App	licability of SO ₂ Control Technologies to ICI Boilers	
	3.7	Effic	ciency Impacts	
	3.8	SO_2	Control Costs	
	3.9	Cha	pter 3 References	
4	PM	I CON	VTROL TECHNOLOGIES	4-1
	4.1	PM	Formation in Combustion Systems	4-1
	4.2	PM	Control Technologies	4-1
	4.3	Desc	cription of Control Technologies	
	4.3	.1	Fabric Filters	
	4.3	.2	Electrostatic Precipitators	4-4
	4.3	.3	Venturi Scrubbers	4-6
	4.3	.4	Cyclones	4-7
	4.3	.5	Core Separator	
	4.4	App	licability of PM Control Technologies to ICI Boilers	
	4.5	Effic	ciency Impacts	
	4.6	PM	Control Costs	
	4.7	Chaj	pter 4 References	4-13
5	AP	PLIC	ATION OF A COST MODEL TO ICI BOILERS	5-1
	5.1	Cost	Model Inputs and Assumptions	5-1
	5.2	Con	parison of the Cost Model Results with Literature	
	5.3	Sum	mary	5-11
	5.4	Cha	pter 5 References	
6	SU	MMA	NRY	6-1
	6.1	NOx	Controls	6-1
	6.2	SO_2	Controls	
	6.3	PM	Controls	
А	PPEN	DIX A	A : Survey of Title V Permits in NESCAUM Region	A-1
A	PPEN	DIX I	3: CUECost-ICI Inputs	B-1

LIST OF FIGURES

FIGURE 1-1.	TOTAL CAPACITY OF INDUSTRIAL BOILERS AS A FUNCTION OF SIZE [EEA, 2005]1-3
FIGURE 1-2.	TOTAL AND AVERAGE BOILER CAPACITY OF U.S. INDUSTRIAL BOILERS AS A FUNCTION
OF FUE	L FIRED [EAA, 2005]
FIGURE 1-3	TOTAL ANNUAL EMISSIONS OF NOX, SO ₂ , AND $PM_{2.5}$ from ICI boilers in the U.S.
AND IN	THE EIGHT-STATE REGION FROM EPA AIRDATA DATABASE
FIGURE 1-4.	Emissions of NOx, SO ₂ , and $PM_{2.5}$ from ICI boilers in the NESCAUM region
FROM N	MANEVU DATABASE AS A FUNCTION OF FUEL FIRED
FIGURE 1-5.	SOLID-FUEL BOILER INFORMATION FROM FOUR NORTHEAST STATES, BASED ON TITLE
V PERM	IIT INFORMATION 1-8
FIGURE 2-1.	LOW-NOX BURNER [TODD DYNASWIRL-LN ^{IM}]
FIGURE 2-2.	GAS REBURN APPLIED TO A STOKER BOILER [WWW.GASTECHNOLOGY.ORG]2-6
FIGURE 2-3.	SNCR SYSTEM SCHEMATIC [FUELTECH]
FIGURE 2-4.	3-D SCHEMATIC OF AN SCR SYSTEM [ALSTOM POWER]
FIGURE 2-5.	SCHEMATIC AND ACTUAL RSCR [TOUPIN, 2007]2-9
FIGURE 2-6.	BLOCK OF MONOLITH CERAMIC HEAT EXCHANGER [TOUPIN, 2007]2-10
FIGURE 2-7.	CAPITAL COST FOR NOX CONTROL FOR COMBUSTION MODIFICATION APPLIED TO ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 2-8.	CAPITAL COST FOR NOX CONTROL FOR SNCR APPLIED TO ICI BOILERS AS A
FUNCTI	ON OF BOILER CAPACITY
FIGURE 2-9.	CAPITAL COST FOR NOX CONTROL FOR SCR APPLIED TO ICI BOILERS AS A FUNCTION
OF BOII	LER CAPACITY
FIGURE 3-1.	SCHEMATIC OF A WFGD SCRUBBER [BOZZUTO, 2007]
FIGURE 3-2.	SCHEMATIC OF A SPRAY DRYER
[HTTP:/	//www.epa.gov/eogapti1/module6/sulfur/control/control.htm]
FIGURE 3-3.	DRY SORBENT INJECTION (DSI) SYSTEM DIAGRAM
[HTTP:/	//www.epa.gov/eogapti1/module6/sulfur/control/control.htm]
FIGURE 3-4.	FLOW DIAGRAM FOR TRONA DSI SYSTEM [DAY, 2006]
FIGURE 3-5.	SO ₂ REMOVAL TEST DATA [DAY, 2007]
FIGURE 3-6.	INDUSTRIAL ENERGY PRICES FOR NO. 6 OIL GREATER THAN 1 PERCENT S, NO. 6 OIL
LESS TH	HAN 1 PERCENT S, AND NO. 2 OIL [SOURCE: US EIA, 2008]
FIGURE 3-7.	INDUSTRIAL ENERGY PRICES FOR NO. 2 (DISTILLATE) OIL [SOURCE: US EIA, 2008]. 3-
10	
FIGURE 3-8.	CAPITAL COST FOR SO_2 control for dry sorbent injection applied to ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 3-9.	CAPITAL COST FOR SO_2 CONTROL FOR SPRAY DRYER ABSORBER APPLIED TO ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 3-10). CAPITAL COST FOR SO_2 CONTROL FOR WET FGD APPLIED TO ICI BOILERS AS A
FUNCTI	ON OF BOILER CAPACITY
FIGURE 4-1.	PHOTOGRAPH OF FABRIC FILTER COMPARTMENT WITH FILTER BAGS [SOURCE:
WWW.H	HAMON-RESEARCHCOTTRELL.COM]
FIGURE 4-2.	SIDE VIEW OF DRY ESP SCHEMATIC DIAGRAM [SOURCE: POWERSPAN]4-4
FIGURE 4-3.	WET ESP [CROLL REYNOLDS]
FIGURE 4-4.	VENTURI SCRUBBER [CROLL REYNOLDS]

1-8
1-9
5-8
5-9
5-9
10
11

LIST OF TABLES

TABLE ES-1. ICI BOILER CONTROL TECHNOLOGIES xvii
TABLE 1-1. CAPACITY OF INDUSTRIAL BOILERS [EEA, 2005] 1-3
TABLE 2-1. CO AND NOX REDUCTION USING RSCR [SOURCE: BPEI 2006]2-10
TABLE 2-2. RSCR COST EFFICIENCY [BPEI, 2008]2-11
TABLE 2-3. SUMMARY OF NOX CONTROL TECHNOLOGIES 2-13
TABLE 2-4. NOX CONTROL COSTS FOR COMBUSTION MODIFICATIONS APPLIED TO ICI BOILERS 2-14
TABLE 2-5. NOX CONTROL COSTS FOR SNCR APPLIED TO ICI BOILERS
TABLE 2-6. NOX CONTROL COSTS FOR SCR APPLIED TO ICI BOILERS 2-18
TABLE 3-1. COMPARISON OF PRICE FOR FSI AND LSDI SYSTEMS FOR A 100 MW COAL-FIRED
BOILER [DICKERMAN, 2006]
TABLE 3-2. COMPARISON OF ALTERNATIVE FGD TECHNOLOGIES [BOZZUTO, 2007]3-8
TABLE 3-3. COST ESTIMATES FOR ALTERNATIVE FGD TECHNOLOGIES [BOZZUTO, 2007]3-8
TABLE 3-4. DISTILLATE AND RESIDUAL OIL STOCKS IN 2006 (X1000 BARRELS) [US EIA, 2006]. 3-9
TABLE 3-5. EXAMPLE OF COSTS OF SWITCHING TO LOW-SULFUR FUEL OIL [FUEL PRICES FROM US
EIA, 2008]
TABLE 3-6. Summary of energy impacts for SO_2 control technologies
TABLE 3-7. SO ₂ control costs applied to ICI boilers
TABLE 4-1. AVAILABLE PM CONTROL OPTIONS FOR ICI BOILERS
TABLE 4-2. CORE SEPARATOR COLLECTION EFFICIENCY [USEPA, 2008; RESOURCE SYSTEMS
GROUP, 2001]
TABLE 4-3. CORE SEPARATOR COST ANALYSIS [B. H. EASON TO P. AMAR, 2008]4-9
TABLE 4-4. Summary of energy impacts for control technologies
TABLE 4-5. PM control costs applied to ICI boilers
TABLE 5-1. CUECOST GENERAL PLANT INPUTS 5-2
TABLE 5-2. FUEL CHARACTERISTICS AND ASSUMPTIONS FOR CUECOST CALCULATION OF HEAT
RATE AND FLUE GAS FLOW RATES
TABLE 5-3. EQUIVALENT HEAT INPUT RATE AND FLUE GAS FLOW RATES FOR 250 and 100
MMBTU/HR HEAT INPUT RATES
TABLE 5-4. CAPITAL AND OPERATING COSTS FOR NOX CONTROL TECHNOLOGIES (ASSUMING
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-5. CAPITAL AND OPERATING COSTS FOR SO_2 control technologies (assuming
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-6. CAPITAL AND OPERATING COSTS FOR PM CONTROL TECHNOLOGIES (ASSUMING
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-7. CAPITAL AND OPERATING COSTS FOR SNCR ON WOOD-FIRED BOILERS, COMPARISON
OF COST CALCULATIONS FROM AF&PA AND CUECOST

EXECUTIVE SUMMARY

ES-1 Objectives

The main objective of this study is to evaluate the viability of technologies for controlling emissions of nitrogen oxides (NOx), sulfur dioxide (SO₂), and particulate matter (PM) from industrial, commercial, and institutional (ICI) boilers. These pollutants contribute to the formation of ozone, fine particles, and regional haze, and to ecosystem acidification. This source sector is coming under increased scrutiny by air quality regulators needing emission reductions to meet Clean Air Act requirements.

This study also includes a literature review of emission control costs and develops methods for estimating the costs and cost effectiveness of air pollution controls for ICI boilers. The study concludes that ICI boilers are a significant source of emissions, are relatively uncontrolled compared to electricity-generating units (EGUs), and offer the potential to achieve cost effective reductions for all three pollutants. The results of this technical and economic evaluation are intended as a resource in assessing regulatory and compliance strategies for ICI boilers.

Most of the technologies considered in this report have been successfully applied to the larger EGU boilers. This study investigates both the feasibility of down-scaling such control technologies for ICI boiler applications and of certain technologies that have not been applied to EGUs, but show promise for the ICI boilers.

ES-2 Report Organization

Chapter One provides an overview of the ICI boiler fleet in terms of boiler size, applications, fuel type and associated emissions. Chapters Two, Three, and Four discuss control technology options for NOx, SO₂ and PM, respectively. Each chapter provides: (1) descriptions of available control technologies; (2) a discussion of the applicability of these technologies to ICI boilers; (3) published cost estimates; and (4) an assessment of the impact of control technologies on overall facility efficiency. Chapter Five summarizes information about air pollution control equipment costs for ICI boilers calculated with the Coal Utility Environmental Cost (CUECost) model.

ES-3 Differences between ICI and EGU Boilers

ICI and EGU boilers differ in size, application, design, and emissions. Most commercial and institutional boilers are relatively small, with an average capacity of 17 MMBtu/hour. Industrial boilers can be as large as 1,000 MMBtu/hr or as small as 0.5 MMBtu/hr. By contrast, the average size of a coal-fired EGU boiler in the U.S. is greater than 2,000 MMBtu/hr.

All coal-fired EGUs in the United States are equipped with PM control devices and many have SO_2 and NOx emission controls. ICI boilers are significantly less likely to have air pollution control devices.

As part of this study, NESCAUM conducted a preliminary survey of the use of emission controls on ICI boilers in the Northeast. Survey results revealed that more than half of the units surveyed in the region had no controls; about one-third had PM controls, while very few units

had NOx controls. None of the surveyed units had SO_2 controls, although some have wet venturi scrubbers for PM control, which minimally reduce SO_2 emissions.

Technical, operational, economic and regulatory factors impose different opportunities and constraints on the applicability of air pollution control devices (APCDs) for EGU and ICI boilers. The following technical and operational characteristics must be evaluated in determining the potential applicability of emission controls for specific ICI boilers.

- Fuel type and quality SO₂, PM, and NOx emissions from coal-fired boilers are typically higher than from those burning natural gas, oil, or wood waste. Some APCD technologies are not particularly sensitive to such variations. For example, an electrostatic precipitator (ESP) or a fabric filter (FF) can accommodate different PM concentrations, although the type and size of PM and gas temperatures will have an impact. Other controls that utilize reagents, such as SO₂ scrubbers and selective catalytic reduction or selective non-catalytic reduction (SCR/SNCR) technologies for NOx, are directly affected by fuel type and quality.
- Duty cycle APCD controls must be capable of accommodating significant variation or cycling of boiler loads. These variations affect flue gas flow rates and temperatures, which in turn may require different control capability. For example, an SCR or SNCR system must operate within a temperature window that may or may not exist across the load range for a particular ICI boiler.
- Design differences The presence of equipment such as economizers or air preheaters has a direct impact on flue gas temperatures. Temperature-sensitive technologies such as ESPs, SO₂ scrubbers, and SCR/SNCR that are widely used in EGUs may or may not be applicable to ICI boilers in certain cases.

ES-4 NOx Control Technologies

Emission control strategies for NOx can be divided into two basic categories: combustion modifications and post-combustion technologies. Control efficiency ranges and cost effectiveness (\$/ton of NOx removed) for various technologies are provided in Table ES-1. Combustion modification technologies, which minimize the formation of NOx during the combustion process, include: combustion tuning; low-NOx burners and overfire air (LNBs and OFA); and gas, oil, or coal reburn.

LNBs have minimal effect on overall operating costs, but may introduce higher carbon monoxide and/or carbon levels in the fly ash, which reflect lower plant efficiency. In the case of gas reburn, operating costs are primarily a function of the fuel cost differential; for coal or oil reburn, fuel preparation costs (pulverization and atomization, respectively) represent the primary operating and maintenance costs. While gas reburn is easier to implement, the fuel differential costs are often prohibitive. The overall cost of low-NOx combustion technology installation depends on the firing system, and this is reflected in the lack of a clear relationship between capital cost and boiler capacity.

Post-combustion technologies reduce the amount of NOx exiting the stack that was formed during combustion. This group includes SNCR, SCR, and regenerative SCR (RSCR) technologies. Because the reaction occurs without the need for catalysts, SNCR systems have

lower capital costs, but achieve lower NOx reduction. SCR, on the other hand, is capitalintensive, but offers the opportunity for significantly greater NOx reductions because a dedicated reactor and a reaction-promoting catalyst ensure a highly controlled, efficient reaction. RSCR combines a regenerative thermal oxidizer with SCR technology, making it suitable for facilities with lower gas temperatures, such as those found in some ICI boilers. RSCRs can also reduce carbon monoxide emissions by half.

ES-5 SO₂ Control Technologies

SO₂ emission control technologies are post-combustion devices that utilize a process involving SO₂ reacting in the exhaust gas with a reagent (usually calcium- or sodium-based) and removal of the resulting product (a sulfate/sulfite) for disposal or commercial use. SO₂ control technologies are commonly referred to as flue gas desulfurization (FGD) and/or "scrubbers" and are usually characterized in terms of the process conditions (wet vs. dry), byproduct utilization (throwaway vs. saleable), and reagent utilization (once-through vs. regenerable). Wet scrubbers provide much greater levels of SO₂ control. Conventional dry processes include spray dryers (SDs) and dry sorbent injection (DSI). The capital costs of wet scrubbers are higher than those of dry scrubbers, although the cost effectiveness values (in dollars per ton of SO₂ removed) of wet and dry processes are similar. DSI technology has a significantly lower capital cost than wet or dry scrubbers and should therefore be more attractive for ICI boilers than conventional scrubbers.

In the eight-state NESCAUM region, residual oil is a common fuel for ICI boilers. Switching to a lower sulfur residual oil (for example, from 3 percent to 1 percent sulfur residual oil) can provide cost-effective SO_2 reductions. The cost of switching to lower sulfur distillate oil is much higher than switching to low sulfur residual oil, because the cost of distillate oil has been about twice that of residual oil in recent years. The cost effectiveness (in dollars per ton of SO_2 removed) from switching from residual fuel oil to distillate fuel oil is not as attractive and falls in the range of the cost effectiveness of installing a FGD scrubber.

ES-6 PM Control Technologies

Combustion processes emit both primary and secondary particulate matter. Primary emissions consist mostly of fly ash (e.g., non-combustible inorganic matter and unburned solid carbon). Secondary emissions are the result of condensable particles such as nitrates and sulfates that typically make up the smaller fraction of the particulate matter. PM control technologies include: fabric filters or "baghouses," wet and dry ESPs, venturi scrubbers, cyclones, and core separators. While PM controls are not currently widely used on ICI boilers, there are no technical reasons why PM controls cannot be applied to solid-fueled and oil-fired ICI boilers.

ES-7 Impact of Control Technologies on Operational Efficiency and Carbon Dioxide Emissions

Air pollution control technologies and strategies (e.g., fuel switching) can have varying impacts on the overall efficiency of the host plant. This impact can be either positive or negative depending on technology and fuel choices.

Carbon dioxide (CO₂) emissions are primarily a function of the carbon content of fuels. However, the application of conventional pollutant control technologies can affect CO_2 emissions. This impact can vary widely among technologies within the same pollutant (e.g., LNB vs. SCR for NOx), as well as across different pollutants (e.g., fabric filter for PM vs. scrubbers for SO₂).

Combustion modification technologies for NOx have essentially no impact on the CO_2 emissions of the host boilers – with the noted exception of reburn when displacing coal or oil with natural gas – because the technologies do not impose any significant parasitic energy consumption (auxiliary power) requirements. With respect to the post-combustion technologies, both SNCR and SCR impose some degree of energy demand on the host boiler. These impacts include pressure, compressor, vaporization, and steam losses, and can range from 1–2 kW/1000 actual cubic feet per minute (acfm) for SNCR and up to about 4 kW/1000 acfm for SCR.

The major components affecting energy consumption for SO_2 systems include electrical power associated with material preparation (e.g., grinding) and handling (pumps/blowers), flue gas pressure loss across the scrubber vessel, and steam requirements. The power consumption of the SO_2 control technologies is further affected by the SO_2 control efficiency of the technology itself. SO_2 controls have a range of potential parasitic losses, from duct injection representing about 1–2 kW/1000 acfm to wet FGD at as high as 8 kW/1000 acfm.

PM control technologies will result in some parasitic energy loss due to pressure loss, power consumption, and ash handling. Dry ESPs and fabric filters have the lowest associated parasitic power consumption (<2 kW/1000 acfm), while high-energy venturi scrubbers can be up to 10 kW/1000 acfm or higher.

ES-8 Cost Analysis

Cost is an important factor in evaluating the viability of air pollution control technologies. Information on capital and operating costs is more readily available for EGU than ICI boilers. Operating costs may be different for ICI boilers than utility boilers because of their size and the fact that they are typically located on smaller sites. Operating costs also include waste disposal and reagent use. ICI boiler sites typically have higher contingency, general facility, engineering, and maintenance costs, as a percentage of total capital cost, than those for utility boilers.

Cost estimates for ICI boilers with capacities ranging from 100 to 250 MMBtu/hr were generated by the CUECost model. This model, created by Raytheon Engineers for US EPA, was originally developed for large coal-fired EGUs and calculates capital and operating costs for certain pre-defined air pollution control devices for NOx, SO₂, and PM. The CUECost model produces approximate estimates (\pm 30 percent accuracy) of installed capital and annualized operating costs. The CUECost model was adapted in this study for ICI boilers burning a variety of fuels by changing the fuel composition and heating value to simulate different fuels. This study represents the first attempt to utilize a comprehensive cost model specific to ICI boilers.

Chapter Two contains a detailed discussion of the literature values for NOx control costs for ICI boilers. The NOx control costs for ICI boilers computed with CUECost were largely consistent with values reported in the literature. In terms of NOx removal, reported values were in the range of \$1,000 to \$3,000 per ton for LNBs or SNCR, and \$2,000 to \$14,000 per ton for SCR. The SCR costs for coal-fired ICI boilers appear to be consistent with the literature, although the CUECost capital cost values for residual oil were higher than the literature values. The capital costs for SNCR calculated from the CUECost models were in good agreement with literature values, particularly their sensitivity to boiler capacity. The capital costs for LNBs

calculated from CUECost for coal-fired boilers were consistent with the literature values, although the costs for residual oil-fired boilers were higher in CUECost than the literature values.

Chapter Three contains a detailed discussion of the literature values for SO_2 control costs for ICI boilers. In terms of the cost per ton of SO_2 removed, reported values were in the range of \$1,600 to \$5,000 for spray dryers (SDs) and \$1,900 to \$5,200, for wet FGDs. The SO_2 capital costs computed with CUECost for SDs were in the range of the literature values at 250 MMBtu/hr. However, the capital costs computed by CUECost for wet FGDs were high compared to values reported in the literature.

Chapter Four contains a detailed discussion of the literature values for PM control costs. Literature values for capital costs for PM control were evaluated from EPA reports on PM controls applied to industrial boilers. The cost effectiveness of ESPs was in the range of \$50 to \$500 per ton of PM for coal, and up to \$20,000 per ton of PM for oil. The cost effectiveness of baghouses was in the range of \$50 to \$1,000 per ton of PM for coal and up to \$15,000 per ton of PM for oil.

The dry-ESP control costs computed with CUECost were consistent with the literature values, although the CUECost predicted slightly higher values than reported by EPA for dry, wire-plate ESPs. The baghouse/fabric filter costs computed with CUECost were higher than the literature values for pulse-jet fabric filters.

This adaptation of CUECost model from EGUs to ICI boilers was intended to investigate the feasibility of estimating costs of controlling emissions of NOx, SO_2 , and PM from ICI boilers. Further detailed work would be needed to validate this approach, but initial results included in this report are promising.

ES-9 Conclusion

ICI boilers are a significant source of NOx, SO₂, and PM emissions, which contribute to the formation of ozone, fine particles, and regional haze, and to ecosystem acidification. These boilers are relatively uncontrolled compared to EGUs and offer the potential to achieve cost-effective reductions for all three pollutants. A host of proven emission control technologies for EGUs can be scaled-down and deployed in industrial, commercial, and institutional settings to cost-effectively reduce emissions of concern. Other technologies that have not been applied to EGUs show promise for ICI boiler applications. Careful analysis will be needed to match the appropriate emission control technology for specific applications given: boiler size, fuel type/quality, duty-cycle, and design characteristics. Further, regulators will need to determine the level of emission reductions needed from this sector in order to inform the appropriate choice of controls.

Pollutant	Technology	Control Efficiency	Cost Effectiveness \$ per ton
NOx			
Combustion Modifications	Tuning	5-15%	current data not available
	LNB	25-55%	\$750-\$7,500
	Reburn	35-60%	current data not available
Post- Combustion	SNCR	30-70%	\$1,300-\$3,700
	SCR	70-90%	\$2,200-\$14,400
	RSCR	60-75%	\$4,500
SO ₂	Wet Scrubbers	95+%	\$1,900-\$5,200
	Spray Dryers	90-95%	\$1,600-\$5,200
	Dry Sorbent Injection	40-90%	current data not available
PM			
	Fabric Filters/Baghouses	99+%	\$400-\$1,000 – coal \$6,900-\$16,500- oil
	Wet/Dry ESPs	99+%	\$160-\$2,600 – coal
			\$2,300 to \$43,000 - oil
	Venturi Scrubbers	50-90%	current data not available
	Cyclones	70-90%	current data not available
	Core Separators	60-75%	current data not available

Table ES-1. ICI Boiler Control Technologies

1 INTRODUCTION

1.1 Objectives

The main objective of this study is to evaluate various available control technologies and their cost effectiveness in reducing emissions of three pollutants: oxides of nitrogen (NOx), sulfur dioxide (SO₂), and primary fine particulate matter ($PM_{2.5}$) from industrial, commercial, and institutional (ICI) boilers. The study results should provide a strong technical and economic basis for developing cost-effective regulations and strategies to reduce emissions of these three major pollutants from ICI boilers.

1.2 Regulatory Drivers

Federal, state and local governments regulate all major criteria air pollutants under the authority of the Clean Air Act (CAA). The CAA mandates control of pollutants such as NOx, SO₂, and PM_{2.5} to attain and maintain National Ambient Air Quality Standards (NAAQSs) for ozone and PM_{2.5}, reduce acidic deposition, and improve visibility under regional haze regulations. Emission standards for specific source categories, including ICI boilers, are also set by federal, state, and local governments to attain and maintain a NAAQS. Examples of these emission standards include New Source Performance Standards (NSPS), Best Available Control Technology (BACT), Lowest Achievable Emission Rate (LAER), Reasonably Available Control Technology (RACT), and Best Available Retrofit Technology (BART).

States must formulate State Implementation Plans (SIPs) that provide a framework for limiting air emissions from major sources as part of a strategy for demonstrating attainment and maintenance of NAAQS. Some individual SIPs (if allowed by the state law) may set more stringent limits on emissions of NOx, SO₂, and PM_{2.5} than required by the federal rules. However, states cannot set less stringent limits than required by federal rules and regulations. Generally, federal, state, and local permitting authorities rely upon available information on the latest advanced technologies for emission control when setting emission limits. Where applicable, permitting authorities require BACT and RACT in order to reduce air emissions from stationary sources. In areas that have not achieved a NAAQS (i.e., non-attainment areas), the CAA requires air pollution limits established by LAER for new major stationary sources and major modifications to existing stationary sources. BACT and RACT analyses consider the cost of controls. LAER control technologies, applicable to new major sources located in non-attainment areas, must be installed, operated and maintained without consideration of costs.

1.3 Characterization of Combustion Sources

1.3.1 Description of Combustion Sources

Boilers utilize the combustion of fuel to produce steam. The hot steam is then employed for space and water heating purposes or for power generation via steam-powered turbines.

Boiler size is typically represented in four ways: fuel input in units of MMBtu/hr, output of steam in lb steam/hr at a specified temperature and pressure, boiler horsepower (1 boiler hp = 33,475 MMBtu/hr), or electrical output in MWhr or MW (if electricity is generated).

The three main types of boilers are described below:

- *Firetube boilers*. Hot gases produced by the combustion of fuel are used to heat water. The hot gases are contained within metal tubes that run through a water bath. Heat transfer through thermal conduction heats the water bath and produces steam. Typically, firetube boilers are small, with capacity below 100 MMBtu/hr.
- *Watertube boilers*. Hot gases produced by fuel combustion heat the metal tubes containing water. Typically, there are several tubes configured as a "wall." Watertube boilers vary in size from less than 10 MMBtu/hr to10,000 MMBtu/hr.
- *Fuel-firing*. Fuel is fed into a furnace and the high gas temperatures generated are used to heat water. Fuel-firing boilers include stoker, cyclone, pulverized coal, and fluidized beds. Stokers burn solid fuel and generate heat either as flame or as hot gas. Pulverized coal (PC) enters the burner as fine particles. The combustion in the furnace produces hot gases. The ash (the unburned fraction) exits in molten or solid form. Fluidized beds utilize an inert material to "suspend" the fuel. The suspension allows for better mixing of the fuel and subsequently better combustion and heat transfer to tubes.

Boilers are also classified by the fuel they use – chiefly coal, oil, natural gas, wood, and waste byproducts.

1.3.2 Emissions by Size, Fuel, and Industry Sector

In 2005, Energy & Environmental Analysis, Inc. [EEA, 2005] estimated that there were 162,805 industrial and commercial boilers in the U.S., which had a total fuel input capacity of 2.7 million MMBtu/hr as summarized in Figure 1-1 and Table 1-1. This estimate included 43,015 industrial boilers with a total capacity of 1.6 million MMBtu/hr and 119,790 commercial boilers with a total capacity of 1.1 million MMBtu/hr. In addition, EEA estimated that there were approximately 16,000 industrial boilers in the non-manufacturing sector with a total capacity of 260,000 MMBtu/hr, but details on size distribution of these boilers were not provided because these units were not well characterized.

The EEA report divided boilers into two major categories (industrial and commercial) instead of the more common characterization as industrial, commercial, and institutional boilers. One segment of the ICI boiler population, identified as non-manufacturing industrial boilers, is not included in the EEA analyses due to a lack of sufficient data. The non-manufacturing segment accounted for only 11 percent of energy consumption in the industrial boiler population. The manufacturing and non-manufacturing segment of the population appear (from EEA's description) to correspond to what would be called industrial boilers. The commercial segment of the population includes what are designated in this report as commercial and institutional boilers. For example, there are several large boilers located at major institutions such as universities (e.g., Notre Dame, Cornell, etc.) and also several large boilers located at major hospitals (e.g., Massachusetts General Hospital) that belong in the institutional category instead

of the commercial sector. Thus, EEA's analysis appears to apply to most of the ICI boiler population, representing 89 percent of energy use by ICI boilers.

Industrial boilers were generally larger than commercial units. Sixty percent of the boilers in the manufacturing sector were greater than 100 MMBtu/hr in capacity, whereas 60 percent of the boilers in the commercial sector were in the range of 10 to 100 MMBtu/hr. The average capacity of the commercial boilers was 10 MMBtu/hr, with most less than 10 MMBtu/hr; the capacity of the average industrial boiler was 36 MMBtu/hr. Non-manufacturing boilers fell in between, at an average capacity of 16 MMBtu/hr. For industrial boilers, the average capacity factor was 47 percent (capacity factor is defined as the ratio of actual heat input in MMBtu to the maximum heat input based on nameplate capacity of the unit, calculated for a period of one year).

	Manufacturing	Non-Mfg	Commercial	
Unit Capacity	Boilers	Boilers*	Boilers	Total
<10 MMBtu/hr	102,306		301,202	403,508
10-50 MMBtu/hr	277,810		463,685	741,495
50-100 MMBtu/hr	243,128		208,980	452,108
100-250 MMBtu/hr	327,327		140,110	467,437
>250 MMBtu/hr	616,209		33,639	649,848
Total Capacity, MMBtu/hr	1,566,780	260,000	1,147,617	2,714,397
Total Capacity >10 MMBtu/hr	1,464,474		846,415	2,310,889**
Total number of units	43,015	16,000	119,790	162,805
Average Capacity, MMBtu/hr	36	16	10	17

Table 1-1.	Capacity o	f industrial	boilers	[EEA, 2	2005]
------------	------------	--------------	---------	---------	-------

*No details provided on range of capacities

**Total does not include non-manufacturing boilers



Figure 1-1. Total capacity of industrial boilers as a function of size [EEA, 2005]

1-3 Appendix III.D.7.7-4231 Five major steam-intensive industries accounted for more than 70 percent of the boiler units and more than 80 percent of the boiler capacity of the manufacturing segment of industrial boilers: food, paper, chemicals, petroleum refining, and primary metals. The non-manufacturing segment of the industrial sector included agriculture, mining and construction. The largest categories in the commercial sector, by capacity, were schools, hospitals, lodgings, and office buildings.

Industrial boilers in the manufacturing sector are used to generate process steam and electricity. The fuels used in manufacturing boilers are related to the size of the boilers and, in some cases, the byproducts generated in the particular manufacturing process.

In the food production subsector, the average boiler capacity was 20 MMBtu/hr. The relatively small average capacity was reflected in the higher percentage (58 percent) of natural gas-fired boilers in the food industry than in any other major subsector, since very small boilers tend to burn natural gas.

The paper industry included some of the largest industrial boilers, with an average boiler size of 109 MMBtu/hr. The paper industry represented more than half (230,000 MMBtu/hr) of the total capacity of the manufacturing sector. More than 60 percent of the fuel used in paper industry boilers was wood (bark, wood chips, etc.) or black liquor, a waste product from the chemical pulping process.

The chemical industry employed both large and small boilers, with about seven percent of the units with capacities smaller than 10 MMBtu/hr, and a significant number (about 350 or 37 percent of total capacity) larger than 250 MMBtu/hr. The primary fuels for chemical industry boilers were natural gas (43 percent), process off-gas (39 percent), and coke (15 percent).

The refining industry had an average boiler size of 143 MMBtu/hr, the largest of any of the major industries, with over 200 boilers with capacities above 250 MMBtu/hr. By-product fuels (refinery gas or carbon monoxide) were the most common fuel source for boilers (58 percent), followed by natural gas (29 percent) and residual oil (11 percent).

About half of the total boiler capacity in the primary metals industry was from boilers larger than 100 MMBtu/hr. By-product fuels, like coke oven gas and blast furnace gas, provided the largest share (63 percent) of boiler fuel in the primary metals industry.

The remaining industries accounted for about 29 percent of manufacturing boilers (12,000 units) or about 18 percent of industrial boiler capacity. The average capacity for the rest of the manufacturing subsector was 23 MMBtu/hr. Approximately 100 boilers at other manufacturing facilities had capacities larger than 250 MMBtu/hr.

Unlike industrial boilers, which serve production processes, commercial boilers provide space heating and hot water for buildings. Natural gas fired the vast majority of commercial boilers, including 85 percent of commercial boiler units and 87 percent of the total commercial boiler capacity. About 10 percent of the commercial boilers were fired by oil. Coal was fired at about one percent of the commercial boilers, but represented five percent of the capacity, reflecting the larger size of commercial coal-fired boilers.

Figure 1-2 summarizes the total US boiler capacity in the manufacturing and commercial sectors as a function of fuel fired (left side of figure) and shows the average capacity per boiler (right side of figure) by fuel type. Coal-fired boilers were the largest in size on average. As discussed above, natural gas accounted for 70 percent of the total industrial boiler capacity in the

EEA survey. Coal and byproduct fuels accounted for about 10 percent each, with lesser capacity in oil- and wood-fired boilers.

In the manufacturing sector, the average coal-fired boiler capacity was about 180 MMBtu/hr, but the average capacity in both sectors combined was about 125 MMBtu/hr. Wood- and byproduct-fired boilers in the manufacturing sector were also large on average (120 and 110 MMBtu/hr, respectively). On the other hand, oil- and natural gas-fired boilers were small, on the order of 20 MMBtu/hr in the manufacturing sector and less than 10 MMBtu/hr in the commercial sector.





From EEA's 2005 study, the following general conclusions about boiler size for the entire U.S. ICI boiler population can be drawn:

- natural gas is the fuel fired at most ICI boilers;
- natural gas- and oil-fired boilers tend to be small, less than 20 MMBtu/hr in capacity;
- boilers fired with coal, wood, or process byproducts are larger in size, greater than 100 MMBtu/hr on average;
- although natural gas fired most of the ICI boilers in the U.S., coal, oil, and wood contribute substantially more to the emissions of SO₂ and PM; and
- all fuels are sources of NOx emissions.

One needs to be careful drawing conclusions for the eight-state NESCAUM region based on the national data in the EEA 2005 study because there are large region-to-region and state-tostate differences in boiler populations. For example, fuel oil is an important fuel in the Northeast, especially in rural areas where natural gas may not be available, while natural gas is predominant in other areas of the country. A preliminary assessment of emissions from ICI boilers by pollutant in the U.S. and in the eight-state NESCAUM region was carried out using data from the AirData database via the EPA website (www.epa.gov/air/data). In this database, stationary sources, such as electric generating plants and factories, are identified individually by name and location. Figure 1-3 compares the annual emission of NOx, SO₂, and PM_{2.5} in the U.S. with the eight-state NESCAUM region for 2002. Emissions in the NESCAUM region are about 5 percent of the US total emissions.



Figure 1-3 Total annual emissions of NOx, SO₂, and PM_{2.5} from ICI boilers in the U.S. and in the eight-state region from EPA AirData database

Another set of data from the eight-state region was extracted from the MANEVU 2002 non-road inventory (<u>www.manevu.org</u>). In this data set, oil-fired boilers were divided into distillate oil and residual oil-fired boilers (Figure 1-4).

NOx emissions in the eight-state NESCAUM region are mostly from oil- and gas-fired boilers. Because these are generally small boilers, combustion controls are good candidates for NOx control. For larger, coal- or wood-fired boilers, SNCR or SCR might also be applicable.

PM emissions are relatively low from coal-fired sources in the eight-state region, which suggests that most of the coal-fired sources already have particulate control devices. Oil- and wood-fired units have higher PM emissions, and PM emissions attributed to natural gas are quite small.

As might be expected, most of the SO_2 emissions from oil-fired boilers come from residual oil-fired boilers because of residual oil's higher sulfur content.



Figure 1-4. Emissions of NOx, SO₂, and PM_{2.5} from ICI boilers in the NESCAUM region from MANEVU database as a function of fuel fired

1.3.3 Differences between EGU and ICI boilers

EGU boilers produce steam in order to generate power. While ICI boilers do in some cases generate steam for electricity production, ICI boilers differ from EGUs in size, steam application, design, and emissions. Most commercial and institutional boilers are small, with an average capacity of 17 MMBtu/hour (Table 1-1). Industrial boilers can be as large as 1,000 MMBtu/hr or as small as 0.5 MMBtu/hr. The average size of a coal-fired EGU boiler in the U.S. is over 200 MW or over 2,000 MMBtu/hr.

All coal-fired EGUs in the United States use control devices to reduce PM emissions. Additionally, many of the EGU boilers are required to use controls for SO_2 and NOx emissions, depending on site-specific factors such as the properties of the fuel burned, when the power plant was built, and the area where the power plant is located.

According to 1999 EPA Information Collection Request (ICR) responses from coal-fired EGUs, 77.4 percent of EGUs had PM post-combustion control only, 18.6 percent had both PM and SO₂ controls, 2.5 percent had PM and NOx controls, and 1.3 percent had all three post-combustion control devices [Kilgroe *et al.*, 2001]. Information from 2004 indicated that the fractions of total capacity of large coal-fired EGUs that have flue gas desulfurization (FGD) to control SO₂ and selective catalytic reduction (SCR) to reduce NOx controls were 38 percent and 37 percent, respectively [NESCAUM, 2005]. Since the 1999 ICR survey, additional NOx and SO₂ controls have been added at a rapid pace to coal-fired EGUs. It is presently not clear how

the implementation of NOx and SO_2 control technologies for EGUs would evolve as a consequence of the recent vacatur of Clean Air Interstate Rule (CAIR) by the U.S. D.C. Circuit.

In contrast to EGUs, ICI boilers are substantially less likely to have air pollution control devices. A study of industrial boilers and process heaters [USEPA, 2004] that looked at 22,117 industrial boilers and process heaters, which burned natural gas, distillate oil, residual oil, and coal, found that 88 percent had no air pollution control equipment.

A preliminary survey was undertaken as part of this study to evaluate the extent to which various emission controls were currently being applied to ICI boilers in the Northeast. These data were acquired from State Title V permits for solid-fueled (coal and wood) boilers as well as additional information from state personnel. The survey collected data in four states: Massachusetts, Vermont, New Hampshire, and New York. The data set was composed of 64 boilers – 47 wood-fired and 17 coal-fired. *Figure 1-5* illustrates the distribution of boiler capacity (by size) and the air pollution control devices (APCDs) in this data set. The full data set is summarized in Appendix A. As can be seen in *Figure 1-5(b)*, more than half of the units had no controls, about one-third had controls only for PM, and very few units had controls for NOx. There were no units with SO₂ controls, although some of the PM controls were wet venturi scrubbers, which might have a limited impact on SO₂ emissions.





There are several factors that directly or indirectly affect the reasons for the discrepancy in APCD deployment between EGU and ICI boilers. Technical and operational as well as business, economic, and regulatory factors impose different constraints and provide different opportunities for the applicability of APCDs for these two categories of boilers. The following discussion summarizes some of the important technical and operational issues.

Large, base-loaded EGUs operate mainly near maximum capacity or steam production. Industrial boilers typically do not run at maximum capacity, although this varies from one industry to another [EEA, 2005]. EGUs produce steam for electricity generation, while ICIs may produce steam for a variety of applications. The type of manufacturing is often more important in determining boiler operation, or duty cycle (load vs. time) than manufacturing demand in general.

ICI boilers generate steam for processing operations for paper, chemical, refinery, and primary metals industries. Commercial boilers produce steam for a variety of processes, while institutional boilers are normally used to produce steam and hot water for space heating in office buildings, hotels, apartment buildings, hospitals, universities, and similar facilities.

Another difference between EGU and ICI boilers is fuel diversity. EGU boilers are mostly single-fuel (coal, No. 6 oil, natural gas), while ICI boilers tend to be designed for and use a more diverse mix of fuels (e.g., fuel by-products, waste, wood) in addition to the three conventional fuels above.

These differences in operational and fuel usage not only affect a boiler's duty cycle, but its design, which is equally important from the perspective of APCD applicability. Examples that directly affect APCD choice and applicability include equipment such as economizers or air preheaters, which affect the temperature of the flue gas at the stack. The differentiation in fuel usage also leads to different design parameters for emissions controls. For example, the iron and steel industry generates blast furnace gas or coke-oven gas, which is used in boilers, resulting in sulfur emissions. Pulp and paper boilers may use wood waste as a fuel, resulting in high PM emissions. Units with short duty cycles may utilize oil or natural gas as a fuel. The use of a wide variety of fuels is an important characteristic of the ICI boiler category.

These factors relate directly to APCD equipment choices and applicability. The following examples should help explain some of these impacts.

- Fuel quality different fuels have different emission characteristics. SO₂, PM, and NOx emissions from coal fired boilers are different from those burning natural gas, oil, or wood waste. Some APCD technologies are not very sensitive to fuel quality variations (e.g., an electrostatic precipitator (ESP) may accommodate different levels of PM concentration, although the type and size of particles and gas temperatures will have an impact). However, others can be directly affected by changes in fuel quality and the resulting changes in pollutant concentrations in the flue gas to be treated (e.g., SO₂ and NOx controls that utilize reagents such as scrubbers for SO₂ and SCR/SNCR for NOx).
- Duty cycle significant variation or cycling of boiler load requires APCD controls capable of accommodating such variations. These variations affect flue gas flow rates and temperatures, which in turn may require different control capability. For example, an SCR or SNCR system must operate within a temperature window that may or may not exist across the load range for a particular ICI boiler.
- Design differences the use of equipment such as economizers or air preheaters has direct impact on the resulting flue gas temperature. Temperature-sensitive technologies such as ESPs, SO₂ scrubbers (wet and dry), and SCR /SNCR that are widely used in EGUs may or may not be applicable for some ICI boilers in such cases.

1.3.4 Control Technology Overview

A variety of emission control technologies are employed to reduce emissions of NOx, SO₂, and primary PM emissions. Technical details of control technologies for NOx, SO₂, and PM are discussed in Chapters Two, Three, and Four, respectively. Pollutant emission controls are generally divided into three major types given in the following list.

- *Pre-combustion Controls*. Control measures in which fuel substitutions are made or fuel pre-processing is performed to reduce pollutant formation in the combustion unit.
- *Combustion Controls.* Control measures in which operating and equipment modifications are made to reduce the amount of pollutants formed during the combustion process; or in which a material is introduced into the combustion unit along with the fuel to capture the pollutants formed before the combustion gases exit the unit.
- *Post-combustion Controls*: Control measures in which one or more air pollution control devices are used at a point downstream of the furnace combustion zone to remove the pollutants from the post-combustion gases.

Data on costs of pollution control equipment taken from the literature are reviewed in the individual technology chapters. In Chapter Five, an existing model for the estimation of air pollution control equipment costs for coal-fired EGUs (CUECost) is applied to ICI boilers burning different fuels (coal, oil, wood) with appropriate caveats and assumptions to provide reasonable and approximate control costs for ICI boilers.

1.4 Chapter 1 References

Energy & Environmental Analysis, Inc. (EEA). *Characterization of the U.S. Industrial Commercial Boiler Population*. May 2005.

Kilgroe, J.D. et al. Control of Mercury Emissions from Coal-Fired Electric Utility Boilers: Interim Report, EPA-600/R-01-109, December 2001.

MACTEC. Assessing Reasonable Progress for Regional Haze in the Mid-Atlantic North Eastern Class I Area - Revised Final Draft; MACTEC Federal Programs: Research Triangle Park, NC, March 8, 2007.

NESCAUM. Assessment of Control Technology Options for BART-Eligible Sources; 2005.

Ozone Transport Commission (OTC). *Identification and Evaluation of Candidate Control Measures – Technical Support Document*. February 28, 2007.

Sabo, E.; Toothman, D. *Identification and Evaluation of Candidate Control Measures Final Technical Support Document*; MACTEC Federal Programs, Inc.: Herndon, VA, February 28, 2007.

Sliwinski, R. "ICI Boiler Control Recommendations," Ozone Transport Commission Fall Meeting, November 15, 2006.

State and Territorial Air Pollution Program Administrators/Association of Local Air Pollution Control Officials (STAPPA/ALAPCO), now known as National Association of Clean Air

Agencies (NACAA). Controlling Fine Particulate Matter under the Clean Air Act: A Menu of Options, March 2006.

US EPA. Alternative Control Techniques Document--NO Emissions from Industrial/Commercial/Institutional (ICI) Boilers; EPA-453/R-94-022; 1994.

US EPA. Regulatory Impact Analysis for the Industrial Boilers and Process Heaters NESHAP, EPA EPA-452/R-04-002, February, 2004.

2 NOx CONTROL TECHNOLOGIES

2.1 Introduction

This brief introduction applies to chapters Two, Three, and Four, which discuss control technology options for ICI boilers for NOx, SO₂, and PM, respectively. However, these chapters are not intended to provide detailed descriptions of the many available technologies for each pollutant. Significant literature is available for that purpose; in the context of this report, these chapters are intended to provide the reader with a general understanding of concepts, performance, applicability, and costs of the main technologies available. Further, in recognition of the concern with climate change, a brief discussion of energy consumption (parasitic power) associated with major technologies is included.

Specifically with respect to the deployment and applicability of air pollution controls, comparisons between ICI boilers and EGUs are relevant because of the more widespread application of pollution control equipment in the EGU sector. This was discussed in some detail in Chapter One. In addition, a few considerations specific to certain technologies and strategies are discussed, as appropriate.

2.1.1 ICI versus EGU Boilers

In general, the greater proliferation of air pollution control technologies in the EGU sector, as opposed to the industrial sector, seems to be driven by three dominant, differentiating factors.

- Size difference and associated emissions between the two: Because EGUs are much larger than ICI boilers, they have been targeted for environmental regulatory controls more heavily over the years.
- Technology costs: While not universally true, ICI boilers often have constraints due to their smaller sizes, diversity of plant layouts, and urban settings, all of which can have a negative impact on the costs of applying some of the control technologies. Conversely, and equally important, opportunities for lower-cost applications to ICI boilers do exist as a result of the smaller sizes, such as in the ability to have systems pre-fabricated and ready to erect onsite, as opposed to on-site construction requirements often needed with larger systems for EGUs.
- Cost recovery: The two sectors are significantly different from a fundamental business view, with EGUs being regulated entities, as opposed to openly competitive markets that exist within the ICI boiler population. This is important in that it affects how business decisions are made in the two sectors, how capital equipment purchases are funded, and also how ICI plants are designed and operated.

2.1.2 Control Technologies' Impact on Efficiency and CO₂ Emissions

Air pollution control technologies and strategies can have varying impacts on the overall efficiency of the host plant. This impact can be either positive or negative and it is a function of the type of technology, as well as fuel choices.

An extreme example of this is the control of SO_2 from a coal-fired unit by two significantly different approaches: in one case, the use of an energy–intensive FGD "scrubber" penalizes the efficiency of such unit by up to 2 percent, resulting in a corresponding increase in CO_2 emissions; a very different and contrasting case, in which the unit chooses to reduce its SO_2 generation by switching from coal to natural gas, yields a corresponding and substantial decrease in its CO_2 emissions. Similarly, an efficient Low-NOx Burner (LNB) may replace an older burner and increase unit efficiency, while reducing NOx emissions, whereas a SNCR or SCR also reduces NOx, but will have some inherent parasitic power requirement that will have a negative impact on overall efficiency (and emissions of CO_2).

These chapters primarily address control technology options, as opposed to fuel switching strategies, except for SO₂. Switching from high-sulfur oil to low-sulfur oil is also discussed in Chapter 3. CO_2 impacts are well established as a function of the carbon content of fuels. The same applies in the case of renewable, carbon-based fuels (biomass). However, with control technologies, the impacts can vary widely among technologies for the same pollutant (e.g., LNB vs. SCR for NOx), as well as across different pollutants (e.g., fabric filter for PM vs. wet and dry scrubbers for SO₂).

In general, efficiency impacts from application of air pollution control technologies can be divided into two major general areas:

- Direct impact (positive or negative) on the combustion process itself (e.g., changes in concentrations of O₂ or CO and in the amount of unburned carbon (UBC) in ash)
- Parasitic power associated with the particular technology or its components (e.g., increased gas pressure loss, power requirements for pumps/fans)

This parasitic power is given here in terms of electric power (kW) per flue gas flow rate (acfm) or kW/1000 acfm. These units are appropriate for several reasons:

- Most ICI boilers do not produce electricity, hence, size is more universally characterized by a parameter other than electrical generation (e.g., flow rate);
- Most control technology suppliers rank their equipment size in terms of gas flow rate as this is the dominant parameter for gas handling equipment sizing;
- If the objective is to "correlate" this parasitic power loss to an equivalent CO₂ impact, it can be done simply by knowing the size (acfm) of the technology application and the CO₂ emission profile of the equivalent kW generation (or savings) to offset the parasitic power loss.

2.2 Discussion of NOx Control Technologies

2.2.1 NOx Formation

The formation of NOx is a byproduct of the combustion of fossil fuels. Nitrogen contained in fuels such as coal and oil, as well as the harmless nitrogen in the air, will react with oxygen during combustion to form NOx. The degree to which this formation evolves depends on many factors including both the combustion process itself and the properties of the particular fuel being burned. This is why similar boilers firing different fuels or similar fuels burned in different boilers can yield different NOx emissions.

2.2.2 NOx Reduction

As a result of complex interactions in the formation of NOx, a variety of approaches to minimize or reduce its emissions into the atmosphere have been and continue to be developed. A relatively simple way of understanding the many technologies available for NOx emission control is to divide them into two major categories: (1) those that minimize the formation of NOx itself during the combustion process (e.g., smaller quantities of NOx are formed); and (2) those that reduce the amount of NOx after it is formed during combustion, but prior to exiting the stack into the atmosphere. It is common to refer to the first approach under the "umbrella" of combustion modifications whereas technologies in the second category are termed post-combustion controls. Within each of these two categories, several technologies and variations of the same technology exist. Finally, combinations of some of these technologies are not only possible, but also often desirable as they may produce more effective NOx control than the application of a stand-alone technology.

2.2.3 Other Benefits of NOx Control Technologies

Some NOx control technologies have shown the potential to promote the capture of mercury (Hg) from the flue gas. Examples include combustion modification technologies (e.g., Low-NOx Burners and Overfire Air – though potentially with higher levels of unburned carbon) and post-combustion technologies (SCR – through the oxidation of mercury, making it more soluble and amenable to capture in a downstream process such as a scrubber for SO₂). This suggests that strategic and economic analyses for NOx controls need to also consider the potential impacts on mercury removal.

2.3 Summary of NOx Control Technologies

2.3.1 Combustion Modifications

Combustion modifications can vary from simple "tuning" or optimization efforts to the deployment of dedicated technologies such as LNBs, Overfire Air (OFA) or reburn (most often done with natural gas and called Gas Reburn - GR).

Boiler Tuning or Optimization

Combustion optimization efforts can lead to reductions in NOx emissions of 5 to 15 percent or even higher in cases where a unit was originally badly "de-tuned." It is important to remember that optimization results are truly a function of the "pre-optimization" condition of the power plant or unit (just as the improvement in an automobile from a tune-up depends on how badly it was running prior to it), and as such have limited opportunity for substantial emission reductions.

Development of "intelligent controls" – software-based systems that "learn" to operate a unit and then maintain its performance during normal operation, can also go a long way towards keeping plants well tuned, as they gain acceptance and become common features in combustion control systems.

2.3.2 Low-NOx Burners and Overfire Air

LNBs and OFA represent practical approaches to minimizing the formation of NOx during combustion. Simply, this is accomplished by controlling the quantities and the way in which fuel and air are introduced and mixed in the boiler (usually referred to as "fuel or air staging").



Figure 2-1. Low-NOx burner [TODD Dynaswirl-LNTM]

Figure 2-1 shows a gas/oil Low-NOx burner. These technologies are prevalent in the electric power industry as well as in ICI boilers at present and increasingly used by ICIs, even at small sizes (less than 10 MMBtu/hr). Competing manufacturers have proprietary designs, geared towards application for different fuels and boiler types, as well as reflecting their own design philosophies. LNBs and OFA, which can be used separately or as a system, are capable of NOx reductions of 30 to 65 percent from uncontrolled baseline levels. Again, the type of boiler and the type of fuel will influence the actual emission reduction achieved.

Particularly for gas-fired applications, as in the majority of ICI boilers, advanced Low-NOx Burners, often referred to as ultra Low-NOx Burners (ULNBs), are commercially offered by several companies. Ultra Low-NOx Burners are capable of achieving NOx emission levels on the order of single digits in ppm. As with all technologies, "pushing the envelope" on emission levels requires increasingly more careful suitability analyses as well as a good understanding of operational constraints. Conversely, the advent of these very low-emission burners (less than 10 ppm NOx), allows units to achieve very low emission rates at costs well below post-combustion alternatives like SCR.

All combustion modification approaches face a common challenge of striking a balance between NOx reduction and decrease in fuel efficiency. The concern is exemplified by typically higher CO and/or carbon levels in the fly ash, which reflect lower efficiency and also the contamination of the fly ash itself, possibly making it unsuitable for reutilization such as in concrete manufacturing. This is a bigger concern for large EGUs than for ICI boilers due to the much larger quantities of ash produced and the associated costs of disposal.

LNBs/OFA have little or no impact on operating costs (other than by the potential for the above-mentioned efficiency loss). Low-NOx Burners are applicable to most ICI boiler types, excluding stoker types and Fluidized Bed Combustion units (FBCs).

2.3.3 Reburn

Reburn, while generically included in the "Combustion Modification" category, is different from the other technologies in this group (LNBs/OFA) in that it "destroys" (or chemically reduces) NOx shortly after it is formed rather than minimizing its formation as discussed previously. From a practical standpoint, this is accomplished by introducing the reburn fuel (theoretically any fossil fuel can be used, however, natural gas is the most common) into the boiler above the main burner region. A portion of the heat input from the primary fuel is replaced by the reburn fuel. Subsequently, this "fuel-rich" environment reacts with and destroys the NOx formed in the main burners. This technology has been implemented in the U.S. and overseas, and while not as popular as LNB/OFA, it is commercial at this time. Owing to stricter compatibility criteria, reburn is not as universal as LNB/OFA in its applicability to the overall boiler population. *Figure 2-2* shows a typical reburn system applied to a stoker boiler.



Figure 2-2. Gas reburn applied to a stoker boiler [www.gastechnology.org]

Specific criteria such as boiler size, availability of natural gas, type and quality of the main fuel, are all important in determining the suitability of a unit for this technology. One important feature of reburn is its compatibility with a particular type of boiler – "Cyclone," – for which the previously mentioned technologies are not particularly well suited. However, this technology has been used only in large EGUs and is not a typical option for ICI boilers. Cyclone boilers are inherently high NOx emitters and are not an attractive option for new or retrofit units with increasingly lower NOx emission limits requirements.

Reburn performance has been shown to range from 30 to 60 percent reduction in NOx emissions, depending on such factors as reburn fuel type and quantity, initial NOx levels, boiler design, etc. Similar to the other combustion modification options, reburn can affect efficiency and fly-ash quality. As such, it requires the same optimum balance between NOx reduction and avoidance of negative impacts. On the other hand, reburn can be thought of as a "dial-in" NOx technology in that NOx reductions are, to a degree, a function of the amount of reburn fuel.

Operating costs are primarily driven by the fuel cost differential in the case of gas reburn, while for coal or oil reburn fuel preparation costs (pulverization and atomization, respectively) represent the dominating O&M costs. Reburn using coal or oil as the reburn fuel does not seem like a very attractive option for ICI boilers for technical reasons (boiler size, residence times), as well as the wider availability of similar performance options simpler to implement, such as LNBs. Gas reburn, while easier to implement, often has a prohibitive operating cost if, for example, natural gas is partially substituted for a less expensive primary fuel. Reburn is therefore an option for larger watertube-type boilers, including stokers, but require appropriate technical and economic analyses to determine suitability. Gas reburn has an impact on CO_2 emissions that is proportional to the type and quantity of fuels displaced (gas vs. coal or oil).

2.3.4 Post-Combustion Controls

Conventional, commercial post-combustion NOx controls include Selective Non-Catalytic Reduction (SNCR) and Selective Catalytic Reduction (SCR). They are fundamentally similar, in that they use an ammonia-containing reagent to react with the NOx produced in the boiler to convert the NOx to harmless nitrogen and water. SNCR accomplishes this at higher temperatures (1700°F-2000°F) in the upper furnace region of the boiler, while SCR operates at lower temperatures (about 700°F) and hence, needs a catalyst to produce the desired reaction between ammonia and NOx. As noted below, SCR technology is capable of achieving much larger reductions in NOx emissions, higher than 90 percent, compared to the 30 to 60 percent reductions achievable by SNCR. *Figure 2-3* and *Figure 2-4* depict views of these two systems.



Figure 2-3. SNCR system schematic [FuelTech]



Figure 2-4. 3-D schematic of an SCR system [Alstom Power]

While the difference between the SNCR and SCR may seem minor, it yields significant differences in performance and costs. In the case of SNCR, the reaction occurs in a somewhat uncontrolled fashion (e.g., the existing upper furnace becomes the reaction vessel, which is not what it was originally designed to be), while in the SCR case, a dedicated reactor and the reaction-promoting catalyst ensure a highly controlled, efficient reaction. In practice, this means that SNCR has lower capital costs (no need for a reactor/catalyst); higher operating costs (lower efficiency means that more reagent is needed to accomplish a given reduction in NOx); and finally, has lower NOx reduction capability (typically 30 to 50 percent, with some units achieving reductions in the 60 percent range). SCR, on the other hand, is capital intensive, but offers lower reagent costs and the opportunity for very high NOx reductions (90 percent or higher).

Costs are driven primarily by the consumption of the chemical reagent – usually (but not necessarily) urea for SNCR and ammonia for SCR, which in turn is dependent upon the efficiency of the process (usually referred to in terms of reagent utilization) as well as the initial NOx level and the desired percent reduction. It is also important to consider possible contamination of fly ash (in the case of coal firing) by ammonia making it potentially unable to be sold. This is, again, a bigger issue for larger EGU plants than for ICI boilers due to the size and quantities involved; as already stated, ICIs burning solid fuel do not typically sell their fly ash.

2.3.4.1 RSCR

Commonly, EGU boilers utilize SCR systems to reduce NOx emissions. However, a conventional SCR may not be cost-effective to retrofit into smaller units like ICI boilers because of the extensive modifications required to accommodate the unit. For some applications, the SCR may be located downstream of the particulate control equipment, where the flue gas temperature is much lower than the range of 650-750°F required for a conventional SCR (Toupin, 2007). These conditions are encountered in some ICI boilers firing a variety of fuels, including biomass.

If it is necessary to compensate for the reduction of flue gas temperatures, a regenerative selective catalytic reduction ($RSCR^{TM}$) system allows the efficient use of an SCR downstream of a particulate control device. The primary application of an RSCR system is the reduction of NOx emissions where the flue gas is typically at 300-400°F (Toupin, 2007). *Figure 2-5* illustrates the schematic and the actual RSCR system. *Figure 2-6* shows a block of ceramic heat exchanger.



Figure 2-5. Schematic and actual RSCR [Toupin, 2007]

A direct-contact regenerative heater technology (i.e., burner), coupled with cycling beds of ceramic heat exchangers, is used to transfer heat to the flue gas. Additionally, some oxidation of CO to CO_2 in the flue gas occurs. The NOx reduction portion of the RSCR takes place on a conventional SCR catalyst. Either anhydrous or aqueous ammonia can be used.

Figure 2-5 (left side) shows the working principles of the RSCR. Essentially, the flue gas in the space between the two canisters (called the retention chamber) is heated by the burner to make up for heat loss through the walls of the canisters and inefficiency in the ceramic heat transfer modules. This raises the temperature in the retention chamber by about 10-15°F. The gas flows into the second canister, through the catalyst, and passes through the second ceramic module, which absorbs heat from the hot flue gas. Once this cycle is completed, the flow reverses, so that the second canister (which was just heated) becomes the inlet canister and the first canister becomes the outlet canister. The cycling between canisters accomplishes a similar function to the continuously rotating heating elements of a conventional regenerative air/gas heater.

Other components of the RSCR include the ductwork, fans, and the ammonia delivery system. Ductwork must be adequately sized to provide sufficient distance for ammonia mixing

and to minimize pressure drop. For the ceramic heat exchanger, factors that need to be taken into consideration during the design process are gas-side pressure drop, thermal efficiency, and cost. A large bed face area reduces the pressure drop and operating cost but increases capital cost. The ammonia delivery system consists of ammonia pumps, storage tanks, interconnecting piping, and a control system. The pump typically does not exceed one horsepower and often a redundant pump is provided to assure continuity in system operation [Toupin, 2007].



Figure 2-6. Block of monolith ceramic heat exchanger [Toupin, 2007]

The RSCR combines a regenerative thermal oxidizer (RTO) (e.g., retention chamber burner) with SCR technology. This ability to control flue gas temperatures allows for high NOx reduction under varying temperature conditions. *Table 2-1* shows the expected reduction in NOx and CO emissions [BPEI, 2006]. This study indicated that the RSCR is able to reduce NOx by 60 to 75 percent and CO by about 50 percent.

	Typical Stoker Design	CO and NOx Reductions from Baseline
Steam Flow lbs/hr x 10 ³	100 - 500	
Steam Press, psi	600 - 900	
Steam Temp., °F	955 - 1000	
Unburned Combustibles Boiler	1.0 - 1.5	
Efficiency Loss (%)		
Furnace Retention sec. ⁽¹⁾	3.0	
Grate Heat Release Btu/hr-ft	850,000 maximum	
Emissions:		
CO lbs/10 ⁶ Btu @ 3.0% O ₂ (ppm)	0.10 - 0.30	Base
	(122 – 370)	
CO w/RSCR lbs/ 10^6 Btu @ 3.0% O ₂	0.05 - 0.15	(-50%)
(ppm)	(61 - 185)	
NOx lbs/10 ⁶ Btu @ 3.0% O ₂ (ppm)	0.15 - 0.25	Base
	(112 – 186)	
NOx w/SNCR lbs/10 ⁶ Btu @ 3.0%	0.10 - 0.17	(-30 to 40%)
O ₂ (ppm)	(75 - 130)	
NOx w/RSCR lbs/10 ⁶ Btu @ 3.0%	0.06 - 0.075	(-60 to 75%)
O ₂ (ppm)	(45 – 56)	

Table 2-1.	CO and NOx	reduction	using RSCR	[Source:	BPEI 2006]
------------	------------	-----------	------------	----------	------------

Additionally, the heat exchanger part of the RSCR has a thermal efficiency of about 95 percent, which translates to fuel savings. Traditional technologies that utilize Ljungstrom or plate type heat exchangers for heat recovery and duct burners to reach the catalyst operating temperature are typically in the range of 70 to 75 percent thermal efficiency.

An analysis performed by BPEI on a typical 25 MW plant with a 75 percent reduction in NOx shows a cost effectiveness of \$4,514 per ton of NOx removed. The cost breakdown is tabulated below in *Table 2-2*.

Plant Overview:	
Plant Gross MW	25
GROSS HEAT INPUT, MMBTU/HR	321
TYPICAL UNCONTROLLED NOx, LB/MMBTU	0.25
TYPICAL CONTROLLED NOx, LB/MMBTU	0.065
NOx REMOVED, TONS/YEAR	249.4
RSCR Cost:	
AMMONIA COST, \$/TON NOx	\$ 419
NATURAL GAS, \$/ton NOx	\$ 404
POWER COST, \$/TON NOx	\$ 589
CATALYST COST, \$/TON	\$ 555
CAPITAL COST, \$/TON	\$ 2,546
TOTAL COST PER TON NOx REMOVED	\$ 4,514

Table 2-2.	RSCR	cost efficiency	[BPEI, 2008]
------------	------	-----------------	--------------

Two RSCR installations (15 and 50MW) are currently in operation in the Northeast. The 15 MW plant uses whole tree chips as fuel; the 50 MW plant uses whole tree chips, waste wood, and construction and demolition wood as fuel for the boilers. The goal of the two installations was to qualify for the Massachusetts Renewable Energy Credits (RECs). The state requirement for qualifying for RECs imposed a NOx level of 0.075 lb/MMBtu or less on a quarterly average basis.

2.3.5 Technology Combinations

In theory, most of the technologies described above can be used together. However, NOx reductions are not necessarily additive, and more importantly, the economics of the combined technologies may or may not be cost-effective. Such analyses are highly specific to the site and strategy. However, several such technology combinations are considered attractive and have gained acceptance. For example, the combination of LNB/OFA with either SCR or SNCR is more prevalent than the application of the post-combustion technologies alone. The economics of this approach are justified by the reduced chemical (SNCR) and capital costs (SCR – smaller reactor/catalyst) due to lower NOx levels entering the SCR/SNCR system. Another combination offered commercially is the hybrid SNCR/SCR concept, which uses the excess ammonia (ammonia "slip") of the SNCR to promote additional NOx reduction in a downstream SCR catalyst.

2.4 Applicability to ICI Boilers

The NOx control technologies previously described are commercially available and are used extensively in EGUs, but most are also applicable to ICI boilers. Because conventional fuels (e.g., coal, oil, gas) as well as alternative fuels (e.g., wood, petroleum coke, process offgases) emit NOx, these technologies are applicable to most boilers using various fuels. With the exception of FBC and Stoker boilers, LNBs are available and widely used for most combinations of boiler types and fuels. OFA and reburn as well as SNCR and SCR technologies require sitespecific suitability analyses, as several important parameters can have substantial impact on their performance or even retrofit feasibility. As already stated, these include available space, residence times and gas temperatures. Conversely, other than firetube type boilers, these technologies are potential candidates for the other boiler types including stokers and FBCs. Finally, the RSCR may offer advantages for applications where low flue gas temperatures are present and a conventional SCR may be more costly to implement.

2.5 Efficiency Impacts

The NOx control technologies involving combustion modification have essentially no impact on the CO_2 emissions of the host boilers, with the noted exception for reburn when displacing coal or oil with natural gas. This is because combustion modification technologies do not impose any significant parasitic energy consumption (auxiliary power). Note that combustion modification technologies can affect the resulting combustion conditions in addition to the desired reduction in NOx emissions. These impacts are reflected in varying temperatures, oxygen levels, and CO/UBC, all of which affect combustion efficiency as discussed previously. However, we do not attempt to quantify these impacts. The overriding assumption is that these NOx control technologies, once deployed, are optimized such that the resulting NOx emissions are achieved without compromising the above parameters (or at least their combined effects).

With respect to the post-combustion technologies, both SNCR and SCR impose some degree of energy impact on the host boiler. The losses attributable to these technologies include the following:

- For SNCR
 - o compressor power (air atomization/mixing)
 - o steam (if steam atomization/mixing)
 - o dry gas loss (air injection into furnace)
 - water evaporation loss
- For SCR
 - o compressor
 - reactor pressure loss
 - o steam (sootblowing)

Table 2-3 summarizes the key parameters for major NOx control technologies.
Technology	Applicability	Performance (% Reduction)	Energy Impacts (kW/1000 acfm)	Comments
LNB	All except Stokers, FBC	30 – 60 (<10ppm possible on gas)	NA	Assumed not to have negative impact on CO/UBC/O ₂
OFA	All except firetube/FBC	30 - 60	NA	Assumed not to have negative impact on CO/UBC/O ₂
Reburn	All except firetube/FBC	30 - 60	NA	Assumed not to have negative impact on CO/UBC/O ₂
SNCR	All except firetube (Must have adequate temperature window)	30 - 70	1 - 2	Compressor/va porization losses
SCR	All (Most likely for larger coal units where LNBs cannot reach very low NOx levels)	60 - 90	0.5 – 1 (gas) 2 - 4 (oil/coal)	Pressure loss/steam

Table 2-3.	Summary	of NOx	control	technologies
------------	---------	--------	---------	--------------

2.6 NOx Control Costs

The following tables summarize published NOx control costs for ICI boilers reported in the literature [US EPA, 1996; NESCAUM, 2000; Khan, 2003; US EPA, 2003; MACTEC, 2005; Whiteman, 2006]. Literature values of capital cost have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness in dollars per ton of NOx removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs. Reagents or consumables can make up a large portion of some operating costs. Costs of reagents and fuels (e.g., ammonia, natural gas) and consumables (e.g., SCR catalyst) change with time, but not always at the general rate of inflation. Some of these costs have increased at rates higher than the general rate of inflation. Thus, cost effectiveness values (or operating costs) from before 2005 have not been reported.

Table 2-4 summarizes the published NOx control costs for combustion modification technologies. The cost of the installation of low-NOx combustion technology depends on the firing system, and this is reflected in the lack of a clear relationship between capital cost and boiler capacity (*Figure 2-7*). Smaller boilers (10 to 50 MMBtu/hr) are often firetube or packaged watertube, whereas larger oil and gas boilers are more likely to be field-erected watertube boilers. Coal-fired boilers can be stokers, pulverized coal (PC), or cyclones. Combustion modification technologies therefore need to be evaluated on a case-by-case basis, taking into account both the fuel and the design of the combustion system. For the substantial majority of the estimates for ICI boilers, capital costs are in the range of \$1,000 to \$6,000 per MMBtu/hr. Cost effectiveness values, where available, are generally in the range of \$1,000 to \$7,000 per ton of NOx removed.

	NOx		Size of	Capital Costs	Base yr.	Cost (\$/ton	
Technologie	Reduction	F	Boiler	@2006\$	for or	NOx @ base	D.f
1 echnology	Kange	Fuel Type	(MMBtu/nr)	(\$/MIMBtu/nr)	Kei. yr	year)	Kei
Overfire Air	15-30	Coal	500	\$2,682	1996		1
GR	35%	Coal	350	\$1,302	1999		2
Gas Reburn	55%	Coal	500	\$2,604	1999		2
LNB	25%	Coal	350	\$6,378	1999		2
LNB	36.0%	Coal	350	\$6,378	1999		2
LNB	50%	Coal	500	\$8,464	1996		1
LNB	51%	Coal	100	\$9,287	1999		6
LNB	51%	Coal	250	\$7,055	1999		6
LNB	51%	Coal	1000	\$4,654	1999		6
LNB	42.6%	Coal (Tangent.)	250	\$5,088	2005	\$3,383	3
LNB	42.6%	Coal (Tangent.)	250	\$5,088	2005	\$3,988	3
LNB	49%	Coal (Wall)	250	\$5,088	2005	\$2,636	3
LNB	49%	Coal (Wall)	250	\$5,088	2005	\$3,101	3
LNB	40%	Pulv. Coal	250	\$346-\$3,610	2005	\$749-\$3,393	3
LNB	45.0%	Resid. Oil	250-FT	\$5,088	2005	\$6,361-\$7,483	3
LNB	50%	Resid. Oil	250-WT	\$5,088	2005	\$4,691-\$5,519	3
LNB	40%	Resid. Oil	250	\$346-\$5,088	2005?	\$1,505-\$6,813	3
LNB	45%	Resid. Oil	10	\$7,617	1996		1
LNB	45%	Resid. Oil	50	\$3,021	1996		1
LNB	45%	Resid. Oil	150	\$1,563	1996		1
LNB	45%	Dist. Oil	10	\$7,617	1996		1
LNB	45%	Dist. Oil	50	\$3,021	1996		1
LNB	45%	Dist. Oil	150	\$1,563	1996		1
LNB	25%	Gas	350	\$6,378	1999		2
LNB	40%-55%	Gas	10	\$7,617	1996		1
LNB	40%-55%	Gas	50	\$3,021	1996		1
LNB	40%-55%	Gas	150	\$1,563	1996		1
LNB+FGR	50%	Pulv. Coal	250	\$930-6,629	2005	\$1,482-\$3,582	3
LNB+FGR	72%	Pulv. Coal	250	\$930-6,629	2005	\$1,029-\$2,488	3
LNB+FGR	50%	Resid. Oil	250	\$930-6,629	2005	\$2,977-\$7,197	3
LNB+FGR	72%	Resid. Oil	250	\$930-6,629	2005	\$2,068-\$4,998	3
LNB+OFA	51%-65%	Coal	100	\$9,287	1999		6
LNB+OFA	51%-65%	Coal	250	\$7,055	1999		6
LNB+OFA	51%-65%	Coal	1000	\$4,654	1999		6
LNB+OFA	30%-50%	Oil	100	\$3,258	1999		6
LNB+OFA	30%-50%	Oil	250	\$2,474	1999		6
LNB+OFA	30%-60%	Oil	1000	\$1,633	1999		6
LNB+OFA	60%	Gas	100	\$3,258	1999		6
LNB+OFA	60%	Gas	250	\$2,474	1999		6
LNB+OFA	60%	Gas	1000	\$1,633	1999		6

Table 2-4.	NOx control	costs for co	mbustion	modifications	applied to	ICI boilers
------------	-------------	--------------	----------	---------------	------------	-------------

Technology	NOx Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs @2006\$ (\$/MMBtu/hr)	Base yr. for or Ref. yr	Cost (\$/ton NOx @ base year)	Ref
ULNB	46%	Pulv. Coal	250	\$1,364	2005	\$1,876	3
ULNB	63%	Pulv. Coal	250	\$1,364	2005	\$933	3
ULNB	72%	Pulv. Coal	250	\$1,364	2005	\$619	3
ULNB	75%	Pulv. Coal	250	\$1,364	2005	\$784	3
ULNB	85%	Pulv. Coal	250	\$1,364	2005	\$692	3
ULNB	75%	Resid. Oil	250	\$1,364	2005	1575	3
ULNB	85%	Resid. Oil	250	\$1,364	2005	1390	3
ULNB	80%	Dist. Oil	24.5	\$8,619	2005	17954	3
ULNB	80%	Dist. Oil	70	\$2,280	2005	5756	3
ULNB	94%	Dist. Oil	68	\$1,987	2005	4751	3
ULNB	94%	Dist. Oil	68	\$1,987	2005	4564	3

Table 2-4 [continued]

References:

1. US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/

2. NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.





Technology	NOx Reduction Range	Fuel Type	Size of Boiler (MMBtu/br)	Capital Costs @2006\$ (\$/MMBtu/br)	Base yr. for	Cost (\$/ton NOx @ base	Pof
SNCR	30%_70%	Coal	500	\$2 044	1996	ycar)	1
SNCR	40%	Coal	100	\$6.717	1999		1 6
SNCR	40%	Coal	250	\$5,717 \$5,102	1999		6
SNCR	40%	Coal	1000	\$3,102 \$3,366	1999		6
SNCR	30%-70%	Resid Oil	50	\$3,300 \$4 297	1996		1
SNCR	30%-70%	Resid Oil	150	\$4 297	1996		1
SNCR	35%		350	\$2.862	1999		2
SNCR			21	\$17,101	2006	\$3,718	4
SNCR			120	\$6,377	2006	\$2,231	4
SNCR			240	\$4,493	2006	\$1,821	4
SNCR			387	\$2,899	2006	\$1,564	4
SNCR			543	\$2,319	2006	\$1,538	4
SNCR			844	\$1,449	2006	\$1,346	4
SNCR	40%	Oil	100	\$5,205	1999		6
SNCR	40%	Oil	250	\$3,954	1999		6
SNCR	40%	Oil	1000	\$2,608	1999		6
SNCR	30%-70%	Dist. Oil	50	\$4,297	1996		1
SNCR	30%-60%	Natural Gas	50	\$4,297	1996		1
SNCR	40%	Gas	100	\$5,372	1999		6
SNCR	40%	Gas	250	\$4,082	1999		6
SNCR	40%	Gas	1000	\$2,693	1999		6
LNB+SNCR	50%-89%	Pulv. Coal	250	\$2,064-6,829	2005	\$1,409-\$4,473	3
LNB+SNCR	50%-89%	Resid. Oil	250	\$2,064-6,829	2005	\$2,229-\$7,909	3

Table 2-5.	NOx control	costs for SNCR	applied to	ICI boilers
	1 COA COMPLOT	CODED TOT DITCH	upplieu to	ICI boners

References:

US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/
 NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost

Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

Table 2-5 summarizes the published NOx control costs for SNCR applied to ICI boilers. As with combustion modifications, the capital cost of SNCR systems is sensitive to the type of combustion system. As long as the boiler has sufficient space for installation of injection lances and mixing of reagent and flue gas (at the appropriate temperature), the capital costs should not depend on the fuel burned. The relationship between capital cost and boiler capacity is shown in *Figure 2-8*. Except for the 1996 EPA estimates for gas and oil boilers, there is a pronounced effect of boiler capacity on capital cost. The graph shows that fuel type is probably secondary to boiler capacity, although there will be an indirect effect of fuel, because fuel type influences the design of the combustion system. The cost effectiveness for SNCR was given by ICAC [Whiteman, 2006] without regard to fuel type and by MACTEC [2005] for coal and residual oil.



Figure 2-8. Capital cost for NOx control for SNCR applied to ICI boilers as a function of boiler capacity

Table 2-6 summarizes the published NOx control costs for SCR. The relationship between capital cost and boiler capacity is shown in *Figure 2-9*. The capital cost of SCR systems is sensitive to the type of fuel and to the level of NOx reduction desired, but not to the combustion system. The volume of catalyst required for an SCR installation depends on the level of desired NOx reduction and on the fuel. Coal-fired power plant applications are the most expensive, since the flue gas entering the SCR contains fly ash, which affects the design of the catalyst. The capital cost for a given fuel and boiler size can vary (see, for example, the variation in capital costs reported for coal application). When an SCR must be retrofit, the cost of the installation depends on the configuration of the specific system. Because the amount of

ductwork required, significant variation in installed capital cost can occur for a given boiler size. Upgrades like rebuilding the air preheater also affect the installed capital cost. MACTEC [2005] gave the cost effectiveness (in dollars per ton of NOx removed) for SCR for coal and residual oil; these costs showed a wide range, because of the wide range in assumed capital costs.

	NOx			Capital Costs			
	Reduction		Size of Boiler	@2006\$	Base yr. for	Cost (\$/ton NOx	
Technology	Range	Fuel Type	(MMBtu/hr)	(\$/MMBtu/hr)	or Ref. yr	@ base year)	Ref.
SCR	80%	Coal	350	\$12,755-19,133	1999		2
SCR	80%-90%	Coal	500	\$15,365-16,145	1996		1
SCR	70%-90%	Pulv. Coal	250	\$1,666-13,881	2005	\$2,233-\$7,280	3
SCR	80%	Coal	100	\$18,574	1999		6
SCR	80%	Coal	250	\$14,110	1999		6
SCR	80%	Coal	1000	\$9,309	1999		6
SCR	80%	Oil	100	\$14,116	1999		6
SCR	80%	Oil	250	\$10,723	1999		6
SCR	80%	Oil	1000	\$7,075	1999		6
SCR		Oil		\$5,102-7,653	1999		5
SCR	70%-90%	Resid. Oil	250	\$1,666-13,881	2005	\$4,363-\$14,431	3
SCR	80%-90%	Resid. Oil	50	\$8,359	1996		1
SCR	80%-90%	Resid. Oil	150	\$4,909	1996		1
SCR	80%-90%	Dist.	50	\$8,359	1996		1
SCR	80%-90%	Dist.	150	\$4,909	1996		1
SCR	80%	Gas	100	\$10,216	1999		6
SCR	80%	Gas	250	\$7,760	1999		6
SCR	80%	Gas	1000	\$5,120	1999		6
SCR	80%	Gas	100	\$9,566	1999		2
SCR	80%	Gas	350	\$7,015	1999		2
SCR	80%-90%	Natural Gas	50	\$8,359	1996		1
SCR	80%-90%	Natural Gas	150	\$4,909	1996		1
SCR	80%	Wood	350	\$6,378-7,653	1999		2
SCR	74%	Wood	321	\$1,978	2006	\$4,514	7

Table 2-6. NOx control costs for SCR applied to ICI boilers

References:

1. US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/

2. NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

7. BPEI. (2008, February). RSCR Cost Effective Analysis.



Figure 2-9. Capital cost for NOx control for SCR applied to ICI boilers as a function of boiler capacity

2.7 Chapter 2 References

Albanese, Vince (2006). "Applications, Issues, & Answer for SNCR." NACAA Fall Meeting in San Antonio, TX.

Babcock Power Environmental Inc. (2006). Regenerative SCR. Worcester: Babcock Power Environmental Inc.

Bodnarik, Andrew M. New Hampshire Department of Environmental Services, "ICI Boiler NOx Control Cost Estimates from the OTC Methodology," presented at the OTC Control Strategy/SAS Committee Meeting, November 2, 2006.

Babcock Power Environmental Inc. (2008). RSCR Cost Effective Analysis.

Khan, Sikander. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

MACTEC. Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

STAPPA/ALAPCO (2006). "Controlling Fine Particulate Matter under the Clean Air Act: A Menu of Options."

Toupin, R. F. (2007). Efficient and Low Emission Stoker Fired Biomass Boiler Technology in Today's Marketplace. Worcester: Babcock Power Environmental Inc.

US EPA. Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. <u>http://www.epa.gov/ttn/catc/dir1/fscr.pdf</u>.

US EPA. OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. <u>http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/</u>.

Whiteman, C. ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

3 SO₂ CONTROL TECHNOLOGIES

3.1 SO₂ Formation

 SO_2 is an undesirable byproduct of the combustion of sulfur-containing fossil fuels. SO_2 , like NOx, is a precursor to ambient fine particles: Thirty to 50 percent of ambient fine PM mass in the eastern U.S. is attributable to sulfate derived from SO_2 . SO_2 is a significant contributor to wet and dry acid deposition on various ecosystems (lakes, streams, soils, and forests). Various coals in the U.S. can have 1 to 3 percent (by mass) sulfur; residual oil (No. 6 oil) can have sulfur contents of 2 percent and higher. Distillate oils are generally lower in sulfur content (less than 0.5 percent by mass). Natural gas has essentially zero sulfur content. However, unlike nitrogen in coal or oil, essentially all of the sulfur in the fuel is oxidized to form SO_2 (a very small percentage is further oxidized to SO_3 depending on fuel and boiler characteristics). This means that the relationship between sulfur content in the fuel and SO_2 emissions is much more direct and linear than that between fuel nitrogen and NOx emissions, and as such, the emission reduction benefits of fuel switching (for example from higher- to lower-sulfur coal or from higher-sulfur oils to lower-sulfur oils) are directly proportional to the difference in sulfur contents of fuels.

Another important difference is that this relationship is, for all practical purposes, independent of the type of boiler technology. Two exceptions to this include the high–alkaline nature of ash in some sub bituminous coals, which causes a portion of the sulfur in the coal to react and form various sulfate salts (mostly calcium sulfate); another is the combustion of coal in fluidized bed combustion (FBC) boilers where the lower temperatures of combustion and the use of alkaline material (e.g., limestone) in the "bed" promote the reaction of SO₂ with calcium to form sulfate, thereby reducing the net emissions of SO₂. In practical terms, this means that most solid- and liquid-fuel-fired systems produce SO₂ emissions proportional to their sulfur content, whereas natural gas combustion produces essentially no SO₂.

Additionally, despite the much smaller quantities of SO_3 formed in comparison to SO_2 , as noted above, SO_3 presents both operational and environmental challenges. Operationally, SO_3 is a concern because if the temperature of the back-end flue gas handling equipment (e.g., ducts, particulate control devices, scrubbers) falls below the acid dew point, corrosion and material deterioration can result. From an environmental perspective, nucleation and condensation of ultra-fine sulfuric acid particles formed from the SO_3 present in the flue gas can contribute to the primary emissions of fine PM from the stack into the atmosphere.

3.2 SO₂ Reduction

As a result of the relationship between fuel sulfur content and SO_2 , SO_2 emission control technologies fall in the category of reducing SO_2 after its formation, as opposed to minimizing its formation during combustion. This is accomplished by reacting the SO_2 in the flue gas with a reagent (usually calcium- or sodium-based) and removing the resulting product (a sulfate/sulfite) for disposal or commercial use, depending on the technology used. SO_2 reduction technologies are commonly referred to as Flue Gas Desulfurization (FGD) or SO_2 "scrubbers" and are usually

described in terms of the process conditions (wet vs. dry), methods for gas-sorbent contact (e.g., absorber vessel vs. duct for dry sorbent injection), byproduct utilization (throwaway vs. saleable), and reagent utilization (once-through vs. regenerable).

Within each technology category, multiple variations are possible and typically involve the type and preparation of the reagent, the temperature of the reaction, and the use of enhancing additives. Because these variations mostly involve complex process chemistry, but are fundamentally similar, this summary focuses on the major categories of SO_2 control technologies, their applicability to ICI boilers, and data on performance and cost. For a more detailed description of FGD technologies, see Srivastava [2000].

As noted earlier, SO_2 control strategies can also include fuel switching (from high-sulfur coal to low-sulfur coal or from high-sulfur oil to low-sulfur oil/natural gas). While not considered a "technology," switching from a higher-sulfur fuel to a lower-sulfur one requires considerable cost and operational analysis. Major issues include price, availability, transportation, and suitability of the boiler or plant to accommodate the new fuel.

3.3 Other FGD Benefits

Significant attention has been given recently to the issue of mercury emissions from EGUs and ICI boilers. It is relevant to note that some FGD technologies have been shown to capture mercury from the flue gas [Jones and Feeley, 2008] by absorbing the water-soluble oxidized forms of mercury from the flue gas. Both wet and dry SO_2 control processes have been and are being tested to determine their mercury capture potential. This suggests that strategic and economic analyses for SO_2 control technologies need to consider the potential side-benefit of mercury removal as well.

3.4 Summary of FGD Technologies

A brief overview of FGD technologies is provided here to give the reader a broad perspective on SO_2 controls.

3.4.1 Wet Processes

Wet FGD (WFGD) or "wet scrubbers" date back to the 1960s with commercial applications in Japan and the U.S. in the early 1970s [NESCAUM 2000]. They represent the predominant SO_2 control technology in use today with over 80 percent of the controlled EGUs capacity in the world and the U.S. [EPA 2000].

In a wet scrubber, the SO₂-containing flue gas passes through a vessel or tower where it contacts an alkaline slurry, usually in a counterflow arrangement. The intensive contact between the gas and the liquid droplets ensures rapid and effective reactions that can yield >90 percent SO₂ capture. Currently, advanced scrubber designs for EGUs have eliminated not only many of the early operational problems, primarily related to reliability, but have also demonstrated very high SO₂ reduction capabilities with the technology being capable of well over 95 percent SO₂ control [Dene *et al.*, 2008]. *Figure 3-1* provides a schematic view of a wet scrubber.



Figure 3-1. Schematic of a WFGD scrubber [Bozzuto, 2007]

Variations of the basic technology, in addition to equipment improvements made over the years, include reagent and byproduct differences. Limestone, lime, sodium carbonate, ammonia, and even seawater-based processes are all commercially available. Limestone is by far the most widely used with commercial-grade gypsum (wallboard quality) being produced in the so-called Limestone Forced Oxidation (LSFO) process. The use of other reagents, as mentioned, is driven by site-specific criteria, such as local reagent availability, economics, and efficiency targets.

Technology costs have changed over time, as expected, reflecting changes in market conditions, labor and raw material costs, local, state, regional, and federal regulatory drivers, and site-specific considerations. Recently, capital costs have trended upward after a downward trend in the mid-late 1990s. These fluctuations have in large part, been driven by labor and material costs, the global nature of technology markets, and regulatory changes within the electric power sector [Sharp, 2007; Cichanowicz, 2007].

3.4.2 Dry Processes

Conventional dry processes include spray dryers (SDs) or "dry scrubbers" and Dry Sorbent Injection (DSI) technologies, and are shown in *Figure 3-2* and *Figure 3-3*, respectively. The technologies are referred to as "dry" because the SO₂ sorbent, while it may be injected as a slurry or a dry powder, is finally dried and collected in a conventional particulate control device, a fabric filter, or an ESP.

SD refers to a configuration where the reaction between SO_2 and the sorbent takes place in a dedicated reactor or scrubber vessel. DSI technology does not require a dedicated reactor and instead uses the existing boiler and duct system as the "reactor," and several configurations are possible based on the temperature window desired. This can occur at the furnace (1800-2200°F), economizer (800-900°F), or in a low-temperature duct (250-300°F). In addition, another common feature of dry scrubbing systems is the need for the particulate control equipment downstream of the sorbent injection. Usually this is accomplished through the use of fabric filters (although, depending on the application, ESPs may be used) that are not only efficient collectors of fine particulates, but can also provide some additional SO₂ removal as the flue gas passes through unreacted sorbent collected on the bags. Dry processes are more compatible with low- to medium-sulfur coals because of the need to limit solid concentrations in the slurry below a threshold for adequate atomization and the need to limit the amount of solids collected in an existing particulate control device. This requirement precludes higher sulfur fuel applications where the required amount of reagent would be above that threshold. Therefore, high-sulfur applications are more typically associated with wet FGDs.



Figure 3-2. Schematic of a spray dryer [http://www.epa.gov/eogapti1/module6/sulfur/control.htm]

It is relevant to note that DSI technology did not gain any meaningful market penetration as part of the EGU compliance options to meet the requirements of the 1990 CAAA (Title IV) "acid rain" legislation for reducing emissions of SO₂. The large number of wet FGD installations in response to the Clean Air Act of 1970, and creation of "emission allowances," combined with the trend to switch fuels (mostly to low-sulfur Powder River Basin or PRB coal) in response to the 1990 CAAA, help explain this situation. However, more recently, interest in DSI technology applications for ICI boilers has been renewed and companies are "revamping" the knowledge base for DSI.



Figure 3-3. Dry Sorbent Injection (DSI) system diagram [http://www.epa.gov/eogapti1/module6/sulfur/control/control.htm]

DSI technologies include calcium (lime) and sodium (trona) reagents and are currently being tested or demonstrated within the ICI boiler sector. Companies such as O'Brien and Gere [Day, 2006; Day, 2007] and Siemens Environmental [Siemens, 2007] are marketing and deploying duct injection systems, and Nalco Mobotec [Haddad *et al.*, 2003] offers furnace sorbent injection (FSI) systems for ICI boilers. O'Brien and Gere, for example, have conducted over 5,000 hours of demonstrations at 15 different boilers since January 2005 to evaluate the viability, performance, and economics of DSI [Day, 2007]. These processes require relatively little new equipment and are thus suitable candidates for ICI boiler retrofit applications, where site constraints (e.g., space) are often critical.

Two examples of DSI systems are Furnace Sorbent Injection (FSI) in which hydrated lime is injected into the upper furnace of the boiler, and Lime Slurry Duct injection (LSDI) where atomized lime slurry is sprayed into the gas stream in the duct. FSI systems were first demonstrated in the 1980s on EGU boilers and are currently operating at ICI boilers [Dickerman, 2006].

FSI systems are capable of removing between 20 to 60 percent of the SO_2 and have shown removal percentages of as high as 90 to 99 percent for HCl and SO_3 [Haddad *et al.*, 2003]. The FSI systems also offer a low capital cost option and the attractiveness of quick cost recovery for ICI boiler sector [Dickerman, 2006].

The LSDI utilizes an atomized spray of lime slurry. The particles are subsequently captured in the downstream particulate collector. Sorbent particle size distribution is important for maximizing SO_2 capture while minimizing operational problems such as duct fallout and deposition.

LSDI systems have been utilized to mitigate plume generation from cement plants, and are capable of SO₂ reductions of up to 90 percent for industrial applications and ICI boilers, as well as HCl and HF reductions of greater than 95 percent [Dickerman, 2006].

In either case, both dry sorbent injection technologies offer an economical method for reducing emissions of SO₂. *Table 3-1* compares the FSI and LSDI systems for a 100 MW boiler, burning coal with one percent sulfur.

Parameter	FSI (Hydrated Lime)	LSDI
SO ₂ Removal	35%	50%
Reagent Cost (\$10 ³ /yr)	\$1,400	\$370
Parasitic Power (\$10 ³ /yr)	\$182	\$182
Disposal Cost (\$10 ³ /yr)	\$168	\$93
Subtotal (\$10 ³ /yr)	\$1,750	\$645
Capital Cost (\$/kW)	\$1,000,000 (10 \$/kW)	\$2,500,000 (25 \$/kW)
Annual Capital Charge (\$10 ³ /yr)	\$100	\$250
Total Operating Cost (\$10 ³ /yr)	\$1,850	\$895
\$/ton SO ₂ Removed	\$1,070	\$311

Table 3-1.	Comparison of	price for FSI an	d LSDI systems for a	100 MW coal-fired bo	iler [Dickerman, 2006]
I UNIC C II	comparison or	price for 1 br un	a hold by stems for a	, roo min o cour mea bo	

Trona (sodium sesquicarbonate) is another reagent that has shown potential to reduce SO_2 emissions. A typical flow diagram is shown in *Figure 3-4* for injection of trona into a duct.



Figure 3-4. Flow diagram for trona DSI system [Day, 2006]

Trona's higher reactivity compared to lime helps it to offset the reaction stoichiometry advantage of lime. More importantly, due to the ability of trona to capture SO_2 when injected at higher temperatures [Cremer *et al.*, 2008], it is potentially applicable to many ICI boilers where flue gas temperatures may be higher that the desired ~300°F required for lime. *Figure 3-5* gives

some test data showing percent SO_2 reduction, [Day, 2006], averaged over several applications for units with ESPs.



Figure 3-5. SO₂ removal test data [Day, 2007]

Figure 3-5 presents results for SO₂ reduction as a function of normalized stoichiometric ratio (NSR), which is the ratio of the reagent (trona in this case) to SO₂ in the flue gas. The two lines depict SO₂ reduction potential for two different sizes of trona at the same flue gas temperature of 700°F. Larger particles (unmilled) result in lower SO₂ reductions, as expected, relative to the milled condition (smaller particle size).

3.4.3 Other SO₂ Scrubbing Technologies

A number of other scrubber technologies have been developed for control of SO₂, but have not to date received significant market share. Among them are sodium- and ammonia-based wet scrubbing technologies. Some of these technologies, like the activated coke process [Dene, 2008], are regenerable (meaning the reagent can be regenerated and used repeatedly) and may produce useful byproducts, such as sulfuric acid, elemental sulfur, and ammonium sulfate. *Table 3-2* and *Table 3-3* present a comparison of the key performance characteristics and attributes for several alternative scrubbing technologies compared with conventional wet and dry scrubbers [Bozzuto, 2007].

	Limestone WFGD	Spray Dryer	Ammonia WFGD	Sodium WFGD
Features	 High Efficiency 	• Low	 High value 	• Low investment cost
	 Low cost reagent 	investment cost	byproduct	Operational
	 Byproduct 	 Dry byproduct 	 Economics 	simplicity
	flexibility	Small footprint	improved at high	
		 No liquid 	sulfur levels	
		waste	 Low operating cost 	
Pros	 Small flue gas 	 Low/medium 	 High sulfur fuel 	 High sulfur fuel
	flow	sulfur fuel	 Larger flue gas 	 Larger flue gas flow
	 Operational 	 Smaller flue 	flow	 Fertilizer market
	simplicity required	gas flow	 Gypsum market 	
	 Acute capital cost 	Short	 Medium cost 	
	 Short evaluation 	evaluation period	evaluation period	
	period			
Cons	 Effluent discharge 	 Limited 	 Acute capital cost 	 Acute capital cost
	issue	landfill area	sensitivity	sensitivity
		• High	 Ultra-low PM 	
		lime/limestone	emission	
		cost ratio	requirements	
Reagent	Limestone	Lime	Ammonia	Caustic, soda ash
Byproduct	Marketable gypsum	Landfill	Fertilizer	Sodium sulfate
	or landfill			
SO ₂ inlet	High	Low/medium	High	High
Removal	>98%	90 - 95%	>98%	>98%
Efficiency				

Table 3-2. Comparison of alternative FGD technologies [Bozzuto, 2007]

 Table 3-3. Cost estimates for alternative FGD technologies [Bozzuto, 2007]

	Limestone WFGD	Spray Dryer	Ammonia WFGD	Sodium WFGD
Capital Cost	25 - 45	15-25	35 - 60	10 - 20
(\$/acfm)				
Power	3-6	2	3-6	2-3
Consumption				
(kW/acfm)				
Reagent Cost	\$15 – 25/ton	\$60 - 75/ton	\$80 - 105/ton	\$100-130/ton
(\$/ton SO ₂				
removed.)				
Byproduct Cost	\$12 - 20/ton -	\$12 - 20/ton	\$150 - 250/ton	??
(\$/ton SO ₂	disposal (\$15/ton)			
removed.)	- sale			

3.5 Use of Fuel Oils with Lower Sulfur Content

Distillate fuel (No. 2 oil) is used in combustion systems in which an atomizer sprays droplets of oil into a combustion chamber and the droplets burn in suspension. Residual fuel oil (No. 6 oil) is also atomized and burned in ICI boilers. No. 6 oil is more viscous and has a higher boiling point range than distillate oil. Preheating is required for metering and atomization of No. 6 oil in industrial combustion systems. A wide range of sulfur contents are available, from less than 0.3 wt% to greater than 3 wt%.

For oil-fired ICI boilers, switching to lower-sulfur oil can provide significant reductions in emissions of SO₂. There is also an additional and important benefit of reduced emissions of $PM_{2.5}$. There are generally costs associated with switching to lower-sulfur fuels, which will undoubtedly vary from region to region.

Table 3-4 shows an example of the stocks of the fuel oils available on the East Coast and in the U.S. in 2006, taken from the Energy Information Administration (EIA) Petroleum Supply Annual [US EIA, 2006]. Substantial stocks of low-sulfur No. 6 fuel oil (less than 0.3 percent sulfur) and of ultra-low-sulfur No. 2 fuel oil (less than 0.0015 percent sulfur) were available both in the U.S. and on the East Coast.

	East Coast		U. S.	Total
Distillate Fuel Oil			31,318	
0.0015% sulfur and under	1,856	(44%)	16,531	(53%)
Greater than 0.0015% to 0.05% sulfur	560	(13%)	6,223	(20%)
Greater than 0.05% sulfur	1,758	(42%)	8,564	(27%)
Residual Fuel Oil			11,936	
Less than 0.31% sulfur	869	(35%)	1,291	(11%)
0.31 to 1% sulfur	975	(39%)	2,544	(21%)
Greater than 1% sulfur	642	(26%)	8,101	(68%)

Table 3-4. Distillate and residual oil stocks in 2006 (x1000 barrels) [US EIA, 2006]

Figure 3-6 shows the prices for residual oil and distillate oil from 1983 through 2007. The differential between low (less than 1 percent sulfur) and high (greater than 1 percent sulfur) sulfur residual oil has been narrowing in recent years. The price of distillate oil in recent years, however, has been at times twice as much as the price of residual oil. The EIA prices for residual oil do not include a breakdown for very low sulfur residual oil (less than 0.31 percent sulfur). However, the prices for No. 2 (distillate) oil are broken out by ultra-low (<15 ppm S), low-sulfur (15-500 ppm S), and high-sulfur (>500 ppm S). These prices, shown in *Figure 3-7*, do not show much difference in price as a function of sulfur content of No. 2 oil.



Figure 3-6. Industrial energy prices for No. 6 oil greater than 1 percent S, No. 6 oil less than 1 percent S, and No. 2 oil [Source: US EIA, 2008]



Figure 3-7. Industrial energy prices for No. 2 (distillate) oil [Source: US EIA, 2008]

3-10 Appendix III.D.7.7-4269 The potential increased costs (in fuel only) for switching to lower-sulfur fuel oil can be estimated as shown in the following example, in which December 2007 fuel prices are used. If the high-sulfur residual oil is assumed to be 3 percent S, the low-sulfur residual oil is assumed to be 1 percent S, and the distillate oil is assumed to be 0.2 percent S, then the cost for fuel switching is shown in *Table 3-5*. These costs are only fuel costs, and do not include any equipment costs needed to switch fuels (for example, burner changes when switching from residual to distillate oil).

The cost estimates in *Table 3-5* suggest that switching from a 3 percent sulfur residual fuel oil to a low-sulfur residual oil (1 percent S) would provide a cost-effective sulfur removal strategy at about \$771 per ton of SO₂ removed. The cost of switching to distillate oil is estimated to be much higher than switching to low-sulfur residual oil, because the cost of distillate oil has been as much as twice that of residual oil in recent years. The cost effectiveness of a wet FGD for 90 to 99 percent SO₂ removal is in the range of \$2,000 to \$5,200/ton SO₂ (see Section 3.8). Thus, a switch to lower-sulfur fuel represents a cost-effective sulfur-compliance strategy for residual oil-fired boilers. The cost effectiveness (in dollars per ton of SO₂ removed) of switching from residual fuel oil to distillate fuel oil is not as attractive and is in the range of the cost effectiveness of installing a FGD or scrubber.

Fuel Switch	SO ₂ reduction	\$/ton SO ₂ removed (2007\$)
From 3% S to 1% Residual Oil*	66.7%	\$771
From 3% S Residual to 0.2% Distillate**	93.6%	\$5,335

Table 3-5. Example of costs of switching to low-sulfur fuel oil [Fuel Prices from US EIA, 2008]

*Assuming December 2007 prices for <1%S and >1%S residual oil **Assuming December 2007 prices for >1%S and distillate oil

3.6 Applicability of SO₂ Control Technologies to ICI Boilers

The technologies described above are commercially available and are used extensively throughout the electric utility industry for coal-firing applications. The EGUs have deployed SO₂ controls (mostly wet and dry scrubbers) since the 1970s. ICI boilers firing coal are good candidates for the application of SO₂ control technologies. At least one oil-fired installation of a wet FGD has been noted in the literature [Caine and Shah, 2008]. Economics, however, will dictate preferred options on a case-by-case basis. It is likely that the higher capital-cost intensive technologies (e.g., wet and dry scrubbers) will be most attractive to larger ICI boilers, whereas the injection technologies (such as DSI) would likely be favored at smaller ICI boilers. The annualized cost of a wet FGD scrubber using wet sodium or alkaline waste can be lower relative to lime and limestone FGD, especially if low-cost waste disposal is available and the amount of SO₂ to be removed is small [Emmel, 2006]. This would suggest that smaller ICI boilers may not be good candidates for high capital-cost FGD systems. However, they should be good candidates for application of lower capital cost technologies such as DSI.

In terms of applicability, it is also important to recognize the impact of sulfur content of coal. Dry scrubbing has been typically restricted to low and medium sulfur coals (less than 2 wt% S) due to economic and technical considerations, including constraints associated with sorbent slurry concentration and adequate atomization performance. Lastly, while theoretically feasible, fluidized bed combustion (FBC) boilers are low emitters of SO_2 due to their inherent combustion process (bed temperature and composition), and are not likely candidates for SO_2 scrubber systems.

3.7 Efficiency Impacts

From the brief descriptions above, it should be clear that the common thread among the major SO_2 control technologies involves the reaction of SO_2 in the flue gas with a sorbent or reagent. The chemical reaction occurs either in a dedicated vessel (scrubber), or in the existing flue gas duct system. The major components affecting energy consumption for these systems include electrical power associated with material preparation (e.g., grinding) and handling (pumps/blowers), flue gas pressure loss across the scrubber vessel, and steam requirements. As expected, the energy penalties associated with a highly efficient (99 percent SO_2 reduction) wet scrubber are higher than for a less energy-intensive technology such as DSI.

The power consumption of SO_2 control technologies is further affected by the SO_2 control efficiency of the technology itself. In other words, SO_2 control performance is related to reagent utilization, commonly referred to as liquid-to-gas (L/G) ratio for wet systems and normalized stoichiometric ratio or reagent (Ca or Na) to-sulfur ratio for dry technologies. This can be explained based on the fact that for a given SO_2 reduction level, lower quantities of reagent not only translate to lower reagent costs, but also to lower energy costs.

Table 3-6 summarizes performance and energy efficiency impacts for the three general SO_2 technologies discussed. It is important to note the values shown in the table, specifically in the "Energy Impact" column, represent nominal ranges based on generic combustion calculations and parasitic energy consumption for each technology. They are not site- or fuel-specific calculations, which are generally dependent on many variables, such as fuel composition, combustion and steam efficiencies, and operating conditions (e.g., excess air). However, these values represent broad, industry-wide averages for impacts of SO_2 control technologies on efficiency.

Technology	Applicability	Performance (% Reduction)	Energy Impact (kW/1000 acfm)
WFGD	Larger coal units, high sulfur coals, excluding FBC	90 - 95+	4 – 8+
Dry Scrubbers (SDs)	Larger units w/ low/medium sulfur coals, excluding FBC	70 – 90+	2 - 4
Duct Injection	Larger units w/ low/medium sulfur coals (FBC applications possible for additional "SO ₂ trim")	30 – 60+	1 - 2

Table 3-6	Summary	of energy	impacts	for SO.	control	technologies
1 able 3-0.	Summary	or energy	impacts	101° 50_{2}	control	technologies

3.8 SO₂ Control Costs

Table 3-7 summarizes published SO₂ control costs for ICI boilers, as reported in the literature [Khan, 2003; US EPA, 2003; Whiteman, 2003; MACTEC, 2005]. Literature values of capital costs have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness in dollars/ton of SO₂ removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs, and reagents or consumables can make up a large portion of some of the operating costs. Costs of reagents and fuels (e.g., limestone, trona) change with time, but not always at the general rate of inflation. Thus, cost effectiveness values (or operating costs) from years before 2005 are not shown in the table. *Table 3-7* summarizes the published SO₂ control costs for a number of SO₂ control technologies.

A range of capital costs has been reported for sorbent injection technologies. *Figure 3-8* shows costs for dry duct injection (e.g., trona injection), wet duct injection (e.g., LSDI), and furnace sorbent injection (FSI). There was a large range of capital costs reported for dry sorbent injection. Wet sorbent injection (e.g., injection of hydrated lime slurry) was reported to have a significantly lower capital cost than dry sorbent injection. FSI capital costs were between dry and wet duct injection. The cost effectiveness (cost in dollars per ton of SO₂ removed) depends on the specific sorbent used and the stoichiometric ratio of sorbent to SO₂.

	SO			Conital Costs	Basa	Cost Effoctivoness	
	Reductio		Size of Boiler	\$2006 per	vear for	(\$/ton	
Technology	n Range	Fuel Type	(MMBtu/hr)	MMBTU/hr	Costs	@Base Yr)	Ref
In-Duct Dry Sorbent Inj.	40%	High-S Coal	100	\$34,228	1999		1
In-Duct Dry Sorbent Inj.	40%	High-S Coal	250	\$24,028	1999		1
In-Duct Dry Sorbent Inj.	40%	High-S Coal	1000	\$15,954	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	100	\$22,953	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	250	\$16,565	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	1000	\$11,031	1999		1
In-Duct Dry Sorbent Inj.	50 - 90%	Coal	100	\$17,327	2003		3
In-Duct Dry Sorbent Inj.	50 - 90%	Coal	250	\$12,624	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	100	\$8,663	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	250	\$4,703	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	1000	\$4,641	2003		3
Furnace Sorbent Inj.	70%	Coal	100	\$26,609	2003		3
Furnace Sorbent Inj.	70%	Coal	250	\$14,851	2003		3
Furnace Sorbent Inj.	70%	Coal	1000	\$7,054	2003		3
Spray Dryer	90%	Coal	100	\$69,744	1999		1
Spray Dryer	90%	Coal	250	\$46,209	1999		1
Spray Dryer	90%	Coal	1000	\$25,861	1999		1
Spray Dryer	90%	Coal	250	\$13,300-188,820	2005	\$1,712-3,578	4
Spray Dryer	95%	Coal	250	\$13,300-188,820	2005	\$1,622-3,390	4
Spray Dryer	90%	Oil	250	\$13,300-188,820	2005	\$1,944-5,219	4
Spray Dryer	95%	Oil	250	\$13,300-188,820	2005	\$1,841-4,945	4

Table 3-7. SO₂ control costs applied to ICI boilers

Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Wet FGD	90%	High-S Coal	100	\$81,939	1999		1
Wet FGD	90%	High-S Coal	250	\$62,318	1999		1
Wet FGD	90%	High-S Coal	1000	\$41,216	1999		1
Wet FGD	90%	Low-S Coal	100	\$76,018	1999		1
Wet FGD	90%	Low-S Coal	250	\$57,759	1999		1
Wet FGD	90%	Low-S Coal	1000	\$38,122	1999		1
Wet FGD	90%	Coal	250	\$11,507-172,672	2005	\$2,089-3,822	4
Wet FGD	99%	Coal	250	\$11,507-172,672	2005	\$1,881-3,440	4
Wet FGD	90%	Oil	100	\$69,848	1999		1
Wet FGD	90%	Oil	250	\$53,066	1999		1
Wet FGD	90%	Oil	1000	\$35,019	1999		1
Wet FGD	90%	Oil	250	\$11,507-172,672	2005	\$2,173-5,215	4
Wet FGD	99%	Oil	250	\$11,507-172,672	2005	\$1,956-4,694	4

Table 3-7 [continued]

References

Khan, S. Methodology, Assumptions, and References Preliminary SO₂ Controls Cost Estimates for Industrial Boilers; US EPA: 2003.
 US EPA, Air Pollution Control Technology Fact Sheet: Flue Gas Desulfurization (FGD - Wet, Spray Dry, and Dry Scrubbers; EPA-452/F-03-034, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ffdg.pdf

3. Whiteman, C., ICAC, "SO₂ Control Technology Cost Estimates for Industrial Boilers" memo to John Robbins, US EPA, December 12, 2003.

4. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.





3-14 Appendix III.D.7.7-4273 Spray dryer (SD) technology has been widely applied to coal-fired EGUs. Estimates in the literature for SD technology for ICI boilers give the same capital costs for coal- and oil-fired boilers [ICAC, 2003; MACTEC, 2005]. *Figure 3-9* summarizes these capital costs for ICI boilers. Note that the MACTEC estimates at 250 MMBtu/hr boiler size assumed high and low equipment cost, but a detailed cost breakdown was not given.



Figure 3-9. Capital cost for SO₂ control for Spray Dryer Absorber applied to ICI boilers as a function of boiler capacity

Wet FGD technology has been widely applied to coal-fired EGU boilers but rarely to ICI boilers, although at least one oil-fired installation has been noted in the literature [Caine and Shah, 2008]. The relationship between FGD capital cost and boiler capacity is shown in *Figure 3-10*. Estimates in the literature give the same capital costs for coal- and oil-fired boilers [ICAC, 2003; MACTEC, 2005], although these estimates are not always based on actual field installation data because installations of wet FGD technology on ICI boilers are few at present.



Figure 3-10. Capital cost for SO₂ control for wet FGD applied to ICI boilers as a function of boiler capacity

3.9 Chapter 3 References

Bozzuto, C. "SO₂ Scrubber Systems," CIBO Industrial Emissions Conference, Portland, ME 2007.

Caine, John, Shah, Hardik. "Next Generation Wet Electrostatic Precipitators," presented at 101st Air & Waste Management Association Annual Meeting, Portland, OR, June 24-26, 2008.

Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emission Control Systems," prepared for UARG, 2007.

Cremer, Marc, Wang, David H., Senior, Connie L. "Testing and Model Based Optimization of SO₂ Removal with Trona in Coal Fired Utility Boilers," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Day, Keith. "Use of Dry Sorbent Injection Systems for Controlling Hg, HCL, SO₂/SO₃, NOx," CIBO 2007.

Day, Keith. *Duct Injection for Controlling SO*₂, *SO*₃, *Hg*, and *HCl*; O'Brien and Gere: Jan. 3, 2006.

Dene, Chuck, Baker, Lesley A., Keeth, Robert J. "FGD Performance Capability," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Dene, Chuck. "ReACT Process Demonstration at Valmy Generating Station," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Dickerman, Jim (2006). "SO₂ Emission Controls for Older and Smaller Boilers," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 25-28, 2006.

Emmel, T. "Use of CUECost Model for Developing Cost Estimates for Industrial Size Boilers," memorandum to CIBO, March 2006.

Haddad, E., Ralston, J., Freen, G., Castagnero, S. "Full-Scale Evaluation of a Multi-Pollutant Reduction Technology: SO₂, Hg, and NOx," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Washington, DC, May 19-22, 2003.

Jones, Andrew P., Feeley, Thomas J. (2008) *Preliminary Economic Analysis of Wet FGD Co-Benefit Enhancement Technologies*. National Energy Technology Laboratory, Pittsburgh, PA, May 2008, http://www.netl.doe.gov/energy-analyses/pubs/Enhanced FGD Hg Capture Economics FINAL May2008.pdf.

Khan, Sikander. *Methodology, Assumptions, and References Preliminary SO*₂ Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

MACTEC. *Boiler Best Available Retrofit Technology (BART) Engineering Analysis*; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Environmental Regulation and Technology Innovation: Controlling Mercury Emissions from Coal-Fired Boilers (Praveen Amar, Project Director), September 2000.

NJ DEP. Workgroup Recommendations and Other Potential Control Measures, Stationary Combustion Sources Workgroup, SCS003 – ICI Boilers, May 2, 2006. www.nj.gov/dep/airworkgroups/docs/wps/scs003_fin.pdf.

Nichols, B. "Air Pollution Control Systems at Virginia Tech's Power Plant," CIBO 2007.

Siemens Environmental Systems and Services. "Dry Scrubbing for Industrial Facilities," CIBO2007.

Sharp, G. Power Magazine, 2007.

Srivistava, R. "Controlling SO₂ Emissions – A Review of Technologies," EPA/600/R-00/093, November 2000.

US EIA. *Petroleum Price Data and Analysis*, accessed March 20, 2008. <u>http://tonto.eia.doe.gov/dnav/pet/pet_pri_top.asp</u>.

US EIA. *Petroleum Supply Annual 2006*, Volume 1, 2006. <u>http://www.eia.doe.gov/oil_gas/petroleum/data_publications/petroleum_supply_annual/psa_volume1/psa_volume1.html</u>.

US EPA. *Integrated Planning Model*, Documentation for EPA Base Case 2006 (v3.0), Section 8, Fuel Assumptions. <u>http://www.epa.gov/airmarkt/progsregs/epa-ipm/docs/Section-8.pdf</u>.

US EPA. *Integrated Planning Model*, Documentations for EPA Base Case 2006 (v3.0), Attachment O. <u>http://www.epa.gov/airmarkt/progsregs/epa-ipm/docs/attachment-o.pdf</u>.

US EPA. Air Pollution Control Technology Fact Sheet: Flue Gas Desulfurization (FGD - Wet, Spray Dry, and Dry Scrubbers; EPA-452/F-03-034, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ffdg.pdf. Whiteman, C. ICAC, "SO₂ Control Technology Cost Estimates for Industrial Boilers," memo to John Robbins, US EPA, December 12, 2003.

4 PM CONTROL TECHNOLOGIES

4.1 PM Formation in Combustion Systems

PM emissions from combustion processes include primary and secondary emissions. Primary emissions consist mostly of fly ash. Secondary emissions are the result of condensable particles such as nitrates and sulfates that typically make up the smaller fraction of the particulate matter (PM_{10} and $PM_{2.5}$). Fly ash refers to the mineral matter of the fuel, which typically includes some level of unburned carbon. ICI boilers burn a variety of fuels that contain ash and, as such, have PM emissions. Therefore, ICI boilers are candidates for PM controls.

Coal and oil contain non-combustible ash material. Other liquid or solid fuels (e.g., petroleum coke, wood) also contain ash. The quantity of ash in the flue gas depends on many factors, such as fuel properties, boiler design, and operating conditions. In dry-bottom, pulverized-coal-fired boilers, approximately 80 percent of the total ash in the as-fired coal exits the boiler as fly ash, and the remaining ash is collected as bottom ash. However, in wet-bottom, pulverized-coal-fired boilers, about 50 percent of the total ash exits the boiler as fly ash. In cyclone boilers (common in the EGU sector but not in the ICI population), most of the ash is retained as liquid slag, and the fly ash is only about 20 percent of the total ash. Fluidized-bed combustors (FBC) emit high levels of fly ash because the coal is fired in suspension and the ash is present in dry form. Stoker-fired boilers can also emit high levels of fly ash. However, overfeed and underfeed stokers emit less fly ash than spreader stokers because combustion takes place in a relatively quiescent fuel bed.

In addition to the nitrates and sulfates mentioned as secondary PM, NOx control technologies that inject ammonia or amine-based reagents (SNCR and SCR) yield a certain amount of ammonia "slip," which can also form fine particulate (ammonium sulfate) as the flue gas temperatures decrease towards the stack.

This section presents a brief description of the major primary PM technologies.

4.2 PM Control Technologies

PM control technologies have been commercially available and widely used in ICI and EGU boilers for many years. *Table 4-1* summarizes the main types of commercially available technologies.

Technology	Description	Applicability	Performance
Fabric filters (Baghouse)	"Baghouses" made of close-knit fabrics remove particulates through filtration.	Primarily used in coal/wood fired industrial/utility boilers. Not used with oil boilers due to clogging.	>99% total and PM _{2.5} removal
ESPs (Dry/Wet)	Charged particles attracted to oppositely charged plates. Collection method either wet/dry.	Widely used in coal applications. Suitable for oil, pet coke and waste solid fuels. Wet ESPs suitable for saturated flue gas.	Effectiveness depends on resistivity of particulates. Low sulfur can reduce performance of dry ESP. >99% reduction of total PM (dry/wet) and sulfuric acid mist and PM _{2.5} (wet)
Venturi Scrubbers	Scrubbers work on the principle of rapid mixing and impingement of the particulate with the liquid droplets and subsequent removal with the liquid waste.	High pressure required for significant removal. Applicable to a wide range of fuels.	50% removal for fine particulates, 99% removal for large (>5 micron) particulates
Cyclones	Cyclones use aerodynamic forces to separate particles from the gas stream.	Widely applicable to all fuels.	70%-90% total PM potential

Table 4-1.	Available	РМ	control	options	for	ICI boilers
1 abic 4-1.	11 vanabic	T TAT	control	options	101	ICI boncis

4.3 Description of Control Technologies

4.3.1 Fabric Filters

Fabric filters (also called baghouses) are essentially giant vacuum cleaners and very effective devices for collecting dry PM from flue gas. They are used in ICI and EGU applications, although less widely than ESPs. Separation occurs when the ash-laden flue gas passes through a porous layer of filter material. As the individual particles accumulate on the surface of the filter, they gradually form a layer of ash known as the "dust cake." Once formed, the dust cake provides most of the filtration. However, they are not particularly well suited for wet gas applications due to the negative impact of wet gas on the bag filters. *Figure 4-1* shows a photograph of the internal components of a fabric filter compartment with several individual bags and mounting mechanisms.



Figure 4-1. Photograph of fabric filter compartment with filter bags [Source: <u>www.hamon-researchcottrell.com</u>]

As shown in *Figure 4-1*, multiple bags are assembled in compartments to provide a large surface area for filtration. The large surface area is required to maintain acceptable pressure loss across the fabric. Groups of bags are placed in compartments, which can be isolated from one another to allow cleaning of the bags (see below), or to allow replacement of some of the bags without shutting down the entire baghouse.

Baghouse size is typically defined in terms of "air-to-cloth" ratio, expressed in the units of velocity in feet per minute (cubic feet per minute of flow divided by square feet of fabric area). The size of the baghouse depends on the particulate loading and characteristics, and the cleaning method used.

The type of bag cleaning method employed characterizes baghouses. Cleaning intensity and frequency are important because the dust cake provides a significant fraction of the fine particulate removal capability of a fabric. Hence, too frequent or too intense a cleaning method may lower the removal efficiency. Conversely, if removal of this dust cake happens infrequently or inefficiently, the pressure drop will increase to unacceptable levels. The major cleaning methods are as follows.

- Reverse-air baghouse In this case, the flue gas flows upward through the vertical bags, which open downward. The fly ash thus collects on the insides of the bags, and the gas flow keeps the bags inflated. To clean the bags, a compartment of the baghouse is taken off-line, and the gas flow in this compartment reversed. This causes the bags to collapse, and collected dust to fall from the bags into hoppers.
- Pulse-jet baghouse In this case, the dust is collected on the outside of the bags, which are mounted on cages to keep them from collapsing. Dust is removed by a reverse pulse of high-pressure air. This cleaning does not require isolation of the bags from the flue gas flow, allowing it to be done on-line. Because pulse-jet cleaning is more intensive than in reverse-air baghouses, the bags in a pulse-jet baghouse remain relatively clean, resulting in the ability to use a higher air-to-cloth ratio or a smaller baghouse compared to the reverse-air type.

Additionally, fabric filters can also be used in applications where fly-ash resistivity makes it difficult for collection with ESPs. Further, baghouses are capable of 99.9 percent removal efficiencies, as well as being able to remove the smaller size PM fraction ($PM_{2.5}$) more efficiently.

4.3.2 Electrostatic Precipitators

ESP's operate on the principle of electrophoresis by imparting a charge to the particulates and collecting them on opposed charged surfaces. Dry vs. wet ESPs refer to whether the gas is water-cooled and saturated prior to entering the charged collection area or is dry. *Figure 4-2* and *Figure 4-3* show schematic views of dry and wet ESPs, respectively. Older ESPs are often of the wire-pipe design, in which the collecting surface consists of one or more tubes (operated wet or dry). The wire-plate design is the other commonly used ESP design, as illustrated in the schematic in *Figure 4-2*.

In gases with high moisture content, dry ESPs are not suitable because the wet gas would severely limit the ability to collect the "sticky" particulates from the plates. The wet ESP technology is capable of very high removal efficiencies and is well suited for the wet gas environments. Both types of ESPs are capable of greater than 99 percent removal of particle sizes above 1 μ m on a mass basis with wet ESPs being capable of such reductions well into the sub-micron level (0.01 μ m) [Altman, 2001].



Figure 4-2. Side view of dry ESP schematic diagram [Source: Powerspan]



Figure 4-3. Wet ESP [Croll Reynolds]

Compared to fabric filters, ESPs affect the flue gas flow minimally, resulting in much lower pressure drops then an equivalent baghouse (typically less than two inches H_2O vs. greater than six inches H_2O for the fabric filter).

An electric field between high-voltage discharge electrodes and grounded collecting electrodes produces a corona discharge from the discharge electrodes, which ionizes the gas passing through the precipitator, and gas ions subsequently ionize fly ash (or other) particles. The negatively charged particles are attracted to the collecting electrodes. To remove the collected fly ash, the collecting electrodes are rapped mechanically, causing the fly ash to fall into hoppers for removal.

A balance generally needs to be struck between higher voltages for higher particulate removal efficiency and excessive sparking which will have the opposite effect. Larger ESPs are sectionalized (see *Figure 4-2*) such that higher voltages can be used in the first sections of the precipitator, where there is more particulate to be removed. Lower voltages are then used in the last, cleaner precipitator sections to avoid excessive sparking between the discharge and collecting electrodes. This has the added advantage that particles re-entrained in the flue gas stream by rapping (striking the electrode to dislodge the dust) may be collected in the downstream sections of the ESP.

Precipitator size is a major variable affecting overall performance or collection efficiency. Size determines residence time (the time a particle spends in the precipitator). Precipitator size also is typically defined in terms of the specific collection area (SCA), the ratio of the surface area of the collection electrodes to the gas flow. Higher SCA leads to higher removal efficiencies. Collection areas can range from as low as 200 to as high as 800 ft²/1000 acfm. In order to achieve collection efficiencies of 99.5 percent, SCA of 350-400 ft²/1000 acfm is typically used. The overall (mass) collection efficiencies of ESPs can exceed 99.9 percent, and efficiencies in excess of 99.5 percent are common. Precipitators with high overall collection efficiencies can achieve high efficiencies across a range of particle sizes so that good control of PM_{10} and $PM_{2.5}$ is possible with well designed and operated electrostatic precipitators.

Unlike dry ESPs, which use rapping to remove particulates from the collecting electrodes, wet ESPs use a water spray to remove the particulates. By continually wetting the collection surface, the collecting walls never build up a layer of particulate matter. This means that there is little or no deterioration of the electrical field due to resistivity, and power levels within a wet ESP can therefore be higher than in a dry ESP. The ability to inject greater electrical power within the wet ESP and elimination of secondary re-entrainment are the main reasons a wet ESP can collect sub-micron particulate more efficiently.

Overall, ESPs have historically been the collection device of choice for many applications in the ICI boiler and EGU boiler sectors. High removal efficiencies are possible and the units are rugged and relatively insensitive to operating upsets. Wet ESPs offer performance characteristics for capturing $PM_{2.5}$ similar to fabric filters and are well suited for applications such as oil firing, for which fabric filters are less attractive, because the sticky ash particles produced from oil combustion can blind the bags.

4.3.3 Venturi Scrubbers

Venturi scrubbers for PM control operate on the principle of rapid mixing and impingement of PM with liquid droplets and subsequent removal with the liquid waste. For particulate controls, the venturi scrubber is an effective technology whose performance is directly related to the pressure loss across the venturi section of the scrubber. However, for higher collecting efficiencies and a wider range of particulate sizes, higher pressure drops are required. High-energy scrubbers operate at pressure losses of 50 to 70 inches of water. Higher pressure drop translates to higher energy consumption. Performance of scrubbers varies significantly across particle size range with as little as 50 percent capture for small (<2 microns) sizes to 99 percent for larger (>5 microns) sizes, on a mass basis. However, venturi scrubbers are seldom used as the primary PM collection device because of excessive pressure drop and associated energy penalties. *Figure 4-4* depicts a venturi scrubber.



Figure 4-4. Venturi scrubber [Croll Reynolds]

4.3.4 Cyclones

Cyclones are devices that separate particulates from the gas stream through inertial forces. As ash-laden gas enters the cyclone near the top, a high-velocity vortex is created inside the device. Heavy particles move outward due to centrifugal force and begin accumulating on the wall of the cyclone. Gravity continuously forces these particles to move downward where they collect in the lower, hopper region of the cyclone. The collected particles eventually discharge through an opening in the bottom of the hopper into a system that transports the particles to a storage area. Smaller and lighter particles that remain suspended in the flue gas move toward the center of the vortex before being discharged through the clean-gas outlet located near the top of the cyclone (see *Figure 4-5*).

Cyclones are comparatively simple devices in design and construction, with no moving parts. Cyclones can operate over a wide range of temperatures, which makes them attractive for smaller ICI boilers that do not have economizers and/or air preheaters (and thus higher stack temperatures than in EGU boilers). Pressure drops across cyclones are typically in the range of 2 to 8 inches of water for a single cyclone. Cyclones can be arranged in arrays (multi-cyclones) and have overall mass removal efficiencies of 70 to 90 percent with the corresponding increase in pressure drop. However, cyclone collection efficiencies are very sensitive to particle size, and control efficiency for fine particulate ($PM_{2.5}$) is poor [Licht, 1988].

Cyclones are most effective at high boiler loads, where flue gas flow rates are highest. From an operational perspective, cyclones have no moving parts, are not sensitive to fuel quality or gas temperature, and require only regular cleaning to avoid plugging. These characteristics have made them good options in the past, particularly in the absence of regulatory PM $_{2.5}$ requirements.



Figure 4-5. Schematic of a cyclone collector [www.dustcollectorexperts.com/cyclone]

Due to the limited potential for $PM_{2.5}$ capture, use of cyclones in new combustion applications is primarily limited to fluidized-bed boilers where they are used to re-circulate the bed material – and not as primary PM control devices.

4.3.5 Core Separator

The core separator is a mechanical device that operates based on aerodynamic separation (like cyclones), but also utilizes a "core separator." The separator portion of the device consists of multiple cylindrical tubes with one inlet and two outlets. One outlet allows for a clean gas stream to exit, while the other outlet is used for recirculating the concentrated stream. This recirculation stream then passes through the cyclone unit (see *Figure 4-6* [Resource Systems Group, 2001]), where it is further cleaned and returned to the separator. This sequential process enhances its overall control efficiency as compared to single or multiple cyclones.



Figure 4-6. Schematic (left) and actual (right) core separator system [EPA, 2003]

The core separator capability for PM removal falls between that of an ESP and a cyclone. Several systems are currently installed on coal- and wood-fired boilers. The core separator unit is capable of overall PM reductions of up to the 90 percent range. Its collection efficiency, however, diminishes to about 50 percent for $PM_{2.5}$. *Table 4-2* displays inlet and outlet PM concentrations and removal efficiency of a core separator at two different plants. *Table 4-3* presents estimated costs for the core separator for two different sizes and gas flow conditions.

Core Separator Inlet Loading (lb/million Btu)	Core Separator Outlet Loading (lb/million Btu)	Removal Efficiency	Boiler Type
0.17	0.07	59%	Wood Fired
0.846	0.214	75%	Stoker – Coal

Table 4-2. Core separator collection efficiency [USEPA, 2008; Resource Systems Group, 2001]

Boiler Size	MMBtu/hr	8	10
	Estimated gas temperature (°F)	500	500
	Estimated gas flow rate (acfm)	4979	5996
Core Separator Size and	Gas Flow per 12" module	660	660
Estimated Price (uninstalled)	-		
	Number of 12" Modules	7	9
	Estimated price	\$110,000	\$130,000
	Gas Flow per 24" Module	2640	2640
	Number of 24" Modules	1	2
	Estimated Price	\$55,000	\$83,000

Table 4-3. Core separator cost analysis [B. H. Eason to P. Amar, 2008]

4.4 Applicability of PM Control Technologies to ICI Boilers

The PM control technologies described in this section are widely available and are used in both ICI and EGU applications. Because all these PM controls are based on the collection of particulates from the flue gas, they are applicable to a variety of boiler types and ash-containing fuels, including coal, oil, wood, petroleum coke, and other waste fuels. Determining the most attractive option for individual applications is a case-by-case decision that needs to account for technical, economic, and regulatory considerations. One exception, as mentioned, is that fabric filters are not suitable for fuel oil applications due to the "stickiness" and composition of the ash.

4.5 Efficiency Impacts

PM control technologies do result in some parasitic energy loss as can be deduced from the brief descriptions of technologies above (see *Table 4-1*). The inherent energy losses associated with each technology are given below and summarized in *Table 4-4*.

- For Fabric Filters
 - o compressor (bag cleaning)
 - o flue gas pressure loss
 - electric power (heaters, ash handling)
- For ESPs
 - o transformer-rectifier (TR) power
 - o flue gas pressure loss
 - o electric power (heaters, ash handling)
- For Venturi Scrubber and Cyclone
 - o flue gas pressure loss

14	ible 4-4. Summary	of energy impacts it	n control technologie	3
Technology	Applicability	Performance (% Reduction)	Energy Impact (kW/1000 acfm)	Comments
Fabric Filter	Coal, Wood	99+	1 – 2	Pressure loss / compressor / ash handling
Dry ESP	Coal, Oil, Wood	99	0.5 – 1.5	Pressure loss / TR power / ash handling
Wet ESP	Coal, Oil, Wood	99+	3 - 6	Pressure loss / TR power / ash handling
Venturi Scrubber	Coal, Oil, Wood	70-90 (Not efficient for PM _{2.5})	5 - 11	Pressure loss
Cyclone	Coal, Wood	70-90 (Not efficient for PM _{2.5})	0.5 – 1.5	Pressure loss

Table 4-4. Summary of energy impacts for control technologies

4.6 PM Control Costs

The following tables summarize published PM control costs for ICI boilers reported in the literature [US EPA, 2003a; US EPA, 2003b; US EPA, 2003c; US EPA, 2003d; US EPA, 2003e; US EPA, 2003f; MACTEC, 2005]. Literature values of capital cost have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness
in dollars per ton of PM removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs. Reagents or consumables can make up a large portion of some of the operating costs, but these items do not always increase with the rate of inflation for chemical plant equipment. Thus, cost effectiveness values (or operating costs) from years before 2005 have not been reported.

Table 4-5 summarizes the published PM control costs for several different PM control technologies. In the EPA references, the capital costs were given in terms of dollars/scfm (2002 dollars). These costs were converted to dollars per MMBtu/hr using the flow rates given in Chapter Five and then converted to 2006 dollars, using the Chemical Engineering Plant Cost Index values.

The MACTEC capital costs [MACTEC, 2005] span a large range, because high and low estimates for capital equipment were used in the calculation. The EPA capital costs are much higher for the wire-pipe ESP (also known as a tubular ESP) than the wire-plate ESP. Note that a size was not given in the EPA cost estimate, so a range is shown. The capital cost comparison is similar for wet ESPs although the capital costs themselves (in dollars/MMBtu/hr) are higher for wet ESPs as compared to dry ESPs.

For fabric filters, pulse-jet and reverse-air fabric filters were considered. These types of equipment have similar collection efficiencies, but the capital costs and effectiveness of pulse-jet fabric filters are lower than that of reverse-air fabric filters.

	Table .		101 Costs ap	blied to rer bollers			
Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu /hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Dry ESP	90%	Coal	250	\$12 365-\$160 754	2005	\$171-\$1 300	7
Dry ESP	99%	Coal	250	\$12,365-\$160,754	2005	\$156-\$1,200	7
Dry ESP	90%	Oil	250	\$6.713-\$87.275	2005	\$2.584-\$21.009	7
Dry ESP	99%	Oil	250	\$6.713-\$87.275	2005	\$2.328-\$18.912	7
Dry ESP (Wire-Pipe)		Coal		\$6.571-\$41.070	2002	+_,=_= +_=,, =_=	1
Dry ESP (Wire-Plate)	90%-99%	Coal		\$3,286-\$10,843	2002		2
Dry ESP (Wire-Pipe)		Resid.Oil		\$5,198-\$32,486	2002		1
Dry ESP (Wire-Plate)	90%-99%	Resid.Oil		\$2,599-\$8,576	2002		2
Dry ESP (Wire-Pipe)		Dist.Oil		\$5,117-\$31,983	2002		1
Dry ESP (Wire-Plate)	90%-99%	Dist.Oil		\$2,559-\$8,443	2002		2
Dry ESP (Wire-Pipe)		Wood		\$7,560-\$47,249	2002		1
Dry ESP (Wire-Plate)	90%-99%	Wood		\$3,780-\$12,474	2002		2
ESP	99.50%	Wood	Small		2005	\$594	8
ESP	99.50%	Wood	Medium		2005	\$203-\$292	8
ESP	99.50%	Wood	Large		2005	\$114-130	8
Fabric Filter	90%	Coal	250	\$7,453-\$93,158	2005	\$444-\$1,006	7
Fabric Filter	99%	Coal	250	\$7,453-\$93,158	2005	\$423-\$957	7
Pulse-Jet Fabric Filter	95%-99.9%	Coal		\$1,971-\$8,543	2002		5
Reverse-Air FF	95%-99.9%	Coal		\$3,286-\$28,585	2002		6
Fabric Filter	90%	Oil	250	\$4,046-\$50,577	2005	\$7,277-\$16,464	7
Fabric Filter	99%	Oil	250	\$4,046-\$50,577	2005	\$6,915-\$15,643	7
Pulse-Jet Fabric Filter	95%-99.9%	Resid.Oil		\$1,559-\$6,757	2002		5
Reverse-Air FF	95%-99.9%	Resid.Oil		\$2,559-\$22,260	2002		6
Pulse-Jet Fabric Filter	95%-99.9%	Dist.Oil		\$1,535-\$6,652	2002		5
Reverse-Air FF	95%-99.9%	Dist.Oil		\$2,599-\$22,610	2002		6
Fabric Filter	99.50%	Wood	Small		2005	\$958	8
Fabric Filter	99.50%	Wood	Medium		2005	\$147-249	8
Fabric Filter	99.50%	Wood	Large		2005	\$91-\$107	8
Pulse-Jet Fabric Filter	95%-99.9%	Wood		\$2,268-\$9,829	2002		5
Reverse-Air FF	95%-99.9%	Wood		\$3,780-\$32,886	2002		6

Table 4-5. PM control costs applied to ICI boilers

Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Wet ESP	90%	Coal	250	\$25,968-\$252,260	2005	\$906-\$2,627	7
Wet ESP	99.9%	Coal	250	\$25,968-\$252,260	2005	\$815-2,365	7
Wet ESP (Wire-						. ,	
Pipe)	90%-99.9%	Coal		\$13,142-\$65,712	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Coal		\$6,571-\$13,142	2002		4
Wet ESP	90%	Oil	250	\$14,098-\$136,955	2005	\$14,938-\$43,036	7
Wet ESP	99.9%	Oil	250	\$14,098-\$136,955	2005	\$13,446-\$38,736	7
Wet ESP (Wire-							
Pipe)	90%-99.9%	Resid.Oil		\$10,395-\$51,977	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Resid.Oil		\$5,198-\$10,395	2002		4
Wet ESP (Wire-							
Pipe)	90%-99.9%	Dist.Oil		\$10,235-\$51,172	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Dist.Oil		\$5,117-\$10,234	2002		4
Wet ESP (Wire-							
Pipe)	90%-99.9%	Wood		\$15,120-\$75,599	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Wood		\$7,560-\$15,120	2002		4

Table 4-5 [continued]

References

1. US EPA, Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) - Wire-Pipe Type; EPA-452/F-03-027, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fdespwpi.pdf

2. US EPA, Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) - Wire-Plate Type; EPA-452/F-03-028, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf

3. US EPA, Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) - Wire-Pipe Type; EPA-452/F-03-029, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fwespwpi.pdf

4. US EPA, Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) - Wire-Plate Type; EPA-452/F-03-030, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fwespwpl.pdf

5. US EPA, Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type; EPA-452/F-03-025, July 15, 2003.

http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf

6. US EPA, Air Pollution Control Technology Fact Sheet: Fabric Filter - Reverse-Air Cleaned Type; EPA-452/F-03-026, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ff-revar.pdf

7. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

8. STAPPA. Controlling PM2.5 Under the Clean Air Act: A Menu of Options; STAPPA/ALAPCO: March 2006.

4.7 Chapter 4 References

Caine, John, Shah, Hardik. "Next Generation Wet Electrostatic Precipitators," presented at 101st Air & Waste Management Association Annual Meeting, Portland, OR, June 24-26, 2008.

Licht, William (1988). *Air Pollution Control Engineering*, 2nd Edition. New York: Marcel Dekker.

Eason, B. "Core Separator Field Performance Data Summary 080118," personal communication to P. Amar, NESCAUM, September 2008.

MACTEC. Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

Resource Systems Group (2001). "An Evaluation of Air Pollution Control Technologies for Small Wood-Fired Boilers." Prepared for Vermont Department of Public Service, Vermont Department of Environmental Conservation (Air Pollution Control Division), New Hampshire Governor's Office of Energy Resources and Community Services, and Massachusetts Division of Energy Resources.

STAPPA. Controlling PM2.5 under the Clean Air Act: A Menu of Options; STAPPA/ALAPCO: March 2006.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) – Wire-Pipe Type; EPA-452/F-03-027, July 15, 2003a. http://www.epa.gov/ttn/catc/dir1/fdespwpi.pdf.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) – Wire-Plate Type; EPA-452/F-03-028, July 15, 2003b. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) – Wire-Pipe Type*; EPA-452/F-03-029, July 15, 2003c. http://www.epa.gov/ttn/catc/dir1/fwespwpi.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) – Wire-Plate Type*; EPA-452/F-03-030, July 15, 2003d. http://www.epa.gov/ttn/catc/dir1/fwespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003e. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter – Reverse-Air Cleaned Type*; EPA-452/F-03-026, July 15, 2003f. <u>http://www.epa.gov/ttn/catc/dir1/ff-revar.pdf</u>.

US EPA. *LSR Success Stories*; Acton, MA, December 16, 2003. http://es.epa.gov/ncer/sbir/success/pdf/lsr_success.pdf.

5 APPLICATION OF A COST MODEL TO ICI BOILERS

When evaluating the applicability of pollution control equipment to a specific ICI boiler, cost and performance capability need to be considered. A number of cost estimation models have been created for estimation of capital and operating costs of retrofit technology for air pollutants. However, most of the cost models have been developed for and applied to EGUs burning coal. Much less work has been carried out on cost estimation models for ICI boilers. In this Chapter, a cost modeling approach currently used for estimating control costs for coal-burning EGUs is modified and then investigated for its applicability to ICI boilers burning coal as well as other fuels. The purpose of this Chapter is to present this modified cost model (CUECost-ICI) and resulting cost calculations. The strengths and weaknesses of this approach are also discussed. However, the purpose of this effort is not to carry out an exhaustive calculation of costs, but to generate a set of reasonable cost estimates for ICI boilers burning different fuels and compare them with published cost information.

5.1 Cost Model Inputs and Assumptions

The Coal Utility Environmental Cost (CUECost) model was developed by Raytheon Engineers for EPA; version 3, and is available on EPA's website at <u>http://www.epa.gov/ttn/catc/products.html</u>. The model calculates capital and operating costs for certain predefined air pollution control devices for control of NOx, SO₂, and PM as applied to coal-fired power plants. The CUECost model produces approximate cost estimates (±30 percent accuracy) of the installed capital and annualized operating costs. The CUECost model was originally designed for and is intended for use on coal-fired boilers greater in size than 100 MW (about 1,000 MMBtu/hr heat input).

Table 5-1 gives the general plant inputs that are needed to set up the model; more inputs are needed for specific air pollution control devices (see Appendix B).

Input Parameter	Comment
Location - State	
	This was designed for EGUs, but can be scaled to
MW Equivalent of Flue Gas to Control System	generate the appropriate gas flow for ICIs
Net Plant Heat Rate	Function of the efficiency of the plant
Plant Capacity Factor	Use averages from EEA study, parametric variations
Percent Excess Air in Boiler	Assume $3\% O_2$ for NG and oil, $7\% O_2$ for coal, wood
	Determines the flow rate for downstream devices such as
Air Heater In-leakage	scrubbers and particulate control devices
Air Heater Outlet Gas Temperature	
Inlet Air Temperature	
Ambient Absolute Pressure	
Pressure After Air Heater	
Moisture in Air	
Ash Split:	Depends on firing system
Fly Ash	
Bottom Ash	
Seismic Zone	
Retrofit Factor	Moderate effect on total capital requirement (TCR)
(1.0 = new, 1.3 = medium, 1.6 = difficult)	
Select Fuel	User can define "coal" with respect to HHV, %S, %ash

Table 5 1	CUECost	gonorol	nlant	innuta
1 able 5-1.	CUECOSI	general	plant	inputs

The EPA version of CUECost contains the following modules for specific air pollution control devices:

- Limestone forced-oxidation, wet FGD scrubber
- Lime spray dryer
- FF
- ESP
- SCR
- SNCR
- LNB
- Natural Gas Reburn

CUECost bases the costs of equipment and operation on the generating capacity (in MW of electricity generated) of a given boiler. Industrial boilers are usually rated by the heat input (in MMBtu/hr); the boiler heat rate is used to convert from heat input to the equivalent size in MW. In order to use CUECost in its present form for ICI boilers, an equivalent size in MW needs to be estimated, although this could be modified in a dedicated ICI boiler version of CUECost (which was not developed in this effort).

Industrial boilers are operated differently from utility boilers, and the inputs for CUECost-ICI must be adjusted accordingly, including:

- Heat rate
- Excess air level

- Flue gas temperatures
- Capacity factor

The default values in the current version of CUECost for EGUs generally do not describe ICI boilers well. Fuel compositions vary widely for ICI boilers, while the EGU version of CUECost includes coal as the only fuel option (with different compositions). However, the user can define other fuels, as described below.

An important factor in determining total installed capital cost is the choice of appropriate retrofit factor, which expresses the difficulty of installing a control technology in an existing plant. In CUECost a retrofit factor of 1.0 denotes a new plant (corresponding to the lowest capital cost), and retrofit factors of 1.3 and 1.6 denote medium and difficult retrofits, respectively. Emmel [2006] noted that this range of retrofit factors significantly understated the cost of retrofit for FGD and SCR technologies when applied to EGUs less than 100 MW. Emmel also noted that on average a retrofit factor of 1.45 was more reasonable and that the factor should be even higher when CUECost is applied to ICI boilers.

The technology options in CUECost are also fixed, and the user cannot create a new technology option without supplying formulae for calculating the capital equipment cost. The technology options for SO_2 control in CUECost, in particular, have been noted to be more appropriate for larger utility boilers than for ICI boilers. Wet FGD and spray dryer technology – the SO_2 scrubbing options in CUECost – are based on lime or limestone reagents and have high capital and operating costs compared to alkaline scrubbers or duct injection. The latter scrubbing options might be more attractive for ICI boilers, but would have to be added to the current version of CUECost.

Finally, Emmel [2006] notes that most ICI boiler sites will have higher contingency, general facility, engineering, and maintenance costs (on a percentage of capital cost basis) than those identified for EGUs in CUECost in order to take into account necessary upgrades or demolition of existing facilities that are less likely to be needed at sites.

In this effort, the CUECost model was adapted for ICI boilers burning a variety of fuels by changing the fuel composition and heating value to simulate different fuels. Capital and operating costs in the model were based on correlations derived from coal-fired power plant experience since no reliable field data were available for the ICI boilers. It is not clear how robust the correlations for capital equipment are for small (≤ 25 MW equivalent) boilers.

The CUECost model is based on the electrical generating capacity. A combustion calculation was used to relate heat input rate to equivalent MW for five different fuels.

Table 5-2 gives the properties of these fuels. Boiler efficiency was specified, and heat rate was calculated from boiler efficiency. The uncontrolled or baseline emissions were based on fuel composition (in the case of SO_2 and PM) or on industry operating experience (in the case of NOx).

Table 5-3 shows the results (in terms of calculated flue gas flow rates) of the combustion calculations for a fixed heat input rate of 250 MMBtu/hr or 100 MMBtu/hr. Flue gas flow rate is an important parameter or input to the cost model, because the size of capital equipment is often related to the flue gas flow rate.

	Bituminous	Wood	No.2 Oil	No.6 Oil	Gas
C, wt%	76.2	27.6	86.4	85.8	75
S, wt%	2.5	0.04	0.6	2.5	0
H wt%	4.6	3.3	12.7	10.6	25
Moisture, wt%	1.4	45	0.02	0.02	0
N _, wt%	1.4	0.3	0.1	0.5	0
O, wt%	7	22.86	0.1	0.5	0
Ash, wt%	6.9	0.9	0.08	0.08	0
Fuel heating value, BTU/lb	13,630	4,633	19,563	18,273	20,800
Unburned carbon, wt% in ash	5	1	75	75	0
Boiler efficiency*	34%	30%	39%	39%	45%
Stack O ₂ , vol% dry	7%	7%	3%	3%	3%
Boiler heat rate, Btu/kWh	10,000	11,370	8,750	8,750	7,600
Uncontrolled or Baseline					
emissions					
NOx, lb NO ₂ /MMBtu	0.60	0.26	0.20	0.40	0.40
SO ₂ , lb/MMBtu	3.67	0.17	0.61	2.74	0.00
PM, lb/MMBtu	5.06	1.94	0.04	0.04	0.00

Table 5-2. Fuel characteristics and assumptions for CUECost calculation of heat rate and flue gas flow rates

*Fuel to MW

Table 5-3.	Equivalent	heat input ra	te and flue gas	flow rates t	for 250 and	100 MMBtu/hr	· heat input rates
I dole e et	Equivalence	neue mpue ru	te una mae gus	no n naves i	tor aco una		near mpar races

	MW	MMBtu/hr	Flue gas, scfm
Bituminous coal (34% efficiency, 7% O_2)	25.0	250	65,305
Wood (30% efficiency, 7% O ₂)	22.0	250	81,184
No.2 oil (39% efficiency, 3% O ₂)	28.6	250	50,622
No.6 oil (39% efficiency, 3% O_2)	28.6	250	51,117
Natural gas (45% efficiency, 3% O ₂)	32.9	250	59,336
Bituminous coal (34% efficiency, 7% O ₂)	10.0	100	26,122
Wood (30% efficiency, 7% O ₂)	8.8	100	32,474
No.2 oil (39% efficiency, 3% O ₂)	11.4	100	20,178
No.6 oil (39% efficiency, 3% O ₂)	11.4	100	20,375
Natural gas (45% efficiency, 3% O ₂)	13.2	100	23,806

5.2 Comparison of the Cost Model Results with Literature

A comparison was made of the CUECost-ICI model with other published information for a selection of fuels and air pollution control devices applied to ICI boilers. Where possible, the inputs for the model were set to be the same as information cited in the literature.

Using the appropriate fuel composition and boiler heat rates, the modified ICI version of the original CUECost (CUECost-ICI) model was run for a number of ICI boiler cases. *Table 5-4*, *Table 5-5*, and *Table 5-6* show the installed capital costs, first-year annual operating costs, and cost per ton of pollutant removed for NOx, SO₂, and PM, respectively. Capital and operating costs were calculated on 2006 dollars basis in the CUECost-ICI model. A complete

list of inputs to CUECost-ICI is included in Appendix B. For the NOx and SO_2 control technologies, percentage reduction of the pollutant was used as an input, so that the CUECost-ICI results could be easily compared to published literature results. For PM controls, a specific emission limit (in lb/MMBtu) was used as an input and the percentage PM reduction was calculated from the fuel ash content.

	Pollutant				Installed		
	removal			_	Capital	Annual	
MMBtu/hr	efficiency	Fuel	Technology	Reagent	Cost, \$M	Cost, \$M	Cost/ton
250	80.0%	Coal	SCR	Ammonia	\$4.394	\$1.253	\$4,763
100	80.0%	Coal	SCR	Ammonia	\$2.585	\$0.702	\$6,668
250	80.0%	No.6 Oil	SCR	Ammonia	\$2.923	\$0.790	\$3,972
100	80.0%	No.6 Oil	SCR	Ammonia	\$1.760	\$0.460	\$5,805
250	80.0%	Nat.Gas	SCR	Ammonia	\$3.005	\$0.811	\$4,673
100	80.0%	Nat.Gas	SCR	Ammonia	\$1.805	\$0.472	\$6,777
250	50.0%	Coal	SNCR	Ammonia	\$1.142	\$0.398	\$2,422
100	50.0%	Coal	SNCR	Ammonia	\$0.969	\$0.317	\$4,817
250	50.0%	No.6 Oil	SNCR	Ammonia	\$0.724	\$0.338	\$2,722
100	50.0%	No.6 Oil	SNCR	Ammonia	\$0.407	\$0.196	\$3,961
250	50.0%	Nat.Gas	SNCR	Ammonia	\$0.785	\$0.362	\$3,335
100	50.0%	Nat.Gas	SNCR	Ammonia	\$0.443	\$0.209	\$4,798
250	40.0%	Coal	LNB		\$1.227	\$0.301	\$2,290
100	40.0%	Coal	LNB		\$0.677	\$0.166	\$3,155
250	40.0%	No.6 Oil	LNB		\$1.339	\$0.329	\$3,305
100	40.0%	No.6 Oil	LNB		\$0.737	\$0.181	\$4,559
250	40.0%	Nat.Gas	LNB		\$1.467	\$0.360	\$4,151
100	40.0%	Nat.Gas	LNB		\$0.810	\$0.199	\$5,715

 Table 5-4. Capital and operating costs for NOx control technologies (assuming 7.5 percent interest and 15-year project life)

							Cost
	Pollutant				Installed		Effectiveness
	removal				Capital	Annual	(dollars per
MMBtu/hr	efficiency	Fuel	Technology	Reagent	Cost, \$M	Cost, \$M	ton)
250	95%	Coal	wFGD	Limestone	\$38.096	\$11.137	\$4,427
100	95%	Coal	wFGD	Limestone	\$33.680	\$9.608	\$9,547
250	95%	No.6 Oil	wFGD	Limestone	\$36.642	\$10.733	\$5,713
100	95%	No.6 Oil	wFGD	Limestone	\$32.805	\$9.368	\$12,510
250	90%	Coal	SD	Lime	\$29.598	\$8.806	\$3,694
100	90%	Coal	SD	Lime	\$26.263	\$7.540	\$7,909
250	90%	No.6 Oil	SD	Lime	\$28.463	\$8.371	\$4,704
100	90%	No.6 Oil	SD	Lime	\$25.723	\$7.344	\$10,352

Table 5-5. Capital and operating costs for SO₂ control technologies (assuming 7.5 percent interest and 15-year project life)

 Table 5-6. Capital and operating costs for PM control technologies (assuming 7.5 percent interest and 15-year project life)

									Cost
									Effective
	Pollutant			PM	Installed	Capital	Capital	Annua	ness (
	removal			Emission,	Capital	cost,	cost,	l Cost,	dollars
MMBtu/hr	efficiency	Fuel	Technology	lb/MMBtu	Cost, \$M	\$/scfm	\$/acfm	\$M	per ton)
250	99.3%	Coal	ESP	0.03	\$4.05	\$62.00	\$43.00	\$1.11	\$342
100	99.3%	Coal	ESP	0.03	\$2.31	\$88.50	\$61.50	\$0.63	\$485
250	99.3%	Coal	FF	0.03	\$4.77	\$73.00	\$50.70	\$1.32	\$406
100	99.3%	Coal	FF	0.03	\$2.88	\$110.20	\$76.60	\$0.78	\$592
250	95.8%	No.6 Oil	ESP	0.01	\$3.40	\$66.60	\$46.30	\$0.93	\$5,689
100	95.8%	No.6 Oil	ESP	0.01	\$2.02	\$99.00	\$68.80	\$0.55	\$8,410
250	95.8%	No.6 Oil	FF	0.01	\$4.09	\$80.00	\$55.60	\$1.14	\$6,940
100	95.8%	No.6 Oil	FF	0.01	\$2.50	\$122.80	\$85.30	\$0.68	\$10,354

For comparison, the American Forest & Paper Association (AF&PA) calculated SNCR control costs in 2006 for wood-fired boilers ranging in size from 88 to 265 MMBtu/hr [Hunt, 2006]. *Table 5-7* below compares the AF&PA costs with the CUECost-ICI costs for wood-fired boilers. The installed capital cost values agree well between CUECost-ICI and the AF&PA estimates, although the CUECost-ICI values for cost effectiveness (dollars per ton of NOx removed) are 20 to 25 percent lower than the AF&PA estimates.

MMBtu/hr	Pollutant removal efficiency	Fuel	Technology	Reagent	Installed Capital Cost, \$M	Annual Cost, \$M	Cost, \$/ton
AF&PA	-						
88.5	70.0%	Wood	SNCR	Urea	\$0.924	\$0.250	\$11,283
176.9	70.0%	Wood	SNCR	Urea	\$1.400	\$0.384	\$8,574
285.4	70.0%	Wood	SNCR	Urea	\$1.786	\$0.502	\$7,480
CUECost							
88.5	70.0%	Wood	SNCR	Urea	\$0.923	\$0.289	\$9,239
176.9	70.0%	Wood	SNCR	Urea	\$1.025	\$0.324	\$5,174
285.4	70.0%	Wood	SNCR	Urea	\$1.130	\$0.361	\$5,011

Table 5-7.	Capital and operating costs for SNCR on wood-fired boilers, comparison of cost calculations from
AF&PA and	nd CUECost

Finally, the CUECost-ICI model results for capital cost were compared with some of the values reported in the literature [US EPA, 1996; NESCAUM, 2000; US EPA, 2003a; US EPA, 2003b; Whiteman, 2006], where available. Literature values of capital costs have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using Chemical Engineering Plant Cost Index values.

The NOx capital costs computed with CUECost-ICI were largely consistent with the literature values. (Chapter Two contains a detailed discussion of the literature values for NOx control costs.)

Figure 5-1 compares capital costs for SCR for boilers burning coal, residual (No. 6) oil, and natural gas. The SCR costs appear to be consistent with the literature values. The literature value for SCR as reported by the Ozone Transport Assessment Group (OTAG) [US EPA, 1996] did not describe its basis in any detail, so it is difficult to determine if the OTAG cost estimates assumed a significantly different space velocity or different equipment than assumed in the CUECost-ICI model.



Figure 5-1. Comparison of CUECost-ICI model and reported literature values for capital cost of SCR for NOx control

The capital costs for SNCR (*Figure 5-2*) calculated from the CUECost-ICI model are in good agreement with literature values, particularly the sensitivity of capital cost to boiler capacity, which was also noted by ICAC [Whiteman, 2006].

The capital costs for LNB (*Figure 5-3*) calculated from the CUECost-ICI model for coalfired boilers were consistent with the literature values, although the capital costs for residual oilfired boilers were higher in the CUECost-ICI model than the literature values. Again, no details were provided in the literature references.



Figure 5-2. Comparison of CUECost-ICI model and reported literature values for capital cost of SNCR for NOx control





5-9 Appendix III.D.7.7-4300 Chapter Three contains a detailed discussion of the literature values for SO_2 control costs. The SO_2 capital costs computed with CUECost-ICI for spray dryers (SDs) were in the range of the literature values at boiler size of 250 MMBtu/hr (*Figure 5-4*). No literature data were available for residual oil-fired boilers and spray dryers. However, the capital costs calculated by CUECost –ICI for wet FGDs (*Figure 5-5*) were high when compared to the literature values.



Figure 5-4. Comparison of CUECost-ICI model and reported literature values for capital cost of Spray Dryer for SO₂ control



Figure 5-5. Comparison of CUECost-ICI model and reported literature values for capital cost of wet FGD for SO₂ control

Literature values for capital costs for PM control were evaluated from EPA reports on PM controls applied to ICI boilers [US EPA, 2003a; US EPA, 2003b]. In these references, the capital costs were given in terms of dollars/scfm (2002\$). These costs were converted to dollars per MMBtu/hr using the flow rates in *Table 5-3* and then converted to 2006 dollars, using the Chemical Engineering Plant Cost Index values. Chapter Four contains a detailed discussion of the literature values for PM control costs.

The dry ESP control costs computed with CUECost-ICI were consistent with the literature values, although the CUECost-ICI predicted slightly higher values than reported by EPA for dry, wire-plate ESPs [US EPA, 2003a]. Note that a size was not given in the EPA cost-estimate. The FF costs computed with CUECost-ICI were higher than the literature values for pulse-jet fabric filters [US EPA 2003b].

5.3 Summary

An existing EPA model for estimating costs of selected control technology for NOx, SO₂, and PM for coal-fired EGU boilers greater than 1,000 MMBtu/hr was adapted for ICI boilers. Inputs were modified to allow a wider variety of fuels and to express boiler capacity in MMBtu/hr instead of MW. Modification of the correlations used for the coal-fired EGU model to calculate capital and operating costs for ICI boilers was outside the scope of this work. The new model, CUECost-ICI provided good agreement with published values of capital cost of APCD equipment for small boiler sizes for coal-, oil- and natural gas-fueled boilers. The resulting model provided a quick and flexible means to estimate capital and operating costs of

specific control technologies as applied to ICI boilers. Further detailed and extensive work will be needed to validate and refine the model's calculation framework for ICI boilers, and to add other APCD technologies to the model.

5.4 Chapter 5 References

Emmel, Thomas. RTP Environmental Associates, "Use of CUECost Model for Developing Cost Estimates for Industrial Size Boilers," memorandum to Pat Dennis, Archer Daniels Midland Company, Robert Bessett, Council of Industrial Boiler Owners, March 22, 2006.

Hunt, T. American Forest & Paper Association, "AF&PA Comments on Draft NOx Model Rule and Related 6.7.06 OTC Resolution," letter to Christopher Recchia, Executive Director, Ozone Transport Commission, November 1, 2006.

MACTEC. *Boiler Best Available Retrofit Technology (BART) Engineering Analysis*; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness (Praveen Amar, Project Director), December 2000.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) -Wire-Plate Type; EPA-452/F-03-028, July 15, 2003a. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003b. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

US EPA. *OTAG Technical Supporting Document*, Chapter 5, Appendix C, 1996. <u>http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/</u>.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003b. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

Whiteman, C. ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

6 SUMMARY

ICI boilers are a significant source of NO_x , SO_2 , and PM emissions, and are relatively uncontrolled, compared to EGUs. More than half of the surveyed ICI boilers in the Northeast have no controls, approximately one-third have PM controls, very few units have NOx controls, and no units have SO_2 controls.

There are a range of technology options for cost-effectively reducing emissions of NOx, SO₂, and PM emissions from ICI boilers in the U.S. Operating costs may differ for ICI boilers than utility boilers, primarily because of their size and location. ICI boiler sites typically have higher contingency, general facility, engineering, and maintenance costs as a percentage of total capital cost than do utility boilers. While ICI boilers often have cost constraints due to their sizes and diversity of plant layout and settings, these factors also provide opportunities for low-cost applications. It is critical to conduct site-specific suitability analyses to assess performance potential or retrofit feasibility, and match the appropriate emission control technology for specific applications given boiler size, fuel type/quality, duty-cycle, and design characteristics.

This study adapted the CUECost model -- initially developed by EPA to estimate costs of selected control technology for NOx, SO₂, and PM for large coal-fired EGU boilers -- to assess ICI boiler control costs. The modeling results were consistent with published values of capital cost of APCD equipment for small boiler sizes for coal-, oil- and natural gas-fueled boilers.

6.1 NOx Controls

Most of the commercially available NOx control technologies used extensively in EGUs may also apply to ICI boilers. Some technologies have potential to capture mercury from the flue gas. Employing a combination of technologies can be more effective in reducing emissions than a stand-alone technology. While most of these technologies can be used together, some combinations may be more cost-effective. This should be assessed on a site- and strategy-specific basis. Options include:

- Boiler Tuning or Optimization, which can yield reductions of five to 15 percent or more;
- *Low-NOx Burner (LNB) and Overfire Air (OFA)*, which can be used separately or as a system, and can reduce NOx emissions by 40 to 60 percent. LNBs are applicable to most ICI boiler types, and are being increasingly used at ICI boilers less than 10 MMBtu/hr. These technologies require site-specific suitability analyses, as several important parameters can have substantial impact on their performance or even retrofit feasibility.
- *Ultra Low-NOx Burners (ULNB)*, which can achieve NOx emission levels on the order of single digits in ppm.
- *Reburn*, which has been used only in large EGU applications, but is an option for larger watertube-type boilers, including stokers. It requires appropriate technical and economic analyses to determine suitability. Reburn may yield 35 to 60 percent reductions in NOx emissions.
- *Selective Catalytic Reduction (SCR)*, which can achieve reductions higher than 90 percent.

- *Selective Non-Catalytic Reduction (SNCR)*, which can achieve between a 30 to 60 percent reduction in NOx.
- *Regenerative Selective Catalytic Reduction (RSCRTM)*, which is able to reduce NOx by 60 to 75 percent and CO by about 50 percent. These systems allow efficient use of an SCR downstream of a particulate control device, where the flue gas typically has a lower temperature than what is required for a conventional SCR. Such conditions are encountered in some ICI boilers firing a variety of fuels, including biomass.

NOx control technologies involving combustion modification have essentially no impact on the CO_2 emissions of the host boilers, with the exception of reburn. SNCR and SCR impose some degree of energy demand on the host boiler, including pressure, compressor, vaporization, and steam losses.

Most estimates for ICI boilers indicate capital costs in the range of \$1,000 to \$6,000 per MMBtu/hr and \$1,000 to \$7,000 per ton of NOx removed. LNBs and SNCR costs range from \$1,000 to \$3,000 per ton. For SCR, costs are between \$2,000 and \$14,000 per ton. SCR and SNCR costs are driven primarily by the consumption of the chemical reagent.

6.2 SO₂ Controls

ICI boilers firing coal are good candidates for employing SO_2 control technologies. Options include:

- Flue Gas Desulfurization (FGD) or Scrubbers. These technologies are commercially • available, and have been used extensively on EGUs since the 1970s. Wet scrubbers (Wet FGD) are the predominant SO_2 control technology currently in use for EGUs, and are typically associated with high-sulfur applications. Dry scrubbers include Spray Dryers (SD) and Dry Sorbent Injection (DSI) technologies, and are more compatible with lowto medium-sulfur coals. Some dry scrubber systems can remove 20 to 60 percent of the SO₂, and in some cases up to 90 to 99 percent for HCl and SO₃. DSI technologies are currently being demonstrated on ICI boilers. Furnace Sorbent Injection systems used on cement plants are capable of SO₂ reductions of up to 90 percent for industrial applications and ICI boilers, as well as HCl and HF reductions of greater than 95 percent. For SDs, cost per ton of SO₂ removed was in the range of \$1,600 to \$5,000. Costs were between \$1,900 and \$3,800 per ton of SO₂ for wet FGDs. While the SO₂ capital costs computed with CUECost for SDs were consistent with the literature at 250 MMBtu/hr, the capital costs computed for wet FGDs were high compared to values reported in the literature.
- *Fuel switching*. While not a control technology *per se*, the emission reduction benefits of fuel switching are directly proportional to the difference in sulfur contents of the fuels. Fuel switching requires considerable cost and operational analyses. In the NESCAUM region, residual oil is commonly used in ICI boilers. Switching from a 3 to a 1 percent sulfur residual oil can provide cost-effective SO₂ reductions at about \$771 per ton of SO₂ removed. For oil-fired ICI boilers, switching to lower-sulfur oil can provide significant reductions in emissions of SO₂, as well as in PM_{2.5}. The cost of switching to distillate oil is estimated to be much higher than for residual oil, because the higher cost of distillate oil.

6.3 PM Controls

ICI boilers burn a variety of fuels that contain fly ash and thus emit PM. PM control technologies have been commercially available and widely used in EGU boilers for many years. While PM controls are not currently widely used on ICI boilers, there are no technical reasons why PM controls cannot be applied to solid-fueled and oil-fired boilers. They are very effective in removing total PM and $PM_{2.5}$, with most options removing greater than 99 percent. The options include: (1) fabric filters or baghouses; (2) wet and dry electrostatic precipitators (ESPs); (3) venturi scrubbers; (4) cyclones; and (5) core separators. Control technology decisions should be made on a case-by-case basis that accounts for technical, economic, and regulatory considerations. Fabric filters are not suitable for fuel oil applications due to the "stickiness" and composition of the ash. The cost effectiveness of baghouses was in the range of \$50 to \$1,000 per ton of PM removed for coal and up to \$15,000 per ton of PM removed for oil. The cost effectiveness of ESPs was in the range of \$50 to \$500 per ton of PM for coal, and up to \$20,000 per ton of PM for oil. PM control technologies will result in some parasitic energy loss due to pressure loss, power consumption, and ash handling. Dry ESPs and fabric filters have the lowest associated parasitic power consumption (<2 kW/1000 acfm), while high-energy venturi scrubbers can have a larger parasitic consumption – up to 10 kW/1000 acfm or higher.

APPENDIX A: Survey of Title V Permits in NESCAUM Region

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,N	IJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Solutia Incorporated	MA	Foster Wheeler	249	Coal (Bit. 0.7%S)	-	0.027	baghouse (Carborundum Environmental Systems)	1.2	-	0.525	OFA (Foster wheeler)	-
St. Gobain Abrasives	MA	Riley	230	Coal (Subbit. 0.63%S)	-	0.1	Dust Collector	1.1	-	0.45	LNB	-
UMASS Amherst	MA	Union Iron Works	80	Coal	-	0.12	baghouse	1.1	-	0.43	-	Convert to CHP No. 2 (9/07)
Cooley Dickinson Hospital	MA	Early 1980s	-	Wood	-	-	-	0.008	-	0.16	-	-
Cooley Dickinson Hospital	MA	2006/ AFS Energy Systems	29.88	Wood	-	0.01	Cyclone, Baghouse	0.025	-	0.15	FGR	-
Seaman Paper	МА	2006/ Hurst Boiler	29.88	Wood	-	0.01	Baghouse	0.025	-	0.15	FGR	-

ICI Coal and W	ood Fire	d in NESCAUM	Region (CT,M	A,ME,NH,N	J,NY,RI,VT)	F	M	s	02	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Cornell University	NY	-	248	Coal	-	0.3	Fabric Filter	Coal 1% S by weight	-	0.4	-	
Cornell University	NY	-	117	Coal	-	0.35	Fabric Filter	Coal 1% S by weight	-	0.4	-	-
Commonwealth Plywood	NY	-	16	Wood	-	-	Multi- Cyclone w/o Fly ash injection	-	-	-	-	-
Crawford Furniture	NY	-	6	Wood	-	-	Single Cyclone	-	-	-	-	-
Deferiet Paper Company	NY	1945/ Combustion Engineering	190	Coal	-	0.46	Multi- Cyclone w/o Fly ash injection, and wet Venturi scrubber	2.5	-	0.5	-	-
Eastman Kodak	NY	-	265	Coal (Bit.)	-	0.26	ESP	2.5 (coal)	-	0.53	-	Boiler # 13

ICI Coal and	l Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	• M	S	D ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Eastman Kodak	NY	-	265	Coal (Bit.)	-	0.26	ESP	2.5 (coal)	-	0.53	-	Boiler # 14
Eastman Kodak	NY	-	478	Coal (Bit.)	#2 Oil	0.26	ESP	-	-	-	-	Boiler # 15
Eastman Kodak	NY	-	500	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 41
Eastman Kodak	NY	-	500	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 42
Eastman Kodak	NY	-	640	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 43
Eastman Kodak	NY	-	705	Coal (Bit.)	#2 Oil	0.035	ESP	.6 (coal)	-	0.42	-	Boiler # 44

ICI Coal and	Wood Fir	ed in NESC	AUM Region (C1	ſ,MA,ME,NH,	NJ,NY,RI,VT)	F	PM	s	02	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Gunlocke Co.	NY	E. Keeler	18	Wood	Oil #2	0.53	Fly Ash Cyclone	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	14.6	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	41.54	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	27.6	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Lyonsdale Biomass	NY	Zurn	290	Wood	-	0.1	-	-	-	0.2	-	
Morton International	NY	-	138	Coal	-	0.34	Fabric Filter, ESP	1.7	-	0.5	-	

ICI Coal	and Woo	d Fired in NES	CAUM Region	(CT,MA,ME,NH,NJ,N	IY,RI,VT)	F	PM	S	D ₂	N	Ox	l l
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
SUNY at Binghamton	NY	International Boiler Works	100	Coal	Coal/Wood Mix	0.6	Multi- Cyclone w/o Fly ash injection	1.7	-	-	-	Х3
SUNY at Binghamton	NY	International Boiler Works	50	Coal	Coal/Wood Mix	0.6	Multi- Cyclone w/o Fly ash injection	1.7	-	-	-	
US Salt - Watkins Glen Refinery	NY	2000?	160	Coal and/or Wood	NG and/or Coal, Wood	0.051	Fabric Filter	1.2	-	0.18	SNCR	
Dirigo Paper	VT	1977	180	Wood	-	0.20 gr/dscf	multiclone	-	-	0.3	none	-
Ethan Allen	VT	1950	59.5	Wood	-	0.45 gr/dscf	multiclone	-	-	1.94lb/ton wet wood 7.45lb/ton dry wood	none	-
Fraser	NH	1981, Zurn	324	Wood/Bark/Paper	# 6 Oil	0.1	Multi-cyclone + Venturi scrubber	0.8	-	0.25	-	

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Tillotson Rubber	NH	1978	41	Wood	-	0.43	Multi-cyclone	-	-	-	-	
Allen Rogers Limited	NH		5	Wood								
Allen Rogers Limited	NH		5	Wood								
Forest Products Processing Center	NH		47	Wood								
Madison Lumber Mill	NH		13	Wood								
Chick Packaging	NH		10	Wood								

ICI Coal and	l Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Ossipee Mountain Land Company	NH		4	Wood								
Ossipee Mountain Land Company	NH		4	Wood								
Tommila Brothers	NH		11	Wood								
Monadnock Forest Products	NH		30	Wood								
Whitney Brothers Company	NH		2	Wood								
HG Wood Industries	NH		9	Wood								

ICI Coal and W	ood Fire	d in NESCA	UM Region (CT	,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Design Contempo	NH		19	Wood								
Design Contempo	NH		13	Wood								
Solon Manufacturing	NH		9	Wood								
Rochester Shoe Tree/Ashland	NH		4	Wood								
Precision Lumber	NH		9	Wood								
King Forest Industries - Wentworth	NH		29	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	M	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Peterboro Basket Company	NH		3	Wood								
Souhegan Wood Products	NH		8	Wood								
Souhegan Wood Products	NH		1	Wood								
Souhegan Wood Products	NH		1	Wood								
Concord Steam Corporation	NH		40	Wood								
Concord Steam Corporation	NH		40	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	s	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Boyce Highlands	NH		4	Wood								
Herrick Millwork	NH		5	Wood								
Northland Forest Products	NH		5	Wood								
Anthony Galluzzo Corporation	NH		4	Wood								
Cousineau Wood Products	NH		14	Wood								
Newport Mills Inc	NH		6	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	Γ,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Newport Mills Inc	NH		6	Wood								
Catamount Pellet Corporation	NH		40	Wood								
Durgin & Crowell Lumber Company	NH		10	Wood								
GH Evarts & Company	NH		7	Wood								
References: 5	State Title	V Permits, C	coal SO ₂ Databas	e, ICI Coal Da	atabase, MA IC	100-250 Boiler	Database, VT IC	I Boiler Databas	e	·	·	

APPENDIX B: CUECost-ICI Inputs

INPUTS

Description	Units	Input 1	Input 2	Input 3	Input 4	Input 5
<u>^</u>		•	•	•	•	•
General Plant Technical Inputs						
Location - State	Abbrev.	PA	PA	PA	PA	PA
Combustion Configuration	Abbrev.	PC	PC	PC	PC	PC
MW Equivalent of Flue Gas to Control System	MW	25	25.1	28.6	28.6	32.9
Net Plant Heat Rate	Btu/kWhr	10,000	11,370	8,750	8,750	7,600
Plant Capacity Factor	%	66%	66%	66%	66%	66%
Total Air Downstream of Economizer	%	154%	169%	118%	118%	119%
Air Heater Leakage	%	12%	12%	12%	12%	12%
Air Heater Outlet Gas Temperature	°F	350	350	350	350	350
Inlet Air Temperature	°F	80	80	80	80	80
Ambient Absolute Pressure	In. of Hg	29.4	29.4	29.4	29.4	29.4
Pressure After Air Heater	In. of H2O	-12	-12	-12	-12	-12
Moisture in Air	lb/lb dry air	0.013	0.013	0.013	0.013	0.013
Ash Split:						
Fly Ash	%	85%	85%	85%	85%	85%
Bottom Ash	%	15%	15%	15%	15%	15%
Seismic Zone	Integer	1.0	1.0	1.0	1.0	1.0
Retrofit Factor	Integer	1.0	1.0	1.0	1.0	1.0
(1.0 = new, 1.3 = medium, 1.6 = difficult)						
Select Coal	Integer	2	3	4	5	6
s Selected Coal a Powder River Basin Coal?	Yes / No	No	No	No	No	No
Economic Inputs						
Cost Basis - Year Dollars	Year	2006	2006	2006	2006	2006
Service Life (levelization period)	Years	15	15	15	15	15
Inflation Rate	%	3%	3%	3%	3%	3%
After Tax Discount Rate (current \$'s)	%	8%	8%	8%	8%	8%
AFDC Rate (current \$'s)	%	8%	8%	8%	8%	8%
First-year Carrying Charge (current \$'s)	%	22%	22%	22%	22%	22%
Levelized Carrying Charge (current \$'s)	%	17%	17%	17%	17%	17%
First-year Carrying Charge (constant \$'s)	%	16%	16%	16%	16%	16%
Levelized Carrying Charge (constant \$'s)	%	12%	12%	12%	12%	12%
Sales Tax	%	6%	6%	6%	6%	6%
Escalation Rates:						
Consumables (O&M)	%	3%	3%	3%	3%	3%
Capital Costs:						
Is Chem. Eng. Cost Index available? If "Yes" input cost basis CE Plant	Yes / No	Yes	Yes	Yes	Yes	Yes
ndex.	Integer	478.7	478.7	478.7	478.7	478.7
If "No" input escalation rate.	%	3%	3%	3%	3%	3%
Construction Labor Rate	\$/hr	\$35	\$35	\$35	\$35	\$35
Prime Contractor's Markup	%	3%	3%	3%	3%	3%

Operating Labor Rate	\$/hr	\$25	\$25	\$25	\$25	\$25
Power Cost	Mills/kWh	47	47	47	47	47
Steam Cost	\$/1000 lbs	3.5	3.5	3.5	3.5	3.5
Limestone Forced Oxidation (LSFO) Inputs						
SO ₂ Removal Required	%	95%	95%	95%	95%	95%
L/G Ratio	gal / 1000 acf	125	125	125	125	125
Design Scrubber with Dibasic Acid Addition?	Integer	2	2	2	2	2
(1 = yes, 2 = no)						
Adiabatic Saturation Temperature	°F	127	127	127	127	127
Reagent Feed Ratio	Factor	1.05	1.05	1.05	1.05	1.05
(Mole CaCO3 / Mole SO ₂ removed)						
Scrubber Slurry Solids Concentration	Wt. %	15%	15%	15%	15%	15%
Stacking, Landfill, Wallboard	Integer	1	1	1	1	1
(1 = stacking, 2 = landfill, 3 = wallboard)						
Number of Absorbers	Integer	1	1	1	1	1
(Max. Capacity = 700 MW per absorber)						
Absorber Material	Integer	1	1	1	1	1
(1 = alloy, 2 = RLCS)						
Absorber Pressure Drop	in. H2O	6	6	6	6	6
Reheat Required ?	Integer	1	1	1	1	1
(1 = yes, 2 = no)						
Amount of Reheat	°F	25	25	25	25	25
Reagent Bulk Storage	Days	60	60	60	60	60
Reagent Cost (delivered)	\$/ton	\$15	\$15	\$15	\$15	\$15
Landfill Disposal Cost	\$/ton	\$25	\$25	\$25	\$25	\$25
Stacking Disposal Cost	\$/ton	\$6	\$6	\$6	\$6	\$6
Credit for Gypsum Byproduct	\$/ton	\$2	\$2	\$2	\$2	\$2
Maintenance Factors by Area (% of Installed Co	st)					
Reagent Feed	%	5%	5%	5%	5%	5%
SO ₂ Removal	%	5%	5%	5%	5%	5%
Flue Gas Handling	%	5%	5%	5%	5%	5%
Waste / Byproduct	%	5%	5%	5%	5%	5%
Support Equipment	%	5%	5%	5%	5%	5%
Contingency by Area (% of Installed Cost)						
Reagent Feed	%	20%	20%	20%	20%	20%
SO ₂ Removal	%	20%	20%	20%	20%	20%
Flue Gas Handling	%	20%	20%	20%	20%	20%
Waste / Byproduct	%	20%	20%	20%	20%	20%
Support Equipment	%	20%	20%	20%	20%	20%
General Facilities by Area (% of Installed Cost)						
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Engineering Fees by Area (% of Installed Cost)						
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%

Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
<u>Lime Spray Dryer (LSD) Inputs</u>						
SO ₂ Removal Required	%	90%	90%	90%	90%	90%
Adiabatic Saturation Temperature	°F	127	127	127	127	127
Flue Gas Approach to Saturation	°F	20	20	20	20	20
Spray Dryer Outlet Temperature	°F	147	147	147	147	147
Reagent Feed Ratio	Factor	0.90	0.90	0.90	0.90	0.90
(Mole CaO / Mole Inlet SO ₂)						
Recycle Rate	Factor	30	30	30	30	30
(lb recycle / lb lime feed)						
Recycle Slurry Solids Concentration	Wt. %	35%	35%	35%	35%	35%
Number of Absorbers	Integer	2	2	2	2	2
(Max. Capacity = 300 MW per spray drye	r)					
Absorber Material	Integer	1	1	1	1	1
(1 = alloy, 2 = RLCS)						
Spray Dryer Pressure Drop	in. H2O	5	5	5	5	5
Reagent Bulk Storage	Days	60	60	60	60	60
Reagent Cost (delivered)	\$/ton	\$60	\$60	\$60	\$60	\$60
Dry Waste Disposal Cost	\$/ton	\$25	\$25	\$25	\$25	\$25
Maintenance Factors by Area (% of Installed	Cost)					
Reagent Feed	%	5%	5%	5%	5%	5%
SO ₂ Removal	%	5%	5%	5%	5%	5%
Flue Gas Handling	%	5%	5%	5%	5%	5%
Waste / Byproduct	%	5%	5%	5%	5%	5%
Support Equipment	%	5%	5%	5%	5%	5%
Contingency by Area (% of Installed Cost)						
Reagent Feed	%	20%	20%	20%	20%	20%
SO ₂ Removal	%	20%	20%	20%	20%	20%
Flue Gas Handling	%	20%	20%	20%	20%	20%
Waste / Byproduct	%	20%	20%	20%	20%	20%
Support Equipment	%	20%	20%	20%	20%	20%
General Facilities by Area (% of Installed Cos	st)					
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Engineering Fees by Area (% of Installed Cos	st)					
Reagent Feed	%	10%	10%	10%	10%	10%
SO_2 Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%

Particulate Control Inputs

Number of Air Preheaters

Outlet Particulate Emission Limit	lbs/MMBtu	0.03	0.03	0.01	0.01	0
Fabric Filter:						
Pressure Drop	in. H2O	6	6	6	6	6
Type (1 = Reverse Gas, 2 = Pulse Jet)	Integer	2	2	2	2	2
Gas-to-Cloth Ratio	acfm/ft ²	5.5	5.5	5.5	5.5	5.5
Bag Material (RGFF fiberglass only)	Integer	1	1	1	1	1
(1 = Fiberglass, 2 = Nomex, 3 = Ryton)						
Bag Diameter	inches	6	6	6	6	6
Bag Length	feet	20	20	20	20	20
Bag Reach		3	3	3	3	3
Compartments Out of Service	%	10%	10%	10%	10%	10%
Bag Life	Years	2	2	2	2	2
Maintenance (% of installed cost)	%	5%	5%	5%	5%	5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	10%	10%	10%	10%	10%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
ESP:						
Strength of the electric field in the $ESP = E$	kV/cm	10.0	10.0	10.0	10.0	10.0
Plate Spacing	in.	12	12	12	12	12
Plate Height	ft.	36	36	36	36	36
Pressure Drop	in. H2O	3	3	3	3	3
Maintenance (% of installed cost)	%	5%	5%	5%	5%	5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	10%	10%	10%	10%	10%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
NOx Control Inputs						
Selective Catalytic Reduction (SCR) Inputs						
NH3/NOx Stoichiometric Ratio	NH3/NOx	0.9	0.9	0.9	0.9	0.9
NOx Reduction Efficiency	Fraction	0.70	0.70	0.70	0.70	0.70
Inlet NOx	lbs/MMBtu	0.6	0.26	0.2	0.4	0.4
Space Velocity (Calculated if zero)	1/hr	3000	3000	11800	11800	16800
Overall Catalyst Life	years	4	4	4	4	4
Ammonia Cost	\$/ton	411.17	411.17	411.17	411.17	411.17
Catalyst Cost	\$/ft3	356.34	356.34	356.34	356.34	356.34
Solid Waste Disposal Cost	\$/ton	25.38	25.38	25.38	25.38	25.38
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	5%	5%	5%	5%	5%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
Number of Reactors	integer	1	1	1	1	1

1

integer

1

1

1

1
Adopted

Selective NonCatalytic Reduction (SNCR) Inputs

Reagent	1:Urea 2:Ammonia	1	1	1	1	1
Number of Injector Levels integer		3	3	3	3	3
Number of Injectors	integer	18	18	18	18	18
Number of Lance Levels	integer	0	0	0	0	0
Number of Lances	integer	0	0	0	0	0
Steam or Air Injection for Ammonia	integer	1	1	1	1	1
NOx Reduction Efficiency	Fraction	0.50	0.50	0.50	0.50	0.50
Inlet NOx	lbs/MMBtu	0.6	0.26	0.2	0.4	0.2
NH3/NOx Stoichiometric Ratio	NH3/NOx	1.2	1.2	1.2	1.2	1.2
Urea/NOx Stoichiometric Ratio	Urea/NOx	1.2	1.2	1.2	1.2	1.2
Urea Cost	\$/ton	200	200	200	200	200
Ammonia Cost	\$/ton	411.17	411.17	411.17	411.17	411.17
Water Cost	\$/1,000 gal	0.22	0.22	0.22	0.22	0.22
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	5%	5%	5%	5%	5%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
Low-NOx Burner Technology Inputs						
NOx Reduction Efficiency	fraction	0.40	0.40	0.40	0.40	0.40
Boiler Type	T:T-fired, W:Wall	W	W	W	W	W
Retrofit Difficulty	L:Low, A:Average, H:High	А	А	А	А	А
Maintenance Labor (% of installed cost)	%	0.8%	0.8%	0.8%	0.8%	0.8%
Maintenance Materials (% of installed cost)	%	1.2%	1.2%	1.2%	1.2%	1.2%
Natural Gas Reburning Inputs						
NOx Reduction Efficiency	fraction	0.61	0.61	0.61	0.61	0.61
Gas Reburn Fraction	fraction	0.15	0.15	0.15	0.15	0.15
Waste Disposal Cost	\$/ton	11.48	11.48	11.48	11.48	11.48
Natural Gas Cost	\$/MMBtu	4.24	4.24	4.24	4.24	4.24
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	2%	2%	2%	2%	2%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%



EPA-450/3-90-016

Small Industrial-Commercial-Institutional Steam Generating Units --Background Information for Promulgated Standards

Emission Standards Division

U.S. ENVIRONMENTAL PROTECTION AGENCY Office of Air and Radiation Office of Air Quality Planning and Standards Research Triangle Park, North Carolina 27711

August 1990

Appendix III.D.7.7-4326

2.3.3 Percent Reduction Standard

1. <u>Comment</u>: Two commenters (IV-D-08, IV-D-28) requested that the 90 percent SO₂ reduction requirement be eliminated and replaced with an emission limit of 520 ng/J (1.2 lb/million Btu) heat input. One commenter (IV-D-08) objected to applying the 90 percent SO₂ reduction requirement to all coal regardless of sulfur content. This commenter stated that the EPA's conclusion that no units will be built in the size range between 22 and 29 MW (75 and 100 million Btu/hr) heat input capacity and operating at greater than 55 percent capacity factor is flawed. This commenter stated that the SO₂ standard of 520 ng/J (1.2 lb/million Btu) heat input for coal-fired plants should apply to all steam generating units in this source category, regardless of size. This commenter further recommended that the full 90 percent SO₂ removal be required only when the 520 ng/J (1.2 lb/million Btu) limit could not be met by using low sulfur coals or by pretreating the coals.

Another commenter (IV-D-28) stated that the 90 percent SO_2 reduction requirement should be removed and that coal-fired steam generating units in the 8.7 to 29 MW (30 to 100 million Btu/hr) range should be required only to meet the 520 ng/J (1.2 lb/million Btu) SO_2 limit. The commenter stated that the percent reduction requirement would place an unjustified cost and performance burden on units in this range that either already meet or are close to meeting the 520 ng/J (1.2 lb/million Btu) SO_2 limit.

<u>Response</u>: Section 111 of the CAA requires standards to reflect application of the best demonstrated technology considering costs, nonair quality health and environmental impacts, and energy requirements. Section 111 also requires that for fossil fuel-fired steam generating units a percent reduction standard be established. Read together, this means that the

2-22

Administrator is compelled to include a percent reduction standard unless the impacts associated with the requirements would be unreasonable. As discussed in the background document, "Model Boiler Cost Analysis for Controlling Sulfur Dioxide (SO₂) Emissions from Small Steam Generating Units" (EPA-450/3-89-14), a small coal-fired steam generating unit of 22 MW (75 million Btu/hr) size and operating at a 55 percent capacity factor has an incremental cost-effectiveness value of about \$3,600/Mg (\$3,300/ton) relative to an emission limit standard of 520 ng/J (1.2 lb/million Btu). Capital and annualized costs are projected to increase by approximately 20 percent over the regulatory baseline for the percent reductions standard. However, these values increase significantly for units less than 22 MW (75 million Btu/hr) heat input capacity and for any unit less than 29 MW (100 million Btu/hr) operating at an annual capacity factor for coal of less than 55 percent. Imposing these high costs for these units was considered to be unreasonable when compared to the increase in emission reductions achievable by the percent reduction requirement on these units. Therefore, in keeping with the requirements of the CAA, the final standards will not require percent reduction for any units operating at less than a 55 percent annual capacity factor for coal or any unit with a heat input capacity of 22 MW (75 million Btu/hr) or less.

Finally, no conclusion was made that coal-fired steam generating units greater than 22 MW (75 million Btu/hr) heat input and greater than 55 percent capacity factor would not be built. Rather, this was a projection of sales over the next five years based on sales trends over the past several years. The sales projections for coal-fired units had no influence on the conclusion of the reasonableness of the percent reduction requirement. (The assumption was used in generating national impacts of the standards.) The model steam generating unit analysis examined the potential impacts of the percent reduction requirement on a coal-fired unit greater than 22 MW (75 million Btu/hr) and greater than 55 percent capacity factor. Therefore, should a unit be built, requiring 90 percent reduction of emissions would be reasonable.

2-23

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

UNIFIED FACILITIES CRITERIA (UFC)

DoD FACILITIES PRICING GUIDE



APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED

Appendix III.D.7.7-4329

UNIFIED FACILITIES CRITERIA (UFC)

DoD FACILITIES PRICING GUIDE

Any copyrighted material included in this UFC is identified at its point of use. Use of the copyrighted material apart from this UFC must have the permission of the copyright holder.

Indicate the preparing activity beside the Service responsible for preparing the document.

U.S. ARMY CORPS OF ENGINEERS

NAVAL FACILITIES ENGINEERING COMMAND (Preparing Activity)

AIR FORCE CIVIL ENGINEER CENTER

Record of Changes (changes are indicated by $1 \dots /1$)

Change No.	Date	Location
1	6-25-18	Update Table 3 with RUC. Text update 3-2.

FOREWORD

The Unified Facilities Criteria (UFC) system is prescribed by MIL-STD 3007 and provides planning, design, construction, sustainment, restoration, and modernization criteria, and applies to the Military Departments, the Defense Agencies, and the DoD Field Activities in accordance with <u>USD (AT&L) Memorandum</u> dated 29 May 2002. UFC will be used for all DoD projects and work for other customers where appropriate. All construction outside of the United States is also governed by Status of Forces Agreements (SOFA), Host Nation Funded Construction Agreements (HNFA), and in some instances, Bilateral Infrastructure Agreements (BIA.) Therefore, the acquisition team must ensure compliance with the most stringent of the UFC, the SOFA, the HNFA, and the BIA, as applicable.

UFC are living documents and will be periodically reviewed, updated, and made available to users as part of the Services' responsibility for providing technical criteria for military construction. Headquarters, U.S. Army Corps of Engineers (HQUSACE), Naval Facilities Engineering Command (NAVFAC), and Air Force Civil Engineer Center (AFCEC) are responsible for administration of the UFC system. Defense agencies should contact the preparing service for document interpretation and improvements. Technical content of UFC is the responsibility of the cognizant DoD working group. Recommended changes with supporting rationale should be sent to the respective service proponent office by the following electronic form: <u>Criteria Change Request</u>. The form is also accessible from the Internet sites listed below.

UFC are effective upon issuance and are distributed only in electronic media from the following source:

• Whole Building Design Guide web site http://dod.wbdg.org/.

Refer to UFC 1-200-01, *DoD Building Code (General Building Requirements)*, for implementation of new issuances on projects.

AUTHORIZED BY:

an & M Willt

LARRY D. McCALLISTER, PhD, PE, PMP, SES Chief, Engineering and Construction Directorate of Civil Works U.S. Army Corps of Engineers

EDWIN H. OSHIBA, SES, DAF Deputy Director of Civil Engineers DCS/Logistics, Engineering & Force Protection

123

JOSEPH E. GOTT, P.E. Chief Engineer Naval Facilities Engineering Command

Mules M. and

MICHAEL McANDREW Deputy Assistant Secretary of Defense (Facilities Investment and Management) Office of the Assistant Secretary of Defense (Energy, Installations, and Environment)

UNIFIED FACILITIES CRITERIA (UFC) [REVISION] SUMMARY SHEET

Document: UFC 3-701-01, DoD Facilities Pricing Guide

Superseding: UFC 3-701-01, dated March 2011

Description: The document provides updated cost and pricing data in support of facility planning, investment and analysis needs.

Reasons for Document:

 This UFC provides updated cost and pricing data intended to support preparation of the DoD budget.

Impact:

• Provides consistency across the DoD for the development of budgets for military construction projects.

Unification Issues

None

TABLE OF CONTENTS

CHAPTER 1	INTRODUCTION	. 1
1-1	PURPOSE AND SCOPE	.1
1-1.1	Chapter 2: Unit Costs for Military Construction Projects.	. 1
1-1.2	Chapter 3: Unit Costs for DoD Facilities Cost Models.	. 1
1-1.3	Chapter 4: Cost Adjustment Factors	. 1
1-2	APPLICABILITY	.1
1-3	DATA TABLES	.1
1-4	PROPONENT	.1
CHAPTER 2	UNIT COSTS FOR MILITARY CONSTRUCTION PROJECTS	. 3
2-1	OVERVIEW	. 3
2-2	FACILITY UNIT COST TABLE	. 3
2-3	GUIDANCE UNIT COST (GUC) DEVELOPMENT METHODOLOGY	. 3
2-3.1	Data Source	. 3
2-3.2	Business Rules	. 3
2-3.3	Data Normalization.	. 4
2-3.4	Primary Facility Included Costs	. 4
2-3.5	Primary Facility Excluded Costs.	. 5
2-3.6	Primary Facility Cost Considerations.	. 6
CHAPTER 3	UNIT COSTS FOR DOD FACILITIES COST MODELS	.7
3-1	OVERVIEW	.7
3-2	REPLACEMENT UNIT COSTS (RUC)	.7
3-2.1	Definition	.7
3-2.2	Use of Replacement Unit Costs	.7
3-3	SUSTAINMENT UNIT COSTS (SUC).	. 8
3-3.1	Definition	. 8
3-3.2	Use of Sustainment Unit Costs	. 9
3-4	UNIT COST SOURCES	10
3-4.1	Source 1 Published Data	10
3-4.2	Source 2 Similar Data	10
3-4.3	Source 3 Derived Data	10
3-5	REVISING UNIT COSTS	11
CHAPTER 4	COST ADJUSTMENT FACTORS	13

4-1

4-1.1 4-1.2

4-1.3

4-1.4

4-1.5

4-2 4-2.1

4-2.2 4-2.3

LOCATION ADJUSTMENTS.	November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018 13
Application	
Data Source	13
Survey	13
Force Majeure	14
User Requested Revisions	14

ESCALATION.14

 Military Construction.
 14

 Plant Replacement Value Escalation Rates.
 14

CHAPTER 1 INTRODUCTION

1-1 PURPOSE AND SCOPE.

The DoD Facilities Pricing Guide supports a spectrum of facility planning, investment, and analysis needs. This version of the Guide reflects updated cost and pricing data for <u>FY 2018</u> intended to support preparation of the DoD budget for <u>FY 2020</u>. It includes reference information organized into three chapters, as follows:

1-1.1 Chapter 2: Unit Costs for Military Construction Projects.

Chapter 2 describes the usage of facility unit cost data for selected DoD facility types in support of preparing Military Construction (MILCON) project documentation (DD Forms 1391) and other program-level estimates in accordance with UFC 3-730-01, "Programming Cost Estimates for Military Construction."

1-1.2 Chapter 3: Unit Costs for DoD Facilities Cost Models.

Chapter 3 describes the usage of unit costs in support of DoD facilities cost models. These unit costs are based upon the reported average DoD facility size or an established benchmark size, as annotated for each Facility Analysis Category (FAC) in the DoD Real Property Classification System (published separately). These unit costs are intended for macro-level analysis and planning rather than individual facilities or projects.

1-1.3 Chapter 4: Cost Adjustment Factors.

Chapter 4 describes the usage of cost adjustment factors for location and price escalation that are applicable to the base unit costs in both Chapters 2 and 3.

1-2 APPLICABILITY.

This UFC applies to all projects in both the continental US (CONUS) and outside the continental US (OCONUS).

1-3 DATA TABLES.

All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

1-4 **PROPONENT**.

The Office of the Assistant Secretary of Defense for Energy, Installations, and Environment is the proponent for the Facilities Pricing Guide. Recommendations from users toward improving the usefulness of this reference are welcome. Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

Adopted

CHAPTER 2 UNIT COSTS FOR MILITARY CONSTRUCTION PROJECTS

2-1 OVERVIEW.

The facility unit costs in this chapter apply to preparation of programming-level cost estimates for constructing military facilities in accordance with the methodology described in UFC 3-730-01.

All data tables in this UFC are found under "Related Materials" in a combined file accompanying this UFC on the (WBDG) Web site: <u>https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.</u>

2-2 FACILITY UNIT COST TABLE.

Table 2 provides facility unit costs for various DoD facility types in dollars per square meter (\$/SM) and equivalent English unit cost data in dollars per square foot (\$/SF) as of <u>October 2017</u>. The listed facility types represent only those facilities most frequently constructed by the Military Services, and the application of a facility unit cost may not be directly applicable for those facilities with unique requirements. See UFC 3-730-01 for additional guidance on facility unit costs and their application.

The unit costs in Table 2 are average unit costs for new construction based on no less than three project awards per building type occurring since September 2014 for Army, Navy, Air Force, Defense Education Activities (for school projects) and Defense Health Agency (for medical projects) facilities as entered into the Historical Analysis Generator (HII) unit cost database prior to 1 Nov 2017. Facility additions which are less than 25% of the Reference Size of the listed facility type, and projects outside of the continental United States (OCONUS), are included only for Family Housing and DoD Schools. For additional information regarding how the facility unit costs are determined, refer to paragraph 2-3, Guidance Unit Cost Development.

2-3 GUIDANCE UNIT COST (GUC) DEVELOPMENT METHODOLOGY.

2-3.1 Data Source.

The data source for the facility unit costs is all reliable HII project records, after excluding records for reasons stated in paragraph 2-2. In general, all project records for the CONUS and projects from Alaska and Hawaii are included.

Facility level information from all three Services projects is entered into HII database for comparable service category codes (CATCODEs). Normalized project unit costs are statistically analyzed to eliminate outliers before calculating the guidance unit cost (GUC).

2-3.2 Business Rules.

The business rules are reviewed annually prior to updating Table 2 Facility Unit Costs for Military Construction. The business rules include the following components.

- The Tri-Service CATCODEs Cross-walk table groups like service CATCODEs to a common Office of the Secretary of Defense (OSD) Code. OSD Codes are not published and are only utilized for this task of segregating data. A minimum of three projects are required within those defined years to create a dataset. If there is insufficient data available within the above three-year period, the dataset search is extended to the last four years.
- Projects are new construction only.
- Projects are located within the CONUS, plus Hawaii and Alaska, except where noted otherwise in Table 2.
- Projects with extreme variation from the mean (50%) are excluded., and
- Exclusion of inappropriate data for cause.

2-3.3 Data Normalization.

Each facility-specific data set is normalized to the National Average Area Cost Factor (ACF=1) and number of bidders, and escalated to October of the year of interest, before unit costs are averaged.

- Escalation: The DoD Selling Price Index (DoD-SPI), which is an average of three commonly accepted national construction price escalation indices, is utilized to escalate actual project award cost data to October of 2017 for this UFC,
- Number of Bidders: Based on actual bid data for the data set,
- Location: Normalize each project award by the appropriate ACF to the national average of 1.0, and
- Facility Size: Normalize each facility award amount in the dataset for facility size, using a normalization process that looks at the facility size as compared to the average facility size of the selected dataset by OSD code.

2-3.4 Primary Facility Included Costs.

The facility unit costs include the following:

- Minimum antiterrorism design features (reference UFC 4-010-01, "DoD Minimum Antiterrorism Standards for Buildings") inside the building meeting Table B-1 standoff distance requirements,
- Sales tax on building materials,

- Building information system costs (e.g., conduits, racks, trays, telecommunication rooms) without any specialized communications requirements,
- Installed (built-in) building equipment and furnishings normally funded with MILCON funds,
- Energy Management Control System (EMCS) connections,
- Intrusion Detection System (IDS) infrastructure, including conduits, racks, and trays,
- Sustainable design and construction features energy consumption reduction requirements mandated before 6 November 2016; and all other sustainable design features for criteria in effect from September 2014 thru September 2017 with the exception of renewable energy generation elements,
- Progressive Collapse premiums for the following specific facility types: Inpatient Hospital/Medical Center, Primary Care Clinic (Attached), Major Command Headquarters Building, Barracks/Dormitory, and Recruit Open Bay (Barracks), and
- Standard foundation systems (e.g. strip/spread footings, thickened edge slab for slab on grade).

2-3.5 Primary Facility Excluded Costs.

The unit costs do not include the following:

- Gross receipt taxes or gross taxes, gross excise taxes, or state commerce taxes,
- "Acts of God" or unusual market conditions,
- Supporting facility costs,
- Equipment acquired with other fund sources, including pre-wired workstations or furnishing systems, intrusion detection systems,
- Sustainable design and construction features renewable energy generation elements; energy consumption reduction requirements mandated on or after 6 November 2016; and all other features mandated since September 2017; these will be estimated separately in accordance with component guidelines and documented on DD Form 1391 per DoD Instruction 4170.11, Installation Energy Management,
- Special foundations (e.g. pre-stressed concrete piles, caissons), intrusion detection system installation, base exterior architectural preservation guidelines,

- Enhanced Anti-Terrorism (AT) standards (exceeding the minimum in UFC 4-010-01, or when minimum standoff distances [Table B-1] are not achieved) construction contingency allowances,
- Cybersecurity costs,
- Supervision, inspection, and overhead (SIOH),
- Design costs (design-build contracts), and Construction cost growth resulting from user changes, unforeseen site conditions, or contract document errors and omissions.

2-3.6 Primary Facility Cost Considerations.

The following are cost considerations for primary facilities:

- <u>Medical facilities</u>: Unit costs <u>include</u> category A and category B equipment and building infrastructure for category C equipment,
- <u>Housing for Unaccompanied Military Personnel</u>: Unit costs for barracks, dormitories, and Unaccompanied Officers Quarters do not include freestanding kitchen equipment. In addition to using the size adjustment factors, use the project size adjustment factors in UFC 3-730-01,
- <u>Child Development Centers</u>: Unit costs <u>do not include</u> free-standing food service equipment or playground area and equipment,
- <u>Family housing</u>: Unit costs are based upon gross area and <u>include</u> sprinkler systems or fire-rated construction. Unit costs <u>include</u> post-award design costs,
- <u>Reserve facilities other than reserve centers</u>: Use the unit cost of the appropriate facility type, and
- Costs are independent of the acquisition strategy and are not specific to any single construction type.

Adopted

3-1 OVERVIEW.

This chapter describes the unit costs and related factors used in support of DoD facilities cost models. These unit costs are intended for macro-level analysis and planning and are not reliable for individual facilities or project estimates.

Unit costs and related factors are associated with FACs represented by a 4-digit code in the DoD Real Property Classification System (RPCS), which is a hierarchical scheme of real property types and functions that serves as the framework for identifying, categorizing, and modeling the DoD's inventory of land and facilities. FACs are common across the department and suitable for department-wide applications. For each FAC, Table 3 identifies the associated unit cost to be used in DoD facilities cost models and metrics.

Whenever possible, unit costs and factors have been based upon approved government or commercial benchmarks. Detailed supporting data for unit costs is available, and accompanies this UFC on the WBDG Web site. All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: <u>https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.</u>

3-2 REPLACEMENT UNIT COSTS (RUC).

3-2.1 \1\ Definition and Use of Replacement Unit Costs. /1/

\1\ Replacement unit costs form the basis of calculating Plant Replacement Value (PRV) in a consistent manner across DoD, representing a complete and useable facility built to current DoD design standards. Replacement unit costs can also support largescale program-level estimates for re-stationing plans with the addition of allowance for site preparation, earthwork, landscaping, and related factors. Replacement unit costs should not be used for individual project estimates. /1/

Replacement \1\ unit /1/ costs include construction of standard foundations, all interior and exterior walls and doors, the roof, utilities out to the 5-foot line, all built-in plumbing and lighting fixtures, security and fire protection systems, electrical distribution, wall and floor coverings, heating and air conditioning systems, and elevators. Replacement \1\ unit /1/ costs do not include project costs such as design, supporting facility costs, special foundations, equipment acquired with other funding sources (e.g. missionfunded components), contingency costs, or supervision, inspection, and overhead (SIOH). \1\ unit /1/ costs also do not include items that are generally considered personal property such as computer systems, and furniture. See paragraph 3-5, Revising Unit Costs, for guidance on requesting changes \1\ to replacement unit costs /1/in Table 3.

3-2.2 \1\ Plant Replacement Value (PRV). /1/

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

DoDI 4165.14 defines PRV as the cost to design and construct a notional facility to current standards to replace an existing facility on the same site. The factor values are provided in the "Report of the Plant Replacement Value (PRV) Panel, August 2001-May 2003" published by the Office of the Deputy Under Secretary of Defense (Installations and Environment). The standard DoD formula for calculating PRV is:

Equation 3-2 Calculating PRV

PRV = Q x RUC x ACF x HF x PD x SIOH x CF

Where:

PRV is plant replacement value

Q is facility quantity, in the same unit of measure as the RUC

RUC is replacement unit cost found in Table 3 of this UFC

ACF is area cost factor found in Table 4 of this UFC, to account for geographical differences in the costs of labor, materials and equipment

HF is an adjustment of 1.05 to account for increased costs for replacement of historical facilities or for construction in a historic district. The factor is 1.0, should the facility not qualify as "historical".

PD is a factor to account for the planning and design of a facility; the current value of this factor is 1.09 for all but medical facilities, and 1.13 for medical facilities.

SIOH is the factor to account for the supervision, inspection, and overhead activities associated with the management of a construction project. The current value of the factor is 1.057 for facilities in the (CONUS), and 1.065 (USACE) or 1.062 (NAVFAC) for facilities in the (OCONUS).

CF is a factor of 1.05 to account for construction contingencies

3-3 SUSTAINMENT UNIT COSTS (SUC).

3-3.1 Definition.

Sustainment provides for maintenance and repair activities necessary to keep a typical inventory of facilities in good working order over its expected service life. It includes the following:

- Regularly scheduled adjustments and inspections, including maintenance inspections (e.g., fire sprinkler heads, HVAC systems) and regulatory inspections (e.g., elevators, bridges),
- Preventive maintenance tasks,
- Emergency response and service calls for minor repairs, and
- Major repair or replacement of facility components (usually accomplished by contract) that are expected to occur periodically throughout the facility service life.

Sustainment includes regular roof replacement, refinishing wall surfaces, repairing and replacing electrical, heating, and cooling systems, replacing tile and carpeting and similar types of work as well as overhead costs which include architectural and engineering services. It does not include repairing or replacing non-attached equipment or furniture, or building components that typically last more than 50 years (such as foundations and structural members). Sustainment does not include restoration, modernization, environmental compliance, facility leases, specialized historical preservation, general facility condition inspections and assessments, planning and design (other than shop drawings), or costs related to Acts of God, which are funded elsewhere. Other tasks associated with facilities operations (such as custodial services, grass cutting, landscaping, waste disposal, and the provision of central utilities) are also not included.

3-3.2 Use of Sustainment Unit Costs.

Sustainment unit costs represent the annual average sustainment cost for each FAC, and serve as the basis for calculating annual facilities sustainment requirements for DoD using the following formula:

Equation 3-3 Calculating Sustainment Requirement

$$SR = Q \times SUC \times SACF \times I$$

Where:

SR is sustainment requirement

Q is facility quantity, in the same unit of measure as the SUC

SUC is sustainment unit cost found in Table 3

SACF is sustainment area cost factor found in Table 4

I is the value(s) representing future-year escalation for operation and maintenance accounts, published in Table 4-4.

The Sustainment Requirement for each qualifying asset in the DoD inventory is aggregated by sustaining organization and sustainment fund type in the Facilities Sustainment Model (FSM), published annually.

3-4 UNIT COST SOURCES.

Unit costs for DoD cost models are developed using a variety of sources. These sources fall into the three categories described below, listed in order of preference of use. The source description and source group for each unit cost are identified in Table 3. Supporting documentation for each unit cost calculation is available in the "Supporting documentation" file download accompanying this UFC document on the WBDG website: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

3-4.1 Source 1 Published Data

Standard, easily-accessible published data that is highly applicable to the FAC. Source 1 is the most desirable due to ease of access, general applicability, and lack of bias. Examples include the DoD Tri-Service Committee on Cost Engineering, Service-specific cost guidance (USACE), commercial cost-estimating guidelines or models, or other Government-published cost guidance from federal, state, or local government agencies (e.g. Fairfax County (Virginia) Park Authority). Non-DoD source 1 data may require refinement for application in DoD, but is still considered source 1 if it closely matches the design attributes of the FAC.

3-4.2 Source 2 Similar Data

Data that is applied to facilities with similar but not identical characteristics (e.g., sewage waste treatment facilities and industrial waste treatment facilities). Source 2 also includes unpublished government or trade association cost data, and Component-validated costs for non-standard facilities that have no commercial counterparts (e.g. missile launch facilities or military ranges).

3-4.3 Source 3 Derived Data

Unpublished project-specific data derived from Component project documents (e.g. DD Forms 1391) or from calculating costs from reported Plant Replacement Value and inventory, or derived from using a ratio of sustainment to construction from a similar source 1 Facilities Analysis Category (e.g. FAC 2115, Aircraft Maintenance Hangar, Depot derived from FAC 2111, Aircraft Maintenance Hangar).

3-5 REVISING UNIT COSTS.

Users of this UFC are encouraged to suggest revisions to the published cost factors, particularly for facilities unique to their mission. Submit proposed changes to the proponent office in accordance with the following guidelines:

- Revised costs should come from an equivalent or superior source,
- Revised costs should be easily audited,
- Revised costs should be consistent with the functional definitions,
- Revised costs should be consistent with the FAC scope and
- Revised costs should be suitable for application throughout DoD.

Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

CHAPTER 4 COST ADJUSTMENT FACTORS

4-1 LOCATION ADJUSTMENTS.

Table 4-1 provides area cost factors (ACFs) to be used for adjusting "bare" unit costs to location-specific costs for the most common locations.

All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

4-1.1 Application

For military construction projects, use the MILCON ACFs with the primary facility unit costs from Chapter 2 or approved Air Force, Army, or Navy MILCON Pricing Guide. For calculating Plant Replacement Value, use the MILCON ACFs with the appropriate RUCs from Chapter 3. For calculating sustainment costs, use the sustainment ACFs with the appropriate SUCs from Chapter 3.

Do not use the MILCON ACFs to modify parametric cost estimates, detailed quantitytake-offs, unit price book (UPB) line items, commercial cost data, or user-generated unit costs. These cost estimating methods and databases have their own processes and factors for adjusting costs to different locations. MILCON ACFs or any component(s) that make up MILCON ACFs are only applicable to construction costs and should not be applied or utilized for any other purpose.

4-1.2 Data Source

In general, the Tri-Service Cost Engineering ACF software program evaluates the local costs for a United States market basket of eight labor crafts, 18 construction materials, and four equipment items. These labor, materials, and equipment (LME) items are representative of the types of products, services, and methods used to construct most military facilities in the United States. Each of the LME costs is normalized and weighted to represent its contribution to the total cost of a typical facility. The normalized LME is then modified by seven matrix factors that cover local conditions affecting construction costs. These matrix factors include weather, seismic, climatic (frost zone, wind loads, and HVAC systems), labor availability, contractor overhead and profit, logistics, and labor productivity and are relative to the U.S. standard. The resultant ACF for each location is normalized again by dividing by the 96-Base-City average to provide a final ACF that reflects the relative relationship of construction costs between that location and the 96-Base-City average as 1.00.

MILCON ACFs are calculated using a LME ratio of 35/63/2. Sustainment ACFs are calculated using a LME ratio of 53/46/1.

4-1.3 Survey

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

Both CONUS and OCONUS construction market surveys were conducted in 2017. The CONUS survey covered 300 locations that included 96 Base Cities (two per state in the continental U.S.). The OCONUS survey included 75 locations, and was based on a market basket of goods for typical U.S. labor, material, equipment, and construction methods.

CONUS and OCONUS surveys are performed annually. When local materials and construction methods differ from those represented by the published ACF, specific adjustments may need to be added to the project estimate to account for any differences. There is no easy correlation between the current MILCON ACFs and previous MILCON ACFs for specific locations. No common benchmarks exist because both the Base City average and the relationships between cities change with each survey. It is possible, however, to compare differences between several locations in this database with differences between the same locations in previous databases.

4-1.4 Force Majeure

The ACF is not intended to, or capable of, responding to rapid changes in the market place. Examples include Acts of God, accelerated construction schedules, changes in the demand and supply for construction materials, labor, and equipment. An increased demand for labor beyond what the local market can supply may require the enticement of premium pay, overtime hours, temporary living expenses, and travel expenses.

4-1.5 User Requested Revisions

Users may request revisions to published ACFs when market conditions unexpectedly change. Each request must be initiated by the USACE District senior cost engineer through HQUSACE or by the NAVFAC regional cost engineer to their corresponding NAVFAC Atlantic or Pacific Tri-Service Cost Engineering committee member. The local cost engineer shall provide updated market basket ACF software input factors with adequate backup documentation to HQUSACE or NAVFAC for them to update the Tri-Service Cost Engineering ACF software.

4-2 ESCALATION.

Tables 4-2, 4-3, and 4-4 provide escalation (inflation) factors used to adjust unit costs in Tables 2 and 3 (expressed in base-year dollars) to the desired year, as follows:

4-2.1 Military Construction.

Military construction project estimates that use unit costs from Table 2 should use the military construction escalation factor from table 4-2 for the expected midpoint of construction as described in UFC 3-730-01.

4-2.2 Plant Replacement Value Escalation Rates.

Plant Replacement Value (PRV) calculations that use replacement unit costs from Table 3 should use the escalation factor from Table 4-3 for the desired program year.

14

4-2.3 Facilities Sustainment.

Modeled facilities sustainment cost estimates that use unit costs from Table 3 should use the O&M escalation factor from Table 4-4 for the desired program year.

Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

APPENDIX A REFERENCES

UNIFIED FACILITIES CRITERIA

http://www.wbdg.org/ccb/browse_cat.php?o=29&c=4

UFC 3-730-01, Programming Cost Estimates for Military Construction

PLANT REPLACEMENT VALUE

https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01

Report of the Plant Replacement Value (PRV) Panel, August 2001 – May 2003, R&K Engineering, Inc. for the Office of the Deputy Under Secretary of Defense (Installations and Environment)



Proposed BACT Alternative

November 19, 2018

Submitted by David Fish Environmental Manager, Aurora Energy <u>dfish@usibelli.com</u> (907) 457-0230

Appendix III.D.7.7-4352

TABLE OF CONTENTS

1.0 Introduction 1.1 ADEC BACT Analysis 1.2 Aurora BACT Analysis 2.0 Economic Infeasibility 3.0 Proposed Alternative BACT – District Heating 3.1 District Heating 3.2 District Heating Expansion 3.3 District Heating Economics 3.4 Output Based Emission 4.0 Proposed Alternative BACT - Firewood Drying Kiln 4.1 Equivalent Emissions 4.2 Firewood Kiln Economics 5.0 Proposed Alternative BACT - Biomass Co-Firing 5.1 Biomass Economics 6.0 Proposed Alternative BACT – Reduction in Potential to Emit 7.0 Precursor Demonstration 8.0 Conclusion Appendix A (Economic Analysis Spreadsheets – V1) Appendix B (Economic Analysis Spreadsheets – V2)

Appendix C (Coal Analyses Summary)

Appendix D (Professional Memos)

1.0 Introduction

The Fairbanks North Star Borough (FNSB) has levels of fine particulate matter (PM_{2.5}) that are above the health based National Ambient Air Quality Standard (NAAQS). In November 2009 the area was designated as a Moderate Nonattainment Area (NAA) based on monitoring data indicating the area did not meet the 2006 24-hour PM_{2.5} standard. On April 28, 2017, the area was re-designated as a "Serious" NAA as a result of not attaining the PM_{2.5} standard within 5-years from designation. As a result, the state is required to propose additional measures to bring the area into compliance within 10-years from designation (i.e., December 2019).

Once EPA re-classified the FNSB $PM_{2.5}$ nonattainment area to Serious, it triggered the requirement for stationary sources with over 70 tons per year (tpy) potential to emit (PTE) for $PM_{2.5}$ or its precursors (SO₂, NO_x, VOC, & NH₃) to conduct a Best Available Control Technology (BACT) analysis. Based on the Alaska Department of Environmental Conservation (ADEC) preliminary evaluations, sulfur dioxides are being evaluated for point source control measures under BACT. At this time, ADEC is considering one control measure per major stationary source to meet BACT and Most Stringent Measures (MSM) for sulfur dioxide (SO2) control. Preliminary Determinations by ADEC suggest a capital cost to Aurora Energy, LLC (Aurora) for BACT compliance of \$12,332,076 for an 80% removal efficiency using dry sorbent injection.

Aurora asserts that the proposed Best Available Control Technologies for sulfur dioxide emissions are not economically feasible. Confronted with this fact, ADEC and the EPA have asked Aurora to suggest an alternative to the ADEC proposed BACT. Within the context of this document Aurora is providing a proposal for alternative BACTs, all of which mitigate Aurora's impact to the nonattainment area problem.

The alternative BACTs proposed by Aurora provide meaningful solutions in offsetting the largest contributing factor to the PM_{2.5} problem in Fairbanks: home heating. The alternative BACTs being proposed by Aurora are more efficient from a dollar per ton of pollutant removed than the ADEC proposed BACT. Aurora strongly believes that these alternatives can have a more positive impact to the air quality issue than the ADEC proposed BACT. Before implementing these alternative BACTs, Aurora needs ADEC and EPA to agree that these alternative BACTs satisfy Aurora's obligations for compliance with the NAA issue and that future controls to address PM_{2.5} in the NAA will not be required.

Additionally, Aurora is making this alternative proposal based on the premise that ADEC and EPA will consider a precursor demonstration to determine the actual contribution of PM_{2.5} by the point sources in the NAA. It has been stated repeatedly that the point sources are not the primary cause of the PM_{2.5} problem. However there has never been a thorough analysis done to understand to what extent the point sources are or are not contributing to the problem. Should a precursor demonstration show that the point sources within the NAA are not major contributors to the PM_{2.5} problem, all PM_{2.5} compliance requirements imposed on the point sources shall be vacated. If however the precursor demonstration shows that the point sources are above the insignificance threshold, the alternative BACTs proposed by Aurora would satisfy the requirements for compliance within the NAA.

In closing, Aurora desires to be a part of the solution to reduce the $PM_{2.5}$ levels within the NAA. Aurora remains convinced that the ADEC proposed BACT is cost prohibitive and an inefficient use of funds. Instead Aurora is proposing alternative BACTs that directly help solve the PM2.5 problem. In proposing these alternatives, Aurora needs ADEC and the EPA to agree to continue to study the source of PM2.5

pollution as well as confirm that these alternative BACTs meet Aurora's compliance with the Clean Air Act for purposes of NAA attainment.

1.1 ADEC BACT Analysis

ADEC provided its review of a BACT analysis for Aurora which included an evaluation of technologies to mitigate emissions of oxides of nitrogen (NOx) and sulfur dioxide (SO₂) emissions, which are precursor pollutants that can form PM_{2.5} in the atmosphere post combustion. The BACT analysis evaluated all available control options for equipment emitting the triggered pollutants and followed a process for selecting the best option based on feasibility, economics, energy, and other impacts. The results of the BACT analysis are reflected in Table 1.

Technology	Pollutant	Capital Cost	Annualized Cost	Cost Effectiveness	
		(\$)	(ə/year)	(\$/1011)	
Selective Non-Catalytic Reduction (SNCR) ¹	NOx	\$ 3,930,809.00	\$ 957,728.00	\$ 2,226.00	
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 17,331,770.00	\$ 2,787,995.00	\$ 3,240.00	
Dry Sorbent Injection (DSI) ²	SO ₂	\$ 12,332,076.00	\$ 4,284,104.00	\$ 6,308.00	
Spray Dry Absorber (SDA) ²	SO ₂	\$ 60,270,115.00	\$ 11,862,577.00	\$ 15,525.00	
Wet Scrubber (WS) ²	SO ₂	\$ 65,957,875.00	\$ 12,160,961.00	\$ 14,469.00	

Table 1: Department Economic Analysis for Technically Feasible NOx and SO₂ controls.

1 - Capital Recovery Factor = 0.094 (7% interest rate for a 20 year equipment life)

2 - Capital Recovery Factor = 0.1098 (7% interest rate for a 15 year equipment life)

1.2 Aurora BACT Analysis

The ADEC requested additional information concerning Aurora's BACT analysis in a letter dated September 13, 2018. One of the ADEC's request were that Aurora comment on the cost analysis spreadsheets developed by ADEC and provided with the Preliminary Draft SIP. Comments were made on the spreadsheets and submitted to the ADEC on November 1, 2018. Below (Table 2) are the results of Aurora's inputs considering EPA and ADEC's comments. Spreadsheets are included along with this proposal for review by the agencies. Several changes to the inputs are documented in the summary for the spreadsheet inputs (See Appendix A & B). In conjunction with the changes made to the spreadsheets, sitespecific quote for SO₂ controls, namely Dry Sorbent Injection (DSI), was provided to the ADEC as requested and included as a parameter within the cost analysis spreadsheets for the referenced control technologies. The EPA is requiring that the cost analyses include a 30 year equipment life for the control technologies except SNCR which is evaluated for 20 year equipment life.

Table 2: Adjustment of ADEC Economic Analysis for Technically Feasible NOx and SO₂ Controls – V.1

Technology	Pollutant	Capital Cost (\$)	Annualized Cost (\$/year)	Cost Effectiveness (\$/ton)	
Selective Non-Catalytic Reduction (SNCR) ²	NOx	\$ 6,208,948.00	\$ 989,197.00	\$ 3,107.00	
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 25,758,941.00	\$ 2,921,054.00	\$ 4,587.00	
Dry Sorbent Injection (DSI) ¹	SO_2	\$ 20,682,000.00	\$ 4,601,940.00	\$ 8,423.00	
Spray Dry Absorber (SDA) ¹	SO_2	\$ 51,115,267.00	\$ 8,716,232.00	\$ 12,408.00	
Wet Scrubber (WS) ^{1,3}	SO_2	\$ 56,318,290.00	\$ 8,839,892.00	\$ 11,440.00	

1 - Capital Recovery Factor = 0.0669 (5.25% interest rate for a 30 year equipment life) [EPA requirement per comments]

2 - Capital Recovery Factor = 0.0820 (5.25% interest rate for a 20 year equipment life) [EPA requirement per comments]

3 - Does not include costs associated with building and maintaining a wastewater treatment facility. [Notation from ADEC spreadsheet]

Table 3 reflects another iteration (V.2) of Aurora's changes to the ADEC's spreadsheets. The results in Table 3 consider a lower emission rate for both SO₂ and NO_x based on 2011 source testing information and/or additional information. The SO_2 emission rate assumed by the state and Aurora has been 0.39 lbs/MMBtu. The coal analysis for feed coal during the test showed elevated sulfur content (0.18%) in comparison to the 5-year weighted average sulfur content from 2013-2017 (0.14 %). Using a conservative conversion from sulfur content (0.14%) to sulfur dioxide, the 5-year weighted average SO_2 emission rate would be 0.36 lbs/MMBtu. This conservative emission rate was used in the calculations to derive the cost effectiveness values in Table 2. The sulfur content during the source test conducted in 2011 (0.18%) when converted to a heat input emission rate considering total conversion of sulfur to SO₂ yields an emission factor of 0.48 lbs/MMBtu. The actual tested emission rate was 0.40 lbs/MMBtu. The emission rate for SO_2 was 83% of the maximum potential. This suggests there is 17% capture of sulfur compounds in the ash. As such, the emission rate derived and used in Table 3, considers a 17% capture of sulfur in the ash. The conversion of sulfur to SO₂ based on the 5-year weighted average sulfur content in coal and a 17% capture rate yields 0.30 lbs/MMBtu (0.36 lbs/MMBtu X 0.834 = 0.30 lbs/MMBtu). The results in Table 3 account for the current sulfur content in coal and the rate adjustment for sulfur capture fraction from the process based on a source test conducted in 2011.

Also accounted for in Table 3 is a more realistic equipment life expectancy for the facility and control equipment. It is not reasonable to consider a 30 year and 20 year life expectancy for the control equipment and the boilers. Considering the age of the Chena Power Plant, Units 1-3 are 50,000 lb/hr boilers that were installed in the early 1950s, and Unit 5 is a 200,000 lb/hr boiler which was installed in 1970. Units 1-3 are already +65 years and Unit 5 is +45 years old. A 30 year horizon should not be applicable to the Chena Power Plant. A 15 year equipment life is considered in the following cost effectiveness analysis (Table 3).

- ····· - ····························						
Technology	Technology Pollutant Capital C		Annualized Cost (\$/year)	Cost Effectiveness (\$/ton)		
Selective Non-Catalytic Reduction (SNCR) ¹	NOx	\$ 6,208,948.00	\$ 1,088,694.00	\$ 3,419.00		
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 25,758,941.00	\$ 3,721,132.00	\$ 5,844.00		
Dry Sorbent Injection (DSI) ¹	SO_2	\$ 20,682,000.00	\$ 4,914,480.00	\$ 10,785.00		
Spray Dry Absorber (SDA) ¹	SO_2	\$ 50,880,540.00	\$ 10,084,456.00	\$ 17,213.00		
Wet Scrubber (WS) ^{1,2}	SO ₂	\$ 56,318,290.00	\$ 10,314,589.00	\$ 16,005.00		

Table 3: Adjustment of ADEC Economic Analysis for Technically Feasible NOx and SO₂ Controls - V.2

1 – Capital Recovery Factor = 0.0980 (5.25% interest rate for a 15 year equipment life)

2 - Does not include costs associated with building and maintaining a wastewater treatment facility. [Notation from ADEC spreadsheet]

2.0 Economic Infeasibility

The BACT review process as outlined by EPA includes five-step approach to determine the best control option. The economic feasibility of potential measures are addressed under Step 4 of the review process. Since there is no cost threshold for economic feasibility for controls within a serious nonattainment area, a source has to make the assertion to the regulatory agencies in order for economic infeasibility to be considered. Aurora's BACT results, as illustrated in Table 3, show that the least expensive SO₂ control technology is a \$20 million dollar investment and the cost effectiveness value is above \$10,000/ton of SO₂ removed.

Therefore, per the fine particulate implementation guidance, if a source contends that a source-specific control level should not be established because the source cannot afford the control measure or technology demonstrated to be economically feasible, the source should make its claim known to the state and support the claim with information regarding the impact of imposing the identified control measure or technology on the following financial indicators to the extent applicable:¹

- 1. Fixed and variable production costs;
- 2. Product supply and demand elasticity;
- 3. Product prices (cost absorption vs. cost pass-through);
- 4. Expected costs incurred by competitors;
- 5. Company Profits;
- 6. Employment costs;
- 7. Other costs (e.g., for BACM implemented by public sector entities).

At this time, ADEC is considering one control measure per major stationary source to meet BACT and Most Stringent Measures (MSM) for sulfur dioxide (SO₂) control. ADEC's preliminary determination suggests Aurora invest \$12,332,076 for DSI technology to remove 80% of the SO₂ emissions from the Chena Power Plant. ADEC estimates that annualized costs for the application would be \$4,284,104. ADEC's projected capital cost for retrofit SO₂ control technology is just above half of the costs of a +50/-30 design (e.g., capital cost \$20,682,000) which was recently submitted to the ADEC. Even if the lower cost for controls estimated by the ADEC were valid, it is not economically feasible and therefore should not be required. Further, ADEC does not know whether the installation of DSI or any control technology on stationary sources will have a significant impact on the overall air quality in the non-attainment area.

Aurora has one electric customer and approximately 200 district heating customers. Income from power production is from wholesale electric sales to the local electrical cooperative, Golden Valley Electrical Association (GVEA). Aurora has a long term contract with GVEA which would be difficult to renegotiate for necessary price increases to accommodate additional control technologies. Pass-through cost opportunities for Aurora's district heating are not viable. The necessary product price increases to cover additional costs of the proposed control technology would price Aurora out of the market for both heat and power. The result would be higher electric and heat costs, coupled with an increase in PM_{2.5} pollution due to the introduction of ground-level emissions from oil and/or gas fired furnaces and boilers that would be installed to replace uneconomic district heat. As Aurora customers switch to less expensive fossil fuels – or yet even less expensive wood – the resulting burden on Aurora's remaining customers will increase, causing more and more of them to switch, resulting in a continuous increase in particulate emissions in the Fairbanks core, and in a death spiral for Aurora as an economically viable business. Within this section, Aurora will address the financial indicators applicable to demonstrate the economic infeasibility of installing and operating ADEC's proposed control technology.

1. Production Costs

Aurora's five year operating costs for electric and district heating (RCA) are provided below in Table 4. Operating costs consist of operations expense, maintenance expense, administrative expenses, and depreciation expense. The net operating costs for power generation was \$0.08/kW in 2017 (Table 4). The

¹ Federal Register, Vol. 81, No.164, Wednesday August 24, 2016. pg. 58085.

margin for income is small as reflected in Table 6. District heating operating costs exceed income generated resulting in a net loss over the past 5 years (Table 6).²

Year	Electrical Total	Net kWh	\$/kWh	District heating Total	Net MMBtu	\$/MMBtu
2017	\$13,795,480	181,113,600	\$0.08	\$4,658,655	262,189	\$17.77
2016	\$13,707,259	189,093,610	\$0.07	\$5,285,399	249,151	\$21.21
2015	\$12,582,952	194,083,220	\$0.06	\$5,395,212	267,686	\$20.16
2014	\$12,250,548	184,058,400	\$0.07	\$5,648,209	273,089	\$20.68
2013	\$10,833,349	181,569,600	\$0.06	\$5,387,853	274,139	\$19.65
Average	\$12,633,918	185,983,686	\$0.07	\$5,275,066	265,251	\$19.89

Table 4:	Aurora	Energy	Operating	Costs

2. Supply and Demand Elasticity

The issue of supply and demand elasticity is addressed in more detail within the context of the following sections. The cost of control technologies cannot be absorbed by Aurora under the current pricing to consumers for district heating and power. Aurora has no alternative but to pass those costs to its customers. Those customers, in turn, would have no choice but to go elsewhere for their heat and power, as Aurora would no longer be competitive with other options. This would be the beginning of a death spiral for Aurora as a business, and the beginning of an increase in lower level emissions in the Fairbanks core as more and more buildings switch to oil or gas for heat.

3. Product prices (cost absorption vs cost pass-through)

Aurora's current product prices are competitive with other power suppliers and heating sources. Aurora's heat business is generally regulated by the Regulatory Commission of Alaska (RCA). District heating prices are set based on Aurora's cost to produce the heat. At the same time, many district heat customers are able to switch to alternative sources of heat, such as oil, gas or wood; therefore, Aurora has a powerful incentive to maintain district heating prices competitive with other heating options. Likewise, GVEA maintains several contracts with various power producers including Aurora. GVEA's portfolio includes power generated with natural gas, hydroelectric gradient, wind, solar, coal, and oil. Aurora's contract with GVEA ensures Aurora's power pricing is competitive and marketable.

District Heating

District heating prices cannot absorb the pass through costs of control technology. Aurora's district heating customer base is approximately 200 including mostly commercial and some residential customers. District steam heating rates are set with oversight by the RCA and do not vary. Hot water district heating prices differ depending on consumers' annual heating needs. The hot water district heating rates are adjusted throughout the year to be competitive with other sources of heat.

Absorbing full or partial costs for upgrades or control technologies is not feasible through district heating rate adjustments. The price adjustment necessary to compensate for the current average annual net loss from district heating (Table 6) would be an increase of \$3.71/MMBtu representing a 20% increase in heating costs. A 20% increase in district heat prices per unit energy (MMBtu) is not marketable. The potential is a loss of revenue from customers switching to alternative forms of heat which would make

² Based on RCA annual filing from 2013-2017.

district heating even less sustainable and exacerbate air quality due to an increase in ground level emissions.

Electric Generation

Aurora's power pricing cannot absorb the pass through cost of control technologies without revising the current contract and becoming less marketable. Aurora sells its power at wholesale price to GVEA, its sole electric customer. Aurora has averaged 186,000 MWh in net sales annually. Pass through of any additional incurred cost would have to be negotiated with GVEA, and would cause an increase in power costs to all customers in GVEA's service area.

Product Pricing for GVEA including Control Technology Costs

ADEC indicates that SO₂ controls are being considered for BACT or Most Stringent Measures (MSM) at this time.³ ADEC's estimate of the capital investment of the preferred control technology for Aurora is estimated to be \$12,332,076 and the annualized cost is estimated to be \$4,284,104. The requirement is that BACT must be installed within 4 years of reclassification of an area from a moderate to a serious nonattainment area.⁴ The Fairbanks North Star Borough nonattainment area designation change from "Moderate" to "Serious" was effective June 9, 2017.⁵ Since the area is now identified as serious, BACT control would have to be in place by June of 2021. Funds for the capital investment would need to be arranged by 2019 to allow for construction and installation of the control equipment. The power purchase agreement with GVEA would need to be renegotiated prior to committing to construction.

Assuming electrical sales would correspond to the 5-year average (185,984 MWh), the weighted average price per MWh at the Chena Power Plant (CPP) would be \$85.51.⁶ When the annualized cost of operating the preferred control technology is included, the price of power from the CPP increases to \$108.55/MWh; a 27% increase in price of power. The average total electric power consumption of sulfur control on Healy Unit #2 is 550.5 kW.⁷ Assuming a comparable station service use, SO₂ control on the Chena Power Plant could require an additional 2.6% for station service load.

The SO₂ control technologies being considered (DSI) require the addition of lime, limestone, or sodium bicarbonate to the gas path prior to the baghouse. The amount of unreacted sorbent added to the process could alter the leaching characteristics of metals from coal ash. Recent testing of coal ash from coal blended with 2% by weight limestone, demonstrated elevated metals leaching from coal ash at various pH. Metals leaching in excess of water quality standards could require Aurora to incur additional disposal costs for coal ash. Aurora would either have to build a coal ash landfill, or take the coal ash to the municipal landfill at a cost to Aurora of \$90/ton.⁸ If additional costs were incurred by Aurora for disposing 20,000 tons of coal ash, then the price per MWh would need to increase to \$118.60; which represents a 39% increase in the price of power.

³ ADEC. 2018. Preliminary Draft, Possible Concepts and Potential Approaches for the development of the FNSB NAA Serious SIP.

⁴ Federal Register, Vol. 81, No.164, Wednesday August 24, 2016.

⁵ Federal Register, Vol. 82, No.89, Wednesday May 10, 2017.

⁶ 2013 Contract Pricing for 2020: \$79.37/MWh (<150,000 MWh) + \$112.12/MWh (>150,000 MWh).

⁷ Alaska Industrial Development and Export Authority. 1999. Spray Dryer Absorber System Performance Test Report, Healy Clean Coal Project. Healy, AK.

⁸ FNSB. 2014. Interior AK Coal Ash. Pg. 42
	0				0				
	Average kWh/year (2013-2017)	No Cor	ntrols	SO2	2 - DSI	SO2	- SDA	SO2	- WS
Annual BACT									
Operating Cost		\$	-	\$4	,284,104	\$11	,862,577	\$12	2,160,961
2020 (\$/kWh)	185,983,686	\$	0.09	\$	0.11	\$	0.15	\$	0.15
2020 (\$/kWh) -2.5%									
station load (BACT)	181,334,094	\$	0.08	\$	0.11	\$	0.15	\$	0.15
Coal Ash Disposal -									
Borough Landfill ¹		\$	-	\$	0.12	\$	0.16	\$	0.16

				~	. ~
$T_{a}hle 5 \cdot S/kW/h$	Wholesale Pricing	for GVEA	including (Control Techno	LOGV COSte
$1 a O C J. \phi K W H$	wholesale i fieling	IOI OVLA	menuumg v	control reenno	logy Costs

1 - Borough Landfill disposal cost based on 20,000 tons of ash; \$90/ton (FNSB. 2014). Interior AK Coal Ash. Pg 42.

Aurora's price of power is in competition with other power producers. If the price of power exceeds that of the competition, Aurora would not be as competitive in the energy market. Currently, GVEA will take as much power as Aurora can produce; however, it is likely that GVEA would reduce the amount of power accepted from Aurora if product prices increase above those of the competition.

4. Expected costs incurred by competitors

The FNSB nonattainment area impacts stationary sources within the area. Aurora's main competitors are power producers outside of the nonattainment area. Aurora's competition will not be required to consider BACT or MSM as a new requirement of a nonattainment area. This puts Aurora at a serious economic disadvantage. It is the only private for-profit power producer in the state being subjected to the $PM_{2.5}$ nonattainment area BACT requirements. Table 5 illustrates the price of wholesale power in $\/kWh$ from Aurora. The price of power with controls is 0.11/kWh. When additional disposal requirements are considered as a result of the use of the control technology, the price of Aurora's wholesale power to GVEA is 0.12/kWh.

Aurora's competition for power sales is primarily natural gas generated power; including Anchorage Municipal Light and Power (AMLP), Matanuska Electric Association, Inc. (MEA), and Chugach Electric Association (CEA). Aurora is also in competition with GVEA's fleet including the coal facilities (Healy #1 and Healy #2). The expected increase in price of Aurora's power due to BACT will make its power less marketable. At \$0.12/kWh, the price of Aurora's power to GVEA would exceed AMLP (\$0.09/kWh), Healy #1 (\$0.10/kWh), MEA (\$0.10/kWh), and CEA (\$0.11/kWh) based on GVEA's cost of power report in 2017⁹. Aurora currently provides 14% of GVEA's power requirements. At current prices, Aurora's power is competitive. An increase in the price of power to \$0.11/kWh or \$0.12/kWh would likely change that perspective.

5. Company Profits

Net income (loss) for Aurora over the past five years are not sufficient to absorb annual control technology costs for any of the control technologies proposed. Table 6 below includes the net income (loss) from district heating, electrical generation and the combined company income (loss) for years 2013

⁹ 2017 GVEA Annual Report to the RCA.

through 2017. Net income (loss) include income generated from district heat and power sales minus the operating costs as presented in Table 2 and include nonutility income, interest income, miscellaneous amortizations, and interest expenses.

			/
Year	Electric	District Heating	Net Income (loss)
2017	\$ 801,037.00	\$ (377,585.00)	\$ 423,452.00
2016	\$ 419,092.50	\$ (1,808,914.00)	\$ (1,389,821.50)
2015	\$ 1,094,599.25	\$ (1,059,348.00)	\$ 35,251.25
2014	\$ 321,876.05	\$ (892,950.00)	\$ (571,073.95)
2013	\$ 420,072.77	\$ (775,432.00)	\$ (355,359.23)
Average	\$ 611,335.51	\$ (982,845.80)	\$ (371,510.29)

Table 6: Aurora Energy, LLC – 5 Year Net Income (Losses)

The annual cost to operate the preferred technology is \$4,284,104 (Table 1 & 4); the average 5-year net income (loss) for Aurora is (\$371,510) [Table 6]. Conclusively, Aurora is not able to absorb the cost of additional control technologies.

The only alternative for Aurora to address annual operating expenses for any proposed control technologies would be to attempt to renegotiate the power contract to raise the price of power to GVEA. However, the rate adjustment would increase the price of Aurora's power to the extent that it would be less competitive.

6. Employment Cost

The state's calculations for annual operation costs of the proposed technologies include labor cost increases. The increases vary depending on the type of control technology. As a part of the state's analysis for SO_2 controls, annualized cost increases include the projection of additional labor for operation, maintenance, and administration.

7. Other Costs

No additional costs were considered.

ADEC has not shown that Aurora's, nor other stationary source's, SO₂ emissions are a significant contributor to the nonattainment area problem. ADEC does not know whether installation of BACT or MSM on stationary sources will significantly mitigate the impact of SO₂ on particulate concentration. Aurora cannot afford the control measure or technology that has been selected by the ADEC in the preliminary BACT analyses. The basis for this determination is that Aurora has consistently shown insufficient income to absorb the cost of the control technologies. Alternatively, increasing the price of power or heat to accommodate the cost of control technology will price Aurora's products out of the market. Any increase in district heating prices would make alternative sources of heat more attractive to consumers. The result would be a loss in business from customers switching to alternate sources of heat. This change in heating source could exacerbate pollution emissions at the ground level due to customers' use of distributed home heating alternatives. Aurora's district heating displaces the emissions from the equivalent of 2 - 2.5 million gallons of heating oil. The current power purchase agreement with GVEA allows Aurora's power to be competitive with other power sellers. The cost of additional control technology would have to be negotiated with Aurora's one customer based on its power purchase agreement and make Aurora's power prices less competitive; and subsequently, less sustainable.

3.0 Proposed Alternative BACT – District Heating

Aurora is sympathetic to the requirements of the Serious Nonattainment Area and believe that a reasonable alternative exists within the framework of what is economically feasible. As previously discussed, Aurora asserts that imposing retrofit controls, as proposed by ADEC, on its older boilers in the next four years is economically infeasible and could have negative impacts on the goals of the community to achieve attainment with the PM_{2.5} standard. As such, Aurora has developed a list of mitigating measures that are more economically sustainable and will have a direct impact on the community with respect to achieving attainment with the PM_{2.5} standard. Included as alternatives are the expansion of district heating, a wood drying kiln, and the potential use of biomass.

3.1 District Heating

Aurora is proposing that past district heat expansions as well as future district heating projects be considered as BACT for the Chena Power Plant. As it stands, Aurora's district heating displaces about 42 tons of SO₂ and 2 tons of particulates annually. District heating is referenced in both the Moderate Area State Implementation Plan (SIP)¹⁰ and the Preliminary Serious Area SIP¹¹ as a Pollution Control Measure for the FNSB NAA. As stated in the Moderate Area SIP, "An increase in the coverage of the district heating systems would therefore result in a decrease in measured PM_{2.5} concentrations". Based on modeling results, the PM_{2.5} concentration attributed to Aurora during an episode in 2008 was $0.02 \,\mu g/m^3$ and the SO₂ concentration at ground level from Aurora represents $0.75 \,\mu g/m^3$ (See Table 7).¹² The

Table 7: Summary of Six Major Fairbanks Point Source Plumes from CALPUFF for the Episode (Jan.23rd to Feb. 9th, 2008) Average Surface Concentrations at the State Office Building of PM2.5 and SO2 in ug/m3.

Power Plant	Episode	Episode
	average	average
	SO ₂ (μg/m ³)	PM _{2.5} (μg/m ³)
UAF- 316	2.75	0.16
Aurora- 315	0.75	0.02
Zehnder-109	0.48	0.19
Flint Hills-071	0.016	0.38
GVEA NP-110	3.8	1.45
Ft. WW- 1121	14	1.6
Total surface concentration	21.8	3.8

implication of the small pollutant contribution from Aurora at ground level is that taller stacks decrease the impact from emissions at ground level. The amount of pollutant loading at ground level within the nonattainment area is mitigated by district heating through the removal of ground level source emissions and vertically displacing them. An added benefit to increasing district heat coverage is an increase in efficiency at the plant. The plant is generally base loaded and driven to operate at a maximum capacity; there is moderate room for growth, but realistically, the plant is nearing its maximum capacity. The plant could accommodate, roughly, an additional 100 MMBtu/hour of heating capacity while still being able to provide a modest amount of electricity.

In order to quantify the impact district heating has on the nonattainment area, Aurora evaluates the potential use of fuel oil based on

¹⁰ ADEC. 2014. *Moderate Area State Implementation Plan. Appendix III.D.5.7.* pg 42.

¹¹ ADEC. 2018. Preliminary Draft, Possible Concepts and Potential Approaches for the development of the FNSB NAA Serious SIP.

¹² ADEC. 2014. Moderate Area State Implementation Plan. Section III.D.5.8-11.

a conversion from the heating load compensated by the plant for district heating. A fuel oil heating value of 137,000 btu/gal and an assumed efficiency of 85% for heating appliances are used to determine the quantity of heating oil equivalent to the district heating load. Since SO₂ and PM_{2.5} are the pollutants of most concern, Aurora is using emission rates for fuel oil using EPA's emission inventory warehouse, AP-42. Using the value of 2566 ppm sulfur in heating oil¹³, an emission rate of 36.92 lbs/10³ gallons (2.64×10^{-1} lbs/MMBtu) for SO₂ emissions and 0.4 lbs/10³ gallons (2.86×10^{-3} lbs/MMBtu) for filterable or direct PM_{2.5} and 1.3 lbs/10³ gallons (9.29×10^{-3} lbs/MMBtu) for condensable PM_{2.5} are derived. Using these emission rates, Aurora can evaluate the impact of district heating on the removal of SO₂ and PM_{2.5} from the nonattainment area.

As part of a further analysis, the SO₂ is converted to PM_{2.5} by using an ADEC derived method for comparing direct emissions of pollutants to PM_{2.5} concentration from various sources. Using this methodology, point source SO₂ emissions, wood smoke emissions, and heating oil SO₂ can be correlated to PM_{2.5} concentration. Through the use of a dispersion model, CALPUFF, ADEC determined that 22% of modeled SO₂ concentration are from point sources at ground level, 78% are from central oil, and <1% from mobile sources. Using this information and the ADEC's methodology (based on 'scenario 2'), a ratio of 5.5 tons SO2 emissions from major sources is estimated to form 1 μ g/m³ of PM_{2.5} as ammonium sulfate [8.38 TPD/(1.1 μ g/m³ x 132g/mol of ammonium sulfate/96 g/mol sulfate)]. Likewise, a ratio of 0.3 tons of wood smoke emissions is estimated to form 1 μ g/m³ of PM_{2.5}.¹⁴ Based on the same methodology, the ratio of SO₂ from fuel oil (78% of modeled concentration) to particulates is 0.8 tons of fuel oil SO₂ emissions to 1 μ g/m³ of PM_{2.5} as ammonium sulfate [4.12 TPD¹⁵/(3.9 μ g/m³ x 132g/mol of ammonium sulfate [4.12 TPD¹⁵/(3.9 μ g/m³ x 132g/mol of ammonium sulfate [4.12 TPD¹⁵/(3.9 μ g/m³ x 132g/mol of ammonium sulfate [8.18 more PM_{2.5} than the SO₂ from point sources and 2.6 times more PM_{2.5} than fuel oil.

Pollutant	Point Sources (SO ₂)	Fuel Oil (SO ₂)	Wood Smoke
Emissions (tons)	5.5	0.8	0.3
$PM_{2.5}$ Equivalent Concentration (μ g/m ³)	1	1	1

Table 8: Source pollutant emission and equivalent contribution in $\mu g/m^3$ of PM_{2.5}.

3.2 District Heat Expansion

District heating from Aurora mitigates emissions from ground level sources. The 5-year average (2013-2017) heating value of Aurora's district heat supply is 265,251 mmbtu/year. That is equivalent to about 2.3 million gallons of heating oil per year; assuming a heating value of 137,000 btu/gal and an 85% efficiency for an oil fired furnace. Using these values, district heat displaces about 42 tons of SO₂ from ground level emissions per year and 2 tons of PM_{2.5} in the down town area. Since 2008, Aurora has added district heating equivalent to 243,000 gallons of fuel oil per year. The impact of the addition is equivalent to the removal of 3510 lbs of wood smoke per year based on SO₂ reduction from fuel oil [4.5 TPY SO₂ fuel oil/0.77 tons SO2 fuel oil/1 µg/m³ x 0.3 tons wood smoke/1 µg/m³ x 2000 lbs/ton]. District heating records show that 67% of heating use is between November – March (151 days). The loading that

¹³ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.6. pg 102.

¹⁴ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

¹⁵ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.6. pg 27.

was mitigated since 2008 is approximately 16 lbs/day of wood smoke equivalence during the winter months.

Aurora has the mechanical potential to expand district heating another 100 mmbtu/hr of additional heating. The equivalent SO_2 removal potential would be about 24 tons per year based on the displacement of 1.3 million gallons of heating oil No.2 (fuel oil S% = 0.26).

3.3 District Heating Economics

Installation of district heating can be costly. The evaluation of DH as a control technology for the plant is difficult to assess a cost/ton comparison. Ideally, the expansion cost would be mitigated by revenue generated from the use of district heating. The business model for district heating would justify the expansion; the added benefit would be the reduction in pollutants emissions from ground level sources, and a decrease in the output based emission rate. In general, efficiency gains at the plant is a sustainable practice with the benefit of reducing pollutant emissions at ground level.

3.4 Output Based Emission

District heat expansion has the added benefit of making the plant more efficient. A method of illustrating efficiency gains with respect to pollutant emissions is in the derivation of an output based emission rate. The output based emission rate for SO_2 at the plant is approximately 4.6 lbs/MW of energy output. The emission rate is based on a conservative calculation using the 5-year weighted average coal sulfur content and converting all of it to SO_2 . The denominator consists of net power and net district heat sales in MW. When the maximum output of district heating is added to the denominator, the emission rate is reduced to 3.4 lbs/MW. This represents a 27% reduction in the emission rate per energy output.

The output based emission rate can be used to show efficiency gains with respect to pollutant emissions. Efficiency gains through the use of central heat and power facilities clearly demonstrate the advantages of minimize emission increases while maximizing energy output.

4.0 Proposed Alternative BACT - Firewood Drying Kiln

Couched within the benefits of district heating, Aurora is proposing an alternative to address its potential formation of fine particulate matter ($PM_{2.5}$) from sulfur dioxide. According to a 2008 report by the Northeast States for Coordinated Air Use Management (NESCAUM), for every 10 percentage point increase in the moisture content of wood, the $PM_{2.5}$ emissions increase by 65% to 167%. The increase in emissions is due to increased amount of wood needed to evaporate the extra moisture and poor combustion conditions leading to reduced heat transfer efficiency. Wood fuel use may double if wet wood were burned as opposed to dry wood.¹⁶ Aurora is proposing to develop and operate a firewood drying kiln using district heat from the Aurora plant to help mitigate the use of wet wood. The general idea is that, along with district heat conversions, Aurora would offset its potential $PM_{2.5}$ formation by providing dry wood to the community from a kiln. The kiln would require 3.5 mmbtu/hour of thermal loading from district heating. The initial moisture content in the wood is assumed to be around 50%; the kiln would evaporate 35% of the moisture to a wood moisture content of 15% or less. By conditioning solid fuel (fire wood) to be used in homes, district heating is effectively expanded without the cost of installation.

¹⁶ ADEC. 2014. *Moderate Area State Implementation Plan. Appendix III.D.5.7.* pg 22.

4.1 Equivalent Emissions

The state has derived a method for comparing direct emissions of pollutants to $PM_{2.5}$ concentration. Using this methodology, point source SO₂ emissions, wood smoke emissions, and heating oil SO₂ can be correlated to $PM_{2.5}$ concentration. Based on 22% of modeled SO₂ concentration from point sources at ground level, a ratio of 5.5 tons SO₂ emissions is estimated to form 1 µg/m³ of $PM_{2.5}$ as ammonium sulfate. Likewise, a ratio of 0.3 tons of wood smoke emissions is estimated to form 1 µg/m³ of $PM_{2.5}$.¹⁷ Using the fore mentioned conversions, Aurora estimated the power plants SO₂ emissions equivalent to wood smoke emission rate at Aurora of 608.3 tons/year of SO₂ (1.67 tpd), the wood smoke emission equivalent is 181 lbs/day [1.67 TPD/ (5.5 tons SO₂ from major sources/1 µg/m³) x 0.3 tons of wood smoke/1 µg/m³ x 2000 lbs/ton]. The equivalent annual wood smoke emission to 608.3 tons of SO₂ emission is proposed to be mitigated through drying wood by reducing 35% moisture from cord wood.

Source of Emissions	SO ₂ Emissions (tpd)	SO ₂ /PM _{2.5} (tpd)/(µg/m ³)	Wood Smoke/PM _{2.5} (tpd)/(µg/m ³)	Wood Smoke Equivalent (lbs/day)
Aurora Energy	1.67	5.5	0.3	181
Displaced Heating Oil Use - DH	0.01	0.8	0.3	10

Table 9: SO2 Conversion to Wood Smoke Equivalent Emission

The emission reduction for $PM_{2.5}$ in lbs/MMBtu was derived using the ADEC's referenced information within the Appendices of the Moderate Area State Implementation Plan (See Tables 10 & 11). The average emission rate for wood burning devices at 50% moisture (1.14 lbs/MMBtu) was subtracted from the average emission rate for wood burning devices at 15% moisture (0.67 lbs/MMBtu). The equivalent amount of cords needed to account for 100% of Aurora's annual SO₂ emissions is 8,495 cords per year.

Table 10. Emission raciors based on wood moisture content	Table	10:	Emission	Factors	based	on	wood	moisture	content
---	-------	-----	----------	---------	-------	----	------	----------	---------

Wood Burning Devices	EF PM2.5 lbs/ton ¹	Btu/lb ²	lbs/MMBtu	Btu/lb ²	lbs/MMBtu	Btu/lb ²	lbs/MMBtu
Moisture content (%)		0		15		50	
non-EPA certified Wood Stoves	11.6	8,119	7.14E-01	6,901	8.40E-01	4,060	1.43E+00
EPA Wood stove non-catalytic	7.57	8,119	4.66E-01	6,901	5.48E-01	4,060	9.32E-01
EPA Wood stove catalytic	8.4	8,119	5.17E-01	6,901	6.09E-01	4,060	1.03E+00
Hydronic Heater weighted 80/20 (OWB unqualified/OWB-Ph2)	9.43	8,119	5.81E-01	6,901	6.83E-01	4,060	1.16E+00
Average emission factor	9.25	8,119	5.70E-01	6,901	6.70E-01	4,060	1.14E+00
Note: 1 - Appendix III.D.5.6-105, Table 5.6-40; 2 - Appendix III.D.5.6-86, Table 5.6-31							

¹⁷ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

Table 11: Calculation to determine how much kiln dried wood is necessary to mitigate AE's SO_2 emissions.

PM 2.5 Daily Emissions Reduction [Scenario 2] (lbs/day)	181
PM 2.5 Annual Emissions Reduction (lbs/year)	66,003
Spruce weight at 20% moisture	2,550
Dry Wood (%) moisture	15
Wet Wood (%) moisture	50
Emission Diff. wet vs. dry (lbs/MMBtu)	4.69E-01
Daily Wood processing minimum (MMBtu/year)	140,695
Cords per year	8,495
cords/load	42
Loads per year	202

4.2 Firewood Kiln Economics

The capital cost and annualized cost of the kiln is much less than that of the other BACT alternatives. The cost effectiveness is determined by a % cost ratio based on drying wood at a maximum potential of 8,495 cords of wood to reduce, effectively, 608.3 tons per year of SO₂-equivalent emission. The annualized cost is used to derive the cost effectiveness ratio of \$980 per ton of pollutant removed.

Table 12: Cost Effectiveness of Kiln

Control Technology	PM 2.5 Reduction (tpy)	Equivalent SO2 Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annual Cost (\$/year)	Cost Effectiveness (\$/ton SO ₂)
Wood Kiln	32.5	608.3	\$ 1,500,000	\$ 736,078	\$ 980

Unlike a traditional BACT approach, the effective emission reduction is hinged on the marketability of dry wood. Aurora plans to market the kiln dried wood as a benefit from a performance and air quality standpoint. The Fairbanks Northstar Borough, ADEC and EPA all have an important role in enforcing the use of dry wood for home heating the NAA.

5.0 Proposed Alternative BACT - Biomass Co-Firing

Aurora's boilers are subject to 40 CFR 63 subpart JJJJJJ. Under the rule, the Chena Power Plant (CPP) boiler units are classified as coal-fired boilers. The definition of coal-fired boiler subcategory extends to coal boilers that burn up to 15% biomass on a total fuel annual heat input basis. This flexibility in definition would allow Aurora to burn up to 15% biomass and still retain its classification as a coal-fired boiler. Aurora has been involved in a projects with Alaska Center for Energy and Power (ACEP) and the US Forestry Service using biomass (wood chips and refuse) as a substitute for coal. The projects did not demonstrate much of a change to the current operations; however, the material used had a significant amount of moisture (40%) and was not uniform. Sizing of the material was an issue and created problems. Biomass refuse and chips were not appropriately sized and created issues with material feeding through the auxiliary coal feed system. Also, due to density differences, material segregation within the bunkers occurred; wood chips tended to be pushed to the top of the coal. Ultimately, the lessons learned from the project were that with the right material sizing and processing, biomass could be used in the boilers to

help increase efficiency. As noted by operators during the project, the biomass burned off quickly leaving holes within the coal bed which allowed for air pockets which qualitatively made coal combustion more effective. The theory is that air voids left after the biomass was burned off facilitated greater air-to-fuel contact. Also, the rapid burning of the biomass may have increased the heat of the coal bed which helped coal combustion. Although this theory has not been vetted though rigorous research, the potential benefits of using biomass within the process may be substantial. At the very least, biomass has very little sulfur and could be a measure to mitigate the emissions of SO_2 from the plant.

The material used during the biomass project at Aurora was unprocessed and, consequently, not uniform. If the biomass material was processed and met some consistency standards there could be a significant measurable gain in efficiency. As such, processed biomass in the form of industrial grade pellets can provide a consistent sizing which would be compatible with the sizing of the stoker coal used at the Chena Power Plant (CPP). The benefit of using an industrial grade pellet is that the anticipated heat content of the pellets are assumed to be upwards of 8300 btu/lb, the moisture content is near 0%, and there is very little sulfur in the fuel. The cons of using an industrial grade biomass pellet is the cost of the fuel which could be as high as \$295/ton. At this cost, the use of biomass is not economical. Furthermore, Aurora has not determined whether or not enough raw timber supply is available around the Fairbanks area to accommodate a consistent 15% blend rate. However, if waste biomass material, such as sawdust or bark, from local wood sellers were processed into pellets the raw material could be acquired at a low cost.

5.1 Biomass Economics

Biomass pellets, due to their lack of sulfur, could be used as mitigation for SO₂ emissions. As stated above, the negative aspect of pellets is in the cost and potential lack of access to raw material supply. In order to derive a price point for pellets that would be acceptable as a control technology, a cost

Table 13: Biomass and Coal Fuel Revenue/MMBtu				
hhv pellets btu/lb	8,300			
hhv pellets mmbtu/ton	16.6			
hhv coal btu/lb	7,613.05			
coal moisture	29%			
heat of vaporization of water @ 77F btu/lb	1,049.70			
coal btu/lb -vaporized free water	7,304			
coal mmbtu/ton -vaporized free water	14.6			
pellet coal equivalent	1.14			
revenue/ton of coal	\$ 79.09			
revenue/mmbtu of coal	\$ 5.41			
revenue/mmbtu of pellets	\$ 4.76			

effectiveness value of 3.125/ton SO₂ removed is used as a reference. This is a conservative estimate derived by the state in the moderate area SIP.¹⁸ If the 5-year average revenue generated by the plant is divided by the 5year average coal use we get a value of \$79.09 revenue/ton of coal. Pellets have a higher btu/lb content than the coal and pellets have no moisture. To account for this discrepancy, coal heating value is

considered after the evaporation of moisture. The energy needed to vaporize free moisture ($h_{vap} = 1049$ btu/lb @ 77F) is multiplied by the moisture fraction of coal to derive the heat content of the coal at 0% moisture. When comparing the wood pellets to coal, the 5-year average heat content (7623 btu/lb) and moisture (29%) is considered. The heating value of coal without moisture is 7304 btu/lb (7623 btu/lb –

¹⁸ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

1049.7*29/100). Pellets would	Table 14: Biomass Cost Effectiveness Calcul	ation
have a heating content of 8300 btu/lb and no moisture. If the price of the pellets were	capital investment (hopper modification to auxillary coal feed system)	\$300,000.00
\$84/ton, the cost effectiveness	loan period (years)	\$5.00
value would be \$3,093.04/ton	interest rate (%)	8%
SO ₂ removed.	monthly loan amount	\$6,082.92
The emission reduction	Annual loan amount	\$72,995.04
potential using pellets at 15%	Burden for 0.5 man equivalent (2016)	\$65,520
total fuel loading is 91.24 tons	5-year avg Annual Coal (tons)	221,758.29
of SO_2 per year. Aurora is	5-year avg coal sulfur (%)	0.14%
actively pursuing this concept;	potential max SO2 (tons/yr)	608.24
however, running the boiler	Annual pellets (%)	15%
with 15% biomass has not	Annual pellets (tons)	29,272.22
industrial wood pellets at the	emission reduction (tons/yr)	91.24
preferred price has not been	Cost pellets (\$/ton)	\$84.00
identified nor has the	Annual cost	\$2,597,381.16
availability of the raw material	Annual revenue	\$2,315,186.17
supply been verified.	annual burden of pellets	\$282,194.99
	cost/ton removed	3,093.04

6.0 Proposed Alternative BACT – Reduction in Potential to Emit

Aurora proposes to monitor the stack gas emissions out of the common stack. The purpose of the monitoring would be to ensure compliance with an SO_2 emission rate of 190 ppm. Instead of taking a reduction in the sulfur content of the coal or PTE for SO_2 emissions, monitoring the stack gas emissions and maintaining a rolling 30-day average at or under 190 ppm ensures that the plant is not exceeding a certain loading rate equal to 0.25% coal sulfur content. Using the SO_2 emission calculation in the Air Quality Operating permit AQ0315TVP03 Rev. 1, Condition 22.1.c; a stack gas concentration of 7.5% O_2 ; and adjusting the S% to 0.25 (in this ultimate analysis the S% is 0.26), the SO_2 concentration is 188 ppm as illustrated below:

I I L'ule I. DO/ ennobient culculule	Figure	1:	SO ₂	emission	calcu	lation
--------------------------------------	--------	----	-----------------	----------	-------	--------

SO2 Concentration P	PPM = (1.00X 10^6 xmol ₅₀₂)/(mo	l _{so2} +mol _{co2} +mol _{o2} +mol _N	2)			
SO2 PPM =						
Where:						
mol SO2 =	[wt% Sfuel,%]/32.06					
mol CO2 =	[wt%Cfuel,%]/12.01					
mol O2 =	MF x [(wt%Nfuel,%]/28.01)+	(4.76xmolCO2)+(4.76xmo	ISO2)+(1.88xmoIH2O)-(3.76x[wt%Ofuel,%]/3	32.00)]		
MF =	[vol%O2,exhaust,%]/(100%-4	4.76x[vol%O2, exhaust, 9	6])			
mol H2O =	[wt%Hfuel,%]/2.016					
mol N2 =	([wt%Nfuel,%]/28.01)+(3.76)	xmolSO2)+(3.76xmolCO2)+(1.88xmolH2O)+(3.76xmolO2)-([wt% Ofuel	,%]/8.51)		
Constituent	mols in flue gas		Ultimate/proximate analysis (AE08162018)	%weight (dry)	Atomic Mass	Atomic Mass
mol _{so2}	0.007796663		wt% Sulfur _{fuel} , %	0.25	Sulphur	32.065
mol _{co2}	5.219382233		wt% Carbon _{fuel} , %	62.69	Carbon	12.011
mol _{H20}	2.277011608		wt% Hydrogen _{fuel} , %	4.59	Hydrogen	1.0079
moloz	3.098516312		wt% Nitrogenfuel, %	0.93	Nitrogen	14.007
mol _{N2}	33.05690137		wt% Oxygen _{fuel} , %	21.8	Oxygen	15.999
MF	0.116640747			%vol		
			Oxygen exhaust %	7.5		
SO ₂ Concentration	188.404394		Source Test Required if exhaust SO ₂ Concer	ntration is greate	er than 500 pp	m m

As mentioned, 190 ppm of SO2 emissions on a 30-day rolling average represents an overall PTE reduction from 0.4% sulfur content to 0.25% while still allowing flexibility with respect to coal quality exceeding 0.25% sulfur.

7.0 Precursor Demonstration

As part of the Serious SIP development, states are required to develop Best Available Control Measures for all source sectors that emit PM_{2.5} and the four major precursor gases (e.g., NOx, SO₂, NH₄, and VOC). The analysis specific to the major stationary source is a Best Available Control Technology analysis. Within the rule, if the state determines through a precursor demonstration that controls for a precursor gas are not needed for attaining the standard, then the controls for a precursor gas are not required to be implemented.¹⁹ The regulations provide for three kinds of precursor analyses, comprehensive (which consider precursor emissions from all sources in the nonattainment area), Major stationary source (which consider precursor emissions from major sources), and Nonattainment New Source Review (which considers potential precursor emissions from new sources).²⁰ For each of the first two analyses, there are two varieties available to the state: a concentration-based analysis (compares the precursor contributions to a numerical threshold) and a sensitivity-based analysis which consider other factors to evaluate if reductions in the precursor emissions would significantly reduce PM_{2.5} levels in a nonattainment area.

The ADEC has successfully demonstrated that oxides of nitrogen NOx and VOC are not a significant precursors to the area. The NOx precursor demonstrations included a comprehensive demonstration with a sensitivity based analysis for the community and a Major Stationary Source – concentration based analysis which demonstrated that major sources are not a significant contributor to the nitrate-based particulate formation.²¹ The state also conducted a comprehensive, concentration-based analysis for SO₂ and concluded that SO₂ emissions in the NAA contribute 5.4 µg/m³ in the Fairbanks area and 4.9 µg/m³ of PM_{2.5} in the North Pole area. Since these concentrations exceed the significance threshold of 1.3 µg/m³ (now 1.5 µg/m³)²², the ADEC proposes not to conduct a sensitivity-based precursor demonstration nor are they considering a major source precursor demonstration.

EPA's draft precursor guidance recognizes that the significance of a precursors contribution is determined based on the facts and circumstances of the area which include source characteristics such as source type, stack height, and location.²³ The rationale for doing a precursor demonstration fits with the site-specific factors listed in the EPA guidance, namely tall stacks. However, the ADEC and EPA have been resistant to performing or further considering a Major Source precursor demonstration.

Aurora sought a third party opinion (Ramboll Environmental) regarding the possibility of a successful SO_2 precursor demonstration that could demonstrate that major stationary sources are an insignificant part of the contribution to the nonattainment area. According with the EPA's precursor demonstration guidelines, a successful major stationary source precursor demonstration must show that SO_2 emissions do not contribute significantly to violations of the PM_{2.5} standard (1.5 µg/m³). If the 'contribution-based'

¹⁹ ADEC. 2018. Preliminary Draft Precursor Demonstration.

²⁰ See 40 C.F.R. § 51.1006

²¹ ADEC. 2018. Preliminary Draft Precursor Demonstration.

²² Draft EPA (2016b) guidance recommended 1.3 μ g/m³ for the PM_{2.5} 24-hour NAAQS as the appropriate threshold to identify insignificant contributions to PM_{2.5} concentrations. A more recent updated technical basis document, EPA (2018) now recommends a threshold for identifying significance of 1.5 μ g/m³.

²³ EPA's 2016 Draft PM_{2.5} Precursor Demonstration Guidance.

analysis indicates that the impact exceeds $1.5 \ \mu g/m^3$, then a 'sensitivity-based' analysis may be conducted to show that a reduction of SO₂ emissions in the range of 30-70% would have only an insignificant impact on lowering PM_{2.5}.

Two main hurdles exist to conducting a credible SO_2 precursor demonstration; 1) the large contribution of sulfate by major and minor source contribution to the nonattainment area; and 2) the large under prediction of sulfate mass through the model (CMAQ). In essence, while the SO_2 sources are observed to contribute significantly to the $PM_{2.5}$ nonattainment area, current modeling systems are not sufficiently accurate to provide a reliable estimate of the impacts of emission reductions from SO_2 .

Utilizing the ADEC's information within the Moderate Area SIP, Aurora's third party consult suggests that there is relevant data to suggest major sources are potentially insignificant contributors to the NAA.

"...data analyses and modeling conducted for the Fairbanks moderate area SIP provide some significant information which suggests that in fact major source SO_2 emissions may not contribute significantly to $PM_{2.5}$ nonattainment."²⁴

As such, a Major Source SO₂ precursor demonstration must be pursued by the ADEC. It is an undue burden for Aurora and other major sources within the NAA subject to the requirements of control measures (BACT, and more likely MSM) considering that there is data to suggest that major sources could be insignificant. Even though updating models and research into the chemistry of sulfate particulate formation is costly and time consuming, it is due diligence on the agencies part to further elucidate the impact of major sources. Ultimately, Aurora will continue to pursue alternative control measures as proposed within this document under the assumption that the agencies (ADEC and EPA) will continue to vet the sulfate contribution disparity between model and observed values with the perspective of major stationary source contribution.

8.0 Conclusion

The proposed BACT alternatives in this document and accompanying information demonstrate that the ADEC proposed BACT are economically infeasible and do very little to solve the air quality problem in the nonattainment area. EPA, the State of Alaska, as well as the local community understand and agree that the majority of the PM_{2.5} problem in the area is from home heating sources. Aurora contends that requiring the implementation of the ADEC proposed BACT controls would cause the pollution problem to worsen due to our district heat customer's refusal to accept a higher cost heating product and instead switching to fuel oil, or wood burning.

Aurora does not believe ADEC has demonstrated that the point sources, or more specifically Aurora, are contributing to the $PM_{2.5}$ problem in a significant enough way to warrant the need for additional control measures. Aurora believes that a precursor demonstration would prove this assertion one way or another. Aurora believes a precursor demonstration is possible and requests that ADEC and the EPA move forward with conducting a precursor demonstration in parallel with the implementation of the SIP. Should a precursor demonstration show that the point sources do not cross over the significance threshold, all point sources should be released from further compliance with the $PM_{2.5}$ requirements.

Even though Aurora is not convinced that major source emissions exceed the significance threshold for $PM_{2.5}$ within the NAA, Aurora is interested in being a part of the solution to reduce $PM_{2.5}$. Aurora's

²⁴ Memo. Ramboll. "Summary of issues related to SO₂ precursor demonstration for Fairbanks".2018.

proposed alternative BACT controls are more effective from an environmental perspective and cost substantially less than the ADEC proposed BACT controls. The table below shows the potential amount of SO_2 and $PM_{2.5}$ removed from the NAA by Aurora's proposed alternative BACT.

Emissions	SO2 (tpy)	PM 2.5 (tpy)	Qualifying Parameters
District Heating	42 tpy at	2 tons at	250,000 - 300,000
(Current Operating Conditions)	ground level	ground level	mmbtu per year
District Heating	24 tpy at	1 ton at	100 mmbtu/hr expansion
(Potential Expansion)	ground level	ground level	potential
Wood Kiln	608.3tpy	33 tons at ground level	8495 cords/yr
Biomass Co-Firing	91.2 tpy		15% by fuel heat input from industrial pellets
Potential to emit reduction	38% reduction in PTE (854 tpy)		State upper limit of 500 ppm over 3 hours. Proposed 190 ppm as a new PTE
Total Potential Reduction	1,619.5 tpy	36 tpy	

Table 15: Summary of BACT Alternatives and Potential Emission Reduction

As clearly shown in this table, the environmental benefits from Aurora's proposed alternative BACTs will positively impact the current NAA. Aurora is prepared to move forward with implementing these alternative BACTs as soon as ADEC is able to provide Aurora with the assurance that additional control measures or fees will not be required in order to demonstrate compliance with the PM2.5 regulations for the NAA.

Aurora is committed to continuing to work with ADEC, EPA and the local community in working toward meaningful solutions to the air quality problem in Interior Alaska.

Appendix A (Economic Analysis Spreadsheets – V1)

Air Pollution Control Cost Estimation Spreadsheet

For Selective Catalytic Reduction (SCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Catalytic Reduction (SCR) control device. SCR is a post-combustion control technology for reducing NO_x emissions that employs a metal-based catalyst and an ammonia-based reducing reagent (urea or ammonia). The reagent reacts selectively with the flue gas NO_x within a specific temperature range to produce N₂ and water vapor.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SCR control technology and the cost methodologies, see Section 4, Chapter 2 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM) (version 5.13). The size and costs of the SCR are based primarily on five parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, reagent consumption rate, and catalyst costs. The equations for utility boilers are identical to those used in the IPM. However, the equations for industrial boilers were developed based on the IPM equations for utility boilers. This approach provides study-level estimates (±30%) of SCR capital and annual costs. Default data in the spreadsheet is taken from the SCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/powersector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will clear many of the input cells and reset others to default values.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SCR is for new construction or retofit of an existing boiler. If the SCR will be installed on an existing boiler, enter a retrofit factor between 0.8 and 1.5. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you select fuel oil or natural gas, the HHV and NPHR fields will be prepopulated with default values. If you select coal, then you must complete the coal input box by first selecting the type of coal burned from the drop down menu. The weight percent sulfur content, HHV, and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided. Method 1 is pre-selected as the default method for calculating the catalyst replacement cost. For coal-fired units, you choose either method 1 or method 2 for calculating the catalyst replacement cost by selecting appropriate radio button.

Step 4: Complete all of the cells highlighted in yellow. If you do not know the catalyst volume (Vol catalyst) or flue gas flow rate (Q_{flue gas}), please enter "UNK" and these values will be calculated for you. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.005 and 0.03, respectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SCR.

Adopted

November 19, 2019

		Data Inputs			
Future the full sector data for some some brothing south					
Enter the following data for your combustion unit:					
Is the combustion unit a utility or industrial boiler?	al 🔻	What type of fu	el does the unit burn?	Coal 🗨	
Is the SCR for a new boiler or retrofit of an existing boiler?	-				
Please enter a retrofit factor between 0.8 and 1.5 based on the level of diffi projects of average retrofit difficulty.	ulty. Enter 1 for 1.5	Simpson, Aaron: No basis was provided ap for installation of select	to justify a retrofit factor reflective catalytic reduction on the	ecting greater than average boilers.	difficulty
Complete all of the highlighted data fields:		High retrofit cost facte unique ductwork and additional engineering	ors may be justified in unusual piping, site preparation, tight f , and asbestos abatement).	circumstances (e.g., long ar its, helicopter or crane insta	nd Ilation,
What is the rating at full load capacity (MMBtu/hr)?	497 MMBtu/hr	Aurora: Location of the 500-800F, would be the 1t's a titght fit, limited	ne catalyst, if it has to be insta he top of the boilers just befor space, asbestos abatement ne	alled within a temperature ra re the economizer and air pr ecessary, duct work is compl	nge of reheater. lex and
What is the higher heating value (HHV) of the fuel?	7,560 Btu/lb	Enter the sulfur	content (%S) =	0.20 percent by weigh	nt
	Simpson, Aaron Typical Gross As R	: Received. http://www.usibelli.com/coal/	data-sheet	Simpson, Aaror Typical Gross As	n: Received. http://www.usibelli.com/coal/data-sheet
What is the estimated actual annual fuel consumption?	569,114,000 lbs/year	For units burnin Note: T for the the def	g coal blends: he table below is pre-popu se parameters in the table b ault values provided.	lated with default values below. If the actual value	for HHV and %S. Please enter the actual values for any parameter is not known, you may use
Enter the net plant heat input rate (NPHR)	18 MMBtu/MW		Fract	tion in	
If the NPHR is not known, use the default NPHR value:	Fuel Type Default NPHR Coal 10 MMBtu/MW Fuel Oil 11 MMBtu/MW Natural Gas 8.2 MMBtu/MW	Si y Please	Bituminous ub-Bituminous Lignite	Blend %5 0 2.35 1 0.2 0 0.91	HHV (Btu/lb) 11,814 7,560 6,534
Plant Elevation	450 Feet above sea l	For coal-fired the catalyst re rows 85 and 8	posed on the data in the tab poilers, you may use eithe placement cost. The equ 5 on the Cost Estimate ta	er Method 1 or Method ations for both method b. Please select your pr	2 to calculate Is are shown on eferred OMethod 2 OMethod 2
Enter the following design parameters for the proposed SCR			_		
Number of days the SCR operates $(t_{\mbox{\tiny SCR}})$	365 days Ass	npson, Aaron: uming baseline of 0.5 lb/MMBtu from	Number of SCR reactor cl	hambers (n _{scr})	1
Number of days the boiler operates (t_{plant})	365 days Sub	ppart Da – Technical Support for posed Revisions to NOx Standard, U.S.	Number of catalyst layers	s (R _{layer})	3
Inlet NO_x Emissions (NOx_{in}) to SCR	0.37 lb/MMBtu	A, Office of Air Quality Planning and ndards, EPA-453/R-94-012, June 1997.	Number of empty catalys	st layers (R _{empty})	1
NOx Removal Efficiency (EF) provided by vendor	80 percent Aur	Tora: Emission Inventory rate based or	Ammonia Slip (Slip) provi	ided by vendor	10 ppm
Stoichiometric Ratio Factor (SRF)	0.525	1 source testing.	(Enter "UNK" if value is n	yers (Vol _{catalyst}) ot known)	UNK Cubic feet
*The SRF value of 0.525 is a default value. User should enter actual value, if known E E C	mpson, Aaron: A's Air Pollution Control Technology Fact 1 Introl. https://www3.epa.gov/ttncatc1/dir1	Sheet indicating 70 - 90 percent	Flue gas flow rate (Q _{fluega} (Enter "UNK" if value is n	s) ot known)	Aurora: Source Test dst 179,783.2 acfm = 162098.5. 162098.5. dstring dstrin
Estimated operating life of the catalyst (H _{catalyst})	24,000 hours				Simpson, Aaron:
Estimated SCR equipment life	30 Years*		Gas temperature at the S	CR inlet (T)	310 °F April 7, 2016 Source Test
r or moustrier owners, the typical equipment life is between 20 and 25 years.			(Q _{fuel})	earc now rate idelor	516 ft ³ /min-MMBtu/hour
Concentration of reagent as stored (C _{stored})	50 percent*	*The reagent concentration	n of 50% and density of 71 lbs/cft	are	
Density of reagent as stored (ρ_{stored})	71 lb/cubic feet*	default values for urea reagent, if different from t	gent. User should enter actual val ne default values provided.	lues for	
Number of days reagent is stored $(t_{storage})$	30 days			Densities of typic 50% urea solutio 29.4% aqueous N 19% aqueous NH	cal SCR reagents: in 71 lbs/ft ³ VH ₃ 56 lbs/ft ³ 4 ₃ 58 lbs/ft ³
Select the reagent used Urea	▼				
Enter the cost data for the proposed SCR:					
Desired dollar-year	2016				
CEPCI for 2016	536.4 Enter the CEPCI	value for 2016 584.6 2012 C	EPCI CEPCI	= Chemical Engineering Pl	lant Cost Index
Annual Interest Kate (i)	5.25 Percent				
Reagent (Cost _{reag})	1.62 \$/gallon for a 50	D percent solution of urea son, Aaron:			
Electricity (Cost _{elect}) Catalyst cost (CC)	0.210 \$/kWh GVEA \$/cubic foot (inc 160.00 catalyst and inst	rates. http://www.gvea.com/rates/rate cludes removal and disposal/regene callation of new catalyst*	s ration of existing	cf is a default value for the cat	alyst cost. User should enter actual value if known.
Operator Labor Rate	63.00 \$/hour (including	g benefits)	¢100)		

Adopted

November 19, 2019

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Operator Hours/Day

ľ

4.00 hours/day*

0.005

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

laintenance and Administrative Charges Cost Factors:	
Maintenance Cost Factor (MCF) =	
Administrative Charges Factor (ACF) =	

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source
Reagent Cost (\$/gallon)	1.62	Based on the average of vendor quotes from 2011 - 2013.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for utilities is based on 2014 electricity production cost data for fossil-fuel plants compiled by the U.S. Energy Information (EIA). Available at http://www.eia.gov/tools/faqs/faq.cfm?id=19&t=3.	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Percent sulfur content for Coal (% weight)	0.31	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Higher Heating Value (HHV) (Btu/lb)	8,730	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Catalyst Cost (\$/cubic foot)	160	Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emissions Control Technologies", July 2013.	

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q _B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tscr/tplant) =	0.99	fraction	
Total operating time for the SCR $(t_{op}) =$	CF _{total} x 8760 =	8657	hours	-
NOx Removal Efficiency (EF) =	(NOxin- NOxout)/NOxin =	80.0	percent	
NOx removed per hour =	$NOx_{in} x EF x Q_B =$	147.11	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	636.77	tons/year	-
NOx removal factor (NRF) =	EF/80	1.00		
Volumetric flue gas flow rate (q _{flue gas}) =	Q _{fuel} x QB x (460 + T)/(460 + 700)n _{scr}	179,783	acfm	-
Space velocity (V _{space}) =	q _{flue gas} /Vol _{catalyst}	30.03	/hour	
Residence Time	1/V _{space}	0.03	hour	
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO_2 Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not applicable;
Atmospheric pressure at sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	does not apply to plants located at
Retrofit Factor (RF)	Retrofit to existing boiler	1.50		elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Adopted

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)(1/((1+ interest rate) ^Y -1), where Y =	0.245	Franklar
	H _{catalyts} /(t _{SCR} x 24 hours) rounded to the hearest integer	0.316	Fraction
Catalyst volume (Vol _{catalyst}) =	2.81 x Q _B x EF _{adj} x Slipadj x Noxadj x Sadj x (Tadj/Nscr)	5,986.26	Cubic feet
Cross sectional area of the catalyst (A _{catalyst}) =	q _{flue gas} /(16ft/sec x 60 sec/min)	187	ft²
Height of each catalyst layer (H _{layer}) =	$(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$	12	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A _{SCR}) =	1.15 x A _{catalyst}	215	ft ²
Reactor length and width dimentions for a square	()0.5	14.7	foot
reactor =	(A _{SCR})	14.7	
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	84	feet

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole
		Density =	71 lb/ft ³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	(NOx _{in} x Q _B x EF x SFR x MW _R)/MW _{NOx} =	101	lb/hour
Reagent Usage Rate (m _{sol}) =	m _{reagent} /Csol =	202	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	21	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x t _{storage} x 24)/Reagent Density =	15,296	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n}-1=$	0.0669
	Where n = Equipment Life and i= Interest Rate	

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	A x 1,000 x 0.0056 x (CoalF x HRF) ^{0.43} =	365.95	kW
	where $A = (0.1 \times QB)$ for industrial boilers.		

Cost Estimate

Total Capital Investment (TCI)

	TCI for Coal-Fired Boilers		
For Coal-Fired Boilers:			
	TCI = $1.3 \times (SCR_{cost} + RPC + APHC + BPC)$		
Capital costs for the SCR (SCR _{cost}) =	\$14,132,761	in 2016 dollars	
Reagent Preparation Cost (RPC) =	\$2,348,710	in 2016 dollars	
Air Pre-Heater Costs (APHC)* =	\$0	in 2016 dollars	
Balance of Plant Costs (BPC) =	\$3,333,099	in 2016 dollars	
Total Capital Investment (TCI) =	\$25,758,941	in 2016 dollars	
st Not applicable - This factor applies only to coal-fired boilers that bu	irn bituminous coal and emits equal to or greater than 3lb/MMBtu of sulfur dic	ixide.	
	SCR Capital Costs (SCR _{cost})		

	SCR Capital Costs (SCR _{cost})	
For Coal-Fired Utility Boilers >25 MW:		
	$SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (B_{MW} \text{ x HRF x CoalF})^{0.92} \text{ x ELEVF x RF}$	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	$SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (0.1 \text{ x} Q_{B} \text{ x} CoalF)^{0.92} \text{ x} ELEVF \text{ x} RF$	
SCR Capital Costs (SCR _{cost}) =		\$14,132,761 in 2016 dollars
	Reagent Preparation Costs (RPC)	
For Coal-Fired Utility Boilers >25 MW:		
	RPC = 490,000 x (NOx _{in} x B _{MW} x NPHR x EF) ^{0.25} x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	RPC = 490,000 x (NOx _{in} x Q _B x EF) ^{0.25} x RF	
Reagent Preparation Costs (RPC) =		\$2,348,710 in 2016 dollars
	Air Pre-Heater Costs (APHC)*	
For Coal-Fired Utility Boilers >25MW:		
	APHC = 69,000 x (B _{MW} x HRF x CoalF) ^{0.78} x AHF x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	APHC = 69,000 x (0.1 x Q ₈ x CoalF) ^{0.78} x AHF x RF	
Air Pre-Heater Costs (APH _{cost}) =		\$0 in 2016 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BPC)	
For Coal-Fired Utility Boilers >25MW:	
$BPC = 460,000 \times (B_{MW} \times HRF \times CoalF)^{0.42} \times ELEVF \times RF$	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:	
BPC = $460,000 \times (0.1 \times Q_B \times CoalF)^{0.42}$ ELEVF x RF	
Balance of Plant Costs (BOP _{cost}) =	\$3,333,099 in 2016 dollars

Annual Costs

Total Annual Cost (TAC) TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$1,193,040 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$1,728,014 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$2,921,054 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)

Annual Maintenance Cost =	0.005 x TCI =	\$128,795 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$297,936 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t _{op} =	\$665,284 in 2016 dollars
Annual Catalyst Replacement Cost =		\$101,026 in 2016 dollars
For coal-fired boilers, the following method Method 1 (for all fuel types): Method 2 (for coal-fired utility boilers):	Is may be used to calcuate the catalyst replacement cost. n _{scr} x Vol _{cat} x (CC _{replace} /R _{layer}) x FWF B _{MW} x 0.4 x (CoalF) ^{2.9} x (NRF) ^{0.71} x (CC _{replace}) x 35.3	* Calculation Method 1 selected.
Direct Annual Cost =		\$1,193,040 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$4,305 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$1,723,709 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,728,014 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$2,921,054 per year in 2016 dollars
NOx Removed =	637 tons/year
Cost Effectiveness =	\$4,587 per ton of NOx removed in 2016 dollars

Air Pollution Control Cost Estimation Spreadsheet For Selective Non-Catalytic Reduction (SNCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Non-Catalytic Reduction (SNCR) control device. SNCR is a post-combustion control technology for reducing NOx emissions by injecting an ammonia-base reagent (urea or ammonia) into the furnace at a location where the temperature is in the appropriate range for ammonia radicals to react with NOx to form nitrogen and water.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SNCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SNCR control technology and the cost methodologoies, see Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SNCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM). The size and costs of the SNCR are based primarily on four parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, and the reagent consumption. This approach provides study-level estimates (±30%) of SNCR capital and annual costs. Default data in the spreadsheet is taken from the SNCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions, such as the boiler configuration and fuel type. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/power-sector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will reset the NSR, plant elevation, estimated equipment life, desired dollar year, cost index (to match desired dollar year), annual interest rate, unit costs for fuel, electricity, reagent, water and ash disposal, and the cost factors for maintenance cost and administrative charges. All other data entry fields will be blank.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SNCR is for new construction or retofit of an existing boiler. If the SNCR will be installed on an existing boiler, enter a retrofit factor equal to or greater than 0.84. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you selected coal, select the type of coal burned from the drop down menu. The NOx emissions rate, weight percent coal ash and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided.

Step 4: Complete all of the cells highlighted in yellow. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.015 and 0.03, repectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SNCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SNCR.

Adopted

November 19, 2019

	Data In	puts	
Enter the following data for your combustion unit:			
Is the combustion unit a utility or industrial boiler? Is the SCR for a new boiler or retrofit of an existing boiler?	Industrial 💌	What type of fuel does the unit burn?	•
Please enter a retrofit factor equal to or greater than 0.84 based on t difficulty. Enter 1 for projects of average retrofit difficulty.	he level of 1.5	* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.	
Complete all of the highlighted data fields:			
		Provide the following information for coal-fired boilers:	
What is the maximum heat input rate (QB)?	497 MMBtu/hr	Type of coal burned: Sub-Bituminous	•
What is the higher heating value (HHV) of the fuel?	7,560 Btu/lb	Enter the sulfur content (%S) = 0.20 per	cent by weight
		or Select the appropriate SO ₂ emission rate: No	t Applicable
What is the estimated actual annual fuel consumption?	569,114,000 lbs/year		cont by waight
Is the boiler a fluid-bed boiler?	No	Ash content (%Ash): 7 per	Lent by weight
Enter the net plant heat input rate (NPHR) If the NPHR is not known, use the default NPHR value:	Is MMBtu/MW Fuel Type Default NPHR Coal 10 MMBtu/MW Fuel Oil 11 MMBtu/MW Natural Gas 8.2 MMBtu/MW	Note: The table below is pre-populated with defenter the actual values for these parameters in parameter is not known, you may use the defau Praction in Coal Blend Bituminous 0 Sub-Bituminous 1 Lignite 0 Please click the calculate button to calculate we values based on the data in the table above.	ault values for HHV, %5, %Ash and cost. Please the table below. If the actual value for any it values provided. %S %Ash HHV (Btu/h) Fuel Cost (S/MMBtu) 2.35 10.4 11,814 2.79 0.2 7 7,560 2.79 0.91 14.3 6,534 1.85 ighted
Enter the following design parameters for the proposed	SNCR:		
Number of days the SNCR operates (t_{SNCR})	365 days	Plant Elevation 450 Fee	t above sea level
Inlet NO _x Emissions (NOx _{in}) to SNCR	0.37 lb/MMBtu		
NOx Removal Efficiency (EF) provided by vendor (Enter "UNK" if value is not known)	40 percent		
Estimated Normalized Stoichiometric Ratio (NSR)	1.05	*The NSR value of 1.05 is a default value. User should enter act	tual value, if known.
Concentration of reagent as stored (C_{stored}) Denisty of reagent as stored (ρ_{stored}) Concentration of reagent injected (C_{inj}) Number of days reagent is stored ($t_{storage}$) Estimated equipment life	50 percent* 71 lb/ft ³ 50 percent 30 days 20 Years	*The reagent concentration of 50% is a default value. User sho Densities of typical SNCR reagents: 50% urea solution 29.4% aqueous NH ₃	uld enter actual value, if known. 71 lbs/ft ³ 56 lbs/ft ³
Select the reagent used	Urea 🔻	таж adreons ин ³	58 lbs/ft

Enter the cost data for the proposed SNCR:

Desired dollar-year	2016	1
CEPCI for 2016	536.4 Enter the CEPCI value for 2016 584.6 2012 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	5.25 Percent	
Fuel (Cost _{fuel})	2.79 \$/MMBtu*	
Reagent (Cost _{reag})	1.62 \$/gallon for a 50 percent solution of urea*	
Water (Cost _{water})	0.0088 \$/gallon*	
Electricity (Cost _{elect})	0.210 \$/kWh	
Ash Disposal (for coal-fired boilers only) (Cost _{ash})	18.00 \$/ton*	
	* The values marked are default values. See the table below for the default values used	-

and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance Cost Factor (MCF) = Administrative Charges Factor (ACF) =

0.015

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the the value used and the reference source .
Reagent Cost	\$1.62/gallon of 50% urea solution	Based on vendor quotes collected in 2014.	
Water Cost (\$/gallon)	0.0088	Average combined water/wastewater rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest cities-brochure-water-wastewater-rate-survey.pdf.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for industrial plants is based on 2014 price data compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-861 and 861S, (http://www.eia.gov/electricity/data.cfm#sales).	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Fuel Cost (\$/MMBtu)	2.79	Weighted average cost based on average 2014 fuel cost data for power plants compilec by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EI/ 923, "Power Plant Operations Report." Available at http://www.eia.gov/electricity/data/eia923/.	
Ash Disposal Cost (\$/ton)	18	Average ash disposal costs based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	
Percent sulfur content for Coal (% weight)	2.35	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet
Percent ash content for Coal (% weight)	10.40	Average ash content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet
Higher Heating Value (HHV) (Btu/lb)	11,814	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q_B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tSNCR/365) =	0.99	fraction	
Total operating time for the SNCR (t_{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(Noxin - NOxout)/Noxin =	40.00	percent	
NOx removed per hour =	$NOx_{in} \times EF \times Q_B =$	73.56	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	318.39	tons/year	
Coal Factor (Coal _F) =	1 for bituminuous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not
Atmospheric pressure at 450 feet above sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	appl [.] 500 1
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		1

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole

Density = 71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	$(NOx_{in} \times Q_B \times NSR \times MW_R)/(MW_{NOx} \times SR) =$	126	lb/hour
	(whre SR = 1 for NH_3 ; 2 for Urea		
Reagent Usage Rate (m _{sol}) =	mreagent/Csol =	252	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	27	gal/hour
Estimated tank volume for reagent storage =		19 121	gallons (storage needed to store a 30 day reagent supply)
	(m _{sol} x 7.4805 x tstorage x 24)/Reagent Density =	15,121	

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n} - 1 =$	0.0820
	Where n = Equipment Life and i= Interest Rate	

Parameter	Equation	Calculated Value	Units
Electricity Usage: Electrcity Consumption (P) =	(0.47 x NOx _{in} x NSR x Q _B)/NPHR =	5.04	kW/hour
Water Usage: Water consumption (q _w) =	$(m_{sol}/Density of water) \times ((C_{stored}/C_{inj}) - 1) =$	0	gallons/hour
Fuel Data: Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	Hv x m _{reagent} x ((1/C _{inj})-1) =	0.11	MMBtu/hour
Ash Disposal: Additional ash produced due to increased fuel consumption (Δash) =	(Δfuel x %Ash x 1E6)/HHV =	1.05	lb/hour

Cost Estimate

Total Capital Investment (TCI) For Coal-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$ For Fuel Oil and Natural Gas-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$ Capital costs for the SNCR (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* = \$0 in 2016 dollars Balance of Plant Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars Total Capital Investment (TCI) = \$6,208,948 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide. SNCR Capital Costs (SNCR_{cost}) For Coal-Fired Utility Boilers: $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$ For Coal-Fired Industrial Boilers: $SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: SNCR_{cost} = 147,000 x ((Q_B/NPHR)x HRF)^{0.42} x ELEVF x RF SNCR Capital Costs (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* For Coal-Fired Utility Boilers: $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$ For Coal-Fired Industrial Boilers: $APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$ Air Pre-Heater Costs (APH_{cost}) = \$0 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 0.3lb/MMBtu of sulfur dioxide. Balance of Plant Costs (BOP_{cost}) For Coal-Fired Utility Boilers: $BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $BOP_{cost} = 213,000 \text{ x} (B_{MW})^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x RF}$ For Coal-Fired Industrial Boilers: $BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: $BOP_{cost} = 213,000 \text{ x} (Q_{R}/NPHR)^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x} RF$ Balance of Plan Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars

Annual Costs

Total Annual Cost (TAC)

TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$477,565 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$511,631 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$989,197 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$93,134 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$372,444 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t_{op} =	\$9,166 in 2016 dollars
Annual Water Cost =	$q_{water} x Cost_{water} x t_{op} =$	\$0 in 2016 dollars
Additional Fuel Cost =	Δ Fuel x Cost _{fuel} x t _{op} =	\$2,739 in 2016 dollars
Additional Ash Cost =	$\Delta Ash x Cost_{ash} x t_{op} x (1/2000) =$	\$82 in 2016 dollars
Direct Annual Cost =		\$477,565 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,794 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$508,837 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$511,631 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$989,197 per year in 2016 dollars
NOx Removed =	318 tons/year
Cost Effectiveness =	\$3,107 per ton of NOx removed in 2016 dollars

Four Boilers Dry Sorbent Injection System - Chena Power Plant

Variable	Designation	Units	Value	Calculation			
Unit Size (Gross)	A	(MW)	27.5	< User Input (Gross Output based on sum of turbines rated size; 20MW, 5MW, and 2.5 MW)			
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)			
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input (Heat Rate is higher because district heating is not included in unit size)			
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input (Based on source testing 2011)			
Type of Coal	E	(sub-bituminous	< User Input			
Particulate Capture	F		Baghouse	< User Input			
Milled Trona	G		TRUE	Based on in-line milling equipment			
	1			Maximum Removal Targets:			
	1			Unmilled Trona with an ESP = 65%			
	1			Milled Trona with an ESP = 80%			
Removal Target	н	(%)	70	Unmilled Trona with a Bachouse = 80%			
	1			Milled Trona with Bachouse = 90%			
	1			Simplified correlation: 70% removal with bachouse, S&L (2013)			
Heat Input		(Btu/br)	495 000 000	A*C*1000			
near mput	,ÿ	(Dtd/III)	433,000,000	1 browned by $1 browned$ and $1 browned$ by $1 browned$ browned by $1 browned$ browned by $1 browned$ browned by $1 browned$ browned			
	1			$\frac{1}{2} \frac{1}{2} \frac{1}$			
NCD			4 55	$\lim_{n \to \infty} u_n u_n = 1 \text{ for } x_{n-1} (u_n (x_{n-1}) (u_n (x_$			
INSK	n n		1.55	$\begin{array}{c} \text{Olymmidd} \text{Torps} \text{with all DGH} = \ (n <40,0.0215 \text{ m}_{0.02356}^{-1}(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.04$			
	1			$\frac{1}{155} = \frac{1}{1010} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{10000} \frac{1}{10000} \frac{1}{10000} \frac{1}{10000000000000000000000000000000000$			
	l	(; 7)		1.35 Recommended for a bagnouse at a target of 70% removal. S&L (2013)			
Irona Feed Rate	M	(ton/hr)	0.33	(1.2011x10~06)***A*C*D			
Sorbent Waste Rate	<u>N</u>	(ton/hr)	0.222	(0.7035-0.00073696*H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3.			
	1			(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV)			
	1			For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000			
Fly Ash Waste Rate	Р	(ton/hr)	0.92	For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400			
	1			For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200			
	1			< User Input (Usibelli Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,560)			
Aux Power	Q	(%)	0.24	=if Milled Trona M*20/A else M*18/A			
Trona Cost	R	(\$/ton)	550	< User Input (based on Stanley Consultant price reference)			
Waste Disposal Cost	i s	(\$/ton)	50				
Aux Power Cost	T T	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)			
Operating Labor Rate		(\$/br)	63				
IPM Model - Updates to Cost and Performat	nce for APC Technologies -	Dry Sorbent Inie	ction for SO2 Control Co	st Development Methodology, March 2013, prepared by Sargent & Lundy LLC for LISEPAhttps://www.epa.gov/sites/production/files/2015			
07/documents/append5 4.pdf							
Capital Cost Calculation (2012 dollars)	apital Cost Calculation (2012 dollars) Comments						
Includes - Equipment installation, building foundations, electrical, and a retrofit difficulty factor of 1.5							
ווכנועפי - בעווףוופווג, ווזגמוומנוסו, טעוועמנוסוא, פופגווגמו, אוע מ דפוטווג עוווגעווץ ומגער טי ד.5							
Base Module (BM) (\$)		_	\$ 1/ 169 111	Base DSI module includes all equipment from unloading to injection but not including field installation			
Linmilled Trona – if $M > 25$ then (682.00)	0* 8 *M) else 6 833 000* 8 *M	-	φ 14,103,111	base bot module includes all equipment non unloading to injection, but not including net installation			
Milled Trona = $if(M>25$ then (750 000*P	3*M) else 7 516 000*B*(M^0	284)					
BM (\$/kW)		-	\$ 515	Base module cost per kW			
		-	φ 010				
Total Project Cost							
A1 = 20% of BM		-	\$ 2833 822	Engineering and construction management costs (CC Manual) (Stapley Consultants)			
$A^{2} = 10\%$ of BM		_	\$ 1,000,022	Labor adjustment for 6 x 10 hour shift premium per diem etc. (CC Manual)			
$A_2 = 10\%$ of BM		_	\$ 1,416,911 \$ 1,416,911	Contractor profit and face (CC Manual) (Stanlay Consultants)			
A3 = 10% 01 BM		-	φ 1,410,311				
CECC (\$) - Excludes Owner's Costs -	BM + A1 + A2 + A3	_	\$ 19,836,755	Capital engineering and construction costs subtotal			
CECC (\$/kW) - Excludes Owner's Cost		_	¢ 13,030,733 ¢ 721	Capital, organocrima, and construction costst subtatal per kW			
CECC (\$KW) - Excludes Owner's Cost	.5	-	φ 721				
B1 = 5% of CECC		=	\$ 991,838	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)			
TPC (\$) - Includes Owners Costs = CE	.CC + B1	=	\$ 20,828,593	Total project cost without Allowance for Funds Used During Construction (AFUDC)			
TPC (\$/kW) - Include Owner's Costs		=	\$ 757	Total project cost per kW without AFUDC			
B2 = 0% of (CECC + B1)		=		AFUDC (Zero for less than 1 year engineering and construction cycle)			
TPC (\$) = CECC + B1 + B2		=	\$ 20,682,000	Total project cost (Spreadsheet = \$20,828,523; Stanley Consultants cost estimate = \$20,682,000)			
TPC (\$/kW)		=	\$ 752	Total project cost per kW			
1							

Dry Sorbent Injection System - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (2 additional operators)*(2080)*U/(A*1000) FOMM (\$/kW yr) = BM*0.01/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM) FOM (\$/kW yr) = FOMO + FOMM + FOMA	= = =	\$ \$ \$	 9.53 Fixed O&M additional operating labor costs (2 additional operators is more realistic) 3.43 Fixed O&M additional maintenance material and labor costs 0.33 Fixed O&M additional administrative labor costs 13.29 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = M*R/A VOMW (\$/MWh) = (N+P)*S/A VOMP (\$/MWh) = Q*T*10 VOM (\$/MWh) = VOMR + VOMW + VOMP	= = =	\$ \$ \$	 6.64 Variable O&M costs for Trona reagent 2.07 Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection 0.507 Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above) 9.21 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$]i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = = =	\$ \$ \$ \$	219,322 CC Manual 413,640 CC Manual 206,820 CC Manual 206,820 CC Manual Revise interest rate to prime (currently 5.25%) per EPA comment Reality is 10 years of useful life of the oldside; 30 years control equipment lifetime based on EPA comments on ADEC Prelim. BACT 1,383,976 CC Manual 2,430,578 5,015,463
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = =	\$	584.6 536.4 4,601,940
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= = =	\$	781 70 546 8,423

Four Boilers Spray Dry Absorber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on total heat input of 497 MMBtu/hour)
Retrofit Factor	В	· · · /	1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input (SDA FGD Estimation only valid up to 3lb/MMBtu SO2 Rate)
Type of Coal	Е		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous=1.05, Lignite=1.07
Heat Rate Factor	G		1.800	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Lime Rate	К	(ton/hr)	0.122	(0.6702*(D^2)+13.42*D)*A*G/2000 (Based on 95% SO2 Removal)
Waste Rate	L	(ton/hr)	0.280	(0.8016*(D^2)+31.1917*D)*A*G/2000
Aux Power	М	(%)	2.462	(0.000547*(D^2)+0.00649*D+1.3)*F*G Should be used for model input
Makeup Water Rate	N	(1000 gph)	2.876	(0.04898*(D^2)+0.5925*D+55.11)*A*F*G/1000
Lime Cost	Р	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf) (GVEA Limestone cost)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.htm)
Operating Labor Rate	Т	(\$/hr)	63	Labor cost including all benefits
IPM Mo	del - Updates to Cost and Performance for A	PC Technologi	es - SDA EGD for	SO2 Control Cost Development Methodology, March 2013, prepared by Sargent & Lundy LLC for US EPA
	https://	www.epa.gov/s	ites/production/file	se/2015-07/documents/chapter 5 appendix 5-1b sda fod.odf
Conital Cost Calculation (2012 dollars)	in point			Commonte anteriaria de la commonte de la
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildin	ng, foundations, electrical, and a retrofit difficu	ulty factor of 1.5		
BMR (\$) = if(A>600 then (A*92,000) else	566,000*(A^0.716))*B*(F*G)^0.6*(D/4)^0.01	=	\$ 13,028,350	Base module absorber island cost
BMF (\$) = if(A>600 then (A*48,700) else	300,000*(A^0.716))*B*(D*G)^0.2	=	\$ 4,426,798	Base module reagent preparation and waste recycle/handling cost
BMB (\$) = if(A>600 then (A*129,900) els	e 799,000*(A^0.716))*B*(F*G)^0.4	=	\$ 16,587,654	Base module balance of plan costs inlcuding: ID or booster fans, piping, ductwork, electrical, etc.
BM (\$) = BMR + BMF + BMB BM (\$/kW)		= =	\$ 34,042,802 \$ 1,238	Total base module cost including retrofit factor Base module cost per kW
Total Project Cost				
A1 = 10% of BM		=	\$ 3,404,280	Engineering and construction management costs
A2 = 10% of BM		=	\$ 3,404,280	Labor adjustment for 6 x 10 hour shift premium, per diem, etc.
A3 = 10% of BM		=	\$ 3,404,280	Contractor profit and fees
			, . ,	
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cost	BM + A1 + A2 + A3 s =	= =	\$ 44,255,642 \$ 1,609	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,212,782	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	CC + B1	=	\$ 46,468,425 \$ 1,690	Total project cost without Allowance for Funds Used During Construction (AFUDC)
B2 = 10% of (CFCC + B1) - \$		\$ 4,646,842	AFUDC (based on a 3 year engineering and construction cycle)	
TPC (\$) - Includes Owner's Costs and AFUDC = CECC + B1 + B2 = \$ 51,115			\$ 51,115,267	Total project cost
TPC (\$/kW) - Includes Owner's Costs a	and AFUDC =	=	\$ 1,859	Total project cost per kW

Spray Dry Absorber - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (4 additional operators)*(2080)*T/(A*1000) FOMM (\$/kW yr) = BM*0.015/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	= = =	\$ \$ \$	 38.12 Fixed O&M additional operating labor costs 12.38 Fixed O&M additional maintenance material and labor costs 1.29 Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	=	\$	51.79 Total Fixed O&M costs
Variable O&M Cost			
VOMR (\$/MWh) = K*P/A	=	\$	1.06 Variable O&M costs for lime reagent
VOMW (\$/MWh) = L*Q/A	=	\$	0.31 Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	=	\$	5.17 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	=	\$	0.75 Variable O&M costs for makeup water
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM	=	\$	7.29 Total Variable O&M Costs
Indirect Annual Costs			
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 525	= = = =	\$ \$ \$ \$	854,570 CC Manual 1,022,305 CC Manual 511,153 CC Manual 511,153 CC Manual
n = Equipment life (years) 30 CRF = 0.0669	=	\$	3,420,477 CC Manual
TOTAL INDIRECT ANNUAL OPERATING COSTS	=	\$	6,319,657
TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	=	\$	9,499,458
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	=		584.6 536.4
TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	=	\$	8,716,232
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons	=		781
SO ₂ REMOVAL EFFICIENCY, %	=		90
TOTAL SO ₂ REMOVED, tons	=		702
SO ₂ COST-EFFECTIVENESS, \$/ton removed	=	\$	12,408

Four Boilers Wet Scrubber - Chena Power Plant

Variable	Designation	Units	Value	Calculation			
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on a total heat input of 497 MMBtu/hr)			
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0) Sargent and Lundy has a drop down menu for selection of an additional waste water treatment plant facility, but no capital or operational cost are implemented so it is not reproduced here.			
Gross Heat Rate	С	(Btu/kWh)	18.000	< User Input			
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input			
Type of Coal	- ш	(,	sub-bituminous	< User Input			
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous = 1.05, Lignite = 1.07			
Heat Rate Factor	G		1.8	C/10000			
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000			
Limestone Rate	K	(ton/hr)	0.16	17.52*A*D*G/2000			
Waste Rate	L	(ton/hr)	0.283	1.811*K			
Aux Power	M	(%)	2.098	(1.05e^(0.155*D))*F*G			
Makeup Water Rate	N	(1000 gph)	3.913	(1.674*D+74.68)*A*F*G/1000			
Limestone Cost	P	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)			
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)			
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)			
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.html)			
Operating Labor Rate	T	(\$/hr)	63	Labor cost including all benefits			
IPM Model - Updates to Cost and Performance for APC Technologies - Wet FGD for SO2 Control Cost Development Methodology, August 2010, prepared by Sargent & Lundy LLC for US EPA. https://www.epa.gov/sites/production/files/2015-07/documents/chapter_5_appendix_5-1a_wet_fgd.pdf							
Capital Cost Calculation (2012 dollars)				Comments			
BMR (\$) = $550,000^{+}(B)^{+}((F^{+}G)^{0.6})^{+}((D/B)^{-1})^{-1}(B)$	ng, roundations, electrical, minor physical/che 2)^0.02)*((A^0.716)	emical waste wa	\$ 12,531,374	Base absorber island cost			
BMF (\$) = 190,000*(B)*((D*G)^0.3)*(A^0	0.716)	=	\$ 2,684,600	Base reagent preparation cost			
BMW (\$) = 100,000*(B)*((D*G)^0.45)*(A	\^0.716)	=	\$ 1,323,921	Base waste handling cost			
BMB (\$) = 1,010,000*(B)*((F*G)^0.4)*(A	^0.716)	=	\$ 20,968,123	Base balance of plan cost including: ID or booster fans, new wet chimney, piping, ductwork, minor waste water treatment, etc			
BMWW (\$) =		=	\$-	Base wastewater treatment facility, beyond minor physical/chemcial treatment			
Base Module (BM) (\$) = BMR + BMF + BM (\$/kW)	BMW + BMB + BMWW	= =	\$ 37,508,019 \$ 1,364	Total base cost including retrofit factor Base cost per kW			
Total Project Cost							
A1 = 10% of BM A2 = 10% of BM A3 = 10% of BM		= = =	\$ 3,750,802 \$ 3,750,802 \$ 3,750,802	Engineering and construction management costs (CC Manual) Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual) Contractor profit and fees (CC Manual)			
CECC (\$) - Excludes Owner's Costs = BM + A1 + A2 + A3 CECC (\$/kW) - Excludes Owner's Costs =		= =	\$ 48,760,424 \$ 1,773	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW			
B1 = 5% of CECC		=	\$ 2,438,021	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)			
TPC (\$) - Includes Owners Costs = CECC + B1 TPC (\$/kW) - Include Owner's Costs =		= =	\$ 51,198,446 \$ 1,862	Total project cost without Allowance for Funds Used During Construction (AFUDC) Total project cost per kW without AFUDC			
B2 = 10% of (CECC + B1)		=	\$ 5,119,844.55	AFUDC (based on a 3 year engineering and construction cycle)			
TPC (\$) - Includes Owner's Costs and AFUDC = CECC + B1 + B2 TPC (\$/kW) - Includes Owner's Costs and AFUDC =		= =	\$ 56,318,290 \$ 2,048	Total project cost Total project cost per kW			

Wet Scrubber - Chena Power Plant

Direct Annual Costs			
Fixed U&M Cost			
FOMO ($\frac{1}{k}$ vr) = (6 additional operators)*(2080)* T/(A*1000)	=	\$	28.59 Fixed O&M additional operating labor costs
FOMM $(\frac{1}{k} + \frac{1}{k}) = \frac{1}{k} = \frac{1}{k}$	=	\$	13.64 Fixed Q&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	=	\$	1.02 Fixed O&M additional administrative labor costs
FOMWW (\$/kW yr) =		\$	- Fixed O&M costs for wastewater treatment facility
		~	40.0F T-1-1 Flored 0.011
	=	Þ	43.25 Total Fixed U&M Costs (arkiv yr)
Variable O&M Cost			
		•	
VOMR (\$/MWh) = K*P/A	=	\$	1.36 Variable O&M costs for limestone reagent
VOMW (\$/MWh) = L*Q/A	=	\$	0.31 Variable O&M costs for waste disposal
VOMP (\$/MWh) = M* R *10	=	\$	4.41 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N *S /A	=	\$	1.02 Variable O&M costs for makeup water
VOMWW (\$/MWh) =	=	\$	- Variable O&M costs for wastewater treatment facility
		•	
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW	=	\$	7.10 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
		-	
Overhead (60% of total labor and material costs)	=	\$	713,645 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Broactive two (40% of total capital investment)	=	\$ \$	713,645 CC Manual 1,126,366 CC Manual 562 192 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment)	= = =	\$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Eactor (CRE) = $[i(4i)^n]^{(1)}(I(4i)^n = 1)$	= = =	\$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25	= = =	\$\$\$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment [ife (vears)) 30	= = =	\$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669	= = =	\$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669	= = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS	= = = =	\$\$ \$\$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2012 (cost year of equation)	= = = = = = =	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 586.6
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	= = = = = = = =	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	- - - - - -	\$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = = = =	\$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i)^n] / [(1+i)^n - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO- EMISSIONS, tons	-	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO2 EMISSIONS, tons SO_ REMOVAL EFEICIENCY 94	= = = = = = = = =	\$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO2 EMISSIONS, tons SO2 REMOVAL EFFICIENCY, % TOTAL UNCONTROLLED SO2 EMISSIONS, tons SO2 REMOVAL EFFICIENCY, %	= = = = = = = = = =	\$\$\$\$ \$ \$	713.645 CC Manual 1.126.366 CC Manual 563.183 CC Manual 563.183 CC Manual 3.768.647 CC Manual 6.735.024 9.634.230 584.6 536.4 8.839.892 781 99 772
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2012 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO2 EMISSIONS, tons SO2 REMOVAL EFFICIENCY, % TOTAL SO2 REMOVED, tons		\$ \$ \$ \$	713.645 CC Manual 1.126.366 CC Manual 563.183 CC Manual 563.183 CC Manual 3.768.647 CC Manual 6.735.024 9.634.230 584.6 536.4 8,839,892 781 99 773
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO2 EMISSIONS, tons SO2 REMOVAL EFFICIENCY, % TOTAL SO2 REMOVED, tons SO2 COST-EFFECTIVENESS, \$/ton removed		\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99 773 11,440 Does not include costs associated with building and maintaining a wastewater treatment facility

Appendix B (Economic Analysis Spreadsheets – V2)
Air Pollution Control Cost Estimation Spreadsheet

For Selective Catalytic Reduction (SCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Catalytic Reduction (SCR) control device. SCR is a post-combustion control technology for reducing NO_x emissions that employs a metal-based catalyst and an ammonia-based reducing reagent (urea or ammonia). The reagent reacts selectively with the flue gas NO_x within a specific temperature range to produce N₂ and water vapor.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SCR control technology and the cost methodologies, see Section 4, Chapter 2 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM) (version 5.13). The size and costs of the SCR are based primarily on five parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, reagent consumption rate, and catalyst costs. The equations for utility boilers are identical to those used in the IPM. However, the equations for industrial boilers were developed based on the IPM equations for utility boilers. This approach provides study-level estimates (±30%) of SCR capital and annual costs. Default data in the spreadsheet is taken from the SCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/powersector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will clear many of the input cells and reset others to default values.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SCR is for new construction or retofit of an existing boiler. If the SCR will be installed on an existing boiler, enter a retrofit factor between 0.8 and 1.5. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you select fuel oil or natural gas, the HHV and NPHR fields will be prepopulated with default values. If you select coal, then you must complete the coal input box by first selecting the type of coal burned from the drop down menu. The weight percent sulfur content, HHV, and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided. Method 1 is pre-selected as the default method for calculating the catalyst replacement cost. For coal-fired units, you choose either method 1 or method 2 for calculating the catalyst replacement cost.

Step 4: Complete all of the cells highlighted in yellow. If you do not know the catalyst volume (Vol catalyst) or flue gas flow rate (Q_{flue gas}), please enter "UNK" and these values will be calculated for you. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.005 and 0.03, respectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SCR.

Adopted

November 19, 2019

		Data Inputs			
Future the full state of the future state to state					
Enter the following data for your combustion unit:					
Is the combustion unit a utility or industrial boiler?	al 🔻	What type of f	uel does the unit burn?	Coal 🗨	
Is the SCR for a new boiler or retrofit of an existing boiler?	-				
		Simpson Aaron:			
Please enter a retrofit factor between 0.8 and 1.5 based on the level of diffic	ulty. Enter 1 for 1.5	No basis was provide	d to justify a retrofit factor ref	flecting greater than average	difficulty
projects of average retrofit difficulty.		ap for installation of sele	ctive catalytic reduction on th	e bollers.	
Complete all of the highlighted data fields:		High retrofit cost fact unique ductwork and	ors may be justified in unusua piping, site preparation, tight	al circumstances (e.g., long ar fits, helicopter or crane insta	nd llation,
		additional engineerin	g, and asbestos abatement).		
What is the rating at full load capacity (MMADtu/br)2	497 MMBtu/hr	Aurora: Location of 500-800E, would be	the catalyst, if it has to be inst the top of the boilers just befor	talled within a temperature ra	nge of eheater
what is the rating at fair load capacity (who baying):		It's a titght fit, limited	l space, asbestos abatement r	necessary, duct work is compl	ex and
What is the higher heating value (HHV) of the fuel?	7,560 Btu/lb	Enter the sulfu	r content (%S) =	0.20 percent by weigh	nt
	Typical Gross As F	: Received. http://www.usibelli.com/coal/	/data-sheet	Simpson, Aaror Typical Gross As	n: Received. http://www.usibelli.com/coal/data-sheet
What is the estimated actual annual fuel consumption?	569,114,000 lbs/year	Cara contina la consti	en eest blander		
		For units burning	ng coal biends:		
		for the	The table below is pre-popu se parameters in the table	ulated with default values below. If the actual value	for HHV and %S. Please enter the actual values for any parameter is not known, you may use
	10 10 10 10 10	the de	fault values provided.		
Enter the net plant heat input rate (NPHK)			Frac	ction in	
If the NPHR is not known use the default NPHR value.	Fuel Type Default NPHR		Coa		HHV (Btu/lb)
in the write shot known, ase the default write value.	Coal 10 MMBtu/MW	s	Sub-Bituminous	1 0.2	7,560
	Fuel Oil 11 MMBtu/MW Natural Gas 8.2 MMBtu/MW		Lignite	0 0.91	6,534
		Please	click the calculate button t	o calculate weighted	
Plant Elevation	450 East above sea	values	based on the data in the ta	able above.	
	450 1 661 80076 368 1	For coal-fired	boilers, you may use eith	ner Method 1 or Method	2 to calculate
		the catalyst re	eplacement cost. The equ	uations for both method	s are shown on O Method 1
		method:	is on the Cost Estimate t	ab. Please select your pr	Not applicable
Enter the following design parameters for the proposed SCR	:				
			Number of CCD seators		
Number of days the SCR operates (I _{SCR})	365 days Ass	npson, Aaron: uming baseline of 0.5 lb/MMBtu from	Number of SCR reactor (chambers (n _{scr})	1
Number of days the boiler operates (t _{plant})	365 days Sub	N Source Performance Standards, opart Da – Technical Support for	Number of catalyst laye	rs (R _{layer})	3
Inlet NO _x Emissions (NOx _{in}) to SCR	0.27 lb/MMRtu Pro	posed Revisions to NOx Standard, U.S. A, Office of Air Quality Planning and	Number of empty cataly	yst layers (R _{empty})	1
NOx Removal Efficiency (EF) provided by vendor	80 percent Sta	ndards, EPA-453/R-94-012, June 1997	Ammonia Slip (Slip) prov	vided by vendor	10 ppm
Stoichiomatric Patio Eastor (SPE)	Au 201	rora: Emission Inventory rate based of 1 source testing.	Nolume of the catalyst la	ayers (Vol _{catalyst})	Simpson, Aaron:
*The SRE value of 0.525 is a default value. User should enter actual value, if known	0.525		(Enter "UNK" if value is	not known)	UNK Cubic feet
	mpson, Aaron:	Shoot indicating 70 00 parcent	(Enter "UNK" if value is	not known)	Aurora: Source Test dso 179,783.2 acfm = 162098.5.
	ntrol. https://www3.epa.gov/ttncatc1/dir	1/fscr.pdf			162098.5 dscf/(1-Bws) =
					acfm; Bws = 0.0984.
Estimated operating life of the catalyst (H _{catalyst})	24,000 hours				
Estimated CCB equipment life	15 Voors*		Gas temperature at the	SCR inlet (T)	310 °F April 7, 2016 Source Test
* For industrial boilers, the typical equipment life is between 20 and 25 years.	ID feals		Base case fuel gas volun	netric flow rate factor	516 ft ³ /min MMRtu/hour
			(Q _{fuel})		and it /min-wiwiblu/nour
Concentration of reagent as stored (C _{stored})	50 percent*	*The reagent concentration	on of 50% and density of 71 lbs/c	ft are	
Density of reagent as stored (p _{stored})	71 lb/cubic feet*	reagent, if different from t	the default values provided.	aiues IOF	
Number of days reagent is stored $(t_{storage})$	30 days			Densities of typic 50% urea solutio	n 71 lbc/ft ³
				29.4% aqueous N	vH ₃ 56 lbs/ft ³
				19% aqueous N⊦	l ₃ 58 lbs/ft ³
Select the reagent used Urea	▼				
Enter the cost data for the proposed SCR:					
Desired dollar-year	2016				
CEPCI for 2016	536.4 Enter the CEPCI	value for 2016 584.6 2012 C	CEPCI CEPCI	I = Chemical Engineering P	lant Cost Index
Annual Interest Rate (i)	5.25 Percent				
Reagent (Cost _{reag})	1.62 \$/gallon for a 50) percent solution of urea			
Electricity (Cost _{elect})	0.210 \$/kWh GVEA	son, Aaron: rates. http://www.gvea.com/rates/rat	es		
	\$/cubic foot (inc	cludes removal and disposal/regene	eration of existing		
Catalyst cost (CC _{replace})	160.00 catalyst and inst	allation of new catalyst*	* \$160	D/cf is a default value for the cat	alyst cost. User should enter actual value, if known.
Operator Labor Rate	63.00 \$/hour (includin	g benefits)			

Adopted

November 19, 2019

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Operator Hours/Day

ľ

4.00 hours/day*

0.005

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

laintenance and Administrative Charges Cost Factors:	
Maintenance Cost Factor (MCF) =	
Administrative Charges Factor (ACF) =	

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source
Reagent Cost (\$/gallon)	1.62	Based on the average of vendor quotes from 2011 - 2013.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for utilities is based on 2014 electricity production cost data for fossil-fuel plants compiled by the U.S. Energy Information (EIA). Available at http://www.eia.gov/tools/faqs/faq.cfm?id=19&t=3.	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Percent sulfur content for Coal (% weight)	0.31	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Higher Heating Value (HHV) (Btu/lb)	8,730	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Catalyst Cost (\$/cubic foot)	160	Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emissions Control Technologies", July 2013.	

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q _B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tscr/tplant) =	0.99	fraction	
Total operating time for the SCR $(t_{op}) =$	CF _{total} x 8760 =	8657	hours	-
NOx Removal Efficiency (EF) =	(NOxin- NOxout)/NOxin =	80.0	percent	
NOx removed per hour =	$NOx_{in} x EF x Q_B =$	147.11	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	636.77	tons/year	-
NOx removal factor (NRF) =	EF/80	1.00		
Volumetric flue gas flow rate (q _{flue gas}) =	Q _{fuel} x QB x (460 + T)/(460 + 700)n _{scr}	179,783	acfm	-
Space velocity (V _{space}) =	q _{flue gas} /Vol _{catalyst}	30.03	/hour	
Residence Time	1/V _{space}	0.03	hour	
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO_2 Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not applicable;
Atmospheric pressure at sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	does not apply to plants located at
Retrofit Factor (RF)	Retrofit to existing boiler	1.50		elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Adopted

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)(1/((1+ interest rate) ^Y -1), where Y =	0.245	Franklar
	H _{catalyts} /(t _{SCR} x 24 hours) rounded to the hearest integer	0.316	Fraction
Catalyst volume (Vol _{catalyst}) =	2.81 x Q _B x EF _{adj} x Slipadj x Noxadj x Sadj x (Tadj/Nscr)	5,986.26	Cubic feet
Cross sectional area of the catalyst (A _{catalyst}) =	q _{flue gas} /(16ft/sec x 60 sec/min)	187	ft²
Height of each catalyst layer (H _{layer}) =	$(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$	12	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A _{SCR}) =	1.15 x A _{catalyst}	215	ft ²
Reactor length and width dimentions for a square	(A) ^{0.5}	14.7	foot
reactor =	(A _{SCR})	14.7	leet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	84	feet

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole
		Density =	71 lb/ft ³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	(NOx _{in} x Q _B x EF x SFR x MW _R)/MW _{NOx} =	101	lb/hour
Reagent Usage Rate (m _{sol}) =	m _{reagent} /Csol =	202	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	21	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x t _{storage} x 24)/Reagent Density =	15,296	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n}-1=$	0.0980
	Where n = Equipment Life and i= Interest Rate	

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	A x 1,000 x 0.0056 x (CoalF x HRF) ^{0.43} =	365.95	kW
	where $A = (0.1 \times QB)$ for industrial boilers.		

Cost Estimate

Total Capital Investment (TCI)

TCI for Coal-Fired Boilers				
For Coal-Fired Boilers:				
	TCI = 1.3 x (SCR _{cost} + RPC + APHC + BPC)			
Capital costs for the SCR (SCR _{cost}) =	\$14,132,761	in 2016 dollars		
Reagent Preparation Cost (RPC) =	\$2,348,710	in 2016 dollars		
Air Pre-Heater Costs (APHC)* =	\$0	in 2016 dollars		
Balance of Plant Costs (BPC) =	\$3,333,099	in 2016 dollars		
Total Capital Investment (TCI) =	\$25,758,941	in 2016 dollars		
* Not applicable - This factor applies only to coal-fired boilers that burn bitumino	us coal and emits equal to or greater than 3lb/MMBtu of sulfur die	oxide.		
	SCR Capital Costs (SCR _{cost})			

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

For Coal-Fired Utility Boilers >25 MW:

 $SCR_{cost} = 270,000 \times (NRF)^{0.2} \times (0.1 \times Q_B \times CoalF)^{0.92} \times ELEVF \times RF$

 $SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (B_{MW} \text{ x HRF x CoalF})^{0.92} \text{ x ELEVF x RF}$

SCR Capital Costs (SCR_{cost}) =

\$14,132,761 in 2016 dollars

Reagent Preparation Costs (RPC)			
For Coal-Fired Utility Boilers >25 MW:			
	RPC = 490,000 x (NO x_{in} x B _{MW} x NPHR x EF) ^{0.25} x RF		
For Coal-Fired Industrial Boilers >250 MMBtu/hour:			
	RPC = 490,000 x (NOx _{in} x Q _B x EF) ^{0.25} x RF		
Reagent Preparation Costs (RPC) =		\$2,348,710 in 2016 dollars	
	Air Pre-Heater Costs (APHC)*		
For Coal-Fired Utility Boilers >25MW:			
	APHC = 69,000 x (B _{MW} x HRF x CoalF) ^{0.78} x AHF x RF		
For Coal-Fired Industrial Boilers >250 MMBtu/hour:			
	APHC = 69,000 x (0.1 x Q ₈ x CoalF) ^{0.78} x AHF x RF		
Air Pre-Heater Costs (APH _{cost}) =		\$0 in 2016 dollars	

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BPC)	
For Coal-Fired Utility Boilers >25MW:	
$BPC = 460,000 \times (B_{MW} \times HRF \times CoalF)^{0.42} \times ELEVF \times RF$	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:	
BPC = $460,000 \times (0.1 \times Q_B \times CoalF)^{0.42}$ ELEVF x RF	
Balance of Plant Costs (BOP _{cost}) =	\$3,333,099 in 2016 dollars

Annual Costs

Total Annual Cost (TAC) TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$1,193,040 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$2,528,093 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$3,721,132 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)

Annual Maintenance Cost =	0.005 x TCI =	\$128,795 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$297,936 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t _{op} =	\$665,284 in 2016 dollars
Annual Catalyst Replacement Cost =		\$101,026 in 2016 dollars
For coal-fired boilers, the following methods may be used to calcuate the catalyst replacement cost. Method 1 (for all fuel types): $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$		* Calculation Method 1 selected.
Direct Annual Cost =		\$1,193,040 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$4,305 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$2,523,788 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$2,528,093 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$3,721,132 per year in 2016 dollars
NOx Removed =	637 tons/year
Cost Effectiveness =	\$5,844 per ton of NOx removed in 2016 dollars

Air Pollution Control Cost Estimation Spreadsheet For Selective Non-Catalytic Reduction (SNCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Non-Catalytic Reduction (SNCR) control device. SNCR is a post-combustion control technology for reducing NOx emissions by injecting an ammonia-base reagent (urea or ammonia) into the furnace at a location where the temperature is in the appropriate range for ammonia radicals to react with NOx to form nitrogen and water.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SNCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SNCR control technology and the cost methodologoies, see Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SNCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM). The size and costs of the SNCR are based primarily on four parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, and the reagent consumption. This approach provides study-level estimates (±30%) of SNCR capital and annual costs. Default data in the spreadsheet is taken from the SNCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions, such as the boiler configuration and fuel type. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/power-sector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will reset the NSR, plant elevation, estimated equipment life, desired dollar year, cost index (to match desired dollar year), annual interest rate, unit costs for fuel, electricity, reagent, water and ash disposal, and the cost factors for maintenance cost and administrative charges. All other data entry fields will be blank.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SNCR is for new construction or retofit of an existing boiler. If the SNCR will be installed on an existing boiler, enter a retrofit factor equal to or greater than 0.84. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you selected coal, select the type of coal burned from the drop down menu. The NOx emissions rate, weight percent coal ash and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided.

Step 4: Complete all of the cells highlighted in yellow. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.015 and 0.03, repectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SNCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SNCR.

Adopted

November 19, 2019

			Data Ir	nputs				
Enter the f	ollowing data for your combustion unit:							
Is the combus	stion unit a utility or industrial boiler? a new boiler or retrofit of an existing boiler?	Industrial 🔻]	What type of	fuel does the unit burn	n? Coal	•	
Please enter a difficulty. En	a retrofit factor equal to or greater than 0.84 based on t ter 1 for projects of average retrofit difficulty.	he level of	1.5	* NOTE: You must docum for the proposed project.	ent why a retrofit factor of	1.5 is appropriate		
Complete all	of the highlighted data fields:							
				Provide the fo	llowing information fo	r coal-fired boilers:		
Wha	t is the maximum heat input rate (QB)?	497	MMBtu/hr	Type of coal be	urned: Si	ub-Bituminous 🔻		
Wha	t is the higher heating value (HHV) of the fuel?	7,560	Btu/lb	Enter the sulfu	ır content (%S) =	0.20 perce	nt by weight	
				or Select the app	ropriate SO ₂ emission	rate: Not A	pplicable 🔻	
Wha	t is the estimated actual annual fuel consumption?	569,114,000	lbs/year	7				
				Ash content (%	6Ash):	7 perce	nt by weight	
Is the	e boiler a fluid-bed boiler?	No 🔻						
				For units burn	ing coal blends:			
Ente	r the net plant heat input rate (NPHR)	18	MMBtu/MW	Note: enter param	The table below is pre the actual values for t neter is not known, you	-populated with defai hese parameters in th a may use the default	ult values for HHV, S table below. If th values provided.	%S, %Ash and cost. Please e actual value for any
If the	PPHR is not known, use the default NPHR value:	Fuel Type Coal Fuel Oil Natural Gas	Default NPHR 10 MMBtu/MW 11 MMBtu/MW 8.2 MMBtu/MW	Please	Bituminous Sub-Bituminous Lignite click the calculate but	Fraction in Coal Blend 9 0 1 0 tton to calculate weig	%Ash 2.35 10.4 0.2 7 0.91 14.3 htted	Fuel Cost HHV (Btu/lb) (\$/MMBtu) 11,814 2.79 7,560 2.79 6,534 1.85
Enter the f	ollowing design parameters for the proposed	I SNCR:		valdes	pased on the data in t	rne table above.		
Num	ber of days the SNCR operates $(t_{s_{NCR}})$	365	days	Plant	Elevation	450 Feet	above sea level	
Inlet	NO _x Emissions (NOx _{in}) to SNCR	0.37	lb/MMBtu					
NOx "UN	Removal Efficiency (EF) provided by vendor (Enter K" if value is not known)	40	percent					
Estin	nated Normalized Stoichiometric Ratio (NSR)	1.05		*The NSR value of 1.	05 is a default value. U	lser should enter actu	al value, if known.	
Conc Deni Conc	entration of reagent as stored (C _{stored}) sty of reagent as stored (p _{stored}) entration of reagent injected (C _{inj})	50 71 50	percent* lb/ft ³ percent	*The reagent concen	tration of 50% is a def	ault value. User shoul	d enter actual value	e, if known.
Num	ber of days reagent is stored (t _{storage})	30	days	4	50% urea so	olution	71 lbs/ft ³	
Estin	nated equipment life	Urea T5	rears	_]	19% aqueo	us NH ₃	58 lbs/ft ³	
Sele	Li the reagent used							

Enter the cost data for the proposed SNCR:

Desired dollar-year	2016	
CEPCI for 2016	536.4 Enter the CEPCI value for 2016 584.6 2012 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	5.25 Percent	
Fuel (Cost _{fuel})	2.79 \$/MMBtu*	
Reagent (Cost _{reag})	1.62 \$/gallon for a 50 percent solution of urea*	
Water (Cost _{water})	0.0088 \$/gallon*	
Electricity (Cost _{elect})	0.210 \$/kWh	
Ash Disposal (for coal-fired boilers only) (Cost _{ash})	18.00 \$/ton*	
	* The values marked are default values. See the table below for the default values used	_

and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance Cost Factor (MCF) = Administrative Charges Factor (ACF) =

0.015

Data Sources for Default Values Used in Calculations:

			If you used your own site-specific values, please enter the the value used and the reference source .
Data Element	Default Value	Sources for Default Value	
Reagent Cost	\$1.62/gallon of	Based on vendor quotes collected in 2014.	
	50% urea		
	solution		
water cost (\$/gallon)	0.0088	Average combined water/wastewater rates for industrial facilities in 2013 compiled by Black & Veatch (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey."	
		Available at http://www.saws.org/who we are/community/RAC/docs/2014/50-largest	
		cities-brochure-water-wastewater-rate-survey.pdf.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for industrial plants is based on 2014 price data	\$0.210/kWh GVEA rates.
		compiled by the U.S. Energy Information Administration (EIA) from data reported on	http://www.gvea.com/rates/rates
		EIA Form EIA-861 and 861S, (http://www.eia.gov/electricity/data.cfm#sales).	
Fuel Cost (\$/MMBtu)	2.79	Weighted average cost based on average 2014 fuel cost data for power plants compiled	1
		by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EI/	
		923, Power Plant Operations Report. Available at	
		http://www.ela.gov/electricity/data/ela525/.	
Ash Disposal Cost (\$/ton)	18	Average ash disposal costs based on U.S. coal data for 2014 compiled by the U.S.	
		Energy Information Administration (EIA) from data reported on EIA Form EIA-923,	
		http://www.eia.gov/electricity/data/eia923/	
Percent sulfur content for Coal (% weight)	2 35	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy	0.20 percent (Typical Gross As Received) Coal data
refeelte suitar content for coal (// weight)	2.55	Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	· · · · · · · · · · · · · · · · · · ·
Percent ash content for Coal (% weight)	10.40	Average ash content based on U.S. coal data for 2014 compiled by the U.S. Energy	7 percent (Typical Gross As Received) Coal data
refeelte asin content for coal (/o weight)	10110	Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	
Higher Heating Value (HHV) (Btu/lb)	11,814	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy	7,560 Btu/lb (Typical Gross As Received). Coal data
		Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q_B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tSNCR/365) =	0.99	fraction	
Total operating time for the SNCR (t_{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(Noxin - NOxout)/Noxin =	40.00	percent	
NOx removed per hour =	NOx _{in} x EF x Q _B =	73.56	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	318.39	tons/year	
Coal Factor (Coal _F) =	1 for bituminuous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not ap
Atmospheric pressure at 450 feet above sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	apply t 500 fee
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole

Density = 71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	$(NOx_{in} \times Q_B \times NSR \times MW_R)/(MW_{NOx} \times SR) =$	126	lb/hour
	(whre SR = 1 for NH_3 ; 2 for Urea		
Reagent Usage Rate (m _{sol}) =	mreagent/Csol =	252	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	27	gal/hour
Estimated tank volume for reagent storage =		19 121	gallons (storage needed to store a 30 day reagent supply)
	(m _{sol} x 7.4805 x tstorage x 24)/Reagent Density =	15,121	

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n} - 1 =$	0.0980
	Where n = Equipment Life and i= Interest Rate	

Parameter	Equation	Calculated Value	Units
Electricity Usage: Electrcity Consumption (P) =	(0.47 x NOx _{in} x NSR x Q ₈)/NPHR =	5.04	kW/hour
Water Usage: Water consumption (q _w) =	$(m_{sol}/Density of water) \times ((C_{stored}/C_{inj}) - 1) =$	0	gallons/hour
Fuel Data: Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	Hv x m _{reagent} x ((1/C _{inj})-1) =	0.11	MMBtu/hour
Ash Disposal: Additional ash produced due to increased fuel consumption (Δash) =	(Δfuel x %Ash x 1E6)/HHV =	1.05	lb/hour

Cost Estimate

Total Capital Investment (TCI) For Coal-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$ For Fuel Oil and Natural Gas-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$ Capital costs for the SNCR (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* = \$0 in 2016 dollars Balance of Plant Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars Total Capital Investment (TCI) = \$6,208,948 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide. SNCR Capital Costs (SNCR_{cost}) For Coal-Fired Utility Boilers: $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$ For Coal-Fired Industrial Boilers: $SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: SNCR_{cost} = 147,000 x ((Q_B/NPHR)x HRF)^{0.42} x ELEVF x RF SNCR Capital Costs (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* For Coal-Fired Utility Boilers: $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$ For Coal-Fired Industrial Boilers: $APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$ Air Pre-Heater Costs (APH_{cost}) = \$0 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 0.3lb/MMBtu of sulfur dioxide. Balance of Plant Costs (BOP_{cost}) For Coal-Fired Utility Boilers: $BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $BOP_{cost} = 213,000 \text{ x} (B_{MW})^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x RF}$ For Coal-Fired Industrial Boilers: $BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: $BOP_{cost} = 213,000 \times (Q_{R}/NPHR)^{0.33} \times (NO_{x}Removed/hr)^{0.12} \times RF$ Balance of Plan Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars

Annual Costs

Total Annual Cost (TAC)

TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$477,565 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$611,129 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$1,088,694 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$93,134 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$372,444 in 2016 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$9,166 in 2016 dollars
Annual Water Cost =	q _{water} x Cost _{water} x t _{op} =	\$0 in 2016 dollars
Additional Fuel Cost =	Δ Fuel x Cost _{fuel} x t _{op} =	\$2,739 in 2016 dollars
Additional Ash Cost =	$\Delta Ash x Cost_{ash} x t_{op} x (1/2000) =$	\$82 in 2016 dollars
Direct Annual Cost =		\$477,565 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,794 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$608,335 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$611,129 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$1,088,694 per year in 2016 dollars
NOx Removed =	318 tons/year
Cost Effectiveness =	\$3,419 per ton of NOx removed in 2016 dollars

Four Boilers Dry Sorbent Injection System - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Gross Output based on sum of turbines rated size; 20MW, 5MW, and 2.5 MW)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input (Heat Rate is higher because district heating is not included in unit size)
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input (Based on source testing 2011)
Type of Coal	E		sub-bituminous	< User Input
Particulate Capture	F		Baghouse	< User Input
Milled Trona	G		TRUE	Based on in-line milling equipment
				Maximum Removal Targets:
				Unmilled Trona with an ESP = 65%
Romoval Target	Ц	(9/)	70	Milled Trona with an ESP = 80%
Removal Larger	н	(70)	10	Unmilled Trona with a Baghouse = 80%
				Milled Trona with Baghouse = 90%
				Simplified correlation; 70% removal with baghouse. S&L (2013)
Heat Input	J	(Btu/hr)	495,000,000	A*C*1000
				Unmilled Trona with an ESP = if(H<40,0.0350*H,0.352e^(0.0345*H))
				Milled Trona with an ESP = if(H<40,0.0270*H,0.353e^(0.0280*H))
NSR	к		1.55	Unmilled Trona with an BGH = if(H<40,0.0215*H,0.295e^(0.0267*H))
				Milled Trona with an BGH = if(H<40,0.0160*H,0.208e^(0.0281*H))
				1.55 Recommended for a baghouse at a target of 70% removal. S&L (2013)
Trona Feed Rate	М	(ton/hr)	0.28	(1.2011x10^-06)*K*A*C*D
Sorbent Waste Rate	Ν	(ton/hr)	0.185	(0.7035-0.00073696*H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3.
				(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV)
				For Bituminous Coal: Ash in Coal = 0.12: Boiler Ash Removal = 0.2. HHV = 11.000
Fly Ash Waste Rate	Р	(ton/hr)	0.92	For PRB Coal: Ash in Coal = 0.06: Boiler Ash Removal = 0.2. HHV = 8.400
		((01,7,11))		For Lignite Coal: Ash in Coal = 0.08: Boiler Ash Removal = 0.2. HHV = 7.200
				c_{-} User Input (Usibelli Coal: Ash in Coal = 0.07: Boiler Ash Removal = 0.6: HHV = 7.560)
	0	(%)	0.20	if Milled Trans M*20(A also M*18/A
Trana Cost	y	(%)	0.20	
Masta Disposal Cost	K Q	(\$/t01)	50	
Aux Power Cost		(\$/IUII) (\$/IUMb)	0.24	
Aux Fower Cost	1	(\$/KV11) (\$/br)	62	 User input (Intp://www.gvea.com/rates/rates)
IPM Model Updates to Cost and Performan	U non for APC Toobhologion	(ə/III) Dru Sarbant Inic	us action for SO2 Control Co	C= Osen input (Labor cost including an benefits (AE 2010)) at Davidopment Methodology. March 2013, propagate & Sargant & Lundu LLC for LISERAbites//www.opg.gov/pitos/production/files/2015
ir wimodel - Opdates to Cost and Fenomial	The for AFC Technologies -	Dry Solbent inje		documents (appendix a manufactor), prepared by Sargent & Lundy LLC for OSLF Attrips.//www.epa.gov/sites/production/nies/2015
Capital Cost Calculation (2012 dollars)			017	Comments
Capital Cost Calculation (2012 donars)				Comments
Includes - Equipment installation building	na foundations electrical an	d a retrofit diffic	ulty factor of 1.5	
moludeo Equipment, motaliditori, buildi	ig, iounduiono, cicotnoui, un			
Base Module (BM) (\$)		=	\$ 14 169 111	Base DSI module includes all equipment from unloading to injection but not including field installation
Unmilled Trona = if(M >25 then (682.00)	0* <mark>B*M</mark>) else 6.833.000* <mark>B</mark> *(M	^0.284)	•,	
Milled Trona = if(M>25 then (750,000*B	*M) else 7,516,000*B*(M^0.2	284)		
BM (\$/kW)	, , , , , , , , , , , , , , , , , , , ,	, =	\$ 515	Base module cost per kW
Total Project Cost				
-				
A1 = 20% of BM		=	\$ 2,833,822	Engineering and construction management costs (CC Manual) (Stanley Consultants)
A2 = 10% of BM		=	\$ 1,416,911	Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual)
A3 = 10% of BM		=	\$ 1,416,911	Contractor profit and fees (CC Manual) (Stanley Consultants)
CECC (\$) - Excludes Owner's Costs =	BM + A1 + A2 + A3	=	\$ 19,836,755	Capital, engineering, and construction costs subtotal
CECC (\$/kW) - Excludes Owner's Cost	ts	=	\$ 721	Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 991,838	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE	CC + B1	=	\$ 20,828,593	Total project cost without Allowance for Funds Used During Construction (AFUDC)
TPC (\$/kW) - Include Owner's Costs		=	\$ 757	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)		=		AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2		=	\$ 20,682,000	Total project cost (Spreadsheet = \$20,828,523; Stanley Consultants cost estimate = \$20,682,000)
TPC (\$/kW)		=	\$ 752	Total project cost per kW

Dry Sorbent Injection System - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (2 additional operators)*(2080)*U/(A*1000) FOMM (\$/kW yr) = BM*0.01/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM) FOM (\$/kW yr) = FOMO + FOMM + FOMA	= = =	\$ \$ \$	 9.53 Fixed O&M additional operating labor costs (2 additional operators is more realistic) 3.43 Fixed O&M additional maintenance material and labor costs 0.33 Fixed O&M additional administrative labor costs 13.29 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = M*R/A VOMW (\$/MWh) = (N+P)*S/A VOMP (\$/MWh) = Q*T*10 VOM (\$/MWh) = VOMR + VOMW + VOMP	= = =	\$ \$ \$	 5.53 Variable O&M costs for Trona reagent 2.00 Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection 0.423 Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above) 7.96 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$]i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$ \$ \$	219,322 CC Manual 413,640 CC Manual 206,820 CC Manual 206,820 CC Manual Revise interest rate to prime (currently 5.25%) per EPA comment Reality is 10 years of useful life of the oldside; 30 years control equipment lifetime based on EPA comments on ADEC Prelim. BACT 2,026,363 CC Manual 3,072,965 5,356,087
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= =	\$	584.6 536.4 4,914,480
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= = =	\$	651 70 456 10,785

Four Boilers Spray Dry Absorber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on total heat input of 497 MMBtu/hour)
Retrofit Factor	В	· · · /	1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input (SDA FGD Estimation only valid up to 3lb/MMBtu SO2 Rate)
Type of Coal	Е		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous=1.05, Lignite=1.07
Heat Rate Factor	G		1.800	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Lime Rate	К	(ton/hr)	0.101	(0.6702*(D^2)+13.42*D)*A*G/2000 (Based on 95% SO2 Removal)
Waste Rate	L	(ton/hr)	0.234	(0.8016*(D^2)+31.1917*D)*A*G/2000
Aux Power	М	(%)	2.461	(0.000547*(D^2)+0.00649*D+1.3)*F*G Should be used for model input
Makeup Water Rate	Ν	(1000 gph)	2.874	(0.04898*(D^2)+0.5925*D+55.11)*A*F*G/1000
Lime Cost	Р	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf) (GVEA Limestone cost)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article 11a2ba10-c211-562e-8da9-87dd16a7b104.htm)
Operating Labor Rate	T	(\$/hr)	63	Labor cost including all benefits
IPM Mo	del - Undates to Cost and Performance for A		es - SDA EGD for	SO2 Control Cost Development Methodology, March 2013, prepared by Sargent & Lundy LLC for LIS EPA
	https://		ites/production/file	2012 Control Cost Destrophilent Methodology, Materizator, propared by Sargent & Editoy EEO for Co ET A.
	https://	www.epa.gov/s	nes/production/me	sizo naonao naona ana ana ana ana ana ana a
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildin	g, foundations, electrical, and a retrofit diffic	ulty factor of 1.5		
BMR (\$) = if(A>600 then (A*92,000) else	566,000*(A^0.716))*B*(F*G)^0.6*(D/4)^0.01	=	\$ 13,004,722	Base module absorber island cost
BMF (\$) = if(A>600 then (A*48,700) else	300,000*(A^0.716))*B*(D*G)^0.2	=	\$ 4,268,968	Base module reagent preparation and waste recycle/handling cost
BMB (\$) = if(A>600 then (A*129,900) else	e 799,000*(A^0.716))*B*(F*G)^0.4	=	\$ 16,587,654	Base module balance of plan costs inlcuding: ID or booster fans, piping, ductwork, electrical, etc.
BM (\$) = BMR + BMF + BMB BM (\$/kW)		= =	\$ 33,861,344 \$ 1,231	Total base module cost including retrofit factor Base module cost per kW
Total Project Cost				
A1 = 10% of BM A2 = 10% of BM A3 = 10% of BM		= = =	 \$ 3,386,134 \$ 3,386,134 \$ 3,386,134 	Engineering and construction management costs Labor adjustment for 6 x 10 hour shift premium, per diem, etc. Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cost	BM + A1 + A2 + A3 s =	= =	\$ 44,019,747 \$ 1,601	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,200,987	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	CC + B1	= =	\$ 46,220,735 \$ 1,681	Total project cost without Allowance for Funds Used During Construction (AFUDC) Total project cost per kW without AFUDC
B2 = 10% of (CECC + B1)		=	\$ 4,622,073	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and TPC (\$/kW) - Includes Owner's Costs a	AFUDC = CECC + B1 + B2 and AFUDC =	= =	\$ 50,842,808 \$ 1,849	Total project cost Total project cost per kW

Spray Dry Absorber - Chena Power Plant

Direct Annual Costs	
Fixed Operating and Maintenance (O&M) Cost	
FOMO (\$/kW yr) = (4 additional operators)*(2080)*T/(A*1000) FOMM (\$/kW yr) = BM*0.015/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	= \$ 38.12 Fixed O&M additional operating labor costs = \$ 12.31 Fixed O&M additional maintenance material and labor costs = \$ 1.29 Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	= \$ 51.73 Total Fixed O&M costs
Variable O&M Cost	
VOMR (\$/MWh) = K*P/A	= \$ 0.88 Variable O&M costs for lime reagent
VOMW (\$/MWh) = L*Q/A	= \$ 0.25 Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	= \$ 5.17 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N *S /A	= \$ 0.75 Variable O&M costs for makeup water
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM	= \$ 7.06 Total Variable O&M Costs
Indirect Annual Costs	
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = $[i (1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980TOTAL INDIRECT ANNUAL OPERATING COSTS	 \$ 853,468 CC Manual \$ 1,016,856 CC Manual \$ 508,428 CC Manual \$ 508,428 CC Manual \$ 508,428 CC Manual \$ 4,981,433 CC Manual \$ 7,868,614
TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= \$ 10,990,629
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= 584.6 = 536.4 = \$ 10,084,456
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= 651 = 90 = 586 = \$ 17,213

Four Boilers Wet Scrubber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on a total heat input of 497 MMBtu/hr)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0) Sargent and Lundy has a drop down menu for selection of an additional waste water treatment plant facility, but no capital or operational cost are implemented so it is not reproduced here.
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input
Type of Coal	E		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous = 1.05, Lignite = 1.07
Heat Rate Factor	G		1.8	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Limestone Rate	К	(ton/hr)	0.13	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	0.236	1.811*K
Aux Power	Μ	(%)	2.079	(1.05e^(0.155*D))*F*G
Makeup Water Rate	N	(1000 gph)	3.908	(1.674*D+74.68)* <mark>A</mark> *F*G/1000
Limestone Cost	P	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.html)
Operating Labor Rate	Т	(\$/hr)	63	Labor cost including all benefits
IPM Model -	Updates to Cost and Performance for APC T	echnologies - W	et FGD for SO2 Co	ntrol Cost Development Methodology. August 2010, prepared by Sargent & Lundy LLC for US EPA.
	https://www	.epa.gov/sites/p	oduction/files/2015	-07/documents/chapter 5 appendix 5-1a wet fod.pdf
Capital Cost Calculation (2012 dollars)		1 0 1		Commonts
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildi	ng, foundations, electrical, minor physical/che	emical waste wa	ter treatment, and a	retrofit difficulty factor of 1.5
BMR (\$) = 550,000*(B)*((F*G)^0.6)*((D/	2)^0.02)*(A^0.716)	=	\$ 12,485,962	Base absorber island cost
BMF (\$) = 190,000*(B)*((D*G)^0.3)*(A^	0.716)	=	\$ 2,542,315	Base reagent preparation cost
BMW (\$) = 100,000*(B)*((D*G)^0.45)*(A	\^0.716)	=	\$ 1,220,076	Base waste handling cost
BMB (\$) = 1,010,000*(B)*((F*G)^0.4)*(A	^0.716)	=	\$ 20,968,123	Base balance of plan cost including: ID or booster fans, new wet chimney, piping, ductwork, minor waste water treatment, etc
BMWW (\$) =		=	\$-	Base wastewater treatment facility, beyond minor physical/chemcial treatment
Base Module (BM) (\$) = BMR + BMF + BM (\$/kW)	BMW + BMB + BMWW	=	\$ 37,216,477 \$ 1,353	Total base cost including retrofit factor Base cost per kW
Total Project Cost				
A1 = 10% of BM		=	\$ 3,721,648	Engineering and construction management costs (CC Manual)
A2 = 10% of BM		=	\$ 3,721,648	Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual)
A3 = 10% of BM		=	\$ 3,721,648	Contractor profit and fees (CC Manual)
	FI 1/ 10 10		• • • • • • • •	
CECC (\$) - Excludes Owner's Costs =	BM + A1 + A2 + A3	=	\$ 48,381,420	Capital, engineering, and construction costs subtotal
CECC (\$/kW) - Excludes Owner's Cos	its =	=	\$ 1,759	Capital, engineering, and construction costst subtotal per KW
B1 = 5% of CECC		=	\$ 2,419,071	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = Cl	ECC + B1	=	\$ 50,800,491	Total project cost without Allowance for Funds Used During Construction (AFUDC)
IPC (\$/kW) - Include Owner's Costs =		=	\$ 1,847	I otal project cost per kw without AFUDC
B2 = 10% of (CECC + B1)		=	\$ 5,080,049.08	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and		_	¢ 55 990 F40	Total project cost
TPC (\$/kW) - Includes Owner's Costs and	and AFUDC -	-	¢ 55,000,540	Total project cost per kW
o (with) - monutes owner s costs		-	÷ 2,032	

Wet Scrubber - Chena Power Plant

Direct Annual Costs			
Fixed O&M Cost			
		•	20.70 Find COM additional provides the sector
FOMO ($\frac{1}{4}$ FOMO)	=	\$	28.59 Fixed O&M additional operating labor costs
$FOMM ($/KW YF) = BM^{-}0.015/(B^{-}A^{-}1000)$ $FOMM ($/(kM yr) = 0.023/(FOMO + 0.43FOMM))$	=	\$ ¢	13.53 Fixed O&M additional maintenance material and labor costs
FONIA (S/KW YI) = 0.03 (FONIO+0.4 FONIMI)	=	¢ ¢	Fixed Oak costs for water tratmant facility
		Ψ	
FOM (\$/kW yr) = FOMO + FOMM + FOMA + FOMWW	=	\$	43.14 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = K*P/A	=	\$	1.14 Variable O&M costs for limestone reagent
		¢	
$VO(MVV (S/MVVN) = L^{-}Q/A$	=	Ъ	0.26 Variable O&M costs for waste disposal
VOMP ($\%$ /MWh) = M*R*10	=	\$	4.37 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N <mark>*S</mark> /A	=	\$	1.02 Variable O&M costs for makeup water
	_	¢	Variable Q8M costs for wastewater treatment facility
	-	φ	
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW	=	\$	6.78 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
Overhead (CO0) of tetal labor and material easts)		er-	744 OZE CC Menuel
Overhead (60% of total labor and material costs)	=	\$	711,875 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Broport tay (1% of total capital investment)	= =	\$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment)	= = =	\$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Easter (CRE) = [i (4) ⁿ] / (4) ⁿ = 1]	= = =	\$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interact ratio (%)	= = =	\$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Evulpment life (upars) 15	= = =	\$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0000	= = =	\$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980	= = = =	\$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980	= = =	\$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980	= = = =	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = =	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = =	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n]/[(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation)	= = = = = =	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	= = = = = =	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	-	\$ \$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ 1 / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	-	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ / / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	-	\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ / / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons	-	\$ \$ \$ \$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFEICIENCY %	-	\$ \$ \$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 568,805 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO2 EMISSIONS, tons SO2 REMOVAL EFFICIENCY, % TOTAL SO. PEMOYED, tons	-	\$ \$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons		\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ 1/ [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO2 EMISSIONS, tons SO2 REMOVAL EFFICIENCY, % TOTAL SO2 REMOVED, tons SO2 COST_EFEFECTIVENESS \$ fran removed		\$ \$ \$ \$ \$	711,875 CC Manual 1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644 16 005 Does not include sects associated with building and maintaining a wastewater tratment facility:

Appendix C (Coal Analyses Summary)

Coal Analyses Summary (As Received)										
Year	Report	Coal	HHV	Moisture	Sulfur					
Units		(tons)	(btu/lb)	(%)	(%)					
2013	А	103,122.35	7,670	27.22	0.15					
2013	В	115,917.00	7,599	27.95	0.17					
2014	А	117,659.65	7,652	27.89	0.15					
2014	В	103,979.45	7,617	27.86	0.14					
2015	А	103,904.80	7,599	29.16	0.14					
2015	В	120,758.30	7,610	29.02	0.15					
2016	А	115,282.20	7,683	31.21	0.12					
2016	В	107,687.35	7,604	29.23	0.14					
2017	А	106,040.35	7,567	32.20	0.11					
2017	В	114,440.00	7,529	32.52	0.10					
Weight	ed average	221,758.29	7,613	29.44	0.14					

Rail Samples Analysis Results for 6/1/13 to 6/30/13

Concernation Concerns and Concerns					****	***	*****	****				10-911-0-1921-0-1921-0-197
Customer	Date	#Cars	вти	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	6/3/2013	8	7490	28.62	8.57	35.96	26.86	0.13	TII	V6	6	741.40
AURORA ENERGY LLC	6/4/2013	13	7552	28.06	8.58	36.44	26.93	0.12	ŤII	V6	6	1,177.90
AURORA ENERGY LLC	6/6/2013	14	7303	28.45	10.15	34.89	26.51	0.14	T II	V6	6	1,308.40
AURORA ENERGY LLC	6/10/2013	16	7414	28.08	9.77	35.36	26.78	0.13	TH	V6	6	1,513.40
AURORA ENERGY LLC	6/13/2013	19	7528	27.82	9.38	35.66	27.15	0.15	ΤH	V6	6	1,749.25
AURORA ENERGY LLC	6/17/2013	7	7626	27.41	9.41	35.51	27.67	0.15	ТШ	V6	6	656.20
AURORA ENERGY LLC	6/18/2013	23	7682	28.49	7.14	36.88	27.50	0.14	ТШ	V6	6	2,079.85
AURORA ENERGY LLC	6/20/2013	26	7386	27,49	10.19	35.92	26.40	0.13	ТΙΙ	V6	6	2,365.55
AURORA ENERGY LLC	6/24/2013	14	7325	28.36	9.89	35.53	26.23	0.14	TII	V6	6	1,289.20
AURORA ENERGY LLC	6/26/2013	13	7522	28.53	8.56	34.56	28.35	0.19	ти	U4	4	1,202.85
AURORA ENERGY LLC	6/28/2013	19	7715	27.62	7.89	36.01	28.49	0.15	TII	U4	4	1,751.50
AURORA ENERGY LLC	6/28/2013	12	7593	28.46	7.84	35.39	28.32	0.14	TII	U4	4	1,071.10
Weighted Averages Sumi	nary											
Customer		Tons		BTU	Н	20	Ash		Volatiles	Cart	on	Sulfur
AURORA ENERGY LLC	~~~~~~********************************	16906.60)	7511.00	2	8.08	8.9	95	35.75) 2	7.23	0.14

Rail Samples Analysis Results for 1/1/13 to 6/30/13

Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2013	10	7504	27.93	9.16	34.93	27.98	0.20	ΤII	Τ4	4	961.05
AURORA ENERGY LLC	1/3/2013	11	7599	26.87	9.32	35.99	27.83	0.18	P2/STK	C1	6/N	1,000.35
AURORA ENERGY LLC	1/4/2013	9	7685	27.59	8.22	36.39	27.81	0.17	P2/STK	C1	6/N	816.20
AURORA ENERGY LLC	1/5/2013	13	7711	27.47	8.17	36.74	27.63	0.18	P2/STK	C1	6/N	1,263.55
AURORA ENERGY LLC	1/7/2013	11	7612	27.77	8.70	35.41	28.12	0.17	P2/STK	C1	6/N	1,057.50
AURORA ENERGY LLC	1/8/2013	9	7565	26.55	10.25	35.37	27.84	0.17	TII/P2	T4/C1	4/6	858.05
AURORA ENERGY LLC	1/9/2013	12	7584	27.03	9.43	35.53	28.01	0.18	T II/P2	T4/C1	4/6	1,113.90
AURORA ENERGY LLC	1/10/2013	6	7692	25.65	9.78	36.60	27.96	0.17	P2/STK	C1	6/N	562.40
AURORA ENERGY LLC	1/11/2013	13	7507	27.09	10.00	35.86	27.05	0.18	P2/STK	C1	6/N	1,223.50
AURORA ENERGY LLC	1/14/2013	9	7566	26.87	9.70	35.71	27.72	0.16	P2/STK	C1	6/N	872.75
AURORA ENERGY LLC	1/15/2013	14	7632	28.16	8.04	35.42	28.38	0.20	TII	Т4	4	1,261.60
AURORA ENERGY LLC	1/16/2013	12	7784	27.66	7.41	36.36	28.57	0.17	τII	Τ4	4	1,096.85
AURORA ENERGY LLC	1/17/2013	7	7758	27.48	8.08	35.70	28.75	0.19	P2/STK	C1	6/N	645.20
AURORA ENERGY LLC	1/18/2013	11	7788	26.88	7.92	36.52	28.68	0.16	P2/STK	C1	6/N	1,007.45
AURORA ENERGY LLC	1/21/2013	8	7678	26.95	8.63	35.72	28.71	0.17	T II/STK	T4	4/N	737.10
AURORA ENERGY LLC	1/22/2013	13	7709	27.10	8.34	35.59	28.98	0.18	T II/STK	Τ4	4/N	1,166.85
AURORA ENERGY LLC	1/23/2013	14	7746	27.10	8.39	36.04	28.47	0.17	P2/STK	C1	6/S	1,223.50
AURORA ENERGY LLC	1/25/2013	7	7754	27.88	7.45	36.79	27.89	0.15	P2/STK	C1	6/N	633.50
AURORA ENERGY LLC	1/25/2013	11	7585	26.81	9.72	36.20	27.28	0.15	P2/STK	C1	6/N	994.60
AURORA ENERGY LLC	1/28/2013	9	7484	26.40	11.09	35.58	26.94	0.15	P2/STK	C1	6/S	807.55
AURORA ENERGY LLC	1/29/2013	11	7691	26.62	9.22	36.11	28.05	0.15	Ρ2/STK	C1	6/S	994.45
AURORA ENERGY LLC	1/30/2013	13	7482	28.23	9.21	35.05	27.52	0.16	P2/STK	C1	6/S	1,150.80
AURORA ENERGY LLC	1/31/2013	10	7460	26.87	10.25	34.89	27.99	0.15	TII/P2	T3/C1	3/6	920.60
AURORA ENERGY LLC	2/1/2013	8	7529	28.24	9.08	35.07	27.61	0.14	ŤΠ	Т3	3	763.65
AURORA ENERGY LLC	2/4/2013	7	7545	28.48	8.71	34.47	28.34	0.13	ТИ	Т3	3	629.95
AURORA ENERGY LLC	2/5/2013	11	7463	28.30	9.56	34.22	27.92	0.14	ΤII	Т3	3	1,015.15
AURORA ENERGY LLC	2/7/2013	8	7491	28.60	8.93	34.76	27.72	0.13	P2/TII	C1/T3	6/3	755.05
AURORA ENERGY LLC	2/8/2013	12	7637	27.97	8.09	36.09	27.86	0.14	P2/TII	C1/T3	6/3	1,113.25
AURORA ENERGY LLC	2/9/2013	12	7740	26.73	8.61	37.24	27.42	0.14	P2	C1	6	1,102.05
AURORA ENERGY LLC	2/11/2013	9	⁷⁵⁰⁶ App	endix II	I.⁰ Ď ⁵7.	7-442	1 ^{28.38}	0.16	T II/P2	T3/C1	3/6	848.85

Rail Samples Analysis Results for 1/1/13 to 6/30/13

	***	****			ALSO AND		*****		distant commencements (15)			
AURORA ENERGY LLC	2/12/2013	15	7649	27.94	8.20	35.09	28.77	0.15	T II	T3	3	1,378.10
AURORA ENERGY LLC	2/13/2013	21	7556	27.99	9.13	34.51	28.38	0.15	ти	Т3	3	1,914.10
AURORA ENERGY LLC	2/14/2013	8	7819	26.40	8.38	36.31	28.91	0.14	P2/STK	C1	6/N	701.80
AURORA ENERGY LLC	2/15/2013	15	7437	27.31	10.59	34.59	27.51	0.15	P2/STK	C1	6/S	1,300.35
AURORA ENERGY LLC	2/18/2013	9	7616	27.77	8.69	34,75	28.80	0.14	TII	Т3	3	852.10
AURORA ENERGY LLC	2/19/2013	5	8065	26.73	6.36	37.32	29.59	0.13	P2/STK	C1	6/S	448.60
AURORA ENERGY LLC	2/20/2013	18	7824	27.32	7.48	37.11	28.09	0.15	P2/STK	C1	6/S	1,648.60
AURORA ENERGY LLC	2/21/2013	7	7607	26.43	10.17	36.29	27.11	0.15	P2/STK	C1	6/S	615.40
AURORA ENERGY LLC	2/22/2013	15	7510	28.05	9.42	35.26	27.28	0.14	TII	Т3	3	1,390.45
AURORA ENERGY LLC	2/25/2013	9	7697	28.21	7.72	34.80	29.27	0.14	TII	Т3	3	817.70
AURORA ENERGY LLC	2/26/2013	14	7588	28.23	8.43	35.08	28.26	0.14	TII/P2	T3/C1	3/6	1,275.05
AURORA ENERGY LLC	2/28/2013	17	7872	27.40	6.91	37.27	28.43	0.15	P2/STK	C1	6/S	1,587.05
AURORA ENERGY LLC	3/4/2013	11	7508	26.13	11.00	35.23	27.65	0.15	P2/TII	C1/T3	6/3	1,033.95
AURORA ENERGY LLC	3/5/2013	11	7682	26.99	8.13	36.34	28.55	0.14	P2/STK	C1	6/S	959.30
AURORA ENERGY LLC	3/6/2013	14	7648	27.25	7.96	36.56	28.23	0.15	P2/STK	C1	6/S	1,302.85
AURORA ENERGY LLC	3/7/2013	7	7717	26.40	8.27	37.82	27.53	0.15	P2/STK	C1	6/S	619.15
AURORA ENERGY LLC	3/8/2013	6	7469	26.55	9.86	37.18	26.41	0.16	P2/STK	C1	6/S	538.30
AURORA ENERGY LLC	3/11/2013	11	7857	27.02	7.45	37.34	28.20	0.15	P2/STK	C1	6/S	1,016.00
AURORA ENERGY LLC	3/12/2013	13	7868	26.99	7.27	37.32	28.43	0.14	P2/STK	C1	6/S	1,200.55
AURORA ENERGY LLC	3/13/2013	18	7437	28.70	8.86	35.07	27.37	0.14	P2/STK	C1	6/S	1,586.50
AURORA ENERGY LLC	3/15/2013	7	7253	25.91	13.37	35.02	25.70	0.14	P2/STK	C1	6/S	652.45
AURORA ENERGY LLC	3/19/2013	11	7570	26.44	10.41	36.24	26.91	0.16	P2/STK	C1	6/S	1,034.15
AURORA ENERGY LLC	3/19/2013	8	7723	26.43	9.14	36.80	27.63	0.14	P2/STK	C1	6/S	734.00
AURORA ENERGY LLC	3/20/2013	11	7812	26.67	8.36	36.58	28.40	0.15	P2/STK	C1	6/S	1,058.60
AURORA ENERGY LLC	3/21/2013	3	7805	26.35	8.46	36.75	28.44	0.15	P2/STK	C1	6/S	264.35
AURORA ENERGY LLC	3/22/2013	8	7580	26.59	10.17	36.01	27.24	0.15	P2/STK	C1	6/S	747.60
AURORA ENERGY LLC	3/25/2013	6	7835	26.61	7.98	37.07	28.35	0.15	P2/STK	C1	6/S	545.80
AURORA ENERGY LLC	3/26/2013	10	7873	26.37	7.94	37.21	28.48	0.16	P2/STK	C1	6/S	911.95
AURORA ENERGY LLC	3/27/2013	11	7633	26.67	9.68	35.80	27.86	0.16	P2/STK	C1	6/S	1,011.95
AURORA ENERGY LLC	3/28/2013	4	7776	26.70	8.29	37.09	27.93	0.15	P2/STK	C 1	6/S	363.85
AURORA ENERGY LLC	4/1/2013	6	7964	26.30	7.22	37.59	28.89	0.15	P2/STK	C1	6/S	527.90
AURORA ENERGY LLC	4/2/2013	11	⁷⁹ A 2pp	eridix I	∐ 6 D87.	73-742462	2 29.16	0.15	P2/STK	C1	6/S	993.45

Rail Samples Analysis Results for 1/1/13 to 6/30/13

			********		Store 1	00000A100000000000000000000000	*****	***				***************************************
935.20	6/S	C1	P2/STK	0.14	28.33	36.64	7.75	27.29	7812	10	4/3/2013	AURORA ENERGY LLC
458.50	6/S	C1	P2/STK	0.14	27.92	36.84	8.53	26.72	7779	5	4/4/2013	AURORA ENERGY LLC
855.30	6/N	C1	P2/STK	0.15	28.28	36.80	8.67	26.26	7866	9	4/5/2013	AURORA ENERGY LLC
934.30	3 6/3	C1/C13	P2/JDRC	0.16	26.89	34.23	11.58	27.30	7363	10	4/8/2013	AURORA ENERGY LLC
1,269.45	6	V6	TII	0.14	26.86	35.20	8.61	29.34	7381	14	4/9/2013	AURORA ENERGY LLC
885.25	6	V6	ТІІ	0.15	27.97	36.44	7.26	28.34	7736	10	4/11/2013	AURORA ENERGY LLC
556.70	6	V6	ТІІ	0.14	26.95	36.55	7.89	28.62	7591	6	4/11/2013	AURORA ENERGY LLC
1,062.00	3/C	C13	JD/GRP	0.15	26.44	32.67	11.50	29.40	7286	11	4/16/2013	AURORA ENERGY LLC
939.50	3	C13	JDRC	0.17	27.25	33.14	10.61	29.01	7385	10	4/16/2013	AURORA ENERGY LLC
730.15	6	V6	ТΠ	0.15	28.31	36.17	7.98	27.55	7746	8	4/18/2013	AURORA ENERGY LLC
750.40	6/W	V6	T II/STK	0.16	28.28	35.88	9.01	26.84	7783	8	4/20/2013	AURORA ENERGY LLC
657.70	6/W	V6	T II/STK	0.16	27.74	36.27	8.10	27.90	7659	7	4/22/2013	AURORA ENERGY LLC
741.05	6/W	V6	T II/STK	0.16	27.61	36.53	8.38	27.47	7706	8	4/23/2013	AURORA ENERGY LLC
856.65	6	V6	ΤII	0.15	27.24	36.03	8.91	27.83	7589	9	4/25/2013	AURORA ENERGY LLC
640.30	6	V6	TII	0.14	26.69	36.16	10.26	26.90	7505	7	4/25/2013	AURORA ENERGY LLC
746.30	6	V6	TII	0.15	26.69	37.23	8.54	27.54	7601	8	4/26/2013	AURORA ENERGY LLC
915.65	6	V6	ТΠ	0.14	27.09	35.78	8.82	28.32	7495	10	4/29/2013	AURORA ENERGY LLC
1,130.20	6	V6	ΤIJ	0.14	25.21	34.60	12.55	27.64	7123	12	4/30/2013	AURORA ENERGY LLC
1,238.65	M/N		GRP/STK	0.17	28.95	35.05	11.11	24.90	7962	12	5/1/2013	AURORA ENERGY LLC
940.15	M/S		GRP/STK	0.17	28.51	34.52	11.77	25.21	7815	10	5/2/2013	AURORA ENERGY LLC
670.35	M/S		GRP/STK	0.18	27.66	33.39	13.91	25.05	7574	7	5/3/2013	AURORA ENERGY LLC
1,223.00	M/S		GRP/STK	0.18	29.14	34.49	11.80	24.57	8042	13	5/3/2013	AURORA ENERGY LLC
278.80	M/N		GRP/STK	0.19	30.41	34.73	10.98	23.89	8200	3	5/6/2013	AURORA ENERGY LLC
765.10	M/N		GRP/STK	0.16	28.19	36.04	9.72	26.05	7876	8	5/20/2013	AURORA ENERGY LLC
1,459.45	M/N		GRP/STK	0.18	30.78	35.53	8.98	24,71	8437	16	5/21/2013	AURORA ENERGY LLC
954.30	М		GRP	0.18	32.54	35.33	8.77	23.37	8746	10	5/23/2013	AURORA ENERGY LLC
1,064.60	М		GRP	0.17	31.45	34.57	9.96	24.03	8414	11	5/23/2013	AURORA ENERGY LLC
819.70	M/N		GRP/STK	0.18	31.31	35.49	9.27	23.93	8508	9	5/27/2013	AURORA ENERGY LLC
1,151.15	M/N		GRP/STK	0.18	31.38	35.30	9.27	24.06	8514	12	5/28/2013	AURORA ENERGY LLC
956.70	6	V6	ТΠ	0.13	27.05	36.48	8.56	27.91	7619	10	5/30/2013	AURORA ENERGY LLC
741.40	6	V6	ΤH	0.13	26.86	35.96	8.57	28.62	7490	8	6/3/2013	AURORA ENERGY LLC
1,177.90	6	V6	TH	0.12	326.93	7364442	[∐₿ ₿ ₿7.	eratix]	75 A 2pp	13	6/4/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 1/1/13 to 6/30/13

AURORA ENERGY LLC		103122.35	5	7670.00	0 27.22		9.	05	35.76	2	7.98	0.15
Customer		Tons	M03407/002-K0027	BTU	H	20	Ash		Volatiles	Cart	noc	Sulfur
Weighted Averages Sun	ımary											
AURORA ENERGY LLC	6/28/2013	12	7593	28.46	7.84	35.39	28.32	0.14	TH	U4	4	1,071.10
AURORA ENERGY LLC	6/28/2013	19	7715	27.62	7.89	36.01	28.49	0.15	TH	U4	4	1,751.50
AURORA ENERGY LLC	6/26/2013	13	7522	28.53	8.56	34.56	28.35	0.19	ΤII	U4	4	1,202.85
AURORA ENERGY LLC	6/24/2013	14	7325	28.36	9.89	35.53	26.23	0.14	TII	V6	6	1,289.20
AURORA ENERGY LLC	6/20/2013	26	7386	27.49	10.19	35.92	26.40	0.13	ΤII	V6	6	2,365.55
AURORA ENERGY LLC	6/18/2013	23	7682	28.49	7.14	36.88	27.50	0.14	ΤII	V6	6	2,079.85
AURORA ENERGY LLC	6/17/2013	7	7626	27.41	9.41	35.51	27.67	0.15	ΤII	V6	6	656.20
AURORA ENERGY LLC	6/13/2013	19	7528	27.82	9.38	35.66	27.15	0.15	ΤII	V6	6	1,749.25
AURORA ENERGY LLC	6/10/2013	16	7414	28.08	9.77	35.36	26.78	0.13	TII	V6	6	1,513.40
AURORA ENERGY LLC	6/6/2013	14	7303	28.45	10.15	34.89	26.51	0.14	ΤII	V6	6	1,308.40
******	******	*********************************	*******	****			*****	*****		*****************		N-1/2011/02/04/04/04/04/04/04/04/04/04/04/04/04/04/

This analysis is representative of the coal shipped using sulfur standard ASTM D4239-12

Coleen Shompson

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 7/1/13 to 12/31/13

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/1/2013	7	7360	26.50	11.80	35.40	26.30	0.15	TBR	C 1	6	652.55
AURORA ENERGY LLC	7/2/2013	21	7675	26.40	9.51	36.33	27.77	0.15	TBR	C1	6	1,961.70
AURORA ENERGY LLC	7/5/2013	23	7565	27.34	9.39	34.94	28.34	0.19	ТП	U4	4	2,171.90
AURORA ENERGY LLC	7/8/2013	10	7538	28.53	8.36	34.23	28.88	0.19	ТІІ	U4	4	917.50
AURORA ENERGY LLC	7/9/2013	29	7645	28.51	7.49	35.44	28.57	0.16	ΤII	U4	4	2,700.95
AURORA ENERGY LLC	7/11/2013	13	7502	28.50	8.82	35.62	27.06	0.18	TBR	C1	6	1,224.95
AURORA ENERGY LLC	7/15/2013	12	7485	29.53	7.66	35.01	27.81	0.19	TII	U4	4	1,067.35
AURORA ENERGY LLC	7/16/2013	11	7317	27.95	10.29	34.12	27.68	0.25	T II	U4	4	1,019.50
AURORA ENERGY LLC	7/22/2013	11	7609	28.80	7.97	34.86	28.37	0.18	тп	U4	4	1,018.45
AURORA ENERGY LLC	7/24/2013	25	7467	28.43	8.50	34.68	28.41	0.19	TI	U4	4	2,303.20
AURORA ENERGY LLC	7/25/2013	13	7416	28.52	9.36	34.76	27.37	0.20	TII	U4	4	1,239.20
AURORA ENERGY LLC	7/29/2013	9	7339	29.30	9.16	33.88	27.67	0.20	ТΙΙ	U4	4	836.20
AURORA ENERGY LLC	8/1/2013	27	7749	27.87	8.65	34.52	28.97	0.15	JR/GRP	C13	4/M	2,483.15
AURORA ENERGY LLC	8/5/2013	10	7833	27.43	9.00	34.23	29.35	0.17	JD/GRP	C13	4/M	948.40
AURORA ENERGY LLC	8/6/2013	18	7752	29.20	7.09	34.40	29.31	0.14	JR/GRP	C13	4/M	1,657.00
AURORA ENERGY LLC	8/8/2013	12	7737	28.58	7.91	34.30	29.22	0.14	JR/GRP	C13	4/M	1,172.25
AURORA ENERGY LLC	8/8/2013	16	7648	28.65	8.33	34.49	28.53	0.13	JR/GRP	C13	4/M	1,524.25
AURORA ENERGY LLC	8/9/2013	12	7552	28.48	8.20	35.34	27.99	0.20	тп	U4	4	1,085.70
AURORA ENERGY LLC	8/12/2013	7	7610	28.79	7.51	34.66	29.05	0.16	TII	U4	4	657.40
AURORA ENERGY LLC	8/13/2013	17	7503	29.40	8.11	34.39	28.11	0.15	JR/T II	C13/U4	4/4	1,550.05
AURORA ENERGY LLC	8/19/2013	9	7696	28.53	8.03	34.46	29.00	0.16	JR	C13	4	834.85
AURORA ENERGY LLC	8/20/2013	17	7764	28.71	7.65	34.86	28.79	0.14	JR/GRP	C13	4/M	1,569.00
AURORA ENERGY LLC	8/22/2013	11	8309	24.18	10.01	34.82	31.00	0.20	GRP/ST	<	M/N	1,008.60
AURORA ENERGY LLC	8/22/2013	15	8288	24.11	9.99	35.32	30.58	0.17	GRP/ST	K	M/N	1,412.05
AURORA ENERGY LLC	8/26/2013	5	7656	27.01	10.63	33.80	28.57	0.19	T II/GRP	U3	3/M	491.15
AURORA ENERGY LLC	8/27/2013	12	7557	27.38	10.91	33.44	28.26	0.15	T II/GRP	U3	3/M	1,141.90
AURORA ENERGY LLC	8/28/2013	10	7705	27.60	9.20	34.46	28.74	0.14	T II/GRP	U3	3/M	905.40
AURORA ENERGY LLC	8/29/2013	12	7822	26.89	10.18	34.14	28.79	0.15	TII/GRP	U3	3/M	1,149.70
AURORA ENERGY LLC	9/3/2013	11	7996	26.39	10.28	34.01	29.33	0.16	TII/GRP	U3	3/M	1,048.10
AURORA ENERGY LLC	9/5/2013	10	⁷⁶⁵⁴ 76	efdix II	I.D.7.	7 34 423	5 ^{28.61}	0.15	T II/GRP	U3	3/M	935.45

Rail Samples Analysis Results for 7/1/13 to 12/31/13

CONFORMATION CONTRACTOR	ANN	URIERRAINSBUSHING	****			*****	*****	O HEATAGATACONROLISMOSIN		*****		**************************************
1,051.50	3	U3	ΤII	0.12	28.58	34.71	8.70	28.02	7566	12	9/5/2013	AURORA ENERGY LLC
808.00	3	U3	ΤII	0.12	28.01	35.10	8.73	28.16	7584	9	9/7/2013	AURORA ENERGY LLC
479.85	3	U3	ТΠ	0.13	28.66	34.02	8.44	28.89	7525	5	9/9/2013	AURORA ENERGY LLC
1,938.20	3	C13	JR	0.13	25.09	32.88	12.49	29.54	6894	20	9/11/2013	AURORA ENERGY LLC
1,900.70	3/N	U3	TII/STK	0.13	28.50	34.77	8.74	27.99	7578	20	9/13/2013	AURORA ENERGY LLC
769.35	3	U3	TII	0.12	28.43	34.53	9.36	27.68	7507	8	9/16/2013	AURORA ENERGY LLC
1,134.85	3	U3	тн	0.13	27.99	34.24	8.87	28.91	7474	12	9/18/2013	AURORA ENERGY LLC
1,756.50	3	U3	ΤII	0.12	28.06	34.11	9.45	28.38	7447	18	9/19/2013	AURORA ENERGY LLC
1,459.60	3	U3	тп	0.12	28.75	34.37	8.52	28.36	7567	15	9/20/2013	AURORA ENERGY LLC
2,034.85	6	C1	TBR	0.15	26.81	35.65	9.98	27.57	7503	21	9/24/2013	AURORA ENERGY LLC
1,425.25	6	C1	TBR	0.15	27.16	36.33	9.92	26.60	7615	15	9/25/2013	AURORA ENERGY LLC
1,261.65	6	C1	TBR	0.15	26.88	37.08	9.47	26.57	7626	13	9/26/2013	AURORA ENERGY LLC
572.95	6	C1	TBR	0.15	26.95	35.62	10.47	26.97	7556	6	9/30/2013	AURORA ENERGY LLC
758.30	6	C1	TBR	0.18	27.20	33.98	11.21	27.62	7354	8	10/2/2013	AURORA ENERGY LLC
1,009.45	4	V4	ΤII	0.16	28.69	34.36	9.13	27.82	7515	11	10/7/2013	AURORA ENERGY LLC
2,203.90	4	V4	ŤΠ	0.15	27.36	33.77	10.30	28.57	7298	23	10/10/2013	AURORA ENERGY LLC
1,618.40	4	V4	ΤII	0.21	27.32	34.26	10.17	28.25	7295	17	10/11/2013	AURORA ENERGY LLC
1,250.95	4	∨4	ΤII	0.21	29.43	34.47	8.67	27.43	7770	13	10/15/2013	AURORA ENERGY LLC
834.60	4	V4	T II	0.18	28.94	34.71	8.19	28.16	7622	9	10/16/2013	AURORA ENERGY LLC
1,448.90	4	V4	ΤII	0.19	28.78	34.73	7.77	28.73	7560	16	10/17/2013	AURORA ENERGY LLC
1,209.15	4	V4	TII	0.18	28.93	35.43	7.91	27.73	7582	13	10/18/2013	AURORA ENERGY LLC
1,476.80	4	V4	ΤII	0.20	28.53	34.45	9.19	27.84	7584	15	10/21/2013	AURORA ENERGY LLC
1,280.80	4	V4	ΤIJ	0.20	27.95	34.58	9.43	28.05	7492	13	10/22/2013	AURORA ENERGY LLC
1,756.85	4	V4	ΤIJ	0.20	28.52	34.70	8.52	28.26	7557	18	10/23/2013	AURORA ENERGY LLC
1,307.25	4/4	V4/W4	T II/T II	0.20	27.88	34.75	9.52	27.86	7539	14	10/26/2013	AURORA ENERGY LLC
1,171.30	4	W4	ΤII	0.20	28.15	34.92	9.19	27.75	7536	13	10/28/2013	AURORA ENERGY LLC
1,070.25	3	Bx	Bdl	0.14	30.00	35.86	5.87	28.27	7871	12	10/29/2013	AURORA ENERGY LLC
1,251.70	3	C4	Bdl	0.12	29.52	34.73	8.16	27.59	7644	13	10/30/2013	AURORA ENERGY LLC
1,561.60	4	W4	ΤII	0.15	28.50	35.49	7.68	28.33	7709	17	11/2/2013	AURORA ENERGY LLC
828.45	3	C4	Bdl	0.17	29.13	35.46	7.16	28.25	7745	9	11/4/2013	AURORA ENERGY LLC
1,007.45	4	W4	ΤII	0.16	28.84	34.70	8.04	28.42	7603	11	11/5/2013	AURORA ENERGY LLC
1,280.20	4	W4	ΤH	0.18	528.52	73442(II. D .47.	eada I	7 ≴€ pp	14	11/6/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 7/1/13 to 12/31/13

	No. of the second s	MARKAN BARANCAN LAND		9673777288394844447	****			CARACTER CONTRACTOR OF CONT			****	
939.25	4	W4	ТШ	0.13	28.70	35.74	6.91	28.65	7677	11	11/7/2013	AURORA ENERGY LLC
726.25	3	C4	Bdl	0.13	29.30	36.48	7.05	27.17	7833	8	11/8/2013	AURORA ENERGY LLC
1,230.50	4	W4	TII	0.21	28.19	34.66	9.12	28.03	7498	13	11/12/2013	AURORA ENERGY LLC
1,615.85	4	W4	ΤII	0.20	29.08	34.84	7.98	28.11	7622	17	11/13/2013	AURORA ENERGY LLC
1,368.50	4	W4	ТП	0.21	28.39	34.21	9.91	27.50	7466	15	11/14/2013	AURORA ENERGY LLC
1,137.60	4	W4	TI	0.20	28.78	34.44	8.72	28.08	7512	12	11/15/2013	AURORA ENERGY LLC
1,169.75	4	W4	тп	0.21	28.65	34.26	9.39	27.70	7497	12	11/18/2013	AURORA ENERGY LLC
1,238.50	4	W4	ТІІ	0.23	27.18	33.66	12.26	26.91	7183	13	11/19/2013	AURORA ENERGY LLC
928.10	4	W4	ти	0.25	27.13	33.17	12.16	27.55	7196	10	11/20/2013	AURORA ENERGY LLC
282.10	4	W4	ти	0.25	27.65	33.48	11.04	27,84	7305	3	11/21/2013	AURORA ENERGY LLC
853.00	4	W4	тн	0.22	27.77	34.53	9.57	28.14	7444	9	11/22/2013	AURORA ENERGY LLC
2,370.10	4	W4	TII	0.19	28.54	34.72	7.91	28.84	7557	25	11/23/2013	AURORA ENERGY LLC
292.95	4	W4	TłI	0.20	28.18	34.71	8.47	28.65	7521	3	11/26/2013	AURORA ENERGY LLC
1,322.45	4	W4	ΤII	0.20	27.89	34.31	9.06	28.74	7453	14	11/27/2013	AURORA ENERGY LLC
946.40	3/N	W4	TII/STK	0.16	29.09	34.71	8.86	27.34	7658	10	11/29/2013	AURORA ENERGY LLC
1,494.70	4	W4	TII	0.18	28.56	34.99	8.37	28.09	7630	17	12/2/2013	AURORA ENERGY LLC
869.90	4	W4	TI	0.20	28.63	34.80	8.08	28.49	7595	10	12/3/2013	AURORA ENERGY LLC
904.75	4	W4	ΤI	0.17	29.76	35.11	7.78	27.36	7734	10	12/4/2013	AURORA ENERGY LLC
763.85	3	C4	BdI	0.13	30.10	35.21	6.95	27.74	7810	8	12/5/2013	AURORA ENERGY LLC
1,063.85	3/4	C4/W4	Bdl/Tll	0.13	29.57	34.53	7.91	27.99	7711	11	12/9/2013	AURORA ENERGY LLC
1,275.10	3	C4	Bdl	0.13	29.92	34.74	7.73	27.62	7739	13	12/10/2013	AURORA ENERGY LLC
881.40	3	C4	Bdl	0.13	29.71	34.24	8.60	27.46	7674	9	12/11/2013	AURORA ENERGY LLC
286.75	3/N	C4	Bdl/STK	0.11	29.51	34.21	8.39	27.89	7696	3	12/13/2013	AURORA ENERGY LLC
852.80	3	C4	Bdl	0.12	29.94	34.06	8.54	27.46	7702	9	12/16/2013	AURORA ENERGY LLC
776.85	4	C4	Bdl	0.13	30.05	34.58	7.89	27.48	7800	8	12/17/2013	AURORA ENERGY LLC
1,176.55	3	C4	Bdl	0.13	30.85	35.46	6.37	27.33	7960	12	12/18/2013	AURORA ENERGY LLC
966.55	3	C4	Bdl	0.12	30.10	34.92	6.73	28.26	7856	10	12/19/2013	AURORA ENERGY LLC
669.90	3/N	C4	Bdl/STK	0.13	29.92	34.88	7.58	27.63	7801	7	12/20/2013	AURORA ENERGY LLC
1,473.00	3/N	C4	Bdl/STK	0.12	30.09	34.75	7.12	28.04	7802	15	12/23/2013	AURORA ENERGY LLC
1,459.65	3/N	C4	BdI/STK	0.15	29.65	34.17	8.37	27.81	7676	15	12/24/2013	AURORA ENERGY LLC
431.00	4	X4	тн	0.19	28.53	35.09	8.14	28.24	7632	5	12/27/2013	AURORA ENERGY LLC
547.85	4	X4	тн	0.22	727.70	734427	III. D ?7	endez]	7 ≸X þr	6	12/27/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 7/1/13 to 12/31/13

***************************************	****	****	X80010-007070097	******		****		1711122/14/1214144	1940-1149-1446-1446-1446-1446-1446-1446-1446	TERMINING STREET	*******	*****
AURORA ENERGY LLC	12/29/2013	27	7744	27.93	7.68	35.17	29.23	0.17	TII	X4	4	2,307.45
AURORA ENERGY LLC	12/30/2013	10	7520	27.94	9.09	34.77	28.20	0.22	ТШ	X4	4	942.95
AURORA ENERGY LLC	12/31/2013	8	7602	27.77	8.55	34.81	28.87	0.22	ΤII	X4	4	744.15
Weighted Averages Summ	ary											
Customer		Tons		BTU	Н	20	Ash		Volatiles	Cart	on	Sulfur
AURORA ENERGY LLC		115917.70)	7599.00	2	7.95	8.8	31	34.72	28	3.53	0.17

This analysis is representative of the coal shipped

using sulfur standard ASTM D4239-12

Colcen Shompson 1-3-14

Rail Samples Analysis Results for 1/1/14 to 6/30/14

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2014	15	7592	27.80	8.87	34.55	28.78	0.20	тп	X4	4	1,370.90
AURORA ENERGY LLC	1/3/2014	15	7615	29.16	7.32	35.00	28.52	0.17	TII	X4	4	1,440.35
AURORA ENERGY LLC	1/6/2014	8	7633	28.42	7.70	34.85	29.03	0.16	ΤII	X4	4	779.40
AURORA ENERGY LLC	1/7/2014	12	7642	28.93	7.31	34.80	28.97	0.17	ти	X4	4	1,137.10
AURORA ENERGY LLC	1/8/2014	13	7615	28.31	8.20	34.76	28.74	0.19	ТΙΙ	X4	4	1,229.35
AURORA ENERGY LLC	1/9/2014	11	7538	28.03	8.94	34.41	28.63	0.23	ТШ	X4	4	1,070.75
AURORA ENERGY LLC	1/10/2014	13	7571	28.86	8.02	34.63	28.49	0.18		X4	4	1,216.15
AURORA ENERGY LLC	1/13/2014	10	7453	27.84	9.86	34.82	27.48	0.22	TII	X4	4	984.25
AURORA ENERGY LLC	1/14/2014	11	7489	28.42	8.99	34.32	28.27	0.22	Bdl	C4	3	1,031.80
AURORA ENERGY LLC	1/15/2014	8	7608	28.12	8.69	34.32	28.87	0.20	тп	X4	4	756.60
AURORA ENERGY LLC	1/16/2014	13	7588	28.25	8.55	34.40	28.80	0.20	ти	X4	4	1,251.05
AURORA ENERGY LLC	1/18/2014	16	7679	29.63	6.32	34.82	29.24	0.14	TII	X4	4	1,478.00
AURORA ENERGY LLC	1/20/2014	10	7735	28.53	7.06	34.71	29.71	0.16	ΤIJ	X4	4	953.85
AURORA ENERGY LLC	1/21/2014	9	7833	28.40	6.48	34.96	30.17	0.13	Bdl	C4	3	805.85
AURORA ENERGY LLC	1/22/2014	12	7767	27.95	7.35	34.72	29.99	0.13	Bdl	C4	3	1,168.20
AURORA ENERGY LLC	1/23/2014	3	7759	28.53	7.30	34.21	29.97	0.13	Bdl	C4	3	293.50
AURORA ENERGY LLC	1/27/2014	9	7379	28.65	9.78	33.16	28.41	0.12	Bdl/JR	C4/C13	3/3	853.10
AURORA ENERGY LLC	1/28/2014	9	7700	28.25	7.82	34.50	29.43	0.15	Bdl/JR	C4/C13	3/3	810.95
AURORA ENERGY LLC	1/29/2014	10	7721	28.70	7.00	34.48	29.82	0.14	Bdl/STK	C4	3/N	917.25
AURORA ENERGY LLC	1/30/2014	15	7737	28.41	7.34	34.81	29.44	0.13	Bdl	C4	3	1,357.75
AURORA ENERGY LLC	1/31/2014	22	7529	29.01	8.13	33.66	29.21	0,12	Bdl	C4	3	2,046.90
AURORA ENERGY LLC	2/3/2014	19	7560	28.92	8.26	33.56	29.26	0.14	Bdl	C4	3	1,809.10
AURORA ENERGY LLC	2/4/2014	12	7527	29.18	8.14	33.53	29.14	0.13	Bdl/ T II	C4/X3	3/3	1,138.90
AURORA ENERGY LLC	2/5/2014	6	7533	28.73	8.62	34.00	28.66	0.13	TII	X3	3	549.45
AURORA ENERGY LLC	2/6/2014	9	7582	28.26	8.89	33.92	28.93	0.12	тн	X3	3	833.35
AURORA ENERGY LLC	2/10/2014	11	7548	28.78	8.49	33.65	29.08	0.13	ΤIJ	X3	3	997.40
AURORA ENERGY LLC	2/12/2014	13	7669	28.02	8.03	34.85	29.10	0.13	ТИ	X 3	3	1,178.00
AURORA ENERGY LLC	2/12/2014	8	7568	27.51	9.42	34.40	28.68	0.12	ΤII	X 3	3	735.35
AURORA ENERGY LLC	2/13/2014	12	7810	26.92	8.17	35.24	29.67	0.19	Bdl	A	4	1,085.25
AURORA ENERGY LLC	2/15/2014	10	⁷⁸ A¹pt	effdix II	17. D9 .7	.7° <u>°</u> 4442	929.07	0.21	Bdl	А	4	964.15

Rail Samples Analysis Results for 1/1/14 to 6/30/14

CHARACTER CONTINUES AND	NY 272111 1012020 1020 1020 1020 1020 1020											
AURORA ENERGY LLC	2/17/2014	8	7821	26.21	8.59	36.19	29.02	0.26	Bdl	А	4	771.90
AURORA ENERGY LLC	2/18/2014	12	7857	26.05	8.45	35.90	29.61	0.23	Bdl	А	4	1,099.50
AURORA ENERGY LLC	2/19/2014	16	7803	26.19	8.75	35.91	29.15	0.21	Bdl/STK	А	4/N	1,524.75
AURORA ENERGY LLC	2/20/2014	7	7738	26.33	9.11	35.75	28.82	0.20	Bdl/STK	А	4/N	670.45
AURORA ENERGY LLC	2/21/2014	18	7702	26.91	8.70	35.77	28.63	0.20	Bdl/STK	А	4/N	1,716.05
AURORA ENERGY LLC	2/24/2014	13	7721	27.34	8.35	35.25	29.07	0.19	Bdl/STK	А	4/N	1,244.25
AURORA ENERGY LLC	2/25/2014	14	7663	27.53	8.50	34.81	29.15	0.15	TII/BdI	X3/A	3/4	1,314.15
AURORA ENERGY LLC	2/27/2014	18	7704	27.80	7.88	35.13	29.20	0.14		X3	3	1,743.25
AURORA ENERGY LLC	2/28/2014	19	7519	28.26	8.83	34.59	28.33	0.13	Bdl/T II	A/X3	4/3	1,856.75
AURORA ENERGY LLC	3/3/2014	11	7539	28.91	8.17	33.90	29.03	0.11	TII/Bdl	X3/A	3/4	1,078.75
AURORA ENERGY LLC	3/4/2014	13	7678	26.91	9.19	35.01	28.89	0.23	Bdl/STK	В	4/N	1,195.00
AURORA ENERGY LLC	3/5/2014	11	7784	26.75	8.53	35.75	28.96	0.21	Bdl/STK	В	4/N	1,084.80
AURORA ENERGY LLC	3/6/2014	7	7723	26.83	8.71	35.41	29.05	0.18	Bdl/STK	В	4/N	691.95
AURORA ENERGY LLC	3/7/2014	7	7758	26.72	8.49	35.58	29.20	0.19	Bdl/STK	в	4/N	666.20
AURORA ENERGY LLC	3/10/2014	7	7719	26.52	9.09	35.53	28.86	0.22	Bdl/STK	в	4/N	671.50
AURORA ENERGY LLC	3/11/2014	11	7675	27.64	8.15	35.24	28.97	0.20	Bdl/STK	В	4/N	1,016.05
AURORA ENERGY LLC	3/12/2014	4	7634	27.35	8.82	35.17	28.66	0.21	Bdl/STK	В	4/N	394.50
AURORA ENERGY LLC	3/13/2014	16	7120	26.15	14.55	33.06	26.25	0.25	Bdl/STK	в	4/N	1,555.45
AURORA ENERGY LLC	3/14/2014	12	7615	27.55	9.03	34.97	28.45	0.18	Bdl/STK	в	4/N	1,178.10
AURORA ENERGY LLC	3/17/2014	3	7872	26.97	7.37	36.05	29.62	0.18	Bdl	В	4	281.15
AURORA ENERGY LLC	3/18/2014	12	7750	27.82	7.64	34.83	29.70	0.16	BdI/STK	в	4/N	1,093.55
AURORA ENERGY LLC	3/19/2014	12	7798	27.45	7.40	35.78	29.38	0.18	Bdl/STK	в	4/N	1,128.70
AURORA ENERGY LLC	3/20/2014	10	7948	26.46	7.32	36.57	29.84	0.23	Bdl/STK	В	4/N	951.45
AURORA ENERGY LLC	3/21/2014	12	7916	27.92	6.00	35.87	30.22	0.12	Bdl	В	4	1,075.20
AURORA ENERGY LLC	3/24/2014	12	7882	27.38	6.81	35.69	15.13	0.14	BdI/STK	в	4/N	1,043.95
AURORA ENERGY LLC	3/25/2014	1	8057	26.46	6.27	36.20	31.04	0.13	Bdl/STK	в	4/N	85.90
AURORA ENERGY LLC	3/26/2014	15	7887	27.68	6.78	35.65	29.90	0.12	Bdl/T II	B/X3	4/3	1,414.80
AURORA ENERGY LLC	3/27/2014	26	7482	27.96	9.07	34.76	28.21	0.11	TH	X3	3	2,390.75
AURORA ENERGY LLC	3/31/2014	8	7310	27.68	11.54	33.38	27.41	0.13	TH	Х3	3	783.60
AURORA ENERGY LLC	4/1/2014	9	7832	28.80	5.23	35.61	30.37	0.10	Bdl	А	3	825.10
AURORA ENERGY LLC	4/2/2014	13	7776	28.29	5.87	35.47	30.37	0.11	Bdl/STK	А	3/N	1,226.70
AURORA ENERGY LLC	4/3/2014	9	75 A 9pp	oendix l	II8 D 77	.73-412423	029.30	0.13	Bdl/STK	А	3/N	892.80

Rail Samples Analysis Results for 1/1/14 to 6/30/14

*****			**		STATISTICS AND STATISTICS	uoanninenenenenen			***
T II/BdI X	0.11	29.05	34.98	7.91	28.07	7695	5	4/4/2014	AURORA ENERGY LLC
Bdl	0.12	30.71	35.24	5.97	28.09	7899	10	4/7/2014	AURORA ENERGY LLC
BdI/STK	0.12	30.43	34.97	6.32	28.29	7861	10	4/8/2014	AURORA ENERGY LLC
Bdl/STK	0.12	30.30	35.28	6.59	27.84	7878	14	4/9/2014	AURORA ENERGY LLC
Bdl/STK	0.12	29.73	34.44	7.47	28.36	7734	13	4/10/2014	AURORA ENERGY LLC
Bdl/STK	0.12	28.74	34.50	8.22	28.55	7609	9	4/11/2014	AURORA ENERGY LLC
Bdl/STK	0.11	29.80	34.83	7.38	27.99	7769	10	4/14/2014	AURORA ENERGY LLC
TIL L	0.13	27.46	36.80	7.20	28.55	7662	12	4/15/2014	AURORA ENERGY LLC
TH L	0.13	25.83	35.30	11.33	27.55	7262	11	4/16/2014	AURORA ENERGY LLC
TII L	0.10	26.14	36.75	9.11	28.02	7462	13	4/17/2014	AURORA ENERGY LLC
Bdl/STK	0.07	29.42	36.14	4.91	29.53	7632	13	4/18/2014	AURORA ENERGY LLC
Bdl/STK	0.11	29.71	35.32	7.25	27.72	7627	9	4/21/2014	AURORA ENERGY LLC
TI L	0.13	27.43	35.47	9.12	27.99	7451	11	4/22/2014	AURORA ENERGY LLC
Bdl/STK	0.12	28.07	35.70	8.16	28.07	7525	11	4/23/2014	AURORA ENERGY LLC
TII L	0.12	27.36	36.21	8.11	28.32	7570	12	4/24/2014	AURORA ENERGY LLC
TH L	0.13	26.51	36.49	8.61	28.40	7464	13	4/25/2014	AURORA ENERGY LLC
TH L	0.13	27.20	35.68	9.55	27.57	7451	11	4/28/2014	AURORA ENERGY LLC
TI: L	0.12	25.97	36.58	9.76	27.69	7397	12	4/30/2014	AURORA ENERGY LLC
TII L	0.13	26.82	36.29	9.03	27.86	7464	12	5/1/2014	AURORA ENERGY LLC
17#1 L	0.14	27.39	36.22	8.15	28.24	7601	11	5/5/2014	AURORA ENERGY LLC
T11 L.	0.14	28.04	36.55	7.63	27.79	7735	10	5/6/2014	AURORA ENERGY LLC
TII L	0.13	27.49	36.83	7.46	28.23	7638	12	5/7/2014	AURORA ENERGY LLC
T II/Bsi LS	0.13	28.00	35.22	8.21	28.57	7544	14	5/8/2014	AURORA ENERGY LLC
Bdl/STK	0.13	29.14	35.31	8.05	27.50	7796	16	5/12/2014	AURORA ENERGY LLC
Bdi/Tii A/	0.12	27.62	37.35	6.78	28.25	7746	12	5/14/2014	AURORA ENERGY LLC
Bdl/Tll A/	0.12	27.28	37.35	7.12	28.25	7712	9	5/15/2014	AURORA ENERGY LLC
TII/BdI LS	0.11	28.18	36.08	7.76	27.99	7707	10	5/16/2014	AURORA ENERGY LLC
TII/Bdl LS	0.13	29.68	35.48	7.92	26.93	7769	8	5/19/2014	AURORA ENERGY LLC
Bdl/STK	0.11	30.10	35.62	6.07	28.22	7915	11	5/20/2014	AURORA ENERGY LLC
Bdl/STK	0.12	29.56	35.07	8.12	27.26	7761	9	5/21/2014	AURORA ENERGY LLC
Bdl/STK	0.11	29.43	35.93	7.27	27.38	7809	7	5/22/2014	AURORA ENERGY LLC
TII L	0.12	126.52	.7381243	III 69 27	peratix	77 A 9	8	5/23/2014	AURORA ENERGY LLC
Rail Samples
Analysis Results for 1/1/14 to 6/30/14

AURORA ENERGY LLC		117659.6	5	7652.00	2	7.89	8.	15	35.29	2	8.54	0.15
Customer		Tons		BTU	مىلىنى مىلىنى	120	Ash		Volatiles	Car	bon	Sulfur
Weighted Averages Sun	nmary			8				,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			****	
AURORA ENERGY LLC	6/30/2014	9	7695	28.75	7.46	34.73	29.06	0.11	Bdl/STK	с	3/N	829.70
AURORA ENERGY LLC	6/26/2014	12	7776	27.04	7.86	35.66	29.45	0.11	Bdl/STK	с	3/N	1,172.35
AURORA ENERGY LLC	6/25/2014	13	7751	28.21	7.20	34.95	29.64	0.11	Bdl/STK	С	3/N	1,259.45
AURORA ENERGY LLC	6/24/2014	10	7712	27.76	8.03	34.70	29.51	0.12	BdI/STK	С	3/N	931.05
AURORA ENERGY LLC	6/23/2014	9	7311	28.02	10.34	35.77	25.87	0.15	ТП	LST	6	867.60
AURORA ENERGY LLC	6/19/2014	18	7458	27.53	9.65	36.66	26.16	0.11	TH	LST	6	1,681.40
AURORA ENERGY LLC	6/18/2014	16	7672	27.62	7.90	37.02	27.47	0.12	TII	LST	6	1,534.80
AURORA ENERGY LLC	6/16/2014	10	7632	27.40	8.88	36.76	26.96	0.12	ТШ	LST	6	964.10
AURORA ENERGY LLC	6/12/2014	5	7669	27.41	8.70	37.27	26.62	0.11	GRP/TII	LST	M/6	489.40
AURORA ENERGY LLC	6/11/2014	7	7704	26.60	10.00	35.94	27.47	0.14	T II/GRP	L.ST	6/M	683.90
AURORA ENERGY LLC	6/9/2014	5	7676	28.30	7.60	36.90	27.20	0.12	ТП	LST	6	481.65
AURORA ENERGY LLC	6/5/2014	13	7690	28.12	7.45	36.87	27.56	0.13	ТІІ	LST	6	1,236.80
AURORA ENERGY LLC	6/3/2014	8	7949	27.23	6.72	36.14	29.91	0.11	Bdl/STK	В	3/N	779.60
AURORA ENERGY LLC	6/2/2014	8	7688	27.53	8.31	34.79	29.39	0.11	Bdl/STK	В	3/N	793.70
AURORA ENERGY LLC	5/30/2014	12	7673	27.44	8.50	34.98	29.08	0.11	Bdl/STK	В	3/N	1,150.20
AURORA ENERGY LLC	5/29/2014	12	7514	27.86	9.02	34.63	28.50	0.13	BdI/STK	В	3/N	1,174.15
AURORA ENERGY LLC	5/28/2014	14	7654	26.98	8.94	35.73	28.36	0.12	Bdl/STK	В	3/N	1,342.05
AURORA ENERGY LLC	5/26/2014	7	7723	28.31	6.78	38.02	26.90	0.12	TII	LST	6	614.05
									an management and a second and a second			

This analysis is representative of the coal shipped using sulfur standard ASTM D4239 - 12 $\,$

Coleen Strompson 7-2-14

Appendix E (Coal Sulfur Summary)

Rail Samples Analysis Results for 7/1/14 to 12/31/14

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/1/2014	17	7525	28.93	8.28	34.19	28.60	0.12	Bdl/STK	с	3/N	1,638.75
AURORA ENERGY LLC	7/2/2014	11	7442	29.33	8.64	34.80	27.23	0.13	Bdl/STK	С	3/N	1,079.80
AURORA ENERGY LLC	7/4/2014	7	7656	27,98	8.07	36.98	26.97	0.11	TII	LST	6	627.85
AURORA ENERGY LLC	7/7/2014	13	7622	28.13	7.79	37.11	26.97	0.12	ΤI	LST	6	1,239.90
AURORA ENERGY LLC	7/9/2014	33	7578	28.14	8.43	36.77	26.67	0.13	ΤII	LST	6	3,141.00
AURORA ENERGY LLC	7/14/2014	13	7395	27.68	9.60	36.03	26.72	0.13	ΤII	LST	6	1,276.45
AURORA ENERGY LLC	7/16/2014	18	7619	28.26	7.73	36.94	27.08	0.12	ТП	LST	6	1,699.05
AURORA ENERGY LLC	7/17/2014	18	7570	28.11	8.29	36.76	26.84	0.12	ΤII	LST	6	1,778.65
AURORA ENERGY LLC	7/21/2014	14	7442	28.16	9.30	36.11	26.43	0.13	ТН	LST	6	1,346.20
AURORA ENERGY LLC	7/23/2014	16	7409	28.35	9.31	36.18	26.16	0.12	тн	LST	6	1,446.00
AURORA ENERGY LLC	7/24/2014	17	7621	27.21	8.61	37.30	26.88	0.11	TII	LST	6	1,544.95
AURORA ENERGY LLC	7/28/2014	5	7539	27.66	8.85	36.81	26.69	0.12	тι	LST	6	490.95
AURORA ENERGY LLC	7/30/2014	6	7675	26.58	9.28	36.70	27.45	0.14	Bdl	C1	6	569.15
AURORA ENERGY LLC	8/4/2014	8	7404	29.01	8.95	35.65	26.39	0.13	ŤΠ	LST	6	795.30
AURORA ENERGY LLC	8/5/2014	8	7750	27.08	8.18	37.34	27.40	0.13	TBR	C1	6	703.80
AURORA ENERGY LLC	8/6/2014	17	7586	26.84	9.66	36.79	26.71	0.14	TBR	C1	6	1,686.45
AURORA ENERGY LLC	8/7/2014	13	7425	27.57	10.25	36.28	25.91	0.13	TBR	C1	6	1,299.70
AURORA ENERGY LLC	8/11/2014	8	7702	27.08	8.56	36.95	27.42	0.13	TBR	C1	6	781.45
AURORA ENERGY LLC	8/13/2014	18	7601	26.69	9.52	36.64	27.16	0.13	TBR	C1	6	1,605.50
AURORA ENERGY LLC	8/14/2014	16	7510	26.42	10.35	36.71	26.53	0.12	TBR	C1	6	1,500.05
AURORA ENERGY LLC	8/16/2014	10	7952	25.09	10.53	36.52	27.87	0.19	GRP/STM	< Comparison of the second sec	M/N	937.00
AURORA ENERGY LLC	8/18/2014	4	7846	25.81	10.48	35.39	28.33	0.17	GRP/STH	K	M/N	403.90
AURORA ENERGY LLC	8/20/2014	5	7972	25.66	10.21	34.89	29.25	0.16	GRP/STH	K	M/N	479.00
AURORA ENERGY LLC	8/21/2014	5	7947	25.16	10.86	35.53	28.45	0.16	GRP/STH	K	M/N	472.20
AURORA ENERGY LLC	8/25/2014	6	7585	26.17	11.19	35.79	26.86	0.14	GRP/STM	< Comparison of the second sec	M/N	575.15
AURORA ENERGY LLC	8/27/2014	5	7844	26.46	9.73	35.49	28.33	0.15	GRP/STK	< Comparison of the second sec	M/N	459.95
AURORA ENERGY LLC	8/28/2014	5	7573	27.55	9.51	35.82	27.13	0.13	TBR	C1	6	453.20
AURORA ENERGY LLC	9/2/2014	5	7853	25.68	10.15	35.75	28.43	0.16	GRP/STK	5	M/N	444.10
AURORA ENERGY LLC	9/3/2014	7	7595	27.30	9.44	35.06	28.21	0.23	Bdl	E	4	599.15
AURORA ENERGY LLC	9/5/2014	9	⁷¹ Å4pp	endix II	1. D .7	7 ³² 443	4 ^{24.76}	0.24	GRP/STK	ζ.	M/N	804.25

Rail Samples Analysis Results for 7/1/14 to 12/31/14

	INCLUSION INCLUSION IN THE INCLUSION INTERNA		*****		Second States and States	****	1999))))))))))))))	SCONDERCE STREET	WSNOW CONTRACTOR OF	*****	****	unzen underen schristlicherste
AURORA ENERGY LLC	9/5/2014	3	7828	23.73	14.19	34.29	27.79	0.22	GRP/STK		M/N	268.65
AURORA ENERGY LLC	9/5/2014	6	7651	23.59	15.37	33.86	27.19	0.23	GRP/STK		M/N	539.60
AURORA ENERGY LLC	9/8/2014	6	7455	27.39	10.16	36.70	25.75	0.13	Bdl	E	4	535.55
AURORA ENERGY LLC	9/10/2014	12	7336	28.02	10.03	35.87	26.09	0.13	ТН	LST	6	1,100.05
AURORA ENERGY LLC	9/11/2014	10	7155	27.65	12.33	34.95	25.08	0.13	ти	LST	6	941.35
AURORA ENERGY LLC	9/15/2014	5	7517	27.42	9.62	35.72	27.25	0.17	Bdl	E	4	464.40
AURORA ENERGY LLC	9/17/2014	7	7531	27.52	9.06	36.59	26.84	0.13	ТШ	LST	6	652.45
AURORA ENERGY LLC	9/18/2014	6	7493	27.99	8.91	35.72	27.39	0.19	ΤIJ	LST	6	539.45
AURORA ENERGY LLC	9/22/2014	5	7793	28.38	6.50	35.62	29.51	0.14	Bdl	E	4	481.40
AURORA ENERGY LLC	9/24/2014	9	7206	26.90	12.00	35.04	26.07	0.13	ТП	LST	6	864.35
AURORA ENERGY LLC	9/25/2014	10	7528	28.00	8.47	36.92	26.61	0.12	TII	LST	6	971.75
AURORA ENERGY LLC	9/27/2014	11	7739	28.34	6.81	36.34	28.51	0.18	Bdl	E	4	1,007.10
AURORA ENERGY LLC	9/29/2014	11	7739	28.09	6.87	35.86	29.18	0.19	Bdl	F	4	1,034.60
AURORA ENERGY LLC	9/30/2014	11	7749	28.54	6.60	35.47	29.41	0.16	Bdl	F	4	984.35
AURORA ENERGY LLC	10/1/2014	26	7815	28.29	6.55	35.84	29.32	0.16	Bdl	F	4	2,485.80
AURORA ENERGY LLC	10/6/2014	10	7591	28.11	8.20	36.05	27.65	0.16	Bdl/Tll	F/LST	4/6	856.70
AURORA ENERGY LLC	10/8/2014	9	7403	27.49	10.14	35.31	27.07	0.16	Bdl/T II	F/LST	4/6	810.80
AURORA ENERGY LLC	10/8/2014	11	7499	28.23	8.70	36.11	26.96	0.12	ΤII	LST	6	985.90
AURORA ENERGY LLC	10/9/2014	12	7495	28.17	8.40	36.91	26.52	0.12	ТП	LST	6	1,116.25
AURORA ENERGY LLC	10/11/2014	13	7566	28.43	7.85	38.08	25.65	0.12	ти	LST	6	1,133.10
AURORA ENERGY LLC	10/13/2014	7	7405	27.91	9.44	36,23	26.43	0.13	ΤII	LST	6	676.50
AURORA ENERGY LLC	10/15/2014	11	7971	26.15	9.33	35.38	29.13	0.15	GRP/STK		M/N	997.30
AURORA ENERGY LLC	10/16/2014	16	8040	25.93	8.50	36.45	29.13	0.16	GRP/STK		M/N	1,476.75
AURORA ENERGY LLC	10/20/2014	9	7629	27.68	8.84	36.03	27.45	0.14	ΤII	LST	6	864.20
AURORA ENERGY LLC	10/21/2014	12	7874	27.45	7.56	35.30	29.69	0.13	Bdl	D	3	1,113.15
AURORA ENERGY LLC	10/22/2014	15	7932	27.59	6.48	35.31	30.62	0.12	Bdl	Е	3	1,424.60
AURORA ENERGY LLC	10/23/2014	14	7880	27.56	6.24	36.02	30.19	0.10	Bdl	Е	3	1,343.80
AURORA ENERGY LLC	10/24/2014	9	7169	30.71	6.85	34.67	27.79	0.12	Jumbo			783.45
AURORA ENERGY LLC	10/27/2014	12	7748	28.04	7.14	35,35	29.47	0.13	Bdl/STK	D	3/N	1,187.15
AURORA ENERGY LLC	10/28/2014	10	7616	28.45	7.79	35.64	28.13	0.12	BdI/T II	D/LST	3/6	922.05
AURORA ENERGY LLC	10/29/2014	10	7494	28.14	8.94	35.97	26.95	0.13	тμ	LST	6	939.80
AURORA ENERGY LLC	10/30/2014	11	7 4 4pp	eadix I	11 8D 97.	7364643	526.15	0.12	TI	LST	6	1,074.40

Rail Samples Analysis Results for 7/1/14 to 12/31/14

STATEMETERS AND A CONTRACTORS AND A CONTRACTORS AND A CONTRACT AND A CONTRACT AND A CONTRACT AND A CONTRACT AND	****************	EADE428-WATERATERSTR.8	HILL CARACTERING AND	355.566822362266666992965	*****************	*****		man and the second s	in a second state of the second s	www.industry.industry.org	AND ADDRESS OF A DESCRIPTION OF A DESCRI	
AURORA ENERGY LLC	10/31/2014	10	7754	28.43	7.39	36.13	28.06	0.13	TII/BdI	LST/D	6/3	943.50
AURORA ENERGY LLC	11/3/2014	6	7675	29.16	6.72	34.86	29.26	0.12	Bdl/JD	D	3/4	566.40
AURORA ENERGY LLC	11/4/2014	13	7741	28.44	6.73	35.24	29.59	0.11	Bdl/JD	D	3/4	1,279.15
AURORA ENERGY LLC	11/5/2014	12	7651	28.22	7.68	35.38	28.73	0.12	Bdl/JD	D	3/4	1,176.25
AURORA ENERGY LLC	11/6/2014	9	7622	28.67	7.42	34.84	29.07	0.12	Bdl/JD	D	3/4	848.35
AURORA ENERGY LLC	11/7/2014	12	7769	28.00	7.20	35.32	29.48	0.11	Bdl/JD	D	3/4	1,064.60
AURORA ENERGY LLC	11/10/2014	7	7769	28.21	6.77	35.31	29.71	0.10	Bdl/JD	D	3/4	650.70
AURORA ENERGY LLC	11/11/2014	12	7739	28.65	6.64	35.20	29.52	0.11	Bdl/JD	D	3/4	1,141.50
AURORA ENERGY LLC	11/12/2014	12	7644	29.46	6.67	34.68	29.19	0.12	Bdl/JD	D	3/4	1,120.25
AURORA ENERGY LLC	11/13/2014	9	7613	29.14	6.79	35.81	28.27	0.11	Bdl/JD	D	3/4	840.50
AURORA ENERGY LLC	11/14/2014	7	7805	27.58	7.75	36.16	28.52	0.14	Bdl/JD	D	3/4	638.10
AURORA ENERGY LLC	11/17/2014	6	7749	26.36	10.84	34.65	28.16	0.19	GRP/STK		M/N	604.55
AURORA ENERGY LLC	11/18/2014	31	7295	26.35	14.74	33.00	25.91	0.17	GRP/STK		M/N	3,113.25
AURORA ENERGY LLC	11/19/2014	12	7822	25.92	11.05	34.90	28.14	0.17	GRP/Bdl	D	M/3	1,161.75
AURORA ENERGY LLC	11/21/2014	4	7765	27.96	9.54	34.70	27.80	0.14	GRP/JD		M/4	355.30
AURORA ENERGY LLC	11/24/2014	9	7821	29,00	5.59	36.00	29.41	0.11	Bdl/JD	F	3/4	792.50
AURORA ENERGY LLC	11/25/2014	12	7837	28.38	5.94	35.63	30.05	0.10	Bdl/JD	F	3/4	1,101.60
AURORA ENERGY LLC	11/26/2014	13	7636	29.62	6.57	35.03	28.79	0.09	Bdl/JD	D	3/4	1,157.55
AURORA ENERGY LLC	11/28/2014	9	7798	28.82	6.04	35.55	29.58	0.09	Bdl/JD	F	3/4	775.45
AURORA ENERGY LLC	12/1/2014	8	7814	28.53	6.40	35.39	29.68	0.10	Bdl/STK	F	3/N	742.55
AURORA ENERGY LLC	12/2/2014	11	7843	27.99	6.73	35.16	30.13	0.11	Bdl/STK	F	3/N	1,039.75
AURORA ENERGY LLC	12/3/2014	10	7718	28.26	7.17	35.07	29.51	0.10	Bdl/STK	F	3/N	862.65
AURORA ENERGY LLC	12/4/2014	8	7659	27.93	7.94	35.42	28.71	0.10	Bdl/STK	F	3/N	753.20
AURORA ENERGY LLC	12/5/2014	13	7660	27.86	8.23	35.41	28.51	0.12	Bdl/STK	F	3/N	1,222.65
AURORA ENERGY LLC	12/8/2014	11	7399	26.38	12.62	34.16	26.85	0.31	Bdl/STK	G	4/N	1,068.05
AURORA ENERGY LLC	12/9/2014	10	7758	27.16	8.46	35.76	28.61	0.25	Bdl/STK	G	4/N	933.35
AURORA ENERGY LLC	12/10/2014	8	7671	27.12	8.79	35.30	28.79	0.23	Bdl/STK	G	4/N	730.55
AURORA ENERGY LLC	12/11/2014	9	7762	27.40	8.01	35.48	29.12	0.21	Bdl/Bdl	G/F	4/3	846.70
AURORA ENERGY LLC	12/12/2014	14	7657	27.61	8.26	35.28	28.85	0.15	Bdl/STK	F	3/N	1,285.70
AURORA ENERGY LLC	12/15/2014	12	7491	29.18	8.10	35.28	27.44	0.15	Bdl/JD	G	4/4	1,100.15
AURORA ENERGY LLC	12/16/2014	18	7630	28.23	8.32	35.71	27.74	0.19	Bdl/JD	G	4/4	1,705.05
AURORA ENERGY LLC	12/17/2014	8	76 A pp	endix l	II7 D 87.	73 54 24B	628.40	0.16	Bdl/JD	G	4/4	770.15

Rail Samples Analysis Results for 7/1/14 to 12/31/14

	in a search an	*****		*********	190721725310570 //151//10	1		770FFFATURR77561	*****	*****		
AURORA ENERGY LLC	12/18/2014	20	7528	31.48	6.44	34.37	27.71	0.13	JD		4	1,850.00
AURORA ENERGY LLC	12/19/2014	4	7626	28.89	7.57	35.42	28.12	0.15	Bdl/JD	G	4/4	372.05
AURORA ENERGY LLC	12/22/2014	10	7561	28.72	8.34	35.26	27.69	0.18	Bdl/JD	G	4/4	981.45
AURORA ENERGY LLC	12/23/2014	17	7598	28.65	8.05	35.35	27.95	0.18	Bdl/JD	G	4/4	1,535.65
AURORA ENERGY LLC	12/24/2014	12	7563	28.54	8.75	35.22	27.50	0.19	Bdl/JD	G	4/4	1,037.65
AURORA ENERGY LLC	12/26/2014	6	7418	26.62	12.03	34.98	26.37	0.28	Bdl/JD	G	4/4	550.45
AURORA ENERGY LLC	12/29/2014	8	7385	27.89	10.46	34.77	26.89	0.25	Bdl/JD	G	4/4	778.85
AURORA ENERGY LLC	12/30/2014	12	7568	29.02	8.07	34.65	28.26	0.21	Bdl/JD	G	4/4	1,145.15
AURORA ENERGY LLC	12/31/2014	10	7643	29.27	7.21	35.29	28.24	0.18	Bdl/JD	G	4/4	880.85
Weighted Averages Sun	nmary											
Customer		Tons	*****	BTU	۲. ۲	20	Ash		Volatiles	Car	bon	Sulfur
AURORA ENERGY LLC	eannan tan na mar Leonain an Na Stàirt Chùir Containn a	103979.45		7617.00	2	7.86	8.1	67	35.66	2	7.82	0.14

This analysis is representative of the coal shipped using sulfur ASTM D4239-12 $\,$

Colien Thompson 1-5-15

Appendix E (Coal Sulfur Summary)

Adopted

7/1/2015

Usibelli Coal Mine

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 1/1/15 to 6/30/15

Customer	Date	#Cars	BTU	%H20	% A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2015	10	7542	28.10	8.78	35.14	27.98	0.22	Bdl/JD	G	4/4	913.35
AURORA ENERGY LLC	1/5/2015	8	7586	29.30	7.87	34.51	28.33	0.21	Bdl/JD	G	4/4	761.95
AURORA ENERGY LLC	1/6/2015	15	7593	29.68	7.16	34.84	28.32	0.21	Bdl/JD	G	4/4	1,331.30
AURORA ENERGY LLC	1/7/2015	10	7609	29.88	6.82	34.57	28.74	0.19	Bdl/JD	G	4/4	913.10
AURORA ENERGY LLC	1/8/2015	13	7572	27.19	9.58	35.09	28.15	0.24	Bdl/JD	G	4/4	1,217.90
AURORA ENERGY LLC	1/9/2015	13	7658	28.66	7.66	35.64	28.04	0,20	Bdl/JD	G	4/4	1,270.65
AURORA ENERGY LLC	1/12/2015	8	7612	27.19	9.36	35.22	28.24	0.22	Bdl/ ⊤ II	G/LST	4/6	735.75
AURORA ENERGY LLC	1/13/2015	13	7605	27.86	8.81	35.00	28.33	0.21	Bdl/T II	G/LST	4/6	1,249.40
AURORA ENERGY LLC	1/14/2015	30	7355	26.04	12.63	34.27	27.07	0.31	Bdl/STK	G	4/N	2,906.30
AURORA ENERGY LLC	1/14/2015	10	7413	26.77	11.28	34.53	27.42	0.30	Bdl/STK	G	4/N	985.30
AURORA ENERGY LLC	1/19/2015	8	7722	27.69	7.86	35.65	28.80	0.15	BdI/S⊺K	G	4/N	710.60
AURORA ENERGY LLC	1/20/2015	13	7615	28.20	7.93	36.17	27.71	0.15	TII/STK	LST	6/N	1,225.25
AURORA ENERGY LLC	1/21/2015	10	7493	27.67	9.57	36.02	26.75	0.14	ТΙΙ	LST	6	954,30
AURORA ENERGY LLC	1/22/2015	8	7625	27.33	8.98	35.40	28.28	0.22	BdI/STK	G	4/N	778.30
AURORA ENERGY LLC	1/26/2015	9	7635	27.97	7.73	35.95	28.36	0.15	Bdl/T II	F/LST	3/6	835.50
AURORA ENERGY LLC	1/27/2015	7	7516	28.18	8.81	36.32	26.69	0.14	тΠ	LST	6	645.20
AURORA ENERGY LLC	1/28/2015	5	7469	28.31	9.15	36.13	26.41	0.15	тп	LST	6	448,45
AURORA ENERGY LLC	1/29/2015	6	7515	28.38	8.44	36.63	26.56	0.13	тп	LST	6	554.05
AURORA ENERGY LLC	1/29/2015	5	7607	28.03	8.04	36.88	27.05	0.13	тш	LST	6	424.60
AURORA ENERGY LLC	1/30/2015	14	7541	28.33	8.44	37.02	26.22	0.13	тп	LST	6	1,209.20
AURORA ENERGY LLC	2/2/2015	9	7551	28.26	8.55	36.52	26.67	0.14	тіі	LST	6	834.90
AURORA ENERGY LLC	2/3/2015	31	7078	28.44	12.14	34.70	24.73	0.15	Т !!	LST	6	2,869.90
AURORA ENERGY LLC	2/3/2015	11	7036	27.65	12.98	35.06	24.32	0.14	ТΙΙ	LST	6	969.85
AURORA ENERGY LLC	2/4/2015	12	7065	28.03	12.16	34.62	25.20	0.15	ТΙΙ	LST	6	1,138.45
AURORA ENERGY LLC	2/9/2015	9	7620	27.91	7.79	35.30	29.02	0.13	Bdl/JD	F	3/4	742.75
AURORA ENERGY LLC	2/10/2015	14	7917	27.82	5.80	35.90	30.48	0.12	Bdl/JD	F	3/4	1,277.15
AURORA ENERGY LLC	2/11/2015	8	7702	29.02	6.64	35.33	29.02	0.12	Bdl/JD	F	3/4	680.85
AURORA ENERGY LLC	2/12/2015	6	7618	28.59	7.59	35.98	27.84	0.12	Bdl/JD	F	3/4	525.70
AURORA ENERGY LLC	2/13/2015	8	7614	29.50	7.11	35.67	27.72	0.12	Bdl/JD	F	3/4	674.15
AURORA ENERGY LLC	2/16/2015	8	7681 Apj	29.80 pendix I	6.49 II.D.7	35.97 .7-443	27.74 9	0.11	T II/JD	LST	6/4	716.15

Rail Samples Analysis Results for 1/1/15 to 6/30/15

AURORA ENERGY LLC	2/17/2015	10	7645	30.40	6.24	35.65	27.71	0.12	JD		4	871.10
AURORA ENERGY LLC	2/18/2015	9	7411	30.93	6.97	34.84	27.27	0.13	T II/JD	LST	6/4	775.50
AURORA ENERGY LLC	2/19/2015	10	7474	29.85	7.43	36.13	26.59	0.12	JD/T II	LST	4/6	893.10
AURORA ENERGY LLC	2/20/2015	12	7556	30.19	6.65	36.82	26.35	0.12	T II/JD	LST	6/4	1,087.75
AURORA ENERGY LLC	2/23/2015	8	7490	30.65	6.82	35.48	27.06	0.13	T II/JD	LST	6/4	756.30
AURORA ENERGY LLC	2/24/2015	11	7576	29.59	7,24	35.95	27.22	0.14	JD/TII	LST	4/6	975.50
AURORA ENERGY LLC	2/25/2015	11	7551	29.41	7.42	35.92	27.25	0.13	T II/JD	LST	6/4	1,033.85
AURORA ENERGY LLC	2/26/2015	11	7582	29.74	6.75	36.28	27.23	0.12	T II/JD	LST	6/4	1,003.80
AURORA ENERGY LLC	2/27/2015	11	7588	29.97	6.61	36.05	27.37	0.12	TII/JD	LST	6/4	1,039.00
AURORA ENERGY LLC	3/2/2015	8	7571	29.92	6.43	36.02	27.64	0.12	TII/JD	LST	6/4	730.55
AURORA ENERGY LLC	3/3/2015	10	7698	29.84	5.91	36.58	27.67	0.11	TII/JD	LST	6/4	910.05
AURORA ENERGY LLC	3/4/2015	4	7547	30.62	6.34	35.70	27.34	0.11	TII/JD	LST	6/4	356.15
AURORA ENERGY LLC	3/5/2015	10	7705	29.51	6.01	36.35	28.13	0.11	TII/JD	LST	6/4	927.65
AURORA ENERGY LLC	3/6/2015	11	7662	30.66	5.49	36.26	27.60	0.11	TII/JD	LST	6/4	1,032.00
AURORA ENERGY LLC	3/10/2015	6	7505	30.34	6.76	36.30	26.60	0.11	TII/JD	LST	6/4	549.70
AURORA ENERGY LLC	3/11/2015	26	7109	31.44	7.90	34.89	25.76	0.10	TII/JD	LST	6/4	2,416.95
AURORA ENERGY LLC	3/12/2015	7	7483	29.94	7.34	35.71	27.02	0.11	TII/JD	LST	6/4	620.10
AURORA ENERGY LLC	3/16/2015	4	7525	29.76	7.33	35.86	27.05	0.14	TII/JD	LST	6/4	370.10
AURORA ENERGY LLC	3/17/2015	5	7468	30.08	7.36	35.59	26.98	0.11	TII/JD	LST	6/4	463.30
AURORA ENERGY LLC	3/18/2015	12	7545	30.21	6.84	35.43	27.53	0.12	TII/JD	LST	6/4	1,088.95
AURORA ENERGY LLC	3/19/2015	12	7549	29.60	7.58	35.96	26.86	0.14	TII/JD	LST	6/4	1,105.10
AURORA ENERGY LLC	3/20/2015	7	7620	29.93	7.00	36.02	27.06	0.12	TII/JD	LST	6/4	680.20
AURORA ENERGY LLC	3/23/2015	5	7555	29.89	6.88	35.98	27.26	0.12	TII/JD	LST	6/4	453.55
AURORA ENERGY LLC	4/2/2015	7	7727	30.71	5.38	35.08	28.84	0.12	JD		4	641.55
AURORA ENERGY LLC	4/6/2015	10	7763	31.03	4.67	35.18	29.13	0.11	JD		4	908,40
AURORA ENERGY LLC	4/7/2015	12	7826	30.95	4.55	35.57	28.93	0.11	JD		4	1,081.35
AURORA ENERGY LLC	4/8/2015	11	7669	31.37	5.35	34.58	28.71	0.11	JD		4	1,022.50
AURORA ENERGY LLC	4/9/2015	13	7561	31.87	5.36	34.64	28.14	0.12	JD		4	1,161.20
AURORA ENERGY LLC	4/10/2015	7	7759	30.74	5.03	35.70	28.54	0.11	JD		4	660.95
AURORA ENERGY LLC	4/13/2015	9	7711	31.37	4.82	34.74	29.07	0.11	JD		4	798.25
AURORA ENERGY LLC	4/14/2015	12	7710	31.37	4.77	35.27	28.60	0.11	JD		4	1,105.30
AURORA ENERGY LLC	4/20/2015	9	7625 App	30.63 pendix]	5.99 [II.D.7	34.56 .7-444	28.82 0	0.09	JD		4	836.95

7/1/2015 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/15 to 6/30/15

			_	_			_					
AURORA ENERGY LLC	4/21/2015	11	7544	30.03	7.59	33.80	28.58	0.11	JD		4	989.35
AURORA ENERGY LLC	4/22/2015	8	7626	29.64	7.23	34.32	28.81	0.14	Bdi/JD	G	4/4	768.10
AURORA ENERGY LLC	4/27/2015	8	7881	29.30	5.28	35.34	30.09	0.11	JD/Bdl	G	4/3	745.75
AURORA ENERGY LLC	4/28/2015	10	7853	29.01	5.21	35.72	30.06	0.11	Bdl/JD	G	3/4	903.75
AURORA ENERGY LLC	4/29/2015	10	7620	31.74	4.50	35.15	28.61	0.10	JD		4	904.95
AURORA ENERGY LLC	4/30/2015	12	7648	28.84	7.36	34.53	29.28	0.11	Bdl/JD	G	3/4	1,151.95
AURORA ENERGY LLC	5/1/2015	8	7453	31.00	6.78	34.50	27.73	0.10	JD		4	733.95
AURORA ENERGY LLC	5/4/2015	10	7424	31.57	6.35	34.12	27.97	0.12	JD		4	891.35
AURORA ENERGY LLC	5/5/2015	8	7414	31.82	6.59	33.68	27.91	0.11	JD		4	747.95
AURORA ENERGY LLC	5/6/2015	11	7610	30.24	6.28	34.87	28.62	0.11	Bdl/JD	G	3/4	980.55
AURORA ENERGY LLC	5/7/2015	9	7511	31.23	6.16	34.56	28.05	0.11	JD		4	873.00
AURORA ENERGY LLC	5/8/2015	8	7743	29.92	5.94	35.21	28.94	0.12	JD		4	704.65
AURORA ENERGY LLC	5/12/2015	15	7685	29.76	6.46	35.56	28.22	0.11	JD		4	1,411.50
AURORA ENERGY LLC	5/13/2015	15	7530	29.73	7.50	35.02	27.76	0.12	Bdl/JD	G	3/4	1,361.45
AURORA ENERGY LLC	5/14/2015	1	7565	30.33	6.72	34.88	28.08	0.11	JD		4	99.55
AURORA ENERGY LLC	5/18/2015	13	7707	29.87	6.38	35.17	28.58	0.11	JD		4	1,253.45
AURORA ENERGY LLC	5/19/2015	8	7694	30.15	6.19	34.79	28.88	0.11	JD		4	704.35
AURORA ENERGY LLC	5/20/2015	12	7626	30.39	6.33	34.90	28.38	0.12	JD		4	1,155.60
AURORA ENERGY LLC	5/21/2015	12	7494	31.30	6.38	34.44	27.89	0.11	JD		4	1,157.45
AURORA ENERGY LLC	5/23/2015	18	7765	29.51	6.18	35.46	28.85	0.11	JD		4	1,660.70
AURORA ENERGY LLC	5/26/2015	8	7580	29.83	7.16	34.9 9	28.03	0.12	JD		4	732.30
AURORA ENERGY LLC	5/27/2015	14	7685	28.61	7.56	35.32	28.52	0.12	JD		4	1,376.90
AURORA ENERGY LLC	5/28/2015	14	7626	29.63	6.99	34.90	28.48	0.12	JD		4	1,353.00
AURORA ENERGY LLC	5/29/2015	6	7579	30.41	6.82	34.66	28.11	0.13	JD		4	565.25
AURORA ENERGY LLC	6/1/2015	9	7636	30.25	6.18	35.13	28.44	0.12	JD		4	857.75
AURORA ENERGY LLC	6/2/2015	8	7728	31.26	4.72	35.04	28.98	0.12	JD		4	727.00
AURORA ENERGY LLC	6/3/2015	12	7547	31.16	6.51	33.90	28.44	0.12	JD		4	1,199.65
AURORA ENERGY LLC	6/4/2015	13	7792	30.16	5.50	34.95	29.39	0.12	JD		4	1,262.20
AURORA ENERGY LLC	6/5/2015	13	7703	30.94	5.14	35.45	28.48	0.11	JD		4	1,158.10
AURORA ENERGY LLC	6/8/2015	10	7842	30.61	4.60	35.17	29.63	0.11	JD		4	944.15
AURORA ENERGY LLC	6/9/2015	8	7726	30.82	5.57	34.59	29.03	0.12	JD		4	772.90
AURORA ENERGY LLC	6/10/2015	9	7794 Apj	30.29 pendix l	4.94 [II.D.7	35.61 .7-444	29.16 1	0.12	JD		4	865.10

7/1/2015 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/15 to 6/30/15

						_					_	
AURORA ENERGY LLC	6/11/2015	2	7952	29.43	5.92	34.72	29.93	0.12	GRP/STK		M/N	194.00
AURORA ENERGY LLC	6/12/2015	11	7855	28.23	7.74	34.69	29.34	0.14	GRP/STK		M/N	1,098.10
AURORA ENERGY LLC	6/15/2015	10	7900	26.99	8.73	35.33	28.95	0.14	GRP/STK		M/N	996.05
AURORA ENERGY LLC	6/16/2015	6	7887	25.37	10.64	35.26	28.73	0.15	GRP/STK		M/N	588.95
AURORA ENERGY LLC	6/17/2015	29	7528	24.32	14.26	34.44	26.99	0.15	GRP/STK		M/N	2,832.55
AURORA ENERGY LLC	6/17/2015	9	7518	24.53	13.61	35.06	26.81	0.15	GRP/STK		M/N	868.65
AURORA ENERGY LLC	6/22/2015	10	7649	28.27	8.58	35.13	28.03	0.13	JD		4	976.50
AURORA ENERGY LLC	6/23/2015	12	7581	28.39	8.07	34.39	29.15	0.13	Bdl		3	1,185.10
AURORA ENERGY LLC	6/24/2015	9	7885	27.12	7.70	35.35	29.83	0.13	Bdl/STK		6/N	861.60
AURORA ENERGY LLC	6/25/2015	8	7813	27.83	6.96	35.60	29.62	0.11	Bdl/STK	Ĩ	3/N	748.55
AURORA ENERGY LLC	6/26/2015	10	8048	26.19	8.73	35.21	29.87	0.15	GRP/STK		M/N	959.85
AURORA ENERGY LLC	6/29/2015	14	8027	26.68	8.75	34.64	29.93	0.15	GRP/STK		M/N	1,393.95
AURORA ENERGY LLC	6/30/2015	14	7934	27.67	7.69	35.54	29.11	0.14	JD		4	1,330.30
Weighted Averages Sur	nmary											
Customer		Tons		BTU	F	120	Ast		Volatiles	Carbo	n	Sulfur
AURORA ENERGY LLC		103904.8	103904.80 7		2	29.16	7.	65	35.23	27.	96	0.14

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date 7-1-15

Date _________

Thompson Colum

Signature

Appendix E (Coal Sulfur Summary)

1/7/2016 Adopted

Usibelli Coal Mine

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 7/1/15 to 12/31/15

Customer	Date	#Cars	BTU	%H20	%A	%∨	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/2/2015	5	7689	29.31	7.19	35.30	28.21	0.13	Bdl/GRF	• I	3/M	497.30
AURORA ENERGY LLC	7/6/2015	14	7636	28.59	7.92	35.01	28.49	0.15	Bld	Ē	4	1,372.10
AURORA ENERGY LLC	7/7/2015	14	7874	26.58	7.76	36.94	28.71	0.21	Bdl	Ĩ.	4	1,382.00
AURORA ENERGY LLC	7/8/2015	3	7865	26.43	7.83	36.21	29.54	0.21	BLD	1	4	316.65
AURORA ENERGY LLC	7/9/2015	8	7770	26.23	8.84	36.65	28.29	0.23	Bdl	1	4	785.95
AURORA ENERGY LLC	7/10/2015	5	7921	25.95	8.00	36.75	29.31	0.19	Bdl	1	4	508.65
AURORA ENERGY LLC	7/13/2015	10	7931	25.76	7.97	36.81	29.47	0.18	Bdl	Ĭ	4	979.25
AURORA ENERGY LLC	7/14/2015	10	7750	26.64	8.53	36.28	28.56	0.21	Bdl	1	4	954.80
AURORA ENERGY LLC	7/15/2015	10	7867	26.76	7.54	36.58	29.13	0.21	Bdl	1	4	982.35
AURORA ENERGY LLC	7/16/2015	15	7868	26.59	7.56	36.90	28.95	0.21	Bdl	1	4	1,462.70
AURORA ENERGY LLC	7/17/2015	8	7832	26.21	7.83	37.22	28.75	0.22	Bdl	1	4	765.40
AURORA ENERGY LLC	7/20/2015	8	7860	27.03	7.13	36.27	29.58	0.19	Bdl	1	4	766.65
AURORA ENERGY LLC	7/21/2015	9	7694	27.61	7.96	35.51	28.93	0.20	Bdl/STI	< 1	4/N	908.35
AURORA ENERGY LLC	7/22/2015	9	7657	29.32	6.95	35.01	28.72	0.15	JD		4	877.65
AURORA ENERGY LLC	7/23/2015	9	7438	30.33	7.55	34.18	27.95	0.12	JD		4	859.90
AURORA ENERGY LLC	7/24/2015	8	7636	29.50	6.86	35.30	28.35	0.11	JD		4	772.45
AURORA ENERGY LLC	7/27/2015	9	7432	31.12	7.58	33.61	27.70	0.13	JD		4	899.50
AURORA ENERGY LLC	7/28/2015	11	7523	30.83	6.76	34.27	28.14	0.12	JD		4	1,073.20
AURORA ENERGY LLC	7/30/2015	7	7425	30.34	7.77	34.10	27.79	0.14	JD		4	693,90
AURORA ENERGY LLC	7/31/2015	8	7734	27.22	7.93	35.90	28.96	0.22	Bdl/Bd	I 1/1	3/4	724.30
AURORA ENERGY LLC	8/3/2015	9	7654	28.48	7.69	35,42	28.41	0.16	JD		4	867.75
AURORA ENERGY LLC	8/4/2015	10	7670	29.51	6.73	35.20	28.57	0.14	JD		4	937.50
AURORA ENERGY LLC	8/5/2015	12	7566	30.37	6.67	35.07	27.90	0.13	JD		4	999.75
AURORA ENERGY LLC	8/6/2015	11	7279	30.35	9.11	34.22	26.33	0.14	JD		4	1,037.80
AURORA ENERGY LLC	8/7/2015	11	7368	30.17	8.21	34.20	27.42	0.15	Bdl/JD	1	4/4	1,056.30
AURORA ENERGY LLC	8/10/2015	18	7660	29.39	6.76	35.20	28.65	0.15	JD/Bd	1 /1	4/4	1,653.75
AURORA ENERGY LLC	8/12/2015	15	7359	31.58	7.10	33.94	27.40	0.14	JD		4	1,416.85
AURORA ENERGY LLC	8/13/2015	18	7510	30.41	6.79	34.63	28.16	0.17	Bdl/JC		4/4	1,775.95
AURORA ENERGY LLC	8/14/2015	15	7733	27.83	7.35	36.00	28.82	0.14	Bdl	1	4	1,397.60
AURORA ENERGY LLC	8/17/2015	10	7663 App	29.07 Dendix II	7.20 I.D.7.	35.01 7-444	28.73 4	0.13	JD		4	943.65

Rail Samples Analysis Results for 7/1/15 to 12/31/15

		-				_	_	_				
AURORA ENERGY LLC	8/18/2015	13	7658	28.80	7.07	35.38	28.76	0.16	JD		4	1,265.45
AURORA ENERGY LLC	8/20/2015	15	7311	31.47	7.37	33.83	27.33	0.12	Bdl/JD	1/	3/4	1,386.75
AURORA ENERGY LLC	8/22/2015	18	7564	31.72	6.35	34.30	27.63	0.10	JD		4	1,546.75
AURORA ENERGY LLC	8/26/2015	15	7740	28.52	8.85	34.07	28.56	0.17	JD/GRP		4/M	1,471.40
AURORA ENERGY LLC	8/28/2015	3	7642	28.09	8.57	35.40	27.94	0.15	GPR/Bdl		M/6	261.50
AURORA ENERGY LLC	8/31/2015	8	7628	27.35	8.96	36.33	27.37	0.14	Bdl		6	720.95
AURORA ENERGY LLC	9/1/2015	17	7681	27.34	8.39	36.84	27.43	0.13	Bdi		6	1,651.15
AURORA ENERGY LLC	9/2/2015	19	7563	27.07	9.34	36.51	27,09	0.14	Bdl		6	1,898.00
AURORA ENERGY LLC	9/3/2015	27	7665	27.56	8.27	35.87	28.31	0.13	Bdl		6	2,698.95
AURORA ENERGY LLC	9/8/2015	17	7806	27.29	7.46	35.64	29.61	0.13	Bdl/STK	1/	3/N	1,594.85
AURORA ENERGY LLC	9/10/2015	20	7891	26.52	7.77	35.76	29.97	0.14	Bdl/GRP	1/	3/M	1,863.50
AURORA ENERGY LLC	9/11/2015	21	7710	26.65	9.21	35.53	28.61	0.14	Bdl/GRP	1	3/M	1,974.90
AURORA ENERGY LLC	9/15/2015	18	7420	26.03	13.40	33.43	27.10	0.16	Bdl/GRP	Ĭ	3/M	1,735.35
AURORA ENERGY LLC	9/16/2015	17	7697	26.35	10.77	36.32	26.56	0.16	GRP/Bdl		M/6	1,681.25
AURORA ENERGY LLC	9/17/2015	17	7519	26.86	10.99	35.61	26,55	0.16	Bdl/GRP		6/M	1,555.60
AURORA ENERGY LLC	9/22/2015	19	7186	27.11	12.93	34.08	25.88	0.17	Bdl/GRP		6/M	1,877.05
AURORA ENERGY LLC	9/23/2015	18	7544	27.46	9.76	34.45	28.34	0.15	Bdl	į	3	1,812.45
AURORA ENERGY LLC	9/24/2015	6	7573	26.47	10.49	34.19	28.85	0.14	Bdl	3	3	604.35
AURORA ENERGY LLC	9/29/2015	6	7141	28.88	11.36	33.89	25.87	0.15	Bdl/GRP	1	3/M	603.55
AURORA ENERGY LLC	9/30/2015	5	7514	28.44	8.69	34.21	28.66	0.13	Bdl/Bdl	1	3/6	490.85
AURORA ENERGY LLC	10/1/2015	10	7360	29.29	9.35	33.72	27.64	0.14	Bdl/Bdl	Т	3/6	949.70
AURORA ENERGY LLC	10/6/2015	17	7434	28.25	9.47	34.75	27,54	0.14	Bdl		6	1,697.60
AURORA ENERGY LLC	10/7/2015	16	7427	28.14	9.75	33.75	28.48	0.13	Bdl/STK	1	3/N	1,590.90
AURORA ENERGY LLC	10/8/2015	16	7766	28.02	6.97	35.04	29.97	0.14	Bdl/STK	I	3/N	1,550.35
AURORA ENERGY LLC	10/12/2015	12	7509	28.74	8.47	34.02	28.77	0.11	Bdl/JD	1	3/4	1,188.55
AURORA ENERGY LLC	10/13/2015	14	7448	29.46	8.57	34.10	27.88	0.11	Bdl/JD	1	3/4	1,378.00
AURORA ENERGY LLC	10/14/2015	15	7329	31.93	7.28	33.16	27.63	0.11	Bdl/JD	I.	3/4	1,487.05
AURORA ENERGY LLC	10/15/2015	5	7435	31.66	6.81	34.31	27.23	0.11	JD		4	472.55
AURORA ENERGY LLC	10/16/2015	6	7723	31.20	5.10	35.54	28.17	0.11	JD		4	564.80
AURORA ENERGY LLC	10/20/2015	15	7561	31.93	5.92	34.77	27.38	0.11	JD		4	1,442.25
AURORA ENERGY LLC	10/21/2015	14	7609	31.67	5.47	34.54	28.32	0.11	JD		4	1,346.70
AURORA ENERGY LLC	10/22/2015	13	7492 App	32.01 Dendix I	6.01 II.D.7.	34.29 7-444:	27.70 5	0.11	JD		4	1,264.45

.

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/15 to 12/31/15

AURORA ENERGY LLC	10/23/2015	15	7347	32.39	6.71	33.49	27.42	0.12	JD		4	1,492.50
AURORA ENERGY LLC	10/27/2015	9	7404	30.15	8.49	34.36	27.00	0.18	Bdl	J	4	910.80
AURORA ENERGY LLC	10/28/2015	11	7586	30.32	6.73	35.02	27.93	0.14	Bld/JD	J/	4/4	1,018.90
AURORA ENERGY LLC	10/29/2015	9	7861	26.44	7.92	36.05	29.59	0.19	Bdl	J	4	922.55
AURORA ENERGY LLC	10/30/2015	11	7948	26.92	7.00	36.90	29.19	0.17	Bdl	J	4	1,070.45
AURORA ENERGY LLC	11/3/2015	10	7438	27.87	10.34	34.56	27.24	0.28	Bdl/JD	J/	4/4	994.40
AURORA ENERGY LLC	11/4/2015	16	7495	29.67	8.21	34.18	27.95	0.20	Bdl	J	4	1,577.40
AURORA ENERGY LLC	11/5/2015	11	7320	29.67	9.27	33.61	27.46	0.22	Bdl	J	4	1,052.25
AURORA ENERGY LLC	11/6/2015	12	7629	27.60	8.75	35.23	28.42	0.25	Bdl/JD	J/	4/4	1,175.00
AURORA ENERGY LLC	11/10/2015	12	7640	28.50	7.97	35.25	28.29	0.19	Bdl	J	4	1,130.35
AURORA ENERGY LLC	11/11/2015	14	7865	27.22	7.50	35.71	29.58	0.21	Bdł	J	4	1,331.05
AURORA ENERGY LLC	11/12/2015	12	7797	27.25	7.73	35.48	29.54	0.23	Bdl	J	4	1,146.35
AURORA ENERGY LLC	11/13/2015	14	7947	26.11	7.79	36.51	29.60	0.19	Bdl	J	4	1,368.95
AURORA ENERGY LLC	11/17/2015	9	7760	27.53	7.86	35.47	29.14	0.20	Bdi/JD	J/	4/4	848,40
AURORA ENERGY LLC	11/18/2015	11	7705	28.38	7.44	35.64	28.55	0.18	Bdl/JD	J	4/4	1,026.00
AURORA ENERGY LLC	11/19/2015	8	7644	30.78	6.20	34.89	28.13	0.15	Bdl/JD	J	4/4	714.95
AURORA ENERGY LLC	11/20/2015	10	7783	29.27	6.29	35.70	28.73	0.15	JD/Bdl	/J	4/4	863.55
AURORA ENERGY LLC	11/23/2015	11	7793	29.35	6.29	35.57	28.79	0.15	JD		4	1,046.45
AURORA ENERGY LLC	11/24/2015	16	7682	30.62	5.97	34.92	28.49	0,12	JD		4	1,518.80
AURORA ENERGY LLC	11/25/2015	13	7770	29.54	6.19	35.63	28.65	0.14	JD/Bdl	/J	4/4	1,206.80
AURORA ENERGY LLC	11/27/2015	12	7612	28.41	7.98	35.68	27.94	0.19	Bdl/STK	J/	4/N	1,178.80
AURORA ENERGY LLC	12/1/2015	21	7514	29.25	8.35	34.58	27.83	0.20	Bdl/STK	J/	4/N	1,971.15
AURORA ENERGY LLC	12/2/2015	9	7587	30.48	6.72	34.32	28.49	0.16	JD		4	834.10
AURORA ENERGY LLC	12/3/2015	12	7577	32.45	4.74	33.98	28.84	0.10	JD		4	1,097.45
AURORA ENERGY LLC	12/4/2015	10	7503	31.28	6.60	33.78	28.35	0.12	JD		4	915.25
AURORA ENERGY LLC	12/8/2015	13	7594	29.65	7.36	34.53	28.47	0.17	Bdl/JD	J/	4/4	1,204.60
AURORA ENERGY LLC	12/9/2015	13	7627	28.50	8.21	34.71	28.58	0.23	Bdl/JD	J/	4/4	1,254.80
AURORA ENERGY LLC	12/10/2015	12	7651	29.18	7.10	35.18	28.55	0.17	Bdl/JD	J/	4/4	1,090.15
AURORA ENERGY LLC	12/11/2015	10	7159	33.74	6.25	34.17	25.84	0.14	JD		4	935.95
AURORA ENERGY LLC	12/15/2015	14	7591	31.15	5.91	35.16	27.78	0.15	Bdl/JD	J	4/4	1,235.25
AURORA ENERGY LLC	12/16/2015	14	7527	31.73	6.00	35.00	27.27	0.16	Bdl/JD	J	4/4	1,288.80
AURORA ENERGY LLC	12/17/2015	14	7639 App	29.80 endix I	6.85 II.D.7.	35.24 7-444(28.12 6	0.16	Bdl/JD	J	4/4	1,258.85

1/7/2016 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/15 to 12/31/15

								_				
AURORA ENERGY LLC	12/18/2015	14	7571	30.68	6.58	34.72	28.03	0.13	Bdl/JD	J	4/4	1,314.95
AURORA ENERGY LLC	12/21/2015	14	7631	30.24	6.30	35.17	28.29	0.15	Bdl/JD	J	4/4	1,318.90
AURORA ENERGY LLC	12/22/2015	14	7549	31.19	5.71	34.71	28.39	0.13	Bdl/JD	J	4/4	1,250.95
AURORA ENERGY LLC	12/23/2015	14	7686	31.43	4.63	35.27	28.68	0.10	Bdl/JD	J	4/4	1,262.70
AURORA ENERGY LLC	12/24/2015	10	7627	31.52	4.92	35.64	27.93	0.11	Bdl/JD	J	4/4	933.25
AURORA ENERGY LLC	12/28/2015	14	7714	30.71	4.93	36.01	28.36	0.11	Bdl/JD	J	4/4	1,246.45
AURORA ENERGY LLC	12/29/2015	16	7780	30.08	5.31	35.97	28.65	0.12	Bdi/JD	j	4/4	1,424.70
AURORA ENERGY LLC	12/30/2015	11	7673	31.40	5.02	35.64	27.95	0.12	Bdi/JD	J	4/4	968.20
AURORA ENERGY LLC	12/31/2015	12	7705	31.63	4.47	35.57	28.34	0.12	Bdl/JD	J	3/4	1,059.70
Weighted Averages Sum	ema r y											
Customer		Tons		BTU	ŀ	120	Ash	1	Volatiles	Carl	on	Sulfur
AURORA ENERGY LLC		120758.3	0	7610.00	2	29.02	7.	69	35.09	2	8.20	0.15

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239.

Coleen Thompson

1-7-16 nompson Date Coleer

Signature

Appendix E (Coal Sulfur Summary)

7/18/2016

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/16 to 6/30/16 Page 1 of 15

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/5/2016	12	7673	31.18	4.92	35.22	28.68	0.11	Bdl/JD	J	4/4	1,108.40
AURORA ENERGY LLC	1/6/2016	14	7682	32.31	4.20	34.85	28.65	0.11	JD		4	1,247.50
AURORA ENERGY LLC	1/7/2016	14	7643	32.35	3.60	35.28	28.78	0.09	JD		4	1,202.65
AURORA ENERGY LLC	1/8/2016	12	7757	31.14	4.23	36.17	28.47	0.11	JD		4	1,070.90
AURORA ENERGY LLC	1/12/2016	13	7631	32.21	4.40	35.14	28.22	0.11	Bdl/JD	J	4/4	1,200.75
AURORA ENERGY LLC	1/13/2016	18	7628	32.43	4.12	35.32	28,15	0.09	JD		4	1,613.00
AURORA ENERGY LLC	1/14/2016	14	7958	28.18	4.48	37.67	29.68	0.11	JD		4	1,188.40
AURORA ENERGY LLC	1/15/2016	16	7789	31.38	4.12	36.77	27.74	0.11	JD		4	1,385.20
AURORA ENERGY LLC	1/19/2016	18	7765	31.50	4.26	35.37	28.87	0.10	JD		4	1,604.95
AURORA ENERGY LLC	1/20/2016	6 16	7842	31,19	4.24	35.66	28,92	0.12	JD		4	1,439.05
AURORA ENERGY LLC	1/21/2016	5 15	7766	31.45	4.46	35.39	28,71	0.13	JD		4	1,348.85
AURORA ENERGY LLC	1/22/2016	5 22	7741	31.09	4.62	35.72	28.58	0.11	JD		4	1,962.55
AURORA ENERGY LLC	1/26/2016	5 14	7416	32.12	6.10	34.25	27.54	0.13	JD		4	1,350.60
AURORA ENERGY LLC	1/27/2016	5 12	7664	31.19	5.07	35.10	28.65	0.11	Bdl/JD	J	4/4	1,095.55
AURORA ENERGY LLC	1/28/2016	5 11	7741	31.54	4.52	35.16	28,79	0.10	Bdl/JD	ſ	4/4	982.50
AURORA ENERGY LLC	1/29/2016	5 13	7646	31.93	4.34	35.66	28.09	0.10	JD		4	1,140.40
AURORA ENERGY LLC	2/2/2016	12	7569	31,65	5,24	34.87	28.26	0.10	JD/Bdl	/J	4/3	1,088.10
AURORA ENERGY LLC	2/3/2016	13	7695	31.32	4.75	35.02	28.92	0.12	Bdl/JD	J	3/4	1,202.80
AURORA ENERGY LLC	2/4/2016	8	7549	30.72	6.88	34.43	27.98	0.18	Bdl/JD	J	4/4	705.70
AURORA ENERGY LLC	2/5/2016	11	7664	30.92	5.55	35.22	28,31	0,14	JD/Bd	I /J	4/4	998.75
AURORA ENERGY LLC	2/9/2016	14	7572	31.26	6.21	34.69	27.85	0.13	JD		4	1,298.35
AURORA ENERGY LLC	2/10/2016	5 13	7785	29.54	6.19	35.63	28.65	0.15	Bdl/JC) J	4/4	1,191.45
AURORA ENERGY LLC	2/11/2010	5 11	7479	31.97	5.48	34.93	27.63	0.14	Bdl/JC) J	4/4	1,023.95
AURORA ENERGY LLC	2/12/2010	6 15	7576	30.68	5.50	35.74	28.08	0.14	Bdl/JC) J	4/4	1,417.30
AURORA ENERGY LLC	2/16/2010	6 16	7634	30.60	5.38	36.09	27.93	0,14	JD/Bd	I /J	4/4	1,512.75
AURORA ENERGY LLC	2/17/201	6 14	7781	29.69	5.73	35.79	28.79	0.17	Bdl/JC) J	4/4	1,299.10
AURORA ENERGY LLC	2/18/201	6 11	7773	30.32	5.11	35.59	28.99	0.14	Bdl/JE) J	4/4	1,016.45
AURORA ENERGY LLC	2/19/201	6 16	7808	29.51	5.45	36.18	28.86	0.14	JD/Bd	! /J	4/4	1,465.95
AURORA ENERGY LLC	2/23/201	6 21	7926 Appe	29.40 endix III	4.93 .D.7.7	36.36 -4449	29.31	0.14	JD		4	1,903,35

7/18/2016

90

Usibelli Coal Mine

Rail Samples

November 19, 2019

Page 2 of 15

		Anal	ysis Re	sults for	1/1/16	to 6/30/	/16					
AURORA ENERGY LLC	2/24/2016	16	7799	31.52	4.31	35.32	28.85	0.12	Bdl/JD	J	4/4	1,498.15
AURORA ENERGY LLC	2/25/2016	15	7794	31.50	4.13	35.15	29.22	0.10	JD		4	1,324.05
AURORA ENERGY LLC	3/1/2016	12	7806	30.97	4,49	36.14	28.40	0.12	JD		4	1,126.55
AURORA ENERGY LLC	3/2/2016	16	7805	31.54	4,14	35.52	28.80	0.11	JD		4	1,478.45
AURORA ENERGY LLC	3/3/2016	14	7717	32.25	4.14	35.10	28.52	0.11	JD		4	1,295.50
AURORA ENERGY LLC	3/4/2016	16	7828	31.13	4,14	36.06	28,67	0,11	JD		4	1,430.90
AURORA ENERGY LLC	3/8/2016	13	7701	29.55	6.64	34.82	28.99	0.12	JD/Bdl	/J	4/3	1,224.45
AURORA ENERGY LLC	3/9/2016	13	7732	30.28	5.88	34.95	28.89	0.11	JD/Bdl	/J	4/3	1,231.45
AURORA ENERGY LLC	3/15/2016	12	7823	29.23	5.87	35.65	29.26	0.11	JD/Bdl	/J	4/3	1,121.25
AURORA ENERGY LLC	3/16/2016	13	7871	30.17	4.64	35.79	29.39	0.11	JD		4	1,143.60
AURORA ENERGY LLC	3/17/2016	13	7767	28.41	7.14	35.19	29.27	0.12	Bdl/STK	J/	3/	1,222.65
AURORA ENERGY LLC	3/18/2016	14	7766	27.74	7.62	35.37	29.27	0.12	Bdl/STK	J/	3/	1,287.65
AURORA ENERGY LLC	3/22/2016	14	7719	29.44	6.41	35.32	28.84	0.11	Bdi/JD	J/	3/4	1,317.00
AURORA ENERGY LLC	3/23/2016	18	7696	30.24	5.71	34.71	29.36	0.10	Bdl/JD	J	3/4	1,647.95
AURORA ENERGY LLC	3/24/2016	16	7574	32.11	4.93	35.45	27.52	0.10	JD		4	1,413.40
AURORA ENERGY LLC	3/29/2016	12	7716	31.99	4.16	35.71	28.14	0.11	JD		4	1,091.50
AURORA ENERGY LLC	3/30/2016	13	7642	32.31	4.18	35.81	27.70	0.11	JD		4	1,222.60
AURORA ENERGY LLC	3/31/2016	15	7741	31.85	4.24	35.23	28.68	0.11	JD		4	1,385.25
AURORA ENERGY LLC	4/1/2016	12	7723	31.82	4.28	35.95	27.95	0.11	JD		4	1,102.80
AURORA ENERGY LLC	4/5/2016	12	7666	31.80	4.77	35.48	27.95	0.12	JD		4	1,153.20
AURORA ENERGY LLC	4/6/2016	13	7705	31.70	4.66	35.12	28.53	0.12	JD		4	1,206.05
AURORA ENERGY LLC	4/7/2016	12	7602	32.54	4.49	34.80	28.18	0.12	JD		4	1,156.65
AURORA ENERGY LLC	4/8/2016	13	7766	31.23	4.49	36.04	28,25	0.11	JD		4	1,227.00
AURORA ENERGY LLC	4/12/2016	10	7756	31.50	4.66	35.46	28.39	0.12	JD		4	960.30
AURORA ENERGY LLC	4/13/2016	11	7760	31.37	4.62	35.61	28.41	0.12	JD		4	1,069.45
AURORA ENERGY LLC	4/14/2016	9	7733	31.94	4.36	35.32	28.38	0.11	JD		4	854.95
AURORA ENERGY LLC	4/15/2016	9	7768	30.79	4.70	35.74	28.78	0.11	JD		4	839.70
AURORA ENERGY LLC	4/18/2016	12	7810	31.46	4.40	35.85	28.29	0.11	JD		4	1,126.80
AURORA ENERGY LLC	4/19/2016	11	7621	32.18	4.88	34.90	28.05	0.11	JD		4	1,035.05
AURORA ENERGY LLC	4/20/2016	13	7585	32.41	4.90	34.42	28,27	0.10	JD		4	1,274.85

Appendix III.D.7.7-4450

7/18/2016

Usibelli Coal Mine

Page 3 of 15

November 19, 2019

Rail Samples Analysis Results for 1/1/16 to 6/30/16

							-					
AURORA ENERGY LLC	4/21/2016	12	7648	31.78	4.97	34.64	28.61	0,10	JD		4	1,128.20
AURORA ENERGY LLC	4/25/2016	12	7804	30.65	5.06	35.23	29.07	0.11	JD		4	1,120.80
AURORA ENERGY LLC	4/26/2016	10	7794	30.80	4.83	35.24	29.13	0.10	JD		4	1,017.70
AURORA ENERGY LLC	4/27/2016	13	7792	31.50	4.34	35.33	28.84	0.10	JD		4	1,255.45
AURORA ENERGY LLC	4/28/2016	13	7717	31.14	4.83	35.23	28.80	0.11	JD		4	1,284.75
AURORA ENERGY LLC	5/2/2016	12	7733	31.54	4.44	35.22	28,81	0,10	JD		4	1,168.35
AURORA ENERGY LLC	5/3/2016	12	7747	31,52	4.43	35.40	28.66	0,11	JD		4	1,073.35
AURORA ENERGY LLC	5/9/2016	3	7772	30.90	5.16	34.88	29.06	0.13	JD		4	288.15
AURORA ENERGY LLC	5/10/2016	3	7870	29.71	5.13	36.25	28,91	0.12	JD		4	268.35
AURORA ENERGY LLC	5/11/2016	4	7720	33.22	3.17	34.91	28.70	0.08	JD		4	372.65
AURORA ENERGY LLC	5/13/2016	8	7504	33.43	4.57	34.09	27.91	0.10	JD		4	761.40
AURORA ENERGY LLC	5/17/2016	11	7630	32.79	4.33	34.71	28.17	0.10	JD		4	1,084.05
AURORA ENERGY LLC	5/18/2016	11	7466	34.38	4.30	33.98	27,35	0.10	JD/JD		3/4	1,050.25
AURORA ENERGY LLC	5/19/2016	11	7277	32.62	7.83	33.49	26.07	0.13	JD/JD		3/4	1,127.45
AURORA ENERGY LLC	5/20/2016	12	7552	31.48	6.32	34.89	27.32	0.12	JD/JD		3/4	1,176.40
AURORA ENERGY LLC	5/23/2016	14	7661	31,33	5.63	34.90	28.15	0.12	JD/JD		3/4	1,367.20
AURORA ENERGY LLC	5/24/2016	13	7685	31.62	5.34	35.25	27.80	0,12	JD/JD		3/4	1,229,45
AURORA ENERGY LLC	5/25/2016	13	7492	32.88	5.31	34.79	27.03	0.12	JD/JD		3/4	1,237.80
AURORA ENERGY LLC	5/26/2016	10	7627	31.34	5.59	35.37	27.71	0.13	JD/JD		3/4	996.95
AURORA ENERGY LLC	5/31/2016	13	7730	30.85	5.28	36.10	27.77	0.11	JD		4	1,246.35
AURORA ENERGY LLC	6/1/2016	13	7826	30.81	4.68	36.26	28.26	0.10	JD/JD		4/3	1,188.90
AURORA ENERGY LLC	6/2/2016	12	7791	31.02	4.90	35.82	28.26	0.12	JD/JD		3/4	1,073.70
AURORA ENERGY LLC	6/3/2016	14	7647	28.04	8.54	35.38	28.04	0.21	JD/Bdl	/K	3/4	1,360.65
AURORA ENERGY LLC	6/6/2016	13	7411	30.10	8.84	34.34	26.72	0.23	Bdl/JD	к	4/3	1,274.75
AURORA ENERGY LLC	6/7/2016	11	7464	31.52	6.83	34.18	27,47	0,11	Bdl/JD	к	4/3	1,035.45
AURORA ENERGY LLC	6/8/2016	11	7491	30.78	7.37	34.34	27.51	0.14	Bdl/JD	к	4/3	1,040.50
AURORA ENERGY LLC	6/9/2016	10	7613	30.80	6.31	35.15	27.74	0.13	Bdl/JD	к	4/3	993.00
AURORA ENERGY LLC	6/13/2016	12	7632	31.54	5.50	34.94	28.02	0.12	Bdl/JD		4/3	1,190.00
AURORA ENERGY LLC	6/14/2016	12	7599	31.45	5.87	34.93	27.76	0.12	JD/JD		3/4	1,177.30
AURORA ENERGY LLC	6/16/2016	24	7514	32.67	5.39	35.16	26.78	0,12	JD/JD		3/4	2,323.85

Appendix III.D.7.7-4451

Page 4 of 15

November 19, 2019

And a strength

Rail Samples	
Analysis Results for 1/1/16 to 6	5/30/ 1 6

AURORA ENERGY LLC	6/20/2016	16	7606	31.88	5,51	35.05	27.57	0.10	JD/JD		3/4	1,578.60
AURORA ENERGY LLC	6/21/2016	16	7641	31.29	6.01	34.95	27.75	0.12	JD/JD		3/4	1,540.35
AURORA ENERGY LLC	6/23/2016	15	7667	31.90	5.11	34.65	28.35	0.12	JD/JD		3/4	1,438.65
AURORA ENERGY LLC	6/27/2016	12	7480	31.07	6,90	34.53	27.50	0.11	JD/JD		3/4	1,109.05
AURORA ENERGY LLC	6/28/2016	11	7637	31.39	5.94	35.68	27.00	0.12	JD/JD		3/4	1,037.70
AURORA ENERGY LLC	6/29/2016	9	7577	30.69	7.06	35.22	27.03	0.13	JD/JD		3/4	863.15
AURORA ENERGY LLC	6/30/2016	13	7574	31.03	6.80	35.12	27.06	0.13	JD/JD		3/4	1,267.15
Customer Weighted Aver	rage								_			
Customer		Tons		BTU	۲	120	Ash		Volatiles	Cart	oon	Sulfur
AURORA ENERGY LLC		115282.2	0	7683.00	3	31.21	5,:	22	35.30	28	3.29	0.12
Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
EIELSON AFB - DFAS	1/5/2016	9	7520	31.96	5.18	34.80	28.07	0.12	Bdi/JD	J	4/4	840.80
EIELSON AFB - DFAS	1/6/2016	10	7660	32.32	4.25	34.80	28.64	0.11	JD		4	916.40
EIELSON AFB - DFAS	1/7/2016	10	7724	32.29	3.66	35.34	28.72	0.10	JD		4	908.10
EIELSON AFB - DFAS	1/12/2016	10	7633	32.22	4.49	35.25	28.05	0.12	Bdl/JD	J	4/4	927.90
EIELSON AFB - DFAS	1/13/2016	10	7661	32.66	3.66	35,37	28.32	0.08	JD		4	893.05
EIELSON AFB - DFAS	1/14/2016	10	7709	31,71	4.17	35.75	28.37	0.10	JD		4	888,45
EIELSON AFB - DFAS	1/15/2016	10	7778	31.00	4.60	36.33	28.08	0.12	JD		4	909.15
EIELSON AFB - DFAS	1/19/2016	12	7712	31.80	4.38	35.14	28.68	0.10	JD		4	1,071.20
EIELSON AFB - DFAS	1/20/2016	11	7723	32.23	4.18	35.17	28.42	0.12	JD		4	973.20
EIELSON AFB - DFAS	1/21/2016	15	7638	32.53	4.44	34.87	28.17	0.13	JD		4	1,379.00
EIELSON AFB - DFAS	1/22/2016	12	7624	31.93	4.92	35.16	28.00	0.11	JD		4	1,105.20
EIELSON AFB - DFAS	1/26/2016	12	7490	32.32	5.40	34.27	28.01	0.11	JD		4	1,134.75
EIELSON AFB - DFAS	1/27/2016	13	7533	31.49	5.77	34,90	27.85	0.12	Bdl/JD) J	4/4	1,215,95
EIELSON AFB - DFAS	1/28/2016	15	7573	32.67	4.75	34.63	27.96	0.10	Bdl/JD) J	4/4	1,350.75
EIELSON AFB - DFAS	2/2/2016	12	7557	32.09	4.95	35,17	27.80	0.10	JD/Bd	I /J	4/3	1,112.15
EIELSON AFB - DFAS	2/3/2016	12	7717	31.10	5.07	34.90	28.93	0.14	Bdi/JD	L (3/4	1,124.55
EIELSON AFB - DFAS	2/4/2016	13	7624	30.85	5.97	34.68	28.51	0.17	Bdl/JD) J	4/4	1,191.10
EIELSON AFB - DFAS	2/5/2016	12	7616	31.11	5.83	35.41	27.65	0.13	JD/Bd	I /J	4/4	1,132.75

Appendix III.D.7.7-4452

Page 15 of 15

Rail Samples Analysis Results for 1/1/16 to 6/30/16

Customer Weighted Average							
Customer	Tons	BTU	H2O	Ash	Volatiles	Carbon	Sulfur
UNIVERSITY OF ALASKA	31802.70	7662.00	31.27	5.37	35.30	28.06	0.12

Weighted Averages Summary

Customer	Tons	BTU	H2O	Ash	Volatiles	Carbon	Sulfur
AURORA ENERGY LLC	115282.20	7683.00	31.21	5.22	35.30	28.29	0.12
EIELSON AFB - DFAS	80214.85	7611.00	31.53	5.47	34.99	28.02	0.12
FORT WAINWRIGHT ACCOUNTING	126389.60	7620.00	31.49	5.41	35.01	28.08	0.12
OTHER COAL SALES	70008.05	7699.00	29.94	6.15	35.52	28.38	0.13
UNIVERSITY OF ALASKA	31802.70	7662.00	31.27	5.37	35.30	28.06	0,12
Total	423697.4	7651.59	31.15	5.49	35.19	28,17	0.12

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date 7 - 18 - 16

Colum Shompson

Signature

Appendix E (Coal Sulfur Summary)

November 19, 2019 *Page 1 of 3*

Rail Samples Analysis Results for 7/1/16 to 12/31/16

			_	_			_					
Customer	Date	#Cars	BTU	%H20	%A	%∨	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/5/2016	15	7570	30.93	6.78	34.59	27.71	0.13	JD/JD		3/4	1,417.10
AURORA ENERGY LLC	7/6/2016	10	7661	30.50	6.07	35.20	28.23	0.11	JD/JD		3/4	999.55
AURORA ENERGY LLC	7/8/2016	15	7588	31.27	6.06	35.54	27.13	0.11	JD/JD		3/4	1,368.70
AURORA ENERGY LLC	7/11/2016	19	7496	32.08	6.04	34.43	27.45	0.11	JD/JD		3/4	1,782.30
AURORA ENERGY LLC	7/12/2016	14	7507	30.39	7.57	35.14	26.90	0.16	Bdl/JD	к	4/3	1,387.10
AURORA ENERGY LLC	7/14/2016	18	7561	29.88	7.43	35.07	27.62	0.16	Bdl/JD	К/	4/3	1,766.80
AURORA ENERGY LLC	7/18/2016	17	7711	29.16	7.11	35.83	27.90	0.17	JD/Bdl	/K	3/4	1,594.70
AURORA ENERGY LLC	7/19/2016	15	7689	29.26	6.72	35.46	28.56	0.17	Bdl/JD	к	4/3	1,378.10
AURORA ENERGY LLC	7/21/2016	18	7652	29.41	6.98	35.14	28.47	0.17	Bdl/JD	к	4/3	1,724.10
AURORA ENERGY LLC	7/25/2016	12	7689	29.04	7.41	34.83	28.73	0.17	Bd!/JD	к	4/3	1,116.65
AURORA ENERGY LLC	7/26/2016	11	7590	29.91	7.20	34.97	27.92	0.16	Bdl/JD	к	4/3	1,036.20
AURORA ENERGY LLC	7/28/2016	11	7616	29.35	7.50	35.18	27.97	0.18	Bdl/JD	к	4/3	1,042.70
AURORA ENERGY LLC	8/1/2016	14	7596	29.24	8.06	34.84	27.87	0.15	Bdl/JD	к	4/3	1,351.50
AURORA ENERGY LLC	8/2/2016	14	7456	30.31	8.00	34.62	27.08	0.15	Bdl/JD	К/	4/3	1,371.25
AURORA ENERGY LLC	8/4/2016	13	7543	30.45	7.11	34.97	27.47	0.14	Bdl/JD	К	4/3	1,234.55
AURORA ENERGY LLC	8/8/2016	19	7554	29.57	8.13	34.64	27.67	0.15	Bdl/JD	К	4/3	1,829.20
AURORA ENERGY LLC	8/9/2016	17	7555	29.32	8.20	34.99	27.50	0.16	Bdl/JD	K/	4/3	1,727.15
AURORA ENERGY LLC	8/12/2016	17	7518	28.78	8.93	35.37	26.93	0.22	JD/Bd	/K	3/4	1,641.20
AURORA ENERGY LLC	8/15/2016	17	7662	28.43	8,18	35.09	28.30	0.21	Bdl/JD	К	4/3	1,541.00
AURORA ENERGY LLC	8/16/2016	17	7663	29.02	7.89	35.79	27.31	0.18	Bdl/JD	к	4/3	1,617.55
AURORA ENERGY LLC	8/18/2016	16	7544	29.54	7.80	35.74	26.92	0.17	Bdl/JC	к	4/3	1,515.30
AURORA ENERGY LLC	8/23/2016	19	7487	29.32	8.70	36.15	25.83	0.18	Bdl/JC	к	4/3	1,860.65
AURORA ENERGY LLC	8/24/2016	19	7632	29.26	7.19	36.57	26.99	0.16	Bdl/JC) К	4/3	1,808-85
AURORA ENERGY LLC	8/25/2016	18	7590	31.48	5.63	35.08	27.81	0.13	JD/JD	•	4/3	1,682.30
AURORA ENERGY LLC	8/29/2016	19	7289	30.74	9.14	34.44	25.70	0.22	JD/JD	I	4/3	1,838.20
AURORA ENERGY LLC	8/30/2016	18	7582	30.55	6.91	35.46	27.09	0.15	JD/JD)	3/4	1,697.80
AURORA ENERGY LLC	9/2/2016	26	7500	30.40	7.65	35.22	26.74	0.14	JD/JC)	3/4	2,510.75
AURORA ENERGY LLC	9/6/2016	18	7450	32.43	6.09	34.66	26.83	0.12	JD/JC)	- 4/3	1,694.70
AURORA ENERGY LLC	9/7/2016	17	7524	31.76	5.90	35.65	26.70	0.12	JD/Bd	I /K	3/4	1,605.50
AURORA ENERGY LLC	9/8/2016	10	7550 App	30.91 bendix II	6.94 I.D.7.	34.82 7-4455	27.35 5	0.13	JD/Bd	II /K	4/4	953.55

Rail Samples Analysis Results for 7/1/16 to 12/31/16

				_			_					
AURORA ENERGY LLC	9/9/2016	10	7573	30.37	6.68	35.37	27.58	0.12	Bdl/JD	к	4/3	959.50
AURORA ENERGY LLC	9/27/2016	7	7558	29.53	7.77	36.09	26.62	0.14	JD/JD		3/4	660.95
AURORA ENERGY LLC	9/30/2016	18	7663	29.00	7.19	36.55	27.26	0.12	JD/Bdl	/K	3/4	1,783.60
AURORA ENERGY LLC	10/3/2016	24	7551	30.59	7.00	35.86	26.56	0.11	JD/Bdl	/K	3/4	2,244.55
AURORA ENERGY LLC	10/5/2016	28	7514	30.13	7.52	34.79	27.56	0.12	Bdl/JD	к	4/3	2,682.10
AURORA ENERGY LLC	10/10/2016	20	7615	29.98	6.97	35.09	27.97	0.12	Bdl/JD	к	4/3	1,895.45
AURORA ENERGY LLC	10/11/2016	21	7415	29.36	9.27	34.88	26.50	0.12	JD		4	1,974.25
AURORA ENERGY LLC	10/17/2016	14	7725	30.51	5.80	35.47	28.22	0.11	JD		4	1,327.05
AURORA ENERGY LLC	10/18/2016	10	7666	30.86	5.74	35.75	27.65	0.11	JD/JD		3/4	910.90
AURORA ENERGY LLC	10/19/2016	11	7674	30.61	5.79	35.44	28.17	0.10	JD/JD		3/4	940.90
AURORA ENERGY LLC	10/24/2016	12	7760	29.11	6.56	36.37	27.97	0.12	JD/JD		3/4	1,137.45
AURORA ENERGY LLC	10/25/2016	12	7729	29.22	6.51	36.28	27.99	0.12	Bdl		6	1,063.15
AURORA ENERGY LLC	10/26/2016	14	7708	28.38	7.47	36.44	27.71	0.12	Bdl/JD		6/4	1,171.40
AURORA ENERGY LLC	10/27/2016	14	7765	27.43	7.69	37.53	27.36	0.13	Bdl/JD		6/4	1,243.80
AURORA ENERGY LLC	10/31/2016	14	7742	26.38	8.92	37.76	26.94	0.14	Bdl		6	1,220.95
AURORA ENERGY LLC	11/1/2016	15	7705	26.55	9.09	38.27	26.09	0.14	Bdl		6	1,290.10
AURORA ENERGY LLC	11/2/2016	14	7726	26.53	8.80	37.76	26.91	0.14	BdI		6	1,238.05
AURORA ENERGY LLC	11/3/2016	13	7774	26.33	8.55	37.90	27.23	0.14	Bdl		6	1,100.70
AURORA ENERGY LLC	11/7/2016	15	7680	27.17	8.92	37.45	26.47	0.13	Bdl		6	1,346.80
AURORA ENERGY LLC	11/8/2016	15	7646	26.81	9.38	37.93	25.89	0.14	Bdl		6	1,315.35
AURORA ENERGY LLC	11/9/2016	15	7631	27.00	9.17	37.46	26.37	0.14	Bdl		6	1,316.60
AURORA ENERGY LLC	11/10/2016	16	7714	26.75	8.56	37.61	27.09	0.13	Bdl		6	1,394.90
AURORA ENERGY LLC	11/14/2016	16	7658	26.44	9.11	37.77	26.68	0.14	Bdl		6	1,432.15
AURORA ENERGY LLC	11/16/2016	16	7680	27.17	8.40	37.84	26.60	0.14	Bdl		6	1,436.00
AURORA ENERGY LLC	11/17/2016	15	7748	27.26	7.86	37.64	27.24	0.13	Bdl		6	1,320.90
AURORA ENERGY LLC	11/21/2016	16	7710	27.01	8.43	37.84	26.73	0.13	BdI		6	1,456.15
AURORA ENERGY LLC	11/22/2016	19	7751	27.30	8.01	38.35	26.34	0.13	Bdl		6	1,754.65
AURORA ENERGY LLC	11/23/2016	17	7736	27.32	7.92	38.15	26.61	0.13	Bdl		6	1,432.75
AURORA ENERGY LLC	11/28/2016	10	7705	27.45	7.89	37.39	27.28	0.13	Bdl		6	876.20
AURORA ENERGY LLC	11/29/2016	10	7464	27.88	9.89	36.20	26.04	0.13	Bdl		6	923.55
AURORA ENERGY LLC	11/30/2016	10	7586	29.83	6.92	36.51	26.75	0.13	JD		4	881.80
AURORA ENERGY LLC	12/1/2016	11	6899 App	28.06 endix II	14.52 II.D.7.	32.87 7-4456	24.55 5	0.12	Bdl/JD		6/4	913.05

1/11/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/16 to 12/31/16

AURORA ENERGY LLC	12/5/2016	12	7660	30.15	6.54	35.11	28.21	0.15	JD	4	1,048.05
AURORA ENERGY LLC	12/6/2016	12	7635	29.90	6.82	35.74	27.54	0.14	JD	4	1,034.60
AURORA ENERGY LLC	12/7/2016	11	7691	30.39	5.66	35.64	28.32	0.12	Bdl/JD	6/4	934.95
AURORA ENERGY LLC	12/8/2016	12	7684	29.22	7.21	37.06	26.52	0.12	JD	4	1,028.90
AURORA ENERGY LLC	12/12/2016	15	7734	28.36	7.03	36.54	28.08	0.16	JD	4	1,336.05
AURORA ENERGY LLC	12/13/2016	15	7656	27.80	8.19	37.25	26.77	0.14	JD	4	1,297.80
AURORA ENERGY LLC	12/14/2016	15	7683	27.72	7.99	36.90	27.40	0.14	JD	4	1,347.60
AURORA ENERGY LLC	12/15/2016	8	7679	27.93	7.85	36.68	27.55	0.15	JD/Bdl	4/6	735.90
AURORA ENERGY LLC	12/19/2016	18	7626	27.91	8.63	37.07	26.40	0.14	Bdl/JD	6/4	1,625.50
AURORA ENERGY LLC	12/20/2016	23	7529	28.73	8.36	36.18	26.74	0.13	Bdl	6	2,003.15
AURORA ENERGY LLC	12/21/2016	8	7177	33.28	5.98	34.15	26.60	0.11	JD	4	702.25
AURORA ENERGY LLC	12/22/2016	7	7498	30.41	6.92	35.74	26.93	0.13	JD	4	625.90
AURORA ENERGY LLC	12/27/2016	13	7617	30.42	6.60	35.98	27.01	0.12	JD	4	1,202.80
AURORA ENERGY LLC	12/28/2016	13	7774	30.23	5.76	36.52	27.49	0.13	JD/Bdl	4/6	1,132.75
AURORA ENERGY LLC	12/29/2016	14	7656	30.08	6.37	36.50	27.06	0.13	Bdl/JD	6/4	1,242.95
AURORA ENERGY LLC	12/29/2016	4	7427	30.47	7.75	35.36	26.42	0.13	Bdl/JD	6/4	355.05
AURORA ENERGY LLC	12/31/2016	14	7668	27.72	8.27	37.22	26.79	0.14	Bdi/JD	6/4	1,292.45
Weighted Averages Sum	mary										
Customer		Tons		BTU		120	Asl	1	Volatiles	Carbon	Sulfur
AURORA ENERGY LLC		107687.3	35	7604.00		29.23	7	.61	35.99	27.17	0.14

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date ____/-//-/7___

Coleen Thompson

Signature

Appendix E (Coal Sulfur Summary)

7/5/2017

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

November 19, 2019 *Page 1 of 4*

Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench Seam	Tons
AURORA ENERGY LLC	1/3/2017	18	7477	30.01	7.72	36.14	26.13	0.14	JD	4	1,692.15
AURORA ENERGY LLC	1/4/2017	19	7629	29.79	6.61	35.98	27.62	0.14	JD	4	1,625.15
AURORA ENERGY LLC	1/5/2017	19	7546	29.25	7.60	35.83	27.32	0.16	JD/ST	K 4/L	1,722.00
AURORA ENERGY LLC	1/6/2017	19	7556	32.13	5.19	35.58	27.11	0.12	JD	4	1,667.00
AURORA ENERGY LLC	1/10/2017	16	7711	31.53	4.83	35.98	27.66	0.11	JD	4	1,414.60
AURORA ENERGY LLC	1/11/2017	11	7587	32.46	4.80	35.38	27.37	0.12	JD	4	960.60
AURORA ENERGY LLC	1/12/2017	15	7557	32.36	5.01	35.04	27.60	0.12	JD	4	1,360.55
AURORA ENERGY LLC	1/13/2017	10	7657	31.58	5.05	35.99	27.38	0.15	JD	4	911.65
AURORA ENERGY LLC	1/16/2017	11	7484	33.02	5.28	34.59	27.11	0.13	JD	4	953.00
AURORA ENERGY LLC	1/17/2017	7	7796	31.16	4.49	35.71	28.65	0.11	JD	4	560.65
AURORA ENERGY LLC	1/19/2017	8	7453	32.25	5.64	35.11	27.00	0.13	JD	4	622.05
AURORA ENERGY LLC	1/20/2017	7	7517	33.70	4.45	34.77	27.08	0.11	JD	4	636.35
AURORA ENERGY LLC	1/21/2017	14	7599	33.03	4.28	34.94	27.75	0.10	JD	4	1,222.40
AURORA ENERGY LLC	1/23/2017	11	7669	32.37	4.38	35.00	28.26	0.10	JD	4	970.45
AURORA ENERGY LLC	1/24/2017	11	7726	32.24	4.34	35.68	27.75	0.10	JD	4	941.95
AURORA ENERGY LLC	1/25/2017	11	7644	32.08	4.71	35.28	27.94	0.09	JD	4	974.55
AURORA ENERGY LLC	1/26/2017	8	7572	32.05	5.46	34.92	27.57	0.10	JD	4	718.10
AURORA ENERGY LLC	1/27/2017	11	7639	31.03	5.90	36.14	26.94	0.12	JD	4	981.45
AURORA ENERGY LLC	1/30/2017	11	7572	32.29	5.53	35.74	26.45	0.12	JD	4	953.15
AURORA ENERGY LLC	1/31/2017	11	7217	32.88	6.93	34.88	25.31	0.14	JD	4	975.95
AURORA ENERGY LLC	2/1/2017	24	6822	34.48	8.09	32.84	24.60	0.14	JD	4	2,255.10
AURORA ENERGY LLC	2/1/2017	4	7170	33.55	6.67	33.62	26.17	0.13	JD	4	355.30
AURORA ENERGY LLC	2/1/2017	3	7252	33.71	5,99	33.75	26.56	0.13	JD	4	267.25
AURORA ENERGY LLC	2/6/2017	9	7551	32.85	4.86	34.74	27.55	0.12	JD	4	790.05
AURORA ENERGY LLC	2/7/2017	10	7554	33.29	4.68	34.92	27.12	0.11	JD	4	877.60
AURORA ENERGY LLC	2/8/2017	10	7691	32.19	4.46	35.15	28.22	0.11	JD	4	869.65
AURORA ENERGY LLC	2/9/2017	9	7651	32.24	4.61	35.16	28.01	0.12	JD	4	796.00
AURORA ENERGY LLC	2/10/2017	10	7729	31.63	4.62	35.76	28.00	0.11	JD	4	875.35
AURORA ENERGY LLC	2/13/2017	9	7625	32.37	4.69	35.17	2 7.77	0.13	JD	4	790.10
AURORA ENERGY LLC	2/14/2017	8	7567 App	32.56 bendix II	4.97 I.D.7.	35.16 7-4459	27.32	0.11	JD	4	692.50

7/5/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

AURORA ENE	RGY LLC	2/15/2017	10	7634	32.54	4.49	35.36	27.61	0.11	JD	4	869.00
AURORA ENE	RGY LLC	2/16/2017	8	7498	33.04	4.98	35.17	26.82	0.12	JD	4	717.70
AURORA ENE	RGY LLC	2/17/2017	9	7463	33.10	5.10	34.31	27.50	0.12	JD	4	814.60
AURORA ENE	RGY LLC	2/21/2017	8	7588	32.49	4.85	35.18	27.48	0.12	JD	4	701.75
AURORA ENE	RGY LLC	2/22/2017	11	7557	33.17	4.44	34.73	27.66	0.11	JD	4	980.00
AURORA ENE	RGY LLC	2/23/2017	12	7563	32.96	4.14	35.22	27.69	0.10	JD	4	1,045.50
AURORA ENE		2/24/2017	12	7688	32.39	4.22	35.42	27.98	0.11	JD	4	957.20
AURORA ENE	RGY LLC	2/27/2017	14	7690	32.22	4.51	35.99	27.28	0.11	jD	4	1,176.20
AURORA ENE	RGY LLC	3/1/2017	13	7165	33.78	5.52	34.38	26.32	0.11	JD	4	1,197.25
AURORA ENE	ERGY LLC	3/2/2017	12	7074	33.61	5.95	34.70	25.75	0.11	JD	4	1,089.10
AURORA ENE	RGY LLC	3/3/2017	17	7451	31.82	5.88	35.09	27.21	0.11	JD	4	1,454.95
AURORA ENE	RGY LLC	3/6/2017	26	7216	32.35	6.16	35.29	26.19	0.11	JD	4	2,389.10
AURORA ENE	ERGY LLC	3/8/2017	13	7505	31.11	6.36	35.34	27.20	0.12	JD/Bdl	4/6	1,072.30
AURORA ENE	ERGY LLC	3/11/2017	28	7281	33.37	5.39	35.01	26.24	0.12	JD/Bdl	4/6	2,582.40
AURORA ENE	ERGY LLC	3/11/2017	12	7569	32.00	4.79	36.18	27.04	0.10	JD/Bdl	4/6	1,076.05
AURORA ENE	ERGY LLC	3/14/2017	13	7651	31.55	4.89	35.87	27.69	0.11	JD	4	1,119.25
AURORA ENE	ERGY LLC	3/15/2017	15	7583	31.90	5.01	35.77	27.32	0.12	JD	4	1,321.40
AURORA ENE	ERGY LLC	3/20/2017	13	7524	32.29	4.83	35.84	27.04	0.12	JD	4	1,120.40
AURORA ENE	ERGY LLC	3/21/2017	12	7579	32.14	4.66	35.78	27.42	0.12	JD	4	1,035.50
AURORA EN	ERGY LLC	3/22/2017	12	7667	32.19	4.11	35.51	28.20	0.11	JD	4	1,045.35
AURORA EN	ERGY LLC	3/23/2017	14	7595	31.37	5.88	34.77	27.97	0.13	JD/GRP	4/C	1,240.20
AURORA EN	ERGY LLC	3/27/2017	14	7651	31.46	5.35	35.39	27.81	0.13	JD/GRP	4/C	1,246.80
AURORA EN	ERGY LLC	3/28/2017	14	7626	31.21	5.57	34.76	28.47	0.13	JD/GRP	4/M	1,254.00
AURORA ENI	ERGY LLC	3/29/2017	10	7571	31.75	5.59	34.86	27.81	0.13	JD/GRP	4/M	902.05
AURORA ENI	ERGY LLC	3/30/2017	13	7577	31.50	5.45	35.40	27.65	0.12	JD/GRP	4/M	1,119.90
AURORA ENI	ERGY LLC	4/3/2017	13	7646	31.95	4.45	36.24	27.36	0.11	JD	4	1,123.15
AURORA ENI	ERGY LLC	4/4/2017	13	7653	32.13	4.28	36.07	27.52	0.10	JD	4	1,148.05
AURORA ENI	ERGY LLC	4/5/2017	13	7681	31.32	5.21	35.50	27.97	0.13	JD/GRP	4/C	1,164.90
AURORA ENI	ERGY LLC	4/6/2017	8	7615	32.59	4.35	35.95	27.12	0.10	JD	4	726.65
AURORA EN	ERGY LLC	4/10/2017	11	7682	32.21	4.28	37.03	26.49	0.11	JD	4	977.45
AURORA EN	ERGY LLC	4/11/2017	12	7681	31.95	4.39	35.97	27.69	0.10	JD	4	1,085.65
AURORA EN	ERGY LLC	4/12/2017	7	7552 App	endix III	1.D.7.7	- 3 5460	27.60	0.11	JD	4	674.75

7/5/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

		_									
AURORA ENERGY LLC	4/13/2017	11	7385	34.02	4.57	34.56	26.86	0.10	JD	4	1,018.95
AURORA ENERGY LLC	4/18/2017	15	7644	32.05	4.35	36.70	26.91	0.11	JD	4	1,391.00
AURORA ENERGY LLC	4/19/2017	7	7663	31.22	5.39	35.74	27.64	0.13	JD	4	624.95
AURORA ENERGY LLC	4/20/2017	15	7624	32.50	4.35	35.84	27.31	0.11	JD	4	1,314.50
AURORA ENERGY LLC	4/21/2017	17	7590	31.89	4.70	35.91	27.50	0.11	JD	4	1,591.90
AURORA ENERGY LLC	4/24/2017	15	7675	31.63	4.45	36.49	27.44	0.10	JD	4	1,391.90
AURORA ENERGY LLC	4/25/2017	13	7577	33.14	4.06	35.38	27.44	0.11	JD	4	1,272.55
AURORA ENERGY LLC	4/26/2017	9	7592	33.84	3.51	35.03	27.62	0.10	JD	4	894.20
AURORA ENERGY LLC	4/27/2017	8	7621	32.87	3.81	36.16	27.16	0.10	JD	4	775.45
AURORA ENERGY LLC	5/1/2017	7	7734	31.63	4.44	36.23	2 7.71	0.12	JD	4	645.70
AURORA ENERGY LLC	5/2/2017	6	7739	30.89	4.60	36.41	28.10	0.11	JD	4	563.10
AURORA ENERGY LLC	5/3/2017	4	7825	30.98	4.22	36.19	28.62	0.11	JD	4	371.55
AURORA ENERGY LLC	5/8/2017	4	7461	33.26	4.78	35.09	26.88	0.12	JD	4	381.75
AURORA ENERGY LLC	5/9/2017	6	7489	32.64	5.06	34.89	27.42	0.11	JD	4	517.50
AURORA ENERGY LLC	5/11/2017	4	7538	31.86	5.27	35.86	27.02	0.11	JD	4	359.75
AURORA ENERGY LLC	5/15/2017	9	7599	31.85	4.95	36.29	26.91	0.10	JD	4	807.40
AURORA ENERGY LLC	5/16/2017	8	7633	31.97	4.66	36.40	26.98	0.10	JD	4	739.40
AURORA ENERGY LLC	5/17/2017	5	7574	33.83	4.08	34.88	27.20	0.09	JD	4	466.55
AURORA ENERGY LLC	5/18/2017	4	7650	33.31	3.42	35.81	27.47	0.09	JD	4	354.65
AURORA ENERGY LLC	5/19/2017	7	7656	32.09	4.24	35.89	27.79	0.10	JD	4	603.30
AURORA ENERGY LLC	5/22/2017	16	7756	31.40	4.24	36.49	27.87	0.10	JD	4	1,430.45
AURORA ENERGY LLC	5/23/2017	12	7512	33.57	4.17	35.75	26.51	0.13	JD	4	1,090.40
AURORA ENERGY LLC	5/24/2017	12	7669	32.70	3.95	35.99	27.36	0.12	JD	4	1,097.30
AURORA ENERGY LLC	5/26/2017	14	7657	31.91	4.59	36.48	27.02	0.11	JD	4	1,311.30
AURORA ENERGY LLC	5/30/2017	9	7675	31.80	4.72	36.29	27.19	0.11	JD	4	835.35
AURORA ENERGY LLC	5/31/2017	8	7693	31.83	4.71	36.93	26.53	0.11	JD	4	747.65
AURORA ENERGY LLC	6/1/2017	3	7701	31.47	4.41	37.05	27.07	0.10	JD	4	265.40
AURORA ENERGY LLC	6/2/2017	4	7777	31.10	4.13	36.64	28.13	0.10	JD	4	346.30
AURORA ENERGY LLC	6/5/2017	12	7650	32.12	4.55	35.36	27.98	0.10	JD	4	1,061.75
AURORA ENERGY LLC	6/6/2017	13	7594	32.33	4.47	35.40	27.81	0.11	JD	4	1,165.40
AURORA ENERGY LLC	6/8/2017	12	7636	32.08	4.40	35.99	27.53	0.10	JD	4	1,067.80
AURORA ENERGY LLC	6/9/2017	11	7674 Appe	31.80 endix II	4.30 I.D.7.7	36.21 7-4461	27.70	0.11	JD	4	1,011.25

7/5/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

AURORA ENERGY LLC		106040.3	5	7567.00	:	32.20	4.	98	35.56	27.26	0.11
Customer	Ē.	Tons		BTU	ŀ	120	Ash	1	Volatiles	Carbon	Sulfur
Weighted Averages Sum	mary										
AURORA ENERGY LLC	6/29/2017	8	7760	31.78	4.09	36.29	27.85	0.10	JD	4	696.20
AURORA ENERGY LLC	6/28/2017	8	7711	31.90	4.58	36.91	26.61	0.11	JD	4	752.00
AURORA ENERGY LLC	6/27/2017	8	7754	31.81	4.08	36.33	27.78	0.11	JD	4	701.85
AURORA ENERGY LLC	6/26/2017	8	7699	32.23	4.30	35.95	27.52	0.12	JD	4	701.50
AURORA ENERGY LLC	6/23/2017	13	7642	32.79	4.37	35.68	27.17	0.12	JD	4	1,163.90
AURORA ENERGY LLC	6/22/2017	12	7555	33.32	4.39	35.52	26.77	0.12	JD	4	1,083.45
AURORA ENERGY LLC	6/20/2017	12	7714	32.35	4.07	35.98	27.60	0.10	JD	4	1,115.05
AURORA ENERGY LLC	6/19/2017	11	7699	32.34	3.91	36.45	27.31	0.10	JD	4	982.95
AURORA ENERGY LLC	6/16/2017	13	7665	32.28	4.53	35.98	27.21	0.12	JD	4	1,167.30
AURORA ENERGY LLC	6/15/2017	12	7675	31.97	4.75	36.23	27.06	0.12	JD	4	1,093.80
AURORA ENERGY LLC	6/13/2017	13	7682	31.87	4.25	36.35	27.54	0.09	JD	4	1,140.90
AURORA ENERGY LLC	6/12/2017	12	7609	32.30	4.32	36.00	27.38	0.10	JD	4	1,063.85
			_			_	_	_			

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date 7-5-17

Date 7-5-17 Colum hompson

Signature

Appendix E (Coal Sulfur Summary)

Rail Samples Analysis Results for 7/1/17 to 12/31/17

Customer	Date	#Cars	BTU	%H20	%А	%V	%C	%S	Site	Bench S	Seam	Tons
AURORA ENERGY LLC	7/3/2017	12	7517	32.85	4.69	35.25	27.22	Ö.11	JD		4	1,086.15
AURORA ENERGY LLC	7/5/2017	13	7551	33.12	4.11	35.68	27.09	0.11	JD		4	1,188.30
AURORA ENERGY LLC	7/6/2017	13	7595	33.11	4.06	35.63	27.20	0.11	JD		4	1,252.50
AURORA ENERGY LLC	7/7/2017	12	7494	33.16	4.13	35.09	27.62	0.11	JD		4	1,164.50
AURORA ENERGY LLC	7/10/2017	11	7516	34.02	4.15	34.55	27.28	0.10	JD		4	1,011.85
AURORA ENERGY LLC	7/11/2017	12	7258	33.79	5.22	35.08	25.92	0.10	JD		4	1,161.40
AURORA ENERGY LLC	7/13/2017	12	6947	34.61	6.24	34.51	24.64	0.10	JD		4	1,145.45
AURORA ENERGY LLC	7/14/2017	11	6816	34.98	6.18	34.21	24.63	0.11	JD		4	1,072.45
AURORA ENERGY LLC	7/17/2017	12	7074	34.52	5.03	34.87	25.58	0.10	JD		4	1,122.60
AURORA ENERGY LLC	7/18/2017	13	7306	33.58	4.88	35.16	26.38	0.11	JD		4	1,222.85
AURORA ENERGY LLC	7/20/2017	13	7165	33.99	5.19	35.42	25.40	0.10	JD		4	1,243.85
AURORA ENERGY LLC	7/25/2017	9	7331	33.62	4.81	35.34	26.24	0.11	JD		4	853.00
AURORA ENERGY LLC	7/26/2017	8	7372	33.16	4.93	35.34	26.58	0.11	JD		4	766.70
AURORA ENERGY LLC	7/27/2017	9	7444	33.20	4.78	35.50	26.53	0.11	JD		4	862.10
AURORA ENERGY LLC	7/28/2017	8	7326	33.62	5.09	35.23	26.07	0.11	JD		4	772.70
AURORA ENERGY LLC	7/31/2017	12	7067	34.65	5.05	34.54	25.77	0.11	JD		4	1,152.10
AURORA ENERGY LLC	8/1/2017	12	7141	33.99	4.94	34.81	26.27	0.11	JD		4	1,150.10
AURORA ENERGY LLC	8/3/2017	12	7164	33.98	5.14	34.57	26.31	0.11	JD		4	1,147.95
AURORA ENERGY LLC	8/4/2017	12	7286	33.90	4.79	35.05	26.27	0.11	JD		4	1,145.30
AURORA ENERGY LLC	8/7/2017	9	7378	33.17	5.03	34.99	26.81	0.11	JD		4	782.15
AURORA ENERGY LLC	8/10/2017	19	7253	33.46	5.18	35.37	25.99	0.11	JD		4	1,810.35
AURORA ENERGY LLC	8/11/2017	20	7318	33.17	5.03	35.36	26.46	0.12	JD		4	1,908.20
AURORA ENERGY LLC	8/14/2017	11	7460	33.07	4.73	35.90	26.91	0.11	JD		4	1,010.35
AURORA ENERGY LLC	8/15/2017	12	7178	34.62	5.07	34.00	26.32	0.12	JD		4	1,140.70
AURORA ENERGY LLC	8/17/2017	12	7233	35.07	4.27	34.48	26.19	0.11	JD		4	1,118.45
AURORA ENERGY LLC	8/18/2017	11	7230	34.34	4.20	35.09	26.38	0.10	JD		4	1,012.25
AURORA ENERGY LLC	8/21/2017	12	7183	34.66	4.57	34.70	26.08	0.10	JD		4	1,132.10
AURORA ENERGY LLC	8/22/2017	11	6965	35.25	5.44	33.99	25.32	0.11	JD		4	1,063.00
AURORA ENERGY LLC	8/24/2017	13	7340	33.83	4.89	35.51	25.78	0.11	JD		4	1,237.30
AURORA ENERGY LLC	8/25/2017	12	7298 Ap r	33.44 Dendix II	4.79 I.D.7	35.35 . 7-446	26.43 4	0.10	JD		4	1,143.30

Rail Samples Analysis Results for 7/1/17 to 12/31/17

EXAMPLE AND	******		*****	**************************************				A CONTRACTOR OF A CONTRACT			
AURORA ENERGY LLC	8/29/2017	13	7624	32.09	3.98	36.19	27.75	0.09	JD	4	1,160.75
AURORA ENERGY LLC	8/30/2017	12	7693	31.67	4.26	35.95	28.12	0.11	JD	4	1,089.50
AURORA ENERGY LLC	8/31/2017	13	7679	31.66	4.54	36.00	27.81	0.12	JD	4	1,198.20
AURORA ENERGY LLC	9/1/2017	16	7556	31.91	4.68	35.57	27.85	0.10	JD	4	1,489.65
AURORA ENERGY LLC	9/5/2017	15	7539	32.49	4.50	35.78	27.23	0.10	JD	4	1,313.40
AURORA ENERGY LLC	9/6/2017	14	7605	32.58	4.13	35.67	27.62	0.10	JD	4	1,306.00
AURORA ENERGY LLC	9/7/2017	14	7651	32.11	4.32	35.95	27.62	0.09	JD	4	1,299.30
AURORA ENERGY LLC	9/8/2017	10	7585	31.81	4.55	35.94	27.71	0.10	JD	4	909.40
AURORA ENERGY LLC	9/11/2017	13	7579	32.39	4.29	35.79	27.54	0.10	JD	4	1,150.80
AURORA ENERGY LLC	9/12/2017	14	7570	32.66	4.03	35.18	28.14	0.09	JD	4	1,235.95
AURORA ENERGY LLC	9/14/2017	14	7678	31.81	4.31	35.96	27.92	0.10	JD	4	1,318.55
AURORA ENERGY LLC	9/18/2017	9	7664	31.53	4.49	35.95	28.03	0.11	JD	4	813.25
AURORA ENERGY LLC	9/19/2017	10	7672	31.57	4.48	35.65	28.30	0.10	JD	4	900.45
AURORA ENERGY LLC	9/21/2017	10	7631	31.22	4.92	36.67	27.20	0.10	JD	4	922.80
AURORA ENERGY LLC	9/22/2017	9	7661	31.07	5.17	36.47	27.30	0.12	JD	4	832.35
AURORA ENERGY LLC	9/25/2017	14	7589	32.54	4.30	35,50	27.67	0.09	JD	4	1,297.15
AURORA ENERGY LLC	9/26/2017	14	7566	32.73	4.36	35.38	27.54	0.10	JD	4	1,304.80
AURORA ENERGY LLC	9/28/2017	12	7661	32.02	4.42	36.00	27.57	0.11	JD	4	1,105.45
AURORA ENERGY LLC	9/29/2017	8	7647	31.64	4.46	35,89	28.01	0.10	JD	4	747.05
AURORA ENERGY LLC	10/2/2017	9	7605	32.57	4.32	35.30	27.82	0.10	JD	4	844.05
AURORA ENERGY LLC	10/5/2017	9	7616	32.89	4.09	35.23	27.80	0.10	JD	4	818.45
AURORA ENERGY LLC	10/6/2017	8	7615	32.44	4.76	35.48	27.33	0.11	JD	4	735.40
AURORA ENERGY LLC	10/9/2017	17	7741	31.67	4.13	36.41	27.80	0.11	JD	4	1,505.25
AURORA ENERGY LLC	10/12/2017	18	7559	32.46	4.67	35.40	27.48	0.11	JD	4	1,721.25
AURORA ENERGY LLC	10/13/2017	17	7502	33.04	4.45	35.28	27.23	0.11	JD	4	1,610.35
AURORA ENERGY LLC	10/16/2017	16	7505	32.67	4.78	35.05	27.50	0.09	JD	4	1,462.45
AURORA ENERGY LLC	10/19/2017	16	7635	32.62	4.06	35.25	28.08	0.09	JD	4	1,483.05
AURORA ENERGY LLC	10/20/2017	16	7771	30.64	4.79	36.18	28.40	0.11	JD	4	1,506.45
AURORA ENERGY LLC	10/23/2017	11	7512	32.84	4.78	34.95	27.43	0.11	JD	4	1,055.65
AURORA ENERGY LLC	10/24/2017	10	7659	32.80	3.76	35.58	27.85	0.10	ĴD	4	960.95
AURORA ENERGY LLC	10/26/2017	10	7778	31.71	3.93	36.18	28.18	0.11	JD	4	935.50
AURORA ENERGY LLC	10/27/2017	12	76 A pp	endix I	II4 D 77.	73-54846	5 28.56	0.11	JD	4	1,090.80

Rail Samples Analysis Results for 7/1/17 to 12/31/17

	*****	попраконски селонарууч	AND	*****	-	a sin'n'n Albert verste an an source	****	NEWNOASSANICATION			
AURORA ENERGY LLC	10/30/2017	17	7638	31.96	4.43	35.98	27.64	0.10	JD	4	1,583.00
AURORA ENERGY LLC	10/31/2017	15	7737	32.08	3.80	35.41	28.72	0.09	JD	4	1,398.05
AURORA ENERGY LLC	11/2/2017	15	7695	31.20	4.63	36,13	28.04	0.10	JD	4	1,375.15
AURORA ENERGY LLC	11/3/2017	16	7568	31.90	5.28	35.76	27.07	0.10	JD	4	1,498.40
AURORA ENERGY LLC	11/6/2017	17	7608	31.44	5.45	34.85	28.27	0.10	JD	4	1,507.55
AURORA ENERGY LLC	11/7/2017	25	7199	33.84	6.32	33.54	26.31	0.09	JD	4	2,432.20
AURORA ENERGY LLC	11/9/2017	7	7639	32.53	4.28	35.73	27.47	0.08	JD	4	600.95
AURORA ENERGY LLC	11/10/2017	17	7717	30.82	4.79	36.38	28.02	0.09	JD	4	1,518.10
AURORA ENERGY LLC	11/13/2017	6	7373	33.38	5.42	34.41	26.79	0.11	JD	4	560.55
AURORA ENERGY LLC	11/14/2017	7	7599	32.39	4.85	35.41	27.35	0.13	JD	4	677.50
AURORA ENERGY LLC	11/16/2017	9	7624	31.94	4.82	35.41	27.84	0.11	JD	4	820.35
AURORA ENERGY LLC	11/20/2017	11	7626	32.25	4.95	35.18	27.62	0.11	JD	4	995.15
AURORA ENERGY LLC	11/21/2017	12	7635	31.90	4.96	35.51	27.63	0.10	JD	4	1,060.50
AURORA ENERGY LLC	11/22/2017	11	7629	31.87	4.81	35.55	27.77	0.10	JD	4	943.05
AURORA ENERGY LLC	11/24/2017	9	7651	31.86	5.02	35.92	27.20	0.12	JD	4	822.90
AURORA ENERGY LLC	11/27/2017	14	7651	31.89	4.89	35,59	27.65	0.12	JD	4	1,257.20
AURORA ENERGY LLC	11/28/2017	20	7615	31.98	4.99	35.71	27.32	0.12	JD	4	1,793.75
AURORA ENERGY LLC	11/30/2017	21	7709	30.84	5.07	35.82	28.27	0.11	JD	4	1,894.15
AURORA ENERGY LLC	12/1/2017	21	7729	30.82	4.85	35.86	28.47	0.12	JD	4	1,908.30
AURORA ENERGY LLC	12/4/2017	17	7826	30.71	4.58	35.95	28.76	0.11	JD	4	1,546.15
AURORA ENERGY LLC	12/5/2017	17	7744	31.15	4.70	35.94	28.21	0.11	JD	4	1,532.85
AURORA ENERGY LLC	12/7/2017	16	7705	31.63	4.59	36.11	27.68	0.11	JD	4	1,428.20
AURORA ENERGY LLC	12/8/2017	15	7601	32.26	4.91	35.14	27.70	0.11	JD	4	1,388.25
AURORA ENERGY LLC	12/11/2017	15	7797	31.63	3.60	35.87	28.90	0.09	JD	4	1,388.65
AURORA ENERGY LLC	12/12/2017	15	7660	30.94	5.44	36.04	27.59	0.10	JD	4	1,419.85
AURORA ENERGY LLC	12/14/2017	16	7730	30.96	5.02	35.96	28.06	0.10	JD	4	1,446.45
AURORA ENERGY LLC	12/18/2017	13	7651	32.79	3.74	34.77	28.71	0.09	JD	4	1,162.00
AURORA ENERGY LLC	12/19/2017	14	7671	32.52	3.99	35.38	28.13	0.09	JD	4	1,281.55
AURORA ENERGY LLC	12/21/2017	14	7678	32.56	4.03	35.53	27.89	0.08	JD	4	1,276.25
AURORA ENERGY LLC	12/22/2017	13	7713	32.05	3.93	35.61	28.41	0.09	JD	4	1,194.20
AURORA ENERGY LLC	12/26/2017	10	7713	32.68	3.47	35.50	28.34	0.08	JD	4	900.45
AURORA ENERGY LLC	12/27/2017	11	77 A %pp	eridix I	II4 D 27.	73-54346	6 28.38	0.10	JD	4	972.05

Rail Samples Analysis Results for 7/1/17 to 12/31/17

n an		IT IT THE REAL PROPERTY AND IN THE REAL PROPERTY.	477.00000000000000000000000000000000000	*******	*****	*****	*****	0.049.040000000000000000000000000000000	2019/11/2019/11/2019/00/2019/10/2019/2019	NATION OF CONTRACTOR OF CONT	**************************************
AURORA ENERGY LLC	12/28/2017	11	7766	31.21	4.38	35.91	28.51	0.09	JD	4	975.75
AURORA ENERGY LLC	12/29/2017	10	7711	31.41	4.64	35.99	27.96	0.10	JD	4	876.15
Weighted Averages Sum	nary										
Customer		Tons		BTU	H	20	Ash		Volatiles	Carbon	Sulfur
AURORA ENERGY LLC		114440.00	}	7529.00	3	2.52	4.(58	35.45	27.36	0.10

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239.

Ben Ziegman

Ben Ziegman Date: 1/4/18 Ben Clegner Signature
Appendix D (Professional Memos)



November 19, 2019 ENVIRONMENT & HEALTH

MEMO

To From Subject David Fish, Aurora Energy LLC Till Stoeckenius Summary of issues related to SO₂ precursor demonstration for Fairbanks

The Alaska Department of Environmental Conservation (ADEC) is currently developing a State Implementation Plan (SIP) for the Fairbanks North Star Borough serious $PM_{2.5}$ nonattainment area (NAA). Fairbanks was reclassified from a moderate $PM_{2.5}$ NAA to a serious $PM_{2.5}$ NAA in June 2017; the serious area SIP is due by December 2018.

As provided for in 40 CFR 51.1006, states can reduce the regulatory burden of complying with $PM_{2.5}$ NAA requirements in the Clean Air Act by conducting $PM_{2.5}$ precursor demonstrations showing that one or more precursors involved in formation of secondary $PM_{2.5}$ do not significantly contribute to violations of the $PM_{2.5}$ National Ambient Air Quality Standard (NAAQS). The current ADEC draft serious area SIP preparation plan includes precursor demonstrations for ammonia (NH₃), nitrogen oxides (NO_x), and volatile organic compounds (VOCs) which conclude that each of these three precursors do not significantly contribute to nonattainment. ADEC did not perform a precursor demonstration for sulfur dioxide (SO₂).

A draft Best Available Control Technology (BACT) demonstration completed by the ADEC as required by the CAA for serious NAAs identifies dry sorbent injection as BACT for the four major SO₂ sources in the Fairbanks NAA. In recognition of the possibility that the SIP may include a requirement for SO₂ controls on their sources without a clear indication of the potential benefits of such controls for reducing ambient $PM_{2.5}$ concentrations, owners of the four major SO₂ sources in the Fairbanks NAA requested (via Aurora Energy) Ramboll's assistance with evaluating possible approaches to conducting a successful major source SO₂ precursor demonstration for Fairbanks.

In accordance with our letter agreement with Aurora of 18 September, Ramboll performed research and analysis related to an SO_2 precursor demonstration for the Fairbanks 24-hour PM_{2.5} serious nonattainment area (NAA). Ramboll reviewed documents describing data analysis and modeling conducted by ADEC and its contractors for the 2014 Fairbanks moderate area SIP and draft analyses

Date November 15, 2018

Ramboll 7250 Redwood Boulevard Suite 105 Novato, CA 94945 USA

T +1 415 899 0700 F +1 415 899 0707 https://ramboll.com





and plans for developing the serious NAA SIP. This included detailed descriptions of emission inventory development, meteorological and photochemical dispersion modeling methods and related sensitivity analyses, air monitoring data analyses and receptor modeling studies and other related materials. Representatives from Ramboll, Aurora Energy and owners of the other major SO₂ sources located within the Fairbanks NAA, along with ADEC and EPA Region X, participated in a conference call to discuss issues involved in conducting a successful major source SO₂ precursor demonstration. We also had several one-on-one conversations with David Fish of Aurora and Robert Ellerman of EPA Region X. A common theme in these discussions was a significant level of skepticism by ADEC and EPA regarding the likelihood of success in developing an approvable major source SO₂ precursor demonstration for the Fairbanks Serious area SIP given uncertainties about sulfate formation mechanisms under Fairbanks winter conditions. A summary of our findings is provided below.

A key element of a NAA SIP is a demonstration that planned emission reductions will result in attainment of the NAAQS in future years. ADEQ uses a computer model (CMAQ) to carry out this attainment demonstration. CMAQ is a photochemical dispersion model which simulates the transport, dispersion, and chemical transformation of emissions from all sources of $PM_{2.5}$ and $PM_{2.5}$ precursors (NH₃, NO_x, VOC, SO₂) affecting the NAA. In order to complete its work within the available time and resources, ADEC is planning to use the same base year $PM_{2.5}$ episodes (Episode 1: 23 January – 11 February 2008 and Episode 2: 2 – 17 November 2008) and modeling approach for the serious NAA SIP attainment demonstration as were used in the moderate area SIP attainment demonstration. This is despite the limited amount of air quality monitoring data available during these episodes and the fact that air quality conditions in Fairbanks have changed significantly since 2008 due to emission reductions during the intervening years. Monitoring of $PM_{2.5}$ component species was conducted at the State Office Building (SOB) in downtown Fairbanks during the 2008 episodes. These data were used in the moderate area SIP to evaluate the ability of CMAQ to accurately reproduce the observed concentrations of $PM_{2.5}$ and its component species.

As shown in Table 1, comparisons of CMAQ predicted PM_{2.5} with observed PM_{2.5} showed over prediction of organic carbon (OC) and elemental carbon (EC) and under predictions of other PM species, including sulfate (SO₄). These over and underpredictions fortuitously balanced each other out, resulting in an apparently accurate prediction of PM_{2.5} total mass. The prediction errors for individual PM species may be the result of an inaccurate emissions inventory or errors in CMAQ (or in the WRF model used to provide meteorological inputs to CMAQ). Of particular note is that CMAQ predicted very little in situ formation of sulfate from SO₂ emissions due to the lack of available oxidizing agents in the model. In technical documents prepared for the Fairbanks moderate area PM_{2.5} SIP, ADEC concluded that CMAQ is under predicting the amount of secondary sulfate formation under the unique Fairbanks winter conditions due to some unknown SO₂ oxidation pathway.



Species	Observed (µg/m³)	Predicted (µg/m³)	Bias (%)
PM _{2.5} (total)	36.1	35.7	-1%
OC	17.0	24.5	44%
EC	2.3	4.3	87%
SO ₄	6.2	2.1	-66%
NO ₃	1.6	1.3	-19%
NH ₄	3.1	1.2	-61%
отн	6.3	2.3	-63%

Table 1. Comparison of observed and predicted PM species concentrations at State Office Building monitoring site (average over days with FRM measurements in both 2008 episodes).

Source: Addressing the precursor gases for Fairbanks PM_{2.5} State Implementation Plan. D. Huff, Alaska Department of Environmental Conservation, 25 September 2014, in Reasonably Available Control Measure (RACM) Analysis (Appendix III.D.5.7 to the Fairbanks PM_{2.5} Moderate State Implementation Plan).

In accordance with EPA's precursor demonstration guidelines, a successful precursor demonstration (in this case for SO₂) must show that SO₂ emissions do not contribute significantly to violations of the PM_{2.5} NAAQS. More specifically, for a major source SO₂ precursor demonstration, the guidance requires a demonstration that eliminating SO₂ emission from all major sources within the NAA would not lower PM_{2.5} concentrations by more than an insignificant amount (defined in the guidance as an amount not exceeding 1.5 μ g/m³).¹ If this "contribution-based" analysis indicates that the impact of major source SO₂ emissions on PM_{2.5} exceeds 1.5 μ g/m³, then a "sensitivity-based" analysis may be conducted to show that a reduction of SO₂ emissions in the range of 30 – 70% would have only an insignificant impact on lowering PM_{2.5} (also defined as an impact of less than 1.5 μ g/m³).

The primary obstacle to conducting a credible SO_2 precursor demonstration for Fairbanks cited by ADEC and EPA results from a combination of two facts:

- 1. the relatively large contribution of sulfate to total $PM_{2.5}$ mass (approximately 17-18% at the SOB) which results in an ammonium sulfate contribution to $PM_{2.5}$ design value² that is well in excess of the "insignificant" concentration threshold (1.5 µg/m³) cited in EPA's precursor demonstration guidance document and which thus implicates the combined impact of major and minor SO₂ sources as significant contributors to peak PM_{2.5} levels; and
- 2. the large under prediction of sulfate mass by CMAQ for the 2008 episodes (normalized mean bias of -66%)³ which leads to the conclusion that the current modeling system (consisting of CMAQ and the emissions estimates and meteorological modeling results used as inputs to CMAQ) does not accurately characterize the contributions of SO₂ sources to the PM_{2.5} design value.

In other words, SO_2 sources are observed to contribute significantly to $PM_{2.5}$ nonattainment and the current modeling system is not sufficiently accurate to provide a reliable estimate of the impacts of emission reductions from SO_2 sources. This makes it difficult to develop a precursor attainment

 $^{^{1}}$ While the 2016 guidance document recommends using 1.3 µg/m3, EPA recently updated and finalized the technical basis document used to set the recommended level and revised the significance threshold to 1.5 µg/m3.

² The design value is the pollutant concentration that is compared to the level of the NAAQS. For the 24-hour PM_{2.5} NAAQS, the design value is the annual 98th percentile daily average concentration averaged over three years.

³ "Addressing the precursor gases for Fairbanks PM_{2.5} State Implementation Plan", D. Huff 9/25/14, Table 1 (p. 125) in Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7.

Adopted



demonstration for major sources of SO_2 based on the current data and modeling system that otherwise would be considered sufficiently reliable to gain approval by EPA. We note that this also brings into question the reliability of a modeled attainment demonstration that includes SO_2 controls on major sources.

Despite the difficulties noted above with formulating an approvable major source SO_2 precursor demonstration, data analyses and modeling conducted for the Fairbanks moderate area SIP^4 provide some significant information which suggests that in fact major source SO_2 emissions may not contribute significantly to $PM_{2.5}$ nonattainment. We summarize these key results below:

- Analysis of CMAQ model results by UAF show almost no secondary SO₄ production during the modeled periods. Thus, nearly all of the modeled SO₄ is from primary SO₄ emissions.
- CMAQ underpredicted the SO₄ concentration at the SOB by an average of 3.22 µg/m³ on days with FRM measurements during the 2008 winter episodes (the average observed SO₄ was 5.25 µg/m³ while the average predicted SO₄ was 2.03 µg/m³; note that these values are taken from Table 2 of *Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7* and differ slightly from the values in Table 1; we are still trying to determine the reason for these small differences).⁵
- ADEC concluded that there is likely sufficient excess NH₄ present under episode conditions so that reductions of secondary SO₄ would not lead to significant increases in other secondary species such as ammonium nitrate.⁶
- Both CMAQ point source SO₂ "zero out" runs in which results from the base case CMAQ run are compared with a CMAQ run in which point source SO₂ emissions are reduced to zero and CALPUFF model runs show that point sources contribute approximately 22% of the total modeled SO₂ from all sources at the SOB monitor with nearly all of the remaining SO₂ coming from heating oil combustion.
 ⁷ Note that the modeled point sources consist of the six major SO₂ sources in the nonattainment area.
- CMAQ zero out runs also show that 5% of primary SO₄ is from point sources. The CMAQ SO₄ prediction at SOB is 2.1 μ g/m³ (Table 1) so the modeled point source primary SO₄ contribution is no more than 0.05 * 2.1 = 0.1 μ g/m³.
- Comparisons of total PM_{2.5} mass concentration to the NAAQS are made using data from a Federal Reference Method (FRM) monitor. However, PM_{2.5} species composition data are obtained from a SASS sampler. PM_{2.5} measurements from these two different monitoring methods are not directly comparable due to various unavoidable sampling artifacts. In accordance with EPA guideline procedures, ADEC applied adjustments to the PM_{2.5} species composition data from the SASS sampler at the SOB using the SANDWICH algorithm to more accurately reflect the composition of PM_{2.5} samples collected by the FRM monitor. These adjustments account for differences in the amount of nitrate, ammonium, carbon, other primary PM_{2.5} components (OPP), and particle bound water (PBW) captured by the two instruments.
- For purposes of developing the moderate area SIP, ADEC used the available ambient monitoring data processed through the SANDWICH algorithm to develop a "design day" PM_{2.5} composition representative of the average composition of PM_{2.5} during high wintertime PM_{2.5} episodes. ADEC also calculated the applicable PM_{2.5} "design value" which represents the PM_{2.5} total mass concentration that is compared to the level of the NAAQS. For the moderate area SIP, the PM_{2.5} design value at the

⁴ <u>https://dec.alaska.gov/air/anpms/communities/fbks-pm2-5-moderate-sip</u>

⁵ See Table 2, p. 129 in Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7

⁶ Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7, p. 131.

⁷ Note that the CALPUFF point source modeling showed that on average only 0.1% of modeled point source SO₂ at SOB during the during Jan. 23rd – Feb 9th 2008 episode days was from the Flint Hills refinery, whereas 36% was from the four power plants and 64% from Ft. Wainwright.

Adopted





SOB site was determined to be 44.7 μ g/m³. Applying the design day composition to the design value results in the design day PM_{2.5} component concentrations shown in Figure 1.

Figure 1. Design day PM_{2.5} speciation at SOB used for the moderate area SIP (source: Appendix III.5.7, p. 122).

- For the design day, the 0.1 μ g/m³ primary sulfate contribution from point sources estimated from the CMAQ zero-out runs noted above scales up to 0.16 μ g/m³ (= 0.1 * 8.17/5.25) where 8.17 μ g/m³ is the amount of SO₄ on the design day and 5.25 μ g/m³ is the average observed amount of SO₄ for the modeled episodes.
- The design day PM composition shown in Figure 1 includes 8.17 μ g/m³ SO₄. The correspondingly scaled SO₄ that is unaccounted for in the CMAQ results is 3.22 * (8.17/5.25) = 5.01 μ g/m³. At one extreme, all of this "unexplained" SO₄ could be attributed to emissions from point sources (i.e., the major SO₂ sources). Perhaps more realistically, one could estimate that 22% of the unexplained SO₄ (0.22 * 5.01 = 1.1 μ g/m³) is from point sources, in keeping with the modeled 22% contribution of point sources to SO₂ noted above. Assuming all SO₄ is in the form of ammonium sulfate, this would be equivalent to a 1.1 * (132/96) = 1.51 μ g/m³ contribution to PM_{2.5}, where the factor 132/96 represents the molecular weight ratio of ammonium sulfate to sulfate. Adding to this the amount of particle bound water (PBW) associated with ammonium sulfate assumed in the SANDWICH estimate of FRM measurement (2/3 * 2.70 μ g/m³ = 1.80 μ g/m³ assumed to be associated with 8.17 μ g/m³ of SO₄ so 1.1 μ g/m³ * (1.80/8.17) = 0.24 μ g/m³ of PBW associated with the point source SO₄) results in a total point source ammonium sulfate with associated PBW contribution of 1.51 + 0.24 = 1.75 μ g/m³.
- The above simple "contribution-based" precursor demonstration result indicates that the major source SO₂ contribution is slightly above the "insignificant contribution" threshold (1.5 μ g/m³) cited



in EPA's Precursor Demonstration Guidance. <u>However</u>, the EPA guidance allows for a "sensitivitybased" precursor demonstration in which the reduction in $PM_{2.5}$ concentration resulting from a 30, 50, or 70% reduction in SO₂ emissions is compared to the 1.5 µg/m³ significance threshold. Based on a linear extrapolation from the above analysis, a maximum 70% reduction in <u>major source</u> SO₂ emissions would be expected to produce a 1.23 µg/m³ decrease in PM_{2.5}, which is below the 1.5 µg/m³ significance threshold. In other words, the PM_{2.5} design value is relatively insensitive to even a large (70%) reduction in major source SO₂ emissions.

Although the above result for a sensitivity-based SO_2 precursor demonstration is encouraging, it must be noted that the precursor demonstration guideline suggests that ADEC may still need to include consideration of the feasibility of major source SO_2 reduction measures in its SIP, even if the sensitivitybased demonstration produces a result below the significance threshold. This may be particularly important for Fairbanks given uncertainties about the amount of SO_4 actually contributed by the major sources.

It is also important to keep in mind that conditions have changed in Fairbanks since 2008 and the new Serious area SIP will use a base year of 2013 to represent "current conditions". Updated area source emissions will be modeled but episodic point source emissions will be based on the 2008 point source inventory. Modeling results are not yet available, so it is not possible to know how the above results might differ for the new base year.



Proposed BACT Alternative

November 19, 2018

Submitted by David Fish Environmental Manager, Aurora Energy <u>dfish@usibelli.com</u> (907) 457-0230

Appendix III.D.7.7-4475

TABLE OF CONTENTS

1.0 Introduction 1.1 ADEC BACT Analysis 1.2 Aurora BACT Analysis 2.0 Economic Infeasibility 3.0 Proposed Alternative BACT – District Heating 3.1 District Heating 3.2 District Heating Expansion 3.3 District Heating Economics 3.4 Output Based Emission 4.0 Proposed Alternative BACT - Firewood Drying Kiln 4.1 Equivalent Emissions 4.2 Firewood Kiln Economics 5.0 Proposed Alternative BACT - Biomass Co-Firing 5.1 Biomass Economics 6.0 Proposed Alternative BACT – Reduction in Potential to Emit 7.0 Precursor Demonstration 8.0 Conclusion Appendix A (Economic Analysis Spreadsheets – V1) Appendix B (Economic Analysis Spreadsheets – V2)

Appendix C (Coal Analyses Summary)

Appendix D (Professional Memos)

1.0 Introduction

The Fairbanks North Star Borough (FNSB) has levels of fine particulate matter (PM_{2.5}) that are above the health based National Ambient Air Quality Standard (NAAQS). In November 2009 the area was designated as a Moderate Nonattainment Area (NAA) based on monitoring data indicating the area did not meet the 2006 24-hour PM_{2.5} standard. On April 28, 2017, the area was re-designated as a "Serious" NAA as a result of not attaining the PM_{2.5} standard within 5-years from designation. As a result, the state is required to propose additional measures to bring the area into compliance within 10-years from designation (i.e., December 2019).

Once EPA re-classified the FNSB $PM_{2.5}$ nonattainment area to Serious, it triggered the requirement for stationary sources with over 70 tons per year (tpy) potential to emit (PTE) for $PM_{2.5}$ or its precursors (SO₂, NO_x, VOC, & NH₃) to conduct a Best Available Control Technology (BACT) analysis. Based on the Alaska Department of Environmental Conservation (ADEC) preliminary evaluations, sulfur dioxides are being evaluated for point source control measures under BACT. At this time, ADEC is considering one control measure per major stationary source to meet BACT and Most Stringent Measures (MSM) for sulfur dioxide (SO2) control. Preliminary Determinations by ADEC suggest a capital cost to Aurora Energy, LLC (Aurora) for BACT compliance of \$12,332,076 for an 80% removal efficiency using dry sorbent injection.

Aurora asserts that the proposed Best Available Control Technologies for sulfur dioxide emissions are not economically feasible. Confronted with this fact, ADEC and the EPA have asked Aurora to suggest an alternative to the ADEC proposed BACT. Within the context of this document Aurora is providing a proposal for alternative BACTs, all of which mitigate Aurora's impact to the nonattainment area problem.

The alternative BACTs proposed by Aurora provide meaningful solutions in offsetting the largest contributing factor to the PM_{2.5} problem in Fairbanks: home heating. The alternative BACTs being proposed by Aurora are more efficient from a dollar per ton of pollutant removed than the ADEC proposed BACT. Aurora strongly believes that these alternatives can have a more positive impact to the air quality issue than the ADEC proposed BACT. Before implementing these alternative BACTs, Aurora needs ADEC and EPA to agree that these alternative BACTs satisfy Aurora's obligations for compliance with the NAA issue and that future controls to address PM_{2.5} in the NAA will not be required.

Additionally, Aurora is making this alternative proposal based on the premise that ADEC and EPA will consider a precursor demonstration to determine the actual contribution of PM_{2.5} by the point sources in the NAA. It has been stated repeatedly that the point sources are not the primary cause of the PM_{2.5} problem. However there has never been a thorough analysis done to understand to what extent the point sources are or are not contributing to the problem. Should a precursor demonstration show that the point sources within the NAA are not major contributors to the PM_{2.5} problem, all PM_{2.5} compliance requirements imposed on the point sources shall be vacated. If however the precursor demonstration shows that the point sources are above the insignificance threshold, the alternative BACTs proposed by Aurora would satisfy the requirements for compliance within the NAA.

In closing, Aurora desires to be a part of the solution to reduce the $PM_{2.5}$ levels within the NAA. Aurora remains convinced that the ADEC proposed BACT is cost prohibitive and an inefficient use of funds. Instead Aurora is proposing alternative BACTs that directly help solve the PM2.5 problem. In proposing these alternatives, Aurora needs ADEC and the EPA to agree to continue to study the source of PM2.5

pollution as well as confirm that these alternative BACTs meet Aurora's compliance with the Clean Air Act for purposes of NAA attainment.

1.1 ADEC BACT Analysis

ADEC provided its review of a BACT analysis for Aurora which included an evaluation of technologies to mitigate emissions of oxides of nitrogen (NOx) and sulfur dioxide (SO₂) emissions, which are precursor pollutants that can form PM_{2.5} in the atmosphere post combustion. The BACT analysis evaluated all available control options for equipment emitting the triggered pollutants and followed a process for selecting the best option based on feasibility, economics, energy, and other impacts. The results of the BACT analysis are reflected in Table 1.

Technology	Pollutant	Capital Cost	Annualized Cost	Cost Effectiveness	
		(\$)	(ə/year)	(\$/1011)	
Selective Non-Catalytic Reduction (SNCR) ¹	NOx	\$ 3,930,809.00	\$ 957,728.00	\$ 2,226.00	
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 17,331,770.00	\$ 2,787,995.00	\$ 3,240.00	
Dry Sorbent Injection (DSI) ²	SO ₂	\$ 12,332,076.00	\$ 4,284,104.00	\$ 6,308.00	
Spray Dry Absorber (SDA) ²	SO ₂	\$ 60,270,115.00	\$ 11,862,577.00	\$ 15,525.00	
Wet Scrubber (WS) ²	SO ₂	\$ 65,957,875.00	\$ 12,160,961.00	\$ 14,469.00	

Table 1: Department Economic Analysis for Technically Feasible NOx and SO₂ controls.

1 - Capital Recovery Factor = 0.094 (7% interest rate for a 20 year equipment life)

2 - Capital Recovery Factor = 0.1098 (7% interest rate for a 15 year equipment life)

1.2 Aurora BACT Analysis

The ADEC requested additional information concerning Aurora's BACT analysis in a letter dated September 13, 2018. One of the ADEC's request were that Aurora comment on the cost analysis spreadsheets developed by ADEC and provided with the Preliminary Draft SIP. Comments were made on the spreadsheets and submitted to the ADEC on November 1, 2018. Below (Table 2) are the results of Aurora's inputs considering EPA and ADEC's comments. Spreadsheets are included along with this proposal for review by the agencies. Several changes to the inputs are documented in the summary for the spreadsheet inputs (See Appendix A & B). In conjunction with the changes made to the spreadsheets, sitespecific quote for SO₂ controls, namely Dry Sorbent Injection (DSI), was provided to the ADEC as requested and included as a parameter within the cost analysis spreadsheets for the referenced control technologies. The EPA is requiring that the cost analyses include a 30 year equipment life for the control technologies except SNCR which is evaluated for 20 year equipment life.

Table 2: Adjustment of ADEC Economic Analysis for Technically Feasible NOx and SO₂ Controls – V.1

Technology	Pollutant	Capital Cost (\$)	Annualized Cost (\$/year)	Cost Effectiveness (\$/ton)
Selective Non-Catalytic Reduction (SNCR) ²	NOx	\$ 6,208,948.00	\$ 989,197.00	\$ 3,107.00
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 25,758,941.00	\$ 2,921,054.00	\$ 4,587.00
Dry Sorbent Injection (DSI) ¹	SO_2	\$ 20,682,000.00	\$ 4,601,940.00	\$ 8,423.00
Spray Dry Absorber (SDA) ¹	SO_2	\$ 51,115,267.00	\$ 8,716,232.00	\$ 12,408.00
Wet Scrubber (WS) ^{1,3}	SO_2	\$ 56,318,290.00	\$ 8,839,892.00	\$ 11,440.00

1 - Capital Recovery Factor = 0.0669 (5.25% interest rate for a 30 year equipment life) [EPA requirement per comments]

2 - Capital Recovery Factor = 0.0820 (5.25% interest rate for a 20 year equipment life) [EPA requirement per comments]

3 - Does not include costs associated with building and maintaining a wastewater treatment facility. [Notation from ADEC spreadsheet]

Table 3 reflects another iteration (V.2) of Aurora's changes to the ADEC's spreadsheets. The results in Table 3 consider a lower emission rate for both SO₂ and NO_x based on 2011 source testing information and/or additional information. The SO_2 emission rate assumed by the state and Aurora has been 0.39 lbs/MMBtu. The coal analysis for feed coal during the test showed elevated sulfur content (0.18%) in comparison to the 5-year weighted average sulfur content from 2013-2017 (0.14 %). Using a conservative conversion from sulfur content (0.14%) to sulfur dioxide, the 5-year weighted average SO_2 emission rate would be 0.36 lbs/MMBtu. This conservative emission rate was used in the calculations to derive the cost effectiveness values in Table 2. The sulfur content during the source test conducted in 2011 (0.18%) when converted to a heat input emission rate considering total conversion of sulfur to SO₂ yields an emission factor of 0.48 lbs/MMBtu. The actual tested emission rate was 0.40 lbs/MMBtu. The emission rate for SO_2 was 83% of the maximum potential. This suggests there is 17% capture of sulfur compounds in the ash. As such, the emission rate derived and used in Table 3, considers a 17% capture of sulfur in the ash. The conversion of sulfur to SO₂ based on the 5-year weighted average sulfur content in coal and a 17% capture rate yields 0.30 lbs/MMBtu (0.36 lbs/MMBtu X 0.834 = 0.30 lbs/MMBtu). The results in Table 3 account for the current sulfur content in coal and the rate adjustment for sulfur capture fraction from the process based on a source test conducted in 2011.

Also accounted for in Table 3 is a more realistic equipment life expectancy for the facility and control equipment. It is not reasonable to consider a 30 year and 20 year life expectancy for the control equipment and the boilers. Considering the age of the Chena Power Plant, Units 1-3 are 50,000 lb/hr boilers that were installed in the early 1950s, and Unit 5 is a 200,000 lb/hr boiler which was installed in 1970. Units 1-3 are already +65 years and Unit 5 is +45 years old. A 30 year horizon should not be applicable to the Chena Power Plant. A 15 year equipment life is considered in the following cost effectiveness analysis (Table 3).

	- ····· - ··· J ····· ···· - ·						
Technology	Pollutant	Capital Cost (\$)	Annualized Cost (\$/year)	Cost Effectiveness (\$/ton)			
Selective Non-Catalytic Reduction (SNCR) ¹	NOx	\$ 6,208,948.00	\$ 1,088,694.00	\$ 3,419.00			
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 25,758,941.00	\$ 3,721,132.00	\$ 5,844.00			
Dry Sorbent Injection (DSI) ¹	SO ₂	\$ 20,682,000.00	\$ 4,914,480.00	\$ 10,785.00			
Spray Dry Absorber (SDA) ¹	SO ₂	\$ 50,880,540.00	\$ 10,084,456.00	\$ 17,213.00			
Wet Scrubber (WS) ^{1,2}	SO_2	\$ 56,318,290.00	\$ 10,314,589.00	\$ 16,005.00			

Table 3: Adjustment of ADEC Economic Analysis for Technically Feasible NOx and SO2 Controls - V.2

1 – Capital Recovery Factor = 0.0980 (5.25% interest rate for a 15 year equipment life)

2 - Does not include costs associated with building and maintaining a wastewater treatment facility. [Notation from ADEC spreadsheet]

2.0 Economic Infeasibility

The BACT review process as outlined by EPA includes five-step approach to determine the best control option. The economic feasibility of potential measures are addressed under Step 4 of the review process. Since there is no cost threshold for economic feasibility for controls within a serious nonattainment area, a source has to make the assertion to the regulatory agencies in order for economic infeasibility to be considered. Aurora's BACT results, as illustrated in Table 3, show that the least expensive SO₂ control technology is a \$20 million dollar investment and the cost effectiveness value is above \$10,000/ton of SO₂ removed.

Therefore, per the fine particulate implementation guidance, if a source contends that a source-specific control level should not be established because the source cannot afford the control measure or technology demonstrated to be economically feasible, the source should make its claim known to the state and support the claim with information regarding the impact of imposing the identified control measure or technology on the following financial indicators to the extent applicable:¹

- 1. Fixed and variable production costs;
- 2. Product supply and demand elasticity;
- 3. Product prices (cost absorption vs. cost pass-through);
- 4. Expected costs incurred by competitors;
- 5. Company Profits;
- 6. Employment costs;
- 7. Other costs (e.g., for BACM implemented by public sector entities).

At this time, ADEC is considering one control measure per major stationary source to meet BACT and Most Stringent Measures (MSM) for sulfur dioxide (SO₂) control. ADEC's preliminary determination suggests Aurora invest \$12,332,076 for DSI technology to remove 80% of the SO₂ emissions from the Chena Power Plant. ADEC estimates that annualized costs for the application would be \$4,284,104. ADEC's projected capital cost for retrofit SO₂ control technology is just above half of the costs of a +50/-30 design (e.g., capital cost \$20,682,000) which was recently submitted to the ADEC. Even if the lower cost for controls estimated by the ADEC were valid, it is not economically feasible and therefore should not be required. Further, ADEC does not know whether the installation of DSI or any control technology on stationary sources will have a significant impact on the overall air quality in the non-attainment area.

Aurora has one electric customer and approximately 200 district heating customers. Income from power production is from wholesale electric sales to the local electrical cooperative, Golden Valley Electrical Association (GVEA). Aurora has a long term contract with GVEA which would be difficult to renegotiate for necessary price increases to accommodate additional control technologies. Pass-through cost opportunities for Aurora's district heating are not viable. The necessary product price increases to cover additional costs of the proposed control technology would price Aurora out of the market for both heat and power. The result would be higher electric and heat costs, coupled with an increase in PM_{2.5} pollution due to the introduction of ground-level emissions from oil and/or gas fired furnaces and boilers that would be installed to replace uneconomic district heat. As Aurora customers switch to less expensive fossil fuels – or yet even less expensive wood – the resulting burden on Aurora's remaining customers will increase, causing more and more of them to switch, resulting in a continuous increase in particulate emissions in the Fairbanks core, and in a death spiral for Aurora as an economically viable business. Within this section, Aurora will address the financial indicators applicable to demonstrate the economic infeasibility of installing and operating ADEC's proposed control technology.

1. Production Costs

Aurora's five year operating costs for electric and district heating (RCA) are provided below in Table 4. Operating costs consist of operations expense, maintenance expense, administrative expenses, and depreciation expense. The net operating costs for power generation was \$0.08/kW in 2017 (Table 4). The

¹ Federal Register, Vol. 81, No.164, Wednesday August 24, 2016. pg. 58085.

margin for income is small as reflected in Table 6. District heating operating costs exceed income generated resulting in a net loss over the past 5 years (Table 6).²

Year	Electrical Total	Net kWh	\$/kWh	District heating Total	Net MMBtu	\$/MMBtu
2017	\$13,795,480	181,113,600	\$0.08	\$4,658,655	262,189	\$17.77
2016	\$13,707,259	189,093,610	\$0.07	\$5,285,399	249,151	\$21.21
2015	\$12,582,952	194,083,220	\$0.06	\$5,395,212	267,686	\$20.16
2014	\$12,250,548	184,058,400	\$0.07	\$5,648,209	273,089	\$20.68
2013	\$10,833,349	181,569,600	\$0.06	\$5,387,853	274,139	\$19.65
Average	\$12,633,918	185,983,686	\$0.07	\$5,275,066	265,251	\$19.89

Table 4:	Aurora	Energy	Operating	Costs

2. Supply and Demand Elasticity

The issue of supply and demand elasticity is addressed in more detail within the context of the following sections. The cost of control technologies cannot be absorbed by Aurora under the current pricing to consumers for district heating and power. Aurora has no alternative but to pass those costs to its customers. Those customers, in turn, would have no choice but to go elsewhere for their heat and power, as Aurora would no longer be competitive with other options. This would be the beginning of a death spiral for Aurora as a business, and the beginning of an increase in lower level emissions in the Fairbanks core as more and more buildings switch to oil or gas for heat.

3. Product prices (cost absorption vs cost pass-through)

Aurora's current product prices are competitive with other power suppliers and heating sources. Aurora's heat business is generally regulated by the Regulatory Commission of Alaska (RCA). District heating prices are set based on Aurora's cost to produce the heat. At the same time, many district heat customers are able to switch to alternative sources of heat, such as oil, gas or wood; therefore, Aurora has a powerful incentive to maintain district heating prices competitive with other heating options. Likewise, GVEA maintains several contracts with various power producers including Aurora. GVEA's portfolio includes power generated with natural gas, hydroelectric gradient, wind, solar, coal, and oil. Aurora's contract with GVEA ensures Aurora's power pricing is competitive and marketable.

District Heating

District heating prices cannot absorb the pass through costs of control technology. Aurora's district heating customer base is approximately 200 including mostly commercial and some residential customers. District steam heating rates are set with oversight by the RCA and do not vary. Hot water district heating prices differ depending on consumers' annual heating needs. The hot water district heating rates are adjusted throughout the year to be competitive with other sources of heat.

Absorbing full or partial costs for upgrades or control technologies is not feasible through district heating rate adjustments. The price adjustment necessary to compensate for the current average annual net loss from district heating (Table 6) would be an increase of \$3.71/MMBtu representing a 20% increase in heating costs. A 20% increase in district heat prices per unit energy (MMBtu) is not marketable. The potential is a loss of revenue from customers switching to alternative forms of heat which would make

² Based on RCA annual filing from 2013-2017.

district heating even less sustainable and exacerbate air quality due to an increase in ground level emissions.

Electric Generation

Aurora's power pricing cannot absorb the pass through cost of control technologies without revising the current contract and becoming less marketable. Aurora sells its power at wholesale price to GVEA, its sole electric customer. Aurora has averaged 186,000 MWh in net sales annually. Pass through of any additional incurred cost would have to be negotiated with GVEA, and would cause an increase in power costs to all customers in GVEA's service area.

Product Pricing for GVEA including Control Technology Costs

ADEC indicates that SO₂ controls are being considered for BACT or Most Stringent Measures (MSM) at this time.³ ADEC's estimate of the capital investment of the preferred control technology for Aurora is estimated to be \$12,332,076 and the annualized cost is estimated to be \$4,284,104. The requirement is that BACT must be installed within 4 years of reclassification of an area from a moderate to a serious nonattainment area.⁴ The Fairbanks North Star Borough nonattainment area designation change from "Moderate" to "Serious" was effective June 9, 2017.⁵ Since the area is now identified as serious, BACT control would have to be in place by June of 2021. Funds for the capital investment would need to be arranged by 2019 to allow for construction and installation of the control equipment. The power purchase agreement with GVEA would need to be renegotiated prior to committing to construction.

Assuming electrical sales would correspond to the 5-year average (185,984 MWh), the weighted average price per MWh at the Chena Power Plant (CPP) would be \$85.51.⁶ When the annualized cost of operating the preferred control technology is included, the price of power from the CPP increases to \$108.55/MWh; a 27% increase in price of power. The average total electric power consumption of sulfur control on Healy Unit #2 is 550.5 kW.⁷ Assuming a comparable station service use, SO₂ control on the Chena Power Plant could require an additional 2.6% for station service load.

The SO₂ control technologies being considered (DSI) require the addition of lime, limestone, or sodium bicarbonate to the gas path prior to the baghouse. The amount of unreacted sorbent added to the process could alter the leaching characteristics of metals from coal ash. Recent testing of coal ash from coal blended with 2% by weight limestone, demonstrated elevated metals leaching from coal ash at various pH. Metals leaching in excess of water quality standards could require Aurora to incur additional disposal costs for coal ash. Aurora would either have to build a coal ash landfill, or take the coal ash to the municipal landfill at a cost to Aurora of \$90/ton.⁸ If additional costs were incurred by Aurora for disposing 20,000 tons of coal ash, then the price per MWh would need to increase to \$118.60; which represents a 39% increase in the price of power.

³ ADEC. 2018. Preliminary Draft, Possible Concepts and Potential Approaches for the development of the FNSB NAA Serious SIP.

⁴ Federal Register, Vol. 81, No.164, Wednesday August 24, 2016.

⁵ Federal Register, Vol. 82, No.89, Wednesday May 10, 2017.

⁶ 2013 Contract Pricing for 2020: \$79.37/MWh (<150,000 MWh) + \$112.12/MWh (>150,000 MWh).

⁷ Alaska Industrial Development and Export Authority. 1999. Spray Dryer Absorber System Performance Test Report, Healy Clean Coal Project. Healy, AK.

⁸ FNSB. 2014. Interior AK Coal Ash. Pg. 42

					Ū.				
	Average kWh/year (2013-2017)	No Cor	ntrols	SO2	- DSI	SO2	- SDA	SO2	- WS
Annual BACT									
Operating Cost		\$	-	\$4,	284,104	\$11	,862,577	\$12	2,160,961
2020 (\$/kWh)	185,983,686	\$	0.09	\$	0.11	\$	0.15	\$	0.15
2020 (\$/kWh) -2.5%									
station load (BACT)	181,334,094	\$	0.08	\$	0.11	\$	0.15	\$	0.15
Coal Ash Disposal -									
Borough Landfill ¹		\$	-	\$	0.12	\$	0.16	\$	0.16

				~	. ~
$T_{a}hle 5 \cdot S/kW/h$	Wholesale Pricing	for GVEA	including (Control Techno	LOGV COSte
$1 a O C J. \phi K W H$	wholesale i fieling	IOI OVLA	menuumg v	control reenno	logy Costs

1 - Borough Landfill disposal cost based on 20,000 tons of ash; \$90/ton (FNSB. 2014). Interior AK Coal Ash. Pg 42.

Aurora's price of power is in competition with other power producers. If the price of power exceeds that of the competition, Aurora would not be as competitive in the energy market. Currently, GVEA will take as much power as Aurora can produce; however, it is likely that GVEA would reduce the amount of power accepted from Aurora if product prices increase above those of the competition.

4. Expected costs incurred by competitors

The FNSB nonattainment area impacts stationary sources within the area. Aurora's main competitors are power producers outside of the nonattainment area. Aurora's competition will not be required to consider BACT or MSM as a new requirement of a nonattainment area. This puts Aurora at a serious economic disadvantage. It is the only private for-profit power producer in the state being subjected to the $PM_{2.5}$ nonattainment area BACT requirements. Table 5 illustrates the price of wholesale power in $\/kWh$ from Aurora. The price of power with controls is 0.11/kWh. When additional disposal requirements are considered as a result of the use of the control technology, the price of Aurora's wholesale power to GVEA is 0.12/kWh.

Aurora's competition for power sales is primarily natural gas generated power; including Anchorage Municipal Light and Power (AMLP), Matanuska Electric Association, Inc. (MEA), and Chugach Electric Association (CEA). Aurora is also in competition with GVEA's fleet including the coal facilities (Healy #1 and Healy #2). The expected increase in price of Aurora's power due to BACT will make its power less marketable. At \$0.12/kWh, the price of Aurora's power to GVEA would exceed AMLP (\$0.09/kWh), Healy #1 (\$0.10/kWh), MEA (\$0.10/kWh), and CEA (\$0.11/kWh) based on GVEA's cost of power report in 2017⁹. Aurora currently provides 14% of GVEA's power requirements. At current prices, Aurora's power is competitive. An increase in the price of power to \$0.11/kWh or \$0.12/kWh would likely change that perspective.

5. Company Profits

Net income (loss) for Aurora over the past five years are not sufficient to absorb annual control technology costs for any of the control technologies proposed. Table 6 below includes the net income (loss) from district heating, electrical generation and the combined company income (loss) for years 2013

⁹ 2017 GVEA Annual Report to the RCA.

through 2017. Net income (loss) include income generated from district heat and power sales minus the operating costs as presented in Table 2 and include nonutility income, interest income, miscellaneous amortizations, and interest expenses.

			/
Year	Electric	District Heating	Net Income (loss)
2017	\$ 801,037.00	\$ (377,585.00)	\$ 423,452.00
2016	\$ 419,092.50	\$ (1,808,914.00)	\$ (1,389,821.50)
2015	\$ 1,094,599.25	\$ (1,059,348.00)	\$ 35,251.25
2014	\$ 321,876.05	\$ (892,950.00)	\$ (571,073.95)
2013	\$ 420,072.77	\$ (775,432.00)	\$ (355,359.23)
Average	\$ 611,335.51	\$ (982,845.80)	\$ (371,510.29)

Table 6: Aurora Energy, LLC – 5 Year Net Income (Losses)

The annual cost to operate the preferred technology is \$4,284,104 (Table 1 & 4); the average 5-year net income (loss) for Aurora is (\$371,510) [Table 6]. Conclusively, Aurora is not able to absorb the cost of additional control technologies.

The only alternative for Aurora to address annual operating expenses for any proposed control technologies would be to attempt to renegotiate the power contract to raise the price of power to GVEA. However, the rate adjustment would increase the price of Aurora's power to the extent that it would be less competitive.

6. Employment Cost

The state's calculations for annual operation costs of the proposed technologies include labor cost increases. The increases vary depending on the type of control technology. As a part of the state's analysis for SO_2 controls, annualized cost increases include the projection of additional labor for operation, maintenance, and administration.

7. Other Costs

No additional costs were considered.

ADEC has not shown that Aurora's, nor other stationary source's, SO₂ emissions are a significant contributor to the nonattainment area problem. ADEC does not know whether installation of BACT or MSM on stationary sources will significantly mitigate the impact of SO₂ on particulate concentration. Aurora cannot afford the control measure or technology that has been selected by the ADEC in the preliminary BACT analyses. The basis for this determination is that Aurora has consistently shown insufficient income to absorb the cost of the control technologies. Alternatively, increasing the price of power or heat to accommodate the cost of control technology will price Aurora's products out of the market. Any increase in district heating prices would make alternative sources of heat more attractive to consumers. The result would be a loss in business from customers switching to alternate sources of heat. This change in heating source could exacerbate pollution emissions at the ground level due to customers' use of distributed home heating alternatives. Aurora's district heating displaces the emissions from the equivalent of 2 - 2.5 million gallons of heating oil. The current power purchase agreement with GVEA allows Aurora's power to be competitive with other power sellers. The cost of additional control technology would have to be negotiated with Aurora's one customer based on its power purchase agreement and make Aurora's power prices less competitive; and subsequently, less sustainable.

3.0 Proposed Alternative BACT – District Heating

Aurora is sympathetic to the requirements of the Serious Nonattainment Area and believe that a reasonable alternative exists within the framework of what is economically feasible. As previously discussed, Aurora asserts that imposing retrofit controls, as proposed by ADEC, on its older boilers in the next four years is economically infeasible and could have negative impacts on the goals of the community to achieve attainment with the PM_{2.5} standard. As such, Aurora has developed a list of mitigating measures that are more economically sustainable and will have a direct impact on the community with respect to achieving attainment with the PM_{2.5} standard. Included as alternatives are the expansion of district heating, a wood drying kiln, and the potential use of biomass.

3.1 District Heating

Aurora is proposing that past district heat expansions as well as future district heating projects be considered as BACT for the Chena Power Plant. As it stands, Aurora's district heating displaces about 42 tons of SO₂ and 2 tons of particulates annually. District heating is referenced in both the Moderate Area State Implementation Plan (SIP)¹⁰ and the Preliminary Serious Area SIP¹¹ as a Pollution Control Measure for the FNSB NAA. As stated in the Moderate Area SIP, "An increase in the coverage of the district heating systems would therefore result in a decrease in measured PM_{2.5} concentrations". Based on modeling results, the PM_{2.5} concentration attributed to Aurora during an episode in 2008 was $0.02 \,\mu g/m^3$ and the SO₂ concentration at ground level from Aurora represents $0.75 \,\mu g/m^3$ (See Table 7).¹² The

Table 7: Summary of Six Major Fairbanks Point Source Plumes from CALPUFF for the Episode (Jan.23rd to Feb. 9th, 2008) Average Surface Concentrations at the State Office Building of PM2.5 and SO2 in ug/m3.

Power Plant	Episode	Episode
	average	average
	SO ₂ (μg/m ³)	PM _{2.5} (μg/m ³)
UAF- 316	2.75	0.16
Aurora- 315	0.75	0.02
Zehnder-109	0.48	0.19
Flint Hills-071	0.016	0.38
GVEA NP-110	3.8	1.45
Ft. WW- 1121	14	1.6
Total surface concentration	21.8	3.8

implication of the small pollutant contribution from Aurora at ground level is that taller stacks decrease the impact from emissions at ground level. The amount of pollutant loading at ground level within the nonattainment area is mitigated by district heating through the removal of ground level source emissions and vertically displacing them. An added benefit to increasing district heat coverage is an increase in efficiency at the plant. The plant is generally base loaded and driven to operate at a maximum capacity; there is moderate room for growth, but realistically, the plant is nearing its maximum capacity. The plant could accommodate, roughly, an additional 100 MMBtu/hour of heating capacity while still being able to provide a modest amount of electricity.

In order to quantify the impact district heating has on the nonattainment area, Aurora evaluates the potential use of fuel oil based on

¹⁰ ADEC. 2014. *Moderate Area State Implementation Plan. Appendix III.D.5.7.* pg 42.

¹¹ ADEC. 2018. Preliminary Draft, Possible Concepts and Potential Approaches for the development of the FNSB NAA Serious SIP.

¹² ADEC. 2014. Moderate Area State Implementation Plan. Section III.D.5.8-11.

a conversion from the heating load compensated by the plant for district heating. A fuel oil heating value of 137,000 btu/gal and an assumed efficiency of 85% for heating appliances are used to determine the quantity of heating oil equivalent to the district heating load. Since SO₂ and PM_{2.5} are the pollutants of most concern, Aurora is using emission rates for fuel oil using EPA's emission inventory warehouse, AP-42. Using the value of 2566 ppm sulfur in heating oil¹³, an emission rate of 36.92 lbs/10³ gallons (2.64×10^{-1} lbs/MMBtu) for SO₂ emissions and 0.4 lbs/10³ gallons (2.86×10^{-3} lbs/MMBtu) for filterable or direct PM_{2.5} and 1.3 lbs/10³ gallons (9.29×10^{-3} lbs/MMBtu) for condensable PM_{2.5} are derived. Using these emission rates, Aurora can evaluate the impact of district heating on the removal of SO₂ and PM_{2.5} from the nonattainment area.

As part of a further analysis, the SO₂ is converted to PM_{2.5} by using an ADEC derived method for comparing direct emissions of pollutants to PM_{2.5} concentration from various sources. Using this methodology, point source SO₂ emissions, wood smoke emissions, and heating oil SO₂ can be correlated to PM_{2.5} concentration. Through the use of a dispersion model, CALPUFF, ADEC determined that 22% of modeled SO₂ concentration are from point sources at ground level, 78% are from central oil, and <1% from mobile sources. Using this information and the ADEC's methodology (based on 'scenario 2'), a ratio of 5.5 tons SO2 emissions from major sources is estimated to form 1 μ g/m³ of PM_{2.5} as ammonium sulfate [8.38 TPD/(1.1 μ g/m³ x 132g/mol of ammonium sulfate/96 g/mol sulfate)]. Likewise, a ratio of 0.3 tons of wood smoke emissions is estimated to form 1 μ g/m³ of PM_{2.5}.¹⁴ Based on the same methodology, the ratio of SO₂ from fuel oil (78% of modeled concentration) to particulates is 0.8 tons of fuel oil SO₂ emissions to 1 μ g/m³ of PM_{2.5} as ammonium sulfate [4.12 TPD¹⁵/(3.9 μ g/m³ x 132g/mol of ammonium sulfate [4.12 TPD¹⁵/(3.9 μ g/m³ x 132g/mol of ammonium sulfate [4.12 trpation and that in Table 8, wood smoke produces 18 times more PM_{2.5} than the SO₂ from point sources and 2.6 times more PM_{2.5} than fuel oil.

Pollutant	Point Sources (SO ₂)	Fuel Oil (SO ₂)	Wood Smoke
Emissions (tons)	5.5	0.8	0.3
$PM_{2.5}$ Equivalent Concentration (μ g/m ³)	1	1	1

Table 8: Source pollutant emission and equivalent contribution in $\mu g/m^3$ of PM_{2.5}.

3.2 District Heat Expansion

District heating from Aurora mitigates emissions from ground level sources. The 5-year average (2013-2017) heating value of Aurora's district heat supply is 265,251 mmbtu/year. That is equivalent to about 2.3 million gallons of heating oil per year; assuming a heating value of 137,000 btu/gal and an 85% efficiency for an oil fired furnace. Using these values, district heat displaces about 42 tons of SO₂ from ground level emissions per year and 2 tons of PM_{2.5} in the down town area. Since 2008, Aurora has added district heating equivalent to 243,000 gallons of fuel oil per year. The impact of the addition is equivalent to the removal of 3510 lbs of wood smoke per year based on SO₂ reduction from fuel oil [4.5 TPY SO₂ fuel oil/0.77 tons SO2 fuel oil/1 µg/m³ x 0.3 tons wood smoke/1 µg/m³ x 2000 lbs/ton]. District heating records show that 67% of heating use is between November – March (151 days). The loading that

¹³ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.6. pg 102.

¹⁴ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

¹⁵ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.6. pg 27.

was mitigated since 2008 is approximately 16 lbs/day of wood smoke equivalence during the winter months.

Aurora has the mechanical potential to expand district heating another 100 mmbtu/hr of additional heating. The equivalent SO_2 removal potential would be about 24 tons per year based on the displacement of 1.3 million gallons of heating oil No.2 (fuel oil S% = 0.26).

3.3 District Heating Economics

Installation of district heating can be costly. The evaluation of DH as a control technology for the plant is difficult to assess a cost/ton comparison. Ideally, the expansion cost would be mitigated by revenue generated from the use of district heating. The business model for district heating would justify the expansion; the added benefit would be the reduction in pollutants emissions from ground level sources, and a decrease in the output based emission rate. In general, efficiency gains at the plant is a sustainable practice with the benefit of reducing pollutant emissions at ground level.

3.4 Output Based Emission

District heat expansion has the added benefit of making the plant more efficient. A method of illustrating efficiency gains with respect to pollutant emissions is in the derivation of an output based emission rate. The output based emission rate for SO_2 at the plant is approximately 4.6 lbs/MW of energy output. The emission rate is based on a conservative calculation using the 5-year weighted average coal sulfur content and converting all of it to SO_2 . The denominator consists of net power and net district heat sales in MW. When the maximum output of district heating is added to the denominator, the emission rate is reduced to 3.4 lbs/MW. This represents a 27% reduction in the emission rate per energy output.

The output based emission rate can be used to show efficiency gains with respect to pollutant emissions. Efficiency gains through the use of central heat and power facilities clearly demonstrate the advantages of minimize emission increases while maximizing energy output.

4.0 Proposed Alternative BACT - Firewood Drying Kiln

Couched within the benefits of district heating, Aurora is proposing an alternative to address its potential formation of fine particulate matter ($PM_{2.5}$) from sulfur dioxide. According to a 2008 report by the Northeast States for Coordinated Air Use Management (NESCAUM), for every 10 percentage point increase in the moisture content of wood, the $PM_{2.5}$ emissions increase by 65% to 167%. The increase in emissions is due to increased amount of wood needed to evaporate the extra moisture and poor combustion conditions leading to reduced heat transfer efficiency. Wood fuel use may double if wet wood were burned as opposed to dry wood.¹⁶ Aurora is proposing to develop and operate a firewood drying kiln using district heat from the Aurora plant to help mitigate the use of wet wood. The general idea is that, along with district heat conversions, Aurora would offset its potential $PM_{2.5}$ formation by providing dry wood to the community from a kiln. The kiln would require 3.5 mmbtu/hour of thermal loading from district heating. The initial moisture content in the wood is assumed to be around 50%; the kiln would evaporate 35% of the moisture to a wood moisture content of 15% or less. By conditioning solid fuel (fire wood) to be used in homes, district heating is effectively expanded without the cost of installation.

¹⁶ ADEC. 2014. *Moderate Area State Implementation Plan. Appendix III.D.5.7.* pg 22.

4.1 Equivalent Emissions

The state has derived a method for comparing direct emissions of pollutants to $PM_{2.5}$ concentration. Using this methodology, point source SO₂ emissions, wood smoke emissions, and heating oil SO₂ can be correlated to $PM_{2.5}$ concentration. Based on 22% of modeled SO₂ concentration from point sources at ground level, a ratio of 5.5 tons SO₂ emissions is estimated to form 1 µg/m³ of $PM_{2.5}$ as ammonium sulfate. Likewise, a ratio of 0.3 tons of wood smoke emissions is estimated to form 1 µg/m³ of $PM_{2.5}$.¹⁷ Using the fore mentioned conversions, Aurora estimated the power plants SO₂ emissions equivalent to wood smoke emission rate at Aurora of 608.3 tons/year of SO₂ (1.67 tpd), the wood smoke emission equivalent is 181 lbs/day [1.67 TPD/ (5.5 tons SO₂ from major sources/1 µg/m³) x 0.3 tons of wood smoke/1 µg/m³ x 2000 lbs/ton]. The equivalent annual wood smoke emission to 608.3 tons of SO₂ emission is proposed to be mitigated through drying wood by reducing 35% moisture from cord wood.

Source of Emissions	SO ₂ Emissions (tpd)	SO ₂ /PM _{2.5} (tpd)/(µg/m ³)	Wood Smoke/PM _{2.5} (tpd)/(µg/m ³)	Wood Smoke Equivalent (lbs/day)
Aurora Energy	1.67	5.5	0.3	181
Displaced Heating Oil Use - DH	0.01	0.8	0.3	10

Table 9: SO2 Conversion to Wood Smoke Equivalent Emission

The emission reduction for $PM_{2.5}$ in lbs/MMBtu was derived using the ADEC's referenced information within the Appendices of the Moderate Area State Implementation Plan (See Tables 10 & 11). The average emission rate for wood burning devices at 50% moisture (1.14 lbs/MMBtu) was subtracted from the average emission rate for wood burning devices at 15% moisture (0.67 lbs/MMBtu). The equivalent amount of cords needed to account for 100% of Aurora's annual SO₂ emissions is 8,495 cords per year.

Table 10. Emission raciors based on wood moisture content	Table	10:	Emission	Factors	based	on	wood	moisture	content
---	-------	-----	----------	---------	-------	----	------	----------	---------

Wood Burning Devices	EF PM2.5 lbs/ton ¹	Btu/lb ²	lbs/MMBtu	Btu/lb ²	lbs/MMBtu	Btu/lb ²	lbs/MMBtu
Moisture content (%)		0		15		50	
non-EPA certified Wood Stoves	11.6	8,119	7.14E-01	6,901	8.40E-01	4,060	1.43E+00
EPA Wood stove non-catalytic	7.57	8,119	4.66E-01	6,901	5.48E-01	4,060	9.32E-01
EPA Wood stove catalytic	8.4	8,119	5.17E-01	6,901	6.09E-01	4,060	1.03E+00
Hydronic Heater weighted 80/20 (OWB unqualified/OWB-Ph2)	9.43	8,119	5.81E-01	6,901	6.83E-01	4,060	1.16E+00
Average emission factor	9.25	8,119	5.70E-01	6,901	6.70E-01	4,060	1.14E+00
Note: 1 - Appendix III.D.5.6-105, Table 5.6-40; 2 - Appendix III.D.5							

¹⁷ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

Table 11: Calculation to determine how much kiln dried wood is necessary to mitigate AE's SO_2 emissions.

PM 2.5 Daily Emissions Reduction [Scenario 2] (lbs/day)	181
PM 2.5 Annual Emissions Reduction (lbs/year)	66,003
Spruce weight at 20% moisture	2,550
Dry Wood (%) moisture	15
Wet Wood (%) moisture	50
Emission Diff. wet vs. dry (lbs/MMBtu)	4.69E-01
Daily Wood processing minimum (MMBtu/year)	140,695
Cords per year	8,495
cords/load	42
Loads per year	202

4.2 Firewood Kiln Economics

The capital cost and annualized cost of the kiln is much less than that of the other BACT alternatives. The cost effectiveness is determined by a % cost ratio based on drying wood at a maximum potential of 8,495 cords of wood to reduce, effectively, 608.3 tons per year of SO₂-equivalent emission. The annualized cost is used to derive the cost effectiveness ratio of \$980 per ton of pollutant removed.

Table 12: Cost Effectiveness of Kiln

Control Technology	PM 2.5 Reduction (tpy)	Equivalent SO2 Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annual Cost (\$/year)	Cost Effectiveness (\$/ton SO ₂)
Wood Kiln	32.5	608.3	\$ 1,500,000	\$ 736,078	\$ 980

Unlike a traditional BACT approach, the effective emission reduction is hinged on the marketability of dry wood. Aurora plans to market the kiln dried wood as a benefit from a performance and air quality standpoint. The Fairbanks Northstar Borough, ADEC and EPA all have an important role in enforcing the use of dry wood for home heating the NAA.

5.0 Proposed Alternative BACT - Biomass Co-Firing

Aurora's boilers are subject to 40 CFR 63 subpart JJJJJJ. Under the rule, the Chena Power Plant (CPP) boiler units are classified as coal-fired boilers. The definition of coal-fired boiler subcategory extends to coal boilers that burn up to 15% biomass on a total fuel annual heat input basis. This flexibility in definition would allow Aurora to burn up to 15% biomass and still retain its classification as a coal-fired boiler. Aurora has been involved in a projects with Alaska Center for Energy and Power (ACEP) and the US Forestry Service using biomass (wood chips and refuse) as a substitute for coal. The projects did not demonstrate much of a change to the current operations; however, the material used had a significant amount of moisture (40%) and was not uniform. Sizing of the material was an issue and created problems. Biomass refuse and chips were not appropriately sized and created issues with material feeding through the auxiliary coal feed system. Also, due to density differences, material segregation within the bunkers occurred; wood chips tended to be pushed to the top of the coal. Ultimately, the lessons learned from the project were that with the right material sizing and processing, biomass could be used in the boilers to

help increase efficiency. As noted by operators during the project, the biomass burned off quickly leaving holes within the coal bed which allowed for air pockets which qualitatively made coal combustion more effective. The theory is that air voids left after the biomass was burned off facilitated greater air-to-fuel contact. Also, the rapid burning of the biomass may have increased the heat of the coal bed which helped coal combustion. Although this theory has not been vetted though rigorous research, the potential benefits of using biomass within the process may be substantial. At the very least, biomass has very little sulfur and could be a measure to mitigate the emissions of SO_2 from the plant.

The material used during the biomass project at Aurora was unprocessed and, consequently, not uniform. If the biomass material was processed and met some consistency standards there could be a significant measurable gain in efficiency. As such, processed biomass in the form of industrial grade pellets can provide a consistent sizing which would be compatible with the sizing of the stoker coal used at the Chena Power Plant (CPP). The benefit of using an industrial grade pellet is that the anticipated heat content of the pellets are assumed to be upwards of 8300 btu/lb, the moisture content is near 0%, and there is very little sulfur in the fuel. The cons of using an industrial grade biomass pellet is the cost of the fuel which could be as high as \$295/ton. At this cost, the use of biomass is not economical. Furthermore, Aurora has not determined whether or not enough raw timber supply is available around the Fairbanks area to accommodate a consistent 15% blend rate. However, if waste biomass material, such as sawdust or bark, from local wood sellers were processed into pellets the raw material could be acquired at a low cost.

5.1 Biomass Economics

Biomass pellets, due to their lack of sulfur, could be used as mitigation for SO₂ emissions. As stated above, the negative aspect of pellets is in the cost and potential lack of access to raw material supply. In order to derive a price point for pellets that would be acceptable as a control technology, a cost

Table 13: Biomass and Coal Fuel Revenue/MMBtu					
hhv pellets btu/lb	8,300				
hhv pellets mmbtu/ton	16.6				
hhv coal btu/lb	7,613.05				
coal moisture	29%				
heat of vaporization of water @ 77F btu/lb	1,049.70				
coal btu/lb -vaporized free water	7,304				
coal mmbtu/ton -vaporized free water	14.6				
pellet coal equivalent	1.14				
revenue/ton of coal	\$ 79.09				
revenue/mmbtu of coal	\$ 5.41				
revenue/mmbtu of pellets	\$ 4.76				

effectiveness value of 3.125/ton SO₂ removed is used as a reference. This is a conservative estimate derived by the state in the moderate area SIP.18 If the 5-year average revenue generated by the plant is divided by the 5year average coal use we get a value of \$79.09 revenue/ton of coal. Pellets have a higher btu/lb content than the coal and pellets have no moisture. To account for this discrepancy, coal heating value is

considered after the evaporation of moisture. The energy needed to vaporize free moisture ($h_{vap} = 1049$ btu/lb @ 77F) is multiplied by the moisture fraction of coal to derive the heat content of the coal at 0% moisture. When comparing the wood pellets to coal, the 5-year average heat content (7623 btu/lb) and moisture (29%) is considered. The heating value of coal without moisture is 7304 btu/lb (7623 btu/lb –

¹⁸ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

1049.7*29/100). Pellets would	Table 14: Biomass Cost Effectiveness Calculation						
have a heating content of 8300 btu/lb and no moisture. If the price of the pellets were	capital investment (hopper modification to auxillary coal feed system)	\$300,000.00					
\$84/ton, the cost effectiveness	loan period (years)	\$5.00					
value would be \$3,093.04/ton	interest rate (%)	8%					
SO ₂ removed.	monthly loan amount	\$6,082.92					
The emission reduction	Annual loan amount	\$72,995.04					
potential using pellets at 15%	Burden for 0.5 man equivalent (2016)	\$65,520					
total fuel loading is 91.24 tons	5-year avg Annual Coal (tons)	221,758.29					
of SO_2 per year. Aurora is	5-year avg coal sulfur (%)	0.14%					
actively pursuing this concept;	potential max SO2 (tons/yr)	608.24					
however, running the boiler	Annual pellets (%)	15%					
with 15% biomass has not	Annual pellets (tons)	29,272.22					
industrial wood pellets at the	emission reduction (tons/yr)	91.24					
preferred price has not been	Cost pellets (\$/ton)	\$84.00					
identified nor has the	Annual cost	\$2,597,381.16					
availability of the raw material	Annual revenue	\$2,315,186.17					
supply been verified.	annual burden of pellets	\$282,194.99					
	cost/ton removed	3,093.04					

6.0 Proposed Alternative BACT – Reduction in Potential to Emit

Aurora proposes to monitor the stack gas emissions out of the common stack. The purpose of the monitoring would be to ensure compliance with an SO_2 emission rate of 190 ppm. Instead of taking a reduction in the sulfur content of the coal or PTE for SO_2 emissions, monitoring the stack gas emissions and maintaining a rolling 30-day average at or under 190 ppm ensures that the plant is not exceeding a certain loading rate equal to 0.25% coal sulfur content. Using the SO_2 emission calculation in the Air Quality Operating permit AQ0315TVP03 Rev. 1, Condition 22.1.c; a stack gas concentration of 7.5% O_2 ; and adjusting the S% to 0.25 (in this ultimate analysis the S% is 0.26), the SO_2 concentration is 188 ppm as illustrated below:

Figure	1:	SO ₂	emission	calcu	lation
1 15010	••	002	emission	curcu.	auton

SO2 Concentration P	PPM = (1.00X 10^6 xmol ₅₀₂)/(mo	l _{so2} +mol _{co2} +mol _{o2} +mol _N	2)			
SO2 PPM =						
Where:						
mol SO2 =	[wt% Sfuel,%]/32.06					
mol CO2 =	[wt%Cfuel,%]/12.01					
mol O2 =	MF x [(wt%Nfuel,%]/28.01)+	(4.76xmolCO2)+(4.76xmo	ISO2)+(1.88xmoIH2O)-(3.76x[wt%Ofuel,%]/3	32.00)]		
MF =	[vol%O2,exhaust,%]/(100%-4	4.76x[vol%O2, exhaust, 9	6])			
mol H2O =	[wt%Hfuel,%]/2.016					
mol N2 =	([wt%Nfuel,%]/28.01)+(3.76)	xmolSO2)+(3.76xmolCO2)+(1.88xmolH2O)+(3.76xmolO2)-([wt% Ofuel	,%]/8.51)		
Constituent	mols in flue gas		Ultimate/proximate analysis (AE08162018)	%weight (dry)	Atomic Mass	Atomic Mass
mol _{so2}	0.007796663		wt% Sulfur _{fuel} , %	0.25	Sulphur	32.065
mol _{co2}	5.219382233		wt% Carbon _{fuel} , %	62.69	Carbon	12.011
mol _{H20}	2.277011608		wt% Hydrogen _{fuel} , %	4.59	Hydrogen	1.0079
moloz	3.098516312		wt% Nitrogenfuel, %	0.93	Nitrogen	14.007
mol _{N2}	33.05690137		wt% Oxygen _{fuel} , %	21.8	Oxygen	15.999
MF	0.116640747			%vol		
			Oxygen exhaust %	7.5		
SO ₂ Concentration	188.404394		Source Test Required if exhaust SO ₂ Concer	ntration is greate	er than 500 pp	m m

As mentioned, 190 ppm of SO2 emissions on a 30-day rolling average represents an overall PTE reduction from 0.4% sulfur content to 0.25% while still allowing flexibility with respect to coal quality exceeding 0.25% sulfur.

7.0 Precursor Demonstration

As part of the Serious SIP development, states are required to develop Best Available Control Measures for all source sectors that emit PM_{2.5} and the four major precursor gases (e.g., NOx, SO₂, NH₄, and VOC). The analysis specific to the major stationary source is a Best Available Control Technology analysis. Within the rule, if the state determines through a precursor demonstration that controls for a precursor gas are not needed for attaining the standard, then the controls for a precursor gas are not required to be implemented.¹⁹ The regulations provide for three kinds of precursor analyses, comprehensive (which consider precursor emissions from all sources in the nonattainment area), Major stationary source (which consider precursor emissions from major sources), and Nonattainment New Source Review (which considers potential precursor emissions from new sources).²⁰ For each of the first two analyses, there are two varieties available to the state: a concentration-based analysis (compares the precursor contributions to a numerical threshold) and a sensitivity-based analysis which consider other factors to evaluate if reductions in the precursor emissions would significantly reduce PM_{2.5} levels in a nonattainment area.

The ADEC has successfully demonstrated that oxides of nitrogen NOx and VOC are not a significant precursors to the area. The NOx precursor demonstrations included a comprehensive demonstration with a sensitivity based analysis for the community and a Major Stationary Source – concentration based analysis which demonstrated that major sources are not a significant contributor to the nitrate-based particulate formation.²¹ The state also conducted a comprehensive, concentration-based analysis for SO₂ and concluded that SO₂ emissions in the NAA contribute 5.4 µg/m³ in the Fairbanks area and 4.9 µg/m³ of PM_{2.5} in the North Pole area. Since these concentrations exceed the significance threshold of 1.3 µg/m³ (now 1.5 µg/m³)²², the ADEC proposes not to conduct a sensitivity-based precursor demonstration nor are they considering a major source precursor demonstration.

EPA's draft precursor guidance recognizes that the significance of a precursors contribution is determined based on the facts and circumstances of the area which include source characteristics such as source type, stack height, and location.²³ The rationale for doing a precursor demonstration fits with the site-specific factors listed in the EPA guidance, namely tall stacks. However, the ADEC and EPA have been resistant to performing or further considering a Major Source precursor demonstration.

Aurora sought a third party opinion (Ramboll Environmental) regarding the possibility of a successful SO_2 precursor demonstration that could demonstrate that major stationary sources are an insignificant part of the contribution to the nonattainment area. According with the EPA's precursor demonstration guidelines, a successful major stationary source precursor demonstration must show that SO_2 emissions do not contribute significantly to violations of the PM_{2.5} standard (1.5 µg/m³). If the 'contribution-based'

¹⁹ ADEC. 2018. Preliminary Draft Precursor Demonstration.

²⁰ See 40 C.F.R. § 51.1006

²¹ ADEC. 2018. Preliminary Draft Precursor Demonstration.

²² Draft EPA (2016b) guidance recommended 1.3 μ g/m³ for the PM_{2.5} 24-hour NAAQS as the appropriate threshold to identify insignificant contributions to PM_{2.5} concentrations. A more recent updated technical basis document, EPA (2018) now recommends a threshold for identifying significance of 1.5 μ g/m³.

²³ EPA's 2016 Draft PM_{2.5} Precursor Demonstration Guidance.

analysis indicates that the impact exceeds $1.5 \ \mu g/m^3$, then a 'sensitivity-based' analysis may be conducted to show that a reduction of SO₂ emissions in the range of 30-70% would have only an insignificant impact on lowering PM_{2.5}.

Two main hurdles exist to conducting a credible SO_2 precursor demonstration; 1) the large contribution of sulfate by major and minor source contribution to the nonattainment area; and 2) the large under prediction of sulfate mass through the model (CMAQ). In essence, while the SO_2 sources are observed to contribute significantly to the $PM_{2.5}$ nonattainment area, current modeling systems are not sufficiently accurate to provide a reliable estimate of the impacts of emission reductions from SO_2 .

Utilizing the ADEC's information within the Moderate Area SIP, Aurora's third party consult suggests that there is relevant data to suggest major sources are potentially insignificant contributors to the NAA.

"...data analyses and modeling conducted for the Fairbanks moderate area SIP provide some significant information which suggests that in fact major source SO_2 emissions may not contribute significantly to $PM_{2.5}$ nonattainment."²⁴

As such, a Major Source SO₂ precursor demonstration must be pursued by the ADEC. It is an undue burden for Aurora and other major sources within the NAA subject to the requirements of control measures (BACT, and more likely MSM) considering that there is data to suggest that major sources could be insignificant. Even though updating models and research into the chemistry of sulfate particulate formation is costly and time consuming, it is due diligence on the agencies part to further elucidate the impact of major sources. Ultimately, Aurora will continue to pursue alternative control measures as proposed within this document under the assumption that the agencies (ADEC and EPA) will continue to vet the sulfate contribution disparity between model and observed values with the perspective of major stationary source contribution.

8.0 Conclusion

The proposed BACT alternatives in this document and accompanying information demonstrate that the ADEC proposed BACT are economically infeasible and do very little to solve the air quality problem in the nonattainment area. EPA, the State of Alaska, as well as the local community understand and agree that the majority of the $PM_{2.5}$ problem in the area is from home heating sources. Aurora contends that requiring the implementation of the ADEC proposed BACT controls would cause the pollution problem to worsen due to our district heat customer's refusal to accept a higher cost heating product and instead switching to fuel oil, or wood burning.

Aurora does not believe ADEC has demonstrated that the point sources, or more specifically Aurora, are contributing to the $PM_{2.5}$ problem in a significant enough way to warrant the need for additional control measures. Aurora believes that a precursor demonstration would prove this assertion one way or another. Aurora believes a precursor demonstration is possible and requests that ADEC and the EPA move forward with conducting a precursor demonstration in parallel with the implementation of the SIP. Should a precursor demonstration show that the point sources do not cross over the significance threshold, all point sources should be released from further compliance with the $PM_{2.5}$ requirements.

Even though Aurora is not convinced that major source emissions exceed the significance threshold for $PM_{2.5}$ within the NAA, Aurora is interested in being a part of the solution to reduce $PM_{2.5}$. Aurora's

²⁴ Memo. Ramboll. "Summary of issues related to SO₂ precursor demonstration for Fairbanks".2018.

proposed alternative BACT controls are more effective from an environmental perspective and cost substantially less than the ADEC proposed BACT controls. The table below shows the potential amount of SO_2 and $PM_{2.5}$ removed from the NAA by Aurora's proposed alternative BACT.

Emissions	SO2 (tpy)	PM 2.5 (tpy)	Qualifying Parameters
District Heating	42 tpy at	2 tons at	250,000 - 300,000
(Current Operating Conditions)	ground level	ground level	mmbtu per year
District Heating	24 tpy at	1 ton at	100 mmbtu/hr expansion
(Potential Expansion)	ground level	ground level	potential
Wood Kiln	608.3tpy	33 tons at ground level	8495 cords/yr
Biomass Co-Firing	91.2 tpy		15% by fuel heat input from industrial pellets
Potential to emit reduction	38% reduction in PTE (854 tpy)		State upper limit of 500 ppm over 3 hours. Proposed 190 ppm as a new PTE
Total Potential Reduction	1,619.5 tpy	36 tpy	

Table 15: Summary of BACT Alternatives and Potential Emission Reduction

As clearly shown in this table, the environmental benefits from Aurora's proposed alternative BACTs will positively impact the current NAA. Aurora is prepared to move forward with implementing these alternative BACTs as soon as ADEC is able to provide Aurora with the assurance that additional control measures or fees will not be required in order to demonstrate compliance with the PM2.5 regulations for the NAA.

Aurora is committed to continuing to work with ADEC, EPA and the local community in working toward meaningful solutions to the air quality problem in Interior Alaska.

Appendix A (Economic Analysis Spreadsheets – V1)

Air Pollution Control Cost Estimation Spreadsheet

For Selective Catalytic Reduction (SCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Catalytic Reduction (SCR) control device. SCR is a post-combustion control technology for reducing NO_x emissions that employs a metal-based catalyst and an ammonia-based reducing reagent (urea or ammonia). The reagent reacts selectively with the flue gas NO_x within a specific temperature range to produce N₂ and water vapor.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SCR control technology and the cost methodologies, see Section 4, Chapter 2 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM) (version 5.13). The size and costs of the SCR are based primarily on five parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, reagent consumption rate, and catalyst costs. The equations for utility boilers are identical to those used in the IPM. However, the equations for industrial boilers were developed based on the IPM equations for utility boilers. This approach provides study-level estimates (±30%) of SCR capital and annual costs. Default data in the spreadsheet is taken from the SCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/powersector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will clear many of the input cells and reset others to default values.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SCR is for new construction or retofit of an existing boiler. If the SCR will be installed on an existing boiler, enter a retrofit factor between 0.8 and 1.5. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you select fuel oil or natural gas, the HHV and NPHR fields will be prepopulated with default values. If you select coal, then you must complete the coal input box by first selecting the type of coal burned from the drop down menu. The weight percent sulfur content, HHV, and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided. Method 1 is pre-selected as the default method for calculating the catalyst replacement cost. For coal-fired units, you choose either method 1 or method 2 for calculating the catalyst replacement cost by selecting appropriate radio button.

Step 4: Complete all of the cells highlighted in yellow. If you do not know the catalyst volume (Vol catalyst) or flue gas flow rate (Q_{flue gas}), please enter "UNK" and these values will be calculated for you. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.005 and 0.03, respectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SCR.

Adopted

November 19, 2019

		Data Ir	nputs			
F						
Enter the following data for your combustion unit:						
Is the combustion unit a utility or industrial boiler?	ial 🔻		What type of fu	el does the unit burn?	Coal	
Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit	•					
Please enter a retrofit factor between 0.8 and 1.5 based on the level of diffi	culty. Enter 1 for		Simpson, Aaron:	to justify a rotrofit factor	reflecting greater than average.	difficulty
projects of average retrofit difficulty.	,	1.5	ap for installation of selec	tive catalytic reduction on	the boilers.	uncury
Complete all of the highlighted date fields			High retrofit cost facto	rs may be justified in unu	sual circumstances (e.g., long ar	nd Ilation
complete an of the highlighted data neids.			additional engineering	, and asbestos abatement).	
What is the rating at full load capacity (MMBtu/hr)?	497	7 MMBtu/hr	Aurora: Location of th 500-800F, would be t	ne catalyst, if it has to be he top of the boilers just l	installed within a temperature ra before the economizer and air pr	nge of eheater.
	7.50	DA: //h	It's a titght fit, limited	space, asbestos abatemer	nt necessary, duct work is compl	lex and
What is the higher heating value (HHV) of the fuel?	7,500	Simpson, Aaron:	Enter the sulful	content (%3) =	Simpson, Aaror	n:
What is the estimated actual annual fuel consumption?	569,114,000	J lbs/year	://www.usibelli.com/coal/c	lata-sheet	Typical Gross As	Received. http://www.usibelli.com/coal/data-sheet
			For units burnin	g coal blends:		
			Note: T	he table below is pre-p	opulated with default values	for HHV and %S. Please enter the actual values
			the def	ault values provided.	Sie Below. II the actual value	ior any parameter is not known, you may use
Enter the net plant heat input rate (NPHR)	18	MMBtu/MW	J	F	raction in	
If the NPHR is not known, use the default NPHR value:	Fuel Type	Default NPHR	1	Bituminous	Coal Blend %S 0 2.35	HHV (Btu/lb) 11,814
	Coal Euel Oil	10 MMBtu/MW 11 MMBtu/MW	Su	Ib-Bituminous	1 0.2	7,560
	Natural Gas	8.2 MMBtu/MW		P. L. H. L.		
			values b	based on the data in the	e table above.	
Plant Elevation	450	Feet above sea level	For coal-fired b	oilers you may use e	either Method 1 or Method	2 to calculate
			the catalyst re	placement cost. The	equations for both method	is are shown on
			rows 85 and 86 method:	5 on the Cost Estimate	e tab. Please select your pr	eferred ONot applicable
Enter the following design parameters for the proposed SCR	:					
Number of days the SCR operates $(t_{\scriptscriptstyle SCR})$	365	days	1:	Number of SCR react	or chambers (n _{scr})	1
Number of days the boiler operates (t_{plant})	265	New Source Perfe	prmance Standards,	Number of catalyst la	iyers (R _{iayer})	2
Inlet NO _x Emissions (NOx _{in}) to SCR		Proposed Revisio EPA, Office of Air	ns to NOx Standard, U.S. Quality Planning and	Number of empty cat	talyst layers (R _{emoty})	1
NOx Removal Efficiency (EF) provided by vendor	0.3	Standards, EPA-4	53/R-94-012, June 1997.	Ammonia Slip (Slip) p	rovided by vendor	10 ppm
Stoichiometric Ratio Factor (SRF)		Aurora: Emission 2011 source test	n Inventory rate based or	Volume of the cataly	st layers (Vol _{catalyst})	Simpson, Aaron:
*The SRF value of 0.525 is a default value. User should enter actual value, if known	0.525			(Enter "UNK" if value Flue gas flow rate (Qf	is not known) _{Juegas})	Aurora: Source Test d
S	impson, Aaron: PA's Air Pollution Contr	ol Technology Fact Sheet indicati	ng 70 - 90 percent	(Enter "UNK" if value	is not known)	179,783.2 acfm = 162098.5.
	ontrol. https://www3.e	pa.gov/tthcatc1/dir1/fscr.pdf	1			162098.5 dscf/(1-Bws) acfm; Bws = 0.0984.
Estimated operating life of the catalyst ($H_{catalyst}$)	24,000) hours				
				Gas temperature at t	he SCR inlet (T)	Simpson, Aaron: 310 °F April 7, 2016 Source Test
Estimated SCR equipment life * For industrial boilers, the typical equipment life is between 20 and 25 years.	30	Years*	1	Base case fuel gas vo	lumetric flow rate factor	516 ft ³ /min.MMRtu/hour
Concentration of reagent as stored (C)		percept*	1	(Q _{fuel})		
Density of reagent as stored (ρ_{stored})	50	lh/cubic feet*	*The reagent concentration default values for urea reag	n of 50% and density of 71 lb gent. User should enter actua	os/cft are al values for	
Number of days reagent is stored (t _{storage})	30	days	reagent, if different from th	e default values provided.	Densities of typic	al SCR reagents:
			-		50% urea solutio	n 71 lbs/ft ³
					19% aqueous NH	I ₃ 58 lbs/ft ³
Select the reagent used Urea	•					
Future the cost data for the survey of CCP						
Enter the cost data for the proposed SCR:						
Desired dollar-year	2016	5				
CEPCI for 2016 Annual Interest Rate (i)	536.4	Enter the CEPCI value for 20 Percent	16 584.6 2012 CE	EPCI CE	PCI = Chemical Engineering PI	ant Cost Index
Reagent (Costron)	1.63	S/gallon for a 50 percent sol	ution of urea			
	0.210	Simpson, Aaron:				
Lectricity (Costelect)	0.210	\$/cubic foot (includes remov	www.gvea.com/rates/rate /al and disposal/regene	ation of existing		
Catalyst cost (CC _{replace})	160.00	catalyst and installation of n	ew catalyst*	* \$	160/cf is a default value for the cat	alyst cost. User should enter actual value, if known.
Operator Labor Rate	63.00	\$/hour (including benefits)				

Adopted

November 19, 2019

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Operator Hours/Day

4.00 hours/day*

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:	
Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source
Reagent Cost (\$/gallon)	1.62	Based on the average of vendor quotes from 2011 - 2013.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for utilities is based on 2014 electricity production cost data for fossil-fuel plants compiled by the U.S. Energy Information (EIA). Available at http://www.eia.gov/tools/faqs/faq.cfm?id=19&t=3.	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Percent sulfur content for Coal (% weight)	0.31	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Higher Heating Value (HHV) (Btu/lb)	8,730	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Catalyst Cost (\$/cubic foot)	160	Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emissions Control Technologies", July 2013.	

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q _B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour]
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tscr/tplant) =	0.99	fraction	
Total operating time for the SCR (t_{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(NOxin- NOxout)/NOxin =	80.0	percent	
NOx removed per hour =	$NOx_{in} x EF x Q_B =$	147.11	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	636.77	tons/year	
NOx removal factor (NRF) =	EF/80	1.00		
Volumetric flue gas flow rate (q _{flue gas}) =	Q _{fuel} x QB x (460 + T)/(460 + 700)n _{scr}	179,783	acfm	
Space velocity (V _{space}) =	q _{flue gas} /Vol _{catalyst}	30.03	/hour	
Residence Time	1/V _{space}	0.03	hour	
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO_2 Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not applicable;
Atmospheric pressure at sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	does not apply to plants located at
Retrofit Factor (RF)	Retrofit to existing boiler	1.50		elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Adopted

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)(1/((1+ interest rate) ^Y -1), where Y =	0.216	Franklar
	H _{catalyts} /(t _{SCR} x 24 hours) rounded to the hearest integer	0.316	Fraction
Catalyst volume (Vol _{catalyst}) =	2.81 x Q _B x EF _{adj} x Slipadj x Noxadj x Sadj x (Tadj/Nscr)	5,986.26	Cubic feet
Cross sectional area of the catalyst (A _{catalyst}) =	q _{flue gas} /(16ft/sec x 60 sec/min)	187	ft²
Height of each catalyst layer (H _{layer}) =	$(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$	12	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A _{SCR}) =	1.15 x A _{catalyst}	215	ft ²
Reactor length and width dimentions for a square	(A) 10.5	14.7	foot
reactor =	(A _{SCR})	14.7	leet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	84	feet

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole
		Density =	71 lb/ft ³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	(NOx _{in} x Q _B x EF x SFR x MW _R)/MW _{NOx} =	101	lb/hour
Reagent Usage Rate (m _{sol}) =	m _{reagent} /Csol =	202	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	21	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x t _{storage} x 24)/Reagent Density =	15,296	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n}-1=$	0.0669
	Where n = Equipment Life and i= Interest Rate	

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	A x 1,000 x 0.0056 x (CoalF x HRF) ^{0.43} =	365.95	kW
	where $A = (0.1 \times QB)$ for industrial boilers.		

Cost Estimate

Total Capital Investment (TCI)

TCI for Coal-Fired Boilers					
For Coal-Fired Boilers:					
	$TCI = 1.3 x (SCR_{cost} + RPC + APHC + BPC)$				
Capital costs for the SCR (SCR _{cost}) =	\$14,132,761	in 2016 dollars			
Reagent Preparation Cost (RPC) =	\$2,348,710	in 2016 dollars			
Air Pre-Heater Costs (APHC)* =	\$0	in 2016 dollars			
Balance of Plant Costs (BPC) =	\$3,333,099	in 2016 dollars			
Total Capital Investment (TCI) =	\$25,758,941	in 2016 dollars			
* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 3lb/MMBtu of sulfur dioxide.					
SCR Canital Costs (SCR)					

	$SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (B_{MW} \text{ x} HRF \text{ x} CoalF)^{0.92} \text{ x} ELEVF \text{ x} RF$
For Coal-Fired Industrial Boilers >250 MMBtu/hour:	

 $SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (0.1 \text{ x} Q_B \text{ x} CoalF)^{0.92} \text{ x} ELEVF \text{ x} RF$

SCR Capital Costs (SCR_{cost}) =

For Coal-Fired Utility Boilers >25 MW:

\$14,132,761 in 2016 dollars

Reagent Preparation Costs (RPC)		
For Coal-Fired Utility Boilers >25 MW:		
	RPC = 490,000 x (NO x_{in} x B _{MW} x NPHR x EF) ^{0.25} x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	$RPC = 490,000 \times (NOx_{in} \times Q_B \times EF)^{0.25} \times RF$	
Reagent Preparation Costs (RPC) =		\$2,348,710 in 2016 dollars
	Air Pre-Heater Costs (APHC)*	
For Coal-Fired Utility Boilers >25MW:		
	APHC = 69,000 x (B _{MW} x HRF x CoalF) ^{0.78} x AHF x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	APHC = 69,000 x $(0.1 \text{ x } Q_8 \text{ x CoalF})^{0.78} \text{ x AHF x RF}$	
Air Pre-Heater Costs (APH _{cost}) =		\$0 in 2016 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BPC)		
For Coal-Fired Utility Boilers >25MW:		
BPC = 460,000 x (B _{MW} x HRFx CoalF) ^{0.42} x ELEVF x RF		
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
BPC = $460,000 \times (0.1 \times Q_B \times CoalF)^{0.42}$ ELEVF x RF		
Balance of Plant Costs (BOP _{cost}) =	\$3,333,099 in 2016 dollars	
Annual Costs

Total Annual Cost (TAC) TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$1,193,040 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$1,728,014 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$2,921,054 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)

Annual Maintenance Cost =	0.005 x TCI =	\$128,795 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$297,936 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t _{op} =	\$665,284 in 2016 dollars
Annual Catalyst Replacement Cost =		\$101,026 in 2016 dollars
For coal-fired boilers, the following methods may be used to calcuate the catalyst replacement cost. Method 1 (for all fuel types): $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$ Method 2 (for coal-fired utility boilers): $B_{MW} \times 0.4 \times (CoalF)^{2.9} \times (NRF)^{0.71} \times (CC_{replace}) \times 35.3$		* Calculation Method 1 selected.
Direct Annual Cost =		\$1,193,040 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$4,305 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$1,723,709 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,728,014 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$2,921,054 per year in 2016 dollars
NOx Removed =	637 tons/year
Cost Effectiveness =	\$4,587 per ton of NOx removed in 2016 dollars

Air Pollution Control Cost Estimation Spreadsheet For Selective Non-Catalytic Reduction (SNCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Non-Catalytic Reduction (SNCR) control device. SNCR is a post-combustion control technology for reducing NOx emissions by injecting an ammonia-base reagent (urea or ammonia) into the furnace at a location where the temperature is in the appropriate range for ammonia radicals to react with NOx to form nitrogen and water.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SNCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SNCR control technology and the cost methodologoies, see Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SNCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM). The size and costs of the SNCR are based primarily on four parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, and the reagent consumption. This approach provides study-level estimates (±30%) of SNCR capital and annual costs. Default data in the spreadsheet is taken from the SNCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions, such as the boiler configuration and fuel type. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/power-sector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will reset the NSR, plant elevation, estimated equipment life, desired dollar year, cost index (to match desired dollar year), annual interest rate, unit costs for fuel, electricity, reagent, water and ash disposal, and the cost factors for maintenance cost and administrative charges. All other data entry fields will be blank.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SNCR is for new construction or retofit of an existing boiler. If the SNCR will be installed on an existing boiler, enter a retrofit factor equal to or greater than 0.84. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you selected coal, select the type of coal burned from the drop down menu. The NOx emissions rate, weight percent coal ash and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided.

Step 4: Complete all of the cells highlighted in yellow. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.015 and 0.03, repectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SNCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SNCR.

Adopted

November 19, 2019

Data Inputs				
Enter the following data for your combustion unit:				
Is the combustion unit a utility or industrial boiler?	Industrial 🔻	What type of fuel does the unit burn?		
Please enter a retrofit factor equal to or greater than 0.84 based on the difficulty. Enter 1 for projects of average retrofit difficulty.	ne level of 1.5	* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.		
Complete all of the highlighted data fields:				
What is the maximum heat input rate (QB)?	497 MMBtu/hr	Provide the following information for coal-fired boilers: Type of coal burned: Sub-Bituminous		
What is the higher heating value (HHV) of the fuel?	7,560 Btu/lb	Enter the sulfur content (%S) = 0.20 percent by weight		
		or Select the appropriate SO ₂ emission rate: Not Applicable V		
What is the estimated actual annual fuel consumption?	569,114,000 lbs/year	Ash content (%Ash): 7 percent by weight		
Is the boiler a fluid-bed boiler?	No			
Enter the net plant heat input rate (NPHR)	18 MMBtu/MW	For units burning coal blends: Note: The table below is pre-populated with default values for HH enter the actual values for these parameters in the table below. I' parameter is not known, you may use the default values provided	V, %S, %Ash and cost. Please f the actual value for any	
If the NPHR is not known, use the default NPHR value:	Fuel Type Default NPHR Coal 10 MMBtu/MW Fuel Oil 11 MMBtu/MW Natural Gas 8.2 MMBtu/MW	Fraction in Coal Blend %S %Ash Bituminous C 2.33 10 Sub-Bituminous 1 0.2 1 Lignite C 0.91 1	Fuel Cost HHV (Btu/lb) (\$/MBtu) 11,814 2.79 7 7,560 2.79 8.3 6,534 1.85	
		Please click the calculate button to calculate weighted values based on the data in the table above.		
Enter the following design parameters for the proposed	SNCR:			
Number of days the SNCR operates ($t_{\mbox{\tiny SNCR}}$)	365 days	Plant Elevation 450 Feet above sea level	7	
Inlet NO_x Emissions (NOx_{in}) to SNCR	0.37 lb/MMBtu		_	
"UNK" if value is not known)	40 percent	-		
Estimated Normalized Stoichiometric Ratio (NSR)	1.05	*The NSR value of 1.05 is a default value. User should enter actual value, if know	n.	
Concentration of reagent as stored (C _{stored})	50 percent*	*The reagent concentration of 50% is a default value. User should enter actual va	alue, if known.	
Concentration of reagent injected (C _{ini})	50 percent	Densities of typical SNCR reagents:		
Number of days reagent is stored (t _{storage})	30 days	50% urea solution 71 lbs/ft ³		
Estimated equipment life	20 Years	29.4% aqueous NH ₃ 56 lbs/ft ³		
Select the reagent used	Urea 🔻	19% aqueous NH ₃ 58 lbs/ft ³		

Enter the cost data for the proposed SNCR:

Desired dollar-year	2016	1
CEPCI for 2016	536.4 Enter the CEPCI value for 2016 584.6 2012 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	5.25 Percent	
Fuel (Cost _{fuel})	2.79 \$/MMBtu*	
Reagent (Cost _{reag})	1.62 \$/gallon for a 50 percent solution of urea*	
Water (Cost _{water})	0.0088 \$/gallon*	
Electricity (Cost _{elect})	0.210 \$/kWh	
Ash Disposal (for coal-fired boilers only) (Cost _{ash})	18.00 \$/ton*	
	* The values marked are default values. See the table below for the default values used	-

and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance Cost Factor (MCF) = Administrative Charges Factor (ACF) =

0.015

Data Sources for Default Values Used in Calculations:

			If you used your own site-specific values, please
Data Element	Default Value	Sources for Default Value	
Reagent Cost	\$1.62/gallon of 50% urea solution	Based on vendor quotes collected in 2014.	
Water Cost (S/gallon)	0.0088	Average combined water/wastewater rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest cities-brochure-water-wastewater-rate-survey.pdf.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for industrial plants is based on 2014 price data compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-861 and 861S, (http://www.eia.gov/electricity/data.cfm#sales).	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Fuel Cost (\$/MMBtu)	2.79	Weighted average cost based on average 2014 fuel cost data for power plants compilec by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA 923, "Power Plant Operations Report." Available at http://www.eia.gov/electricity/data/eia923/.	
Ash Disposal Cost (\$/ton)	18	Average ash disposal costs based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	
Percent sulfur content for Coal (% weight)	2.35	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet
Percent ash content for Coal (% weight)	10.40	Average ash content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet
Higher Heating Value (HHV) (Btu/lb)	11,814	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q_B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tSNCR/365) =	0.99	fraction	
Total operating time for the SNCR (t _{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(Noxin - NOxout)/Noxin =	40.00	percent	
NOx removed per hour =	NOx _{in} x EF x Q _B =	73.56	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	318.39	tons/year	
Coal Factor (Coal _F) =	1 for bituminuous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not a
Atmospheric pressure at 450 feet above sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	apply 500 fe
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole

Density = 71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	$(NOx_{in} \times Q_B \times NSR \times MW_R)/(MW_{NOx} \times SR) =$	126	lb/hour
	(whre SR = 1 for NH_3 ; 2 for Urea		
Reagent Usage Rate (m _{sol}) =	mreagent/Csol =	252	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	27	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x tstorage x 24)/Reagent Density =	19,121	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n} - 1 =$	0.0820
	Where n = Equipment Life and i= Interest Rate	

Parameter	Equation	Calculated Value	Units
Electricity Usage: Electrcity Consumption (P) =	(0.47 x NOx _{in} x NSR x Q ₈)/NPHR =	5.04	kW/hour
Water Usage: Water consumption (q _w) =	$(m_{sol}/Density of water) x ((C_{stored}/C_{inj}) - 1) =$	0	gallons/hour
Fuel Data: Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	Hv x m _{reagent} x ((1/C _{inj})-1) =	0.11	MMBtu/hour
Ash Disposal: Additional ash produced due to increased fuel consumption (Δash) =	(Δfuel x %Ash x 1E6)/HHV =	1.05	lb/hour

Cost Estimate

Total Capital Investment (TCI) For Coal-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$ For Fuel Oil and Natural Gas-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$ Capital costs for the SNCR (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* = \$0 in 2016 dollars Balance of Plant Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars Total Capital Investment (TCI) = \$6,208,948 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide. SNCR Capital Costs (SNCR_{cost}) For Coal-Fired Utility Boilers: $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$ For Coal-Fired Industrial Boilers: $SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: SNCR_{cost} = 147,000 x ((Q_B/NPHR)x HRF)^{0.42} x ELEVF x RF SNCR Capital Costs (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* For Coal-Fired Utility Boilers: $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$ For Coal-Fired Industrial Boilers: $APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$ Air Pre-Heater Costs (APH_{cost}) = \$0 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 0.3lb/MMBtu of sulfur dioxide. Balance of Plant Costs (BOP_{cost}) For Coal-Fired Utility Boilers: $BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $BOP_{cost} = 213,000 \text{ x} (B_{MW})^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x RF}$ For Coal-Fired Industrial Boilers: $BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: $BOP_{cost} = 213,000 \text{ x} (Q_{R}/NPHR)^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x} RF$ Balance of Plan Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars

Annual Costs

Total Annual Cost (TAC)

TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$477,565 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$511,631 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$989,197 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$93,134 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$372,444 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t_{op} =	\$9,166 in 2016 dollars
Annual Water Cost =	$q_{water} x Cost_{water} x t_{op} =$	\$0 in 2016 dollars
Additional Fuel Cost =	Δ Fuel x Cost _{fuel} x t _{op} =	\$2,739 in 2016 dollars
Additional Ash Cost =	$\Delta Ash x Cost_{ash} x t_{op} x (1/2000) =$	\$82 in 2016 dollars
Direct Annual Cost =		\$477,565 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,794 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$508,837 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$511,631 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$989,197 per year in 2016 dollars
NOx Removed =	318 tons/year
Cost Effectiveness =	\$3,107 per ton of NOx removed in 2016 dollars

Four Boilers Dry Sorbent Injection System - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Gross Output based on sum of turbines rated size; 20MW, 5MW, and 2.5 MW)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input (Heat Rate is higher because district heating is not included in unit size)
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input (Based on source testing 2011)
Type of Coal	E	(sub-bituminous	< User Input
Particulate Capture	F		Baghouse	< User Input
Milled Trona	G		TRUE	Based on in-line milling equipment
	1			Maximum Removal Targets:
	1			Unmilled Trona with an ESP = 65%
	1			Milled Trona with an ESP = 80%
Removal Target	н	(%)	70	Unmilled Trona with a Bachouse = 80%
	1			Milled Trona with Bachouse = 90%
	1			Simplified correlation: 70% removal with bachouse, S&L (2013)
Heat Input		(Btu/br)	495 000 000	A*C*1000
near mput	,ÿ	(Dtd/III)	433,000,000	1 browned by $1 browned$ and $1 browned$ by $1 browned$ browned by $1 browned$ browned by $1 browned$ browned by $1 browned$ browned
	1			$\frac{1}{2} \frac{1}{2} \frac{1}$
NCD			4 55	$\lim_{n \to \infty} u_n u_n = 1 \text{ for } x_{n-1} (u_n (x_{n-1}) (u_n (x_$
INSK	n n		1.55	$\begin{array}{c} \text{Olymmidd} \text{Torps} \text{with all DGH} = \ (n <40,0.0215 \text{ m}_{0.02356}^{-1}(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{with all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{Torps} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.045(0.0201 \text{ m}_{0.015}^{-1})) \\ \text{Milled} \text{With all DGH} = \ (n <40,0.045(0.04$
	1			$\frac{1}{155} = \frac{1}{1010} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{10000} \frac{1}{10000} \frac{1}{10000000000000000000000000000000000$
	l	(; 7)		1.35 Recommended for a bagnouse at a target of 70% removal. S&L (2013)
Irona Feed Rate	M	(ton/hr)	0.33	(1.2011x10~06)*K*A*C*D
Sorbent Waste Rate	<u>N</u>	(ton/hr)	0.222	(0.7035-0.00073696*H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3.
	1			(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV)
	1			For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000
Fly Ash Waste Rate	Р	(ton/hr)	0.92	For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400
	1			For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200
	1			< User Input (Usibelli Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,560)
Aux Power	Q	(%)	0.24	=if Milled Trona M*20/A else M*18/A
Trona Cost	R	(\$/ton)	550	< User Input (based on Stanley Consultant price reference)
Waste Disposal Cost	s s	(\$/ton)	50	
Aux Power Cost	T T	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Operating Labor Rate		(\$/br)	63	
IPM Model - Updates to Cost and Performat	nce for APC Technologies -	Dry Sorbent Inie	ction for SO2 Control Co	st Development Methodology, March 2013, prepared by Sargent & Lundy LLC for LISEPAhttps://www.epa.gov/sites/production/files/2015
		21) 0012011 11.90	07/	
Capital Cost Calculation (2012 dollars)			017	Comments
				common of the second seco
Includes - Equipment installation buildin	a foundations electrical ar	nd a retrofit diffic	rulty factor of 1.5	
melades - Equipment, installation, buildin	ig, ioundations, electrical, al			
Base Module (BM) (\$)		_	\$ 1/ 169 111	Base DSI module includes all equipment from unloading to injection but not including field installation
Linmilled Trong – if $M > 25$ then (682.00)	0* 8 *M) else 6 833 000* 8 *M	-	φ 14,103,111	base bot module includes all equipment non unloading to injection, but not including net installation
Milled Trona = $if(M>25$ then (750 000*P	3*M) else 7 516 000*B*(M^0	284)		
BM (\$/kW)		-	\$ 515	Base module cost per kW
		-	φ 010	
Total Project Cost				
A1 = 20% of BM		-	\$ 2833 822	Engineering and construction management costs (CC Manual) (Stapley Consultants)
$A^{2} = 10\%$ of BM		_	\$ 1,000,022	Labor adjustment for 6 x 10 hour shift premium per diem etc. (CC Manual)
$A_2 = 10\%$ of BM		_	\$ 1,416,911 \$ 1,416,911	Contractor profit and face (CC Manual) (Stanlay Consultants)
A3 = 10% 01 BM		-	φ 1,410,311	
CECC (\$) - Excludes Owner's Costs -	BM + A1 + A2 + A3	_	\$ 19,836,755	Capital engineering and construction costs subtotal
CECC (\$/kW) - Excludes Owner's Cost		_	¢ 13,030,733 ¢ 721	Capital, organocrima, and construction costs subtatal per kW
CECC (\$KW) - Excludes Owner's Cost	.5	-	φ 721	
B1 = 5% of CECC		=	\$ 991,838	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE	.CC + B1	=	\$ 20,828,593	Total project cost without Allowance for Funds Used During Construction (AFUDC)
TPC (\$/kW) - Include Owner's Costs		=	\$ 757	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)		=		AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2		=	\$ 20,682,000	Total project cost (Spreadsheet = \$20,828,523; Stanley Consultants cost estimate = \$20,682,000)
TPC (\$/kW)		=	\$ 752	Total project cost per kW
1				

Dry Sorbent Injection System - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (2 additional operators)*(2080)*U/(A*1000) FOMM (\$/kW yr) = BM*0.01/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM) FOM (\$/kW yr) = FOMO + FOMM + FOMA	= = =	\$ \$ \$	 9.53 Fixed O&M additional operating labor costs (2 additional operators is more realistic) 3.43 Fixed O&M additional maintenance material and labor costs 0.33 Fixed O&M additional administrative labor costs 13.29 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = M*R/A VOMW (\$/MWh) = (N+P)*S/A VOMP (\$/MWh) = Q*T*10 VOM (\$/MWh) = VOMR + VOMW + VOMP	= = =	\$ \$ \$	 6.64 Variable O&M costs for Trona reagent 2.07 Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection 0.507 Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above) 9.21 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$]i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = = =	\$ \$ \$ \$	219,322 CC Manual 413,640 CC Manual 206,820 CC Manual 206,820 CC Manual Revise interest rate to prime (currently 5.25%) per EPA comment Reality is 10 years of useful life of the oldside; 30 years control equipment lifetime based on EPA comments on ADEC Prelim. BACT 1,383,976 CC Manual 2,430,578 5,015,463
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = =	\$	584.6 536.4 4,601,940
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= = =	\$	781 70 546 8,423

Four Boilers Spray Dry Absorber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on total heat input of 497 MMBtu/hour)
Retrofit Factor	В	· · · /	1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input (SDA FGD Estimation only valid up to 3lb/MMBtu SO2 Rate)
Type of Coal	Е		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous=1.05, Lignite=1.07
Heat Rate Factor	G		1.800	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Lime Rate	К	(ton/hr)	0.122	(0.6702*(D^2)+13.42*D)*A*G/2000 (Based on 95% SO2 Removal)
Waste Rate	L	(ton/hr)	0.280	(0.8016*(D^2)+31.1917*D)*A*G/2000
Aux Power	М	(%)	2.462	(0.000547*(D^2)+0.00649*D+1.3)*F*G Should be used for model input
Makeup Water Rate	N	(1000 gph)	2.876	(0.04898*(D^2)+0.5925*D+55.11)*A*F*G/1000
Lime Cost	Р	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf) (GVEA Limestone cost)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.htm)
Operating Labor Rate	Т	(\$/hr)	63	Labor cost including all benefits
IPM Mo	del - Updates to Cost and Performance for A	PC Technologi	es - SDA EGD for	SO2 Control Cost Development Methodology, March 2013, prepared by Sargent & Lundy LLC for US EPA
	https://	www.epa.gov/s	ites/production/file	se/2015-07/documents/chapter_5_appendix_5-tb_sda_fot_odf
Conital Cost Calculation (2012 dollars)	in point			Commonte anteria de la commonte de l
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildin	ng, foundations, electrical, and a retrofit difficu	ulty factor of 1.5		
BMR (\$) = if(A>600 then (A*92,000) else	566,000*(A^0.716))*B*(F*G)^0.6*(D/4)^0.01	=	\$ 13,028,350	Base module absorber island cost
BMF (\$) = if(A>600 then (A*48,700) else	300,000*(A^0.716))*B*(D*G)^0.2	=	\$ 4,426,798	Base module reagent preparation and waste recycle/handling cost
BMB (\$) = if(A>600 then (A*129,900) els	e 799,000*(A^0.716))*B*(F*G)^0.4	=	\$ 16,587,654	Base module balance of plan costs inlcuding: ID or booster fans, piping, ductwork, electrical, etc.
BM (\$) = BMR + BMF + BMB BM (\$/kW)		= =	\$ 34,042,802 \$ 1,238	Total base module cost including retrofit factor Base module cost per kW
Total Project Cost				
A1 = 10% of BM		=	\$ 3,404,280	Engineering and construction management costs
A2 = 10% of BM		=	\$ 3,404,280	Labor adjustment for 6 x 10 hour shift premium, per diem, etc.
A3 = 10% of BM		=	\$ 3,404,280	Contractor profit and fees
			, . ,	
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cost	BM + A1 + A2 + A3 s =	= =	\$ 44,255,642 \$ 1,609	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,212,782	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	CC + B1	=	\$ 46,468,425 \$ 1,690	Total project cost without Allowance for Funds Used During Construction (AFUDC)
B2 = 10% of (CECC + B1)		=	\$ 4,646,842	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and	AFUDC = CECC + B1 + B2	=	\$ 51,115,267	Total project cost
TPC (\$/kW) - Includes Owner's Costs a	and AFUDC =	=	\$ 1,859	Total project cost per kW

Spray Dry Absorber - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (4 additional operators)*(2080)*T/(A*1000) FOMM (\$/kW yr) = BM*0.015/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	= = =	\$ \$ \$	 38.12 Fixed O&M additional operating labor costs 12.38 Fixed O&M additional maintenance material and labor costs 1.29 Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	=	\$	51.79 Total Fixed O&M costs
Variable O&M Cost			
VOMR (\$/MWh) = K*P/A	=	\$	1.06 Variable O&M costs for lime reagent
VOMW (\$/MWh) = L*Q/A	=	\$	0.31 Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	=	\$	5.17 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	=	\$	0.75 Variable O&M costs for makeup water
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM	=	\$	7.29 Total Variable O&M Costs
Indirect Annual Costs			
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 525	= = = =	\$ \$ \$ \$	854,570 CC Manual 1,022,305 CC Manual 511,153 CC Manual 511,153 CC Manual
n = Equipment life (years) 30 CRF = 0.0669	=	\$	3,420,477 CC Manual
TOTAL INDIRECT ANNUAL OPERATING COSTS	=	\$	6,319,657
TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	=	\$	9,499,458
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	=		584.6 536.4
TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	=	\$	8,716,232
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons	=		781
SO ₂ REMOVAL EFFICIENCY, %	=		90
TOTAL SO ₂ REMOVED, tons	=		702
SO ₂ COST-EFFECTIVENESS, \$/ton removed	=	\$	12,408

Four Boilers Wet Scrubber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on a total heat input of 497 MMBtu/hr)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0) Sargent and Lundy has a drop down menu for selection of an additional waste water treatment plant facility, but no capital or operational cost are implemented so it is not reproduced here.
Gross Heat Rate	С	(Btu/kWh)	18.000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input
Type of Coal	E		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous = 1.05, Lignite = 1.07
Heat Rate Factor	G		1.8	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Limestone Rate	К	(ton/hr)	0.16	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	0.283	1.811*K
Aux Power	М	(%)	2.098	(1.05e^(0.155*D))*F*G
Makeup Water Rate	N	(1000 gph)	3.913	(1.674*D+74.68)*A*F*G/1000
Limestone Cost	Р	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ftdg.pdf)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ftdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.html)
Operating Labor Rate	Т	(\$/hr)	63	Labor cost including all benefits
IPM Model -	Updates to Cost and Performance for APC 1 https://www	Fechnologies - W v.epa.gov/sites/p	et FGD for SO2 Co roduction/files/2015-	ntrol Cost Development Methodology, August 2010, prepared by Sargent & Lundy LLC for US EPA. 07/documents/chapter_5_appendix_5-1a_wet_fgd.pdf
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildin BMR (\$) = 550,000*(B)*((F*G)^0.6)*((D/	ng, foundations, electrical, minor physical/cho 2)^0.02)*(A^0.716)	emical waste wa =	ter treatment, and a \$ 12,531,374	retrofit difficulty factor of 1.5 Base absorber island cost
BMF (\$) = 190,000*(B)*((D*G)^0.3)*(A^0).716)	=	\$ 2,684,600	Base reagent preparation cost
BMW (\$) = 100,000*(B)*((D*G)^0.45)*(A	^0.716)	=	\$ 1,323,921	Base waste handling cost
BMB (\$) = 1,010,000*(B)*((F*G)^0.4)*(A	^0.716)	=	\$ 20,968,123	Base balance of plan cost including: ID or booster fans, new wet chimney, piping, ductwork, minor waste water treatment, etc
BMWW (\$) =		=	\$ -	Base wastewater treatment facility, beyond minor physical/chemcial treatment
Base Module (BM) (\$) = BMR + BMF + BM (\$/kW)	BMW + BMB + BMWW	= =	\$ 37,508,019 \$ 1,364	Total base cost including retrofit factor Base cost per kW
Total Project Cost				
A1 = 10% of BM A2 = 10% of BM A3 = 10% of BM		= = =	\$ 3,750,802 \$ 3,750,802 \$ 3,750,802 \$ 3,750,802	Engineering and construction management costs (CC Manual) Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual) Contractor profit and fees (CC Manual)
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cos	BM + A1 + A2 + A3 ts =	= =	\$ 48,760,424 \$ 1,773	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,438,021	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	ECC + B1	= =	\$ 51,198,446 \$ 1,862	Total project cost without Allowance for Funds Used During Construction (AFUDC) Total project cost per kW without AFUDC
B2 = 10% of (CECC + B1)		=	\$ 5,119,844.55	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and TPC (\$/kW) - Includes Owner's Costs	AFUDC = CECC + B1 + B2 and AFUDC =	= =	\$ 56,318,290 \$ 2,048	Total project cost Total project cost per kW

Wet Scrubber - Chena Power Plant

	_		
Direct Annual Costs			
Fixed U&M Cost			
FOMO ($\frac{1}{k}$ vr) = (6 additional operators)*(2080)* T/(A*1000)	=	\$	28.59 Fixed O&M additional operating labor costs
FOMM ($\frac{1}{k}$ vr) = BM*0.015/(B*A*1000)	=	\$	13.64 Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	=	\$	1.02 Fixed Q&M additional administrative labor costs
FOMWW (\$/kW yr) =		\$	- Fixed O&M costs for wastewater treatment facility
		•	
	=	φ	43.25 Total Fixed U&M Costs (arkiv yr)
Variable O&M Cost			
		•	
VOMR (\$/MWh) = K*P/A	=	\$	1.36 Variable O&M costs for limestone reagent
VOMW (\$/MWh) = L*Q/A	=	\$	0.31 Variable O&M costs for waste disposal
		•	
$VOMP (\$/MWh) = M^*R^*10$	=	\$	4.41 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	=	\$	1.02 Variable O&M costs for makeup water
	-	\$	- Variable ORM costs for wastewater treatment facility
	-	Ψ	
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW	=	\$	7.10 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs	_		
Overhead (60% of total labor and material costs)	=	\$	713,645 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment)	=	\$ \$	713,645 CC Manual 1,126,366 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment)	= = =	\$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment)	= = = =	\$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n] / [(1+i)^n - 1]$	= = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25	= = =	\$\$ \$\$ \$\$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30	= = =	\$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1]i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669	= = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS	= = = =	\$ \$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6.735.024
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1]i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669TOTAL INDIRECT ANNUAL OPERATING COSTS	= = = =	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Linsurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation)	= = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	= = = = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	- - - - - -	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = =	\$ \$ \$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = = = =	\$ \$ \$ \$ \$	713.645 CC Manual 1,126.366 CC Manual 563.183 CC Manual 563.183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons	= = = = = = = = =	\$\$\$\$ \$ \$ \$	713.645 CC Manual 1.126.366 CC Manual 563.183 CC Manual 563.183 CC Manual 3.768.647 CC Manual 6.735.024 9.634.230 584.6 536.4 8.839.892 781
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY. %	= = = = = = = = = =	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO- REMOVED tons	-	\$\$\$\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99 773
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Linsurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons		\$\$\$\$\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99 773
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed		\$\$\$\$\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99 773 11,440 Does not include costs associated with building and maintaining a wastewater treatment facility

Appendix B (Economic Analysis Spreadsheets – V2)

Air Pollution Control Cost Estimation Spreadsheet

For Selective Catalytic Reduction (SCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Catalytic Reduction (SCR) control device. SCR is a post-combustion control technology for reducing NO_x emissions that employs a metal-based catalyst and an ammonia-based reducing reagent (urea or ammonia). The reagent reacts selectively with the flue gas NO_x within a specific temperature range to produce N₂ and water vapor.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SCR control technology and the cost methodologies, see Section 4, Chapter 2 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM) (version 5.13). The size and costs of the SCR are based primarily on five parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, reagent consumption rate, and catalyst costs. The equations for utility boilers are identical to those used in the IPM. However, the equations for industrial boilers were developed based on the IPM equations for utility boilers. This approach provides study-level estimates (±30%) of SCR capital and annual costs. Default data in the spreadsheet is taken from the SCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/powersector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will clear many of the input cells and reset others to default values.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SCR is for new construction or retofit of an existing boiler. If the SCR will be installed on an existing boiler, enter a retrofit factor between 0.8 and 1.5. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you select fuel oil or natural gas, the HHV and NPHR fields will be prepopulated with default values. If you select coal, then you must complete the coal input box by first selecting the type of coal burned from the drop down menu. The weight percent sulfur content, HHV, and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided. Method 1 is pre-selected as the default method for calculating the catalyst replacement cost. For coal-fired units, you choose either method 1 or method 2 for calculating the catalyst replacement cost.

Step 4: Complete all of the cells highlighted in yellow. If you do not know the catalyst volume (Vol catalyst) or flue gas flow rate (Q_{flue gas}), please enter "UNK" and these values will be calculated for you. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.005 and 0.03, respectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SCR.

Adopted

November 19, 2019

		Data Ir	nputs			
Enter the following data for your combustion unit:						
Is the combustion unit a utility or industrial boiler?	al 🔻		What type of fu	el does the unit burn?	Coal	
Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit	•					
Please optor a retrofit factor between 0.9 and 1.5 based on the level of diffi	culty Entor 1 for		Simpson, Aaron:			
projects of average retrofit difficulty.	uity. Enter 1 for	1.5	No basis was provided ap for installation of select	I to justify a retrofit factor ctive catalytic reduction or	reflecting greater than average the boilers.	difficulty
			High retrofit cost facto	ors may be justified in unu	sual circumstances (e.g., long a	nd
Complete all of the highlighted data fields:			unique ductwork and additional engineering	piping, site preparation, ti , and asbestos abatement	ght fits, helicopter or crane insta).	allation,
			Aurora: Location of the	he catalyst, if it has to be	installed within a temperature ra	ange of
What is the rating at full load capacity (MMBtu/hr)?	497 M	MBtu/hr	500-800F, would be t It's a titght fit, limited	he top of the boilers just space, asbestos abateme	before the economizer and air p nt necessary, duct work is comp	reheater. lex and
What is the higher heating value (HHV) of the fuel?	7,560 Bt	u/lb	Enter the sulfur	content (%S) =	0.20 percent by weig	ht
	Si Ty	mpson, Aaron: pical Gross As Received. http	://www.usibelli.com/coal/	data-sheet	Simpson, Aaro Typical Gross As	n: Received. http://www.usibelli.com/coal/data-sheet
What is the estimated actual annual fuel consumption?	569,114,000 lbs	s/year	For units burnin	ur coal blonds:	_	
			For units burnin	ile table below is pro p	opulated with default values	for HHV and P/C. Diagra enter the actual values
			for the	se parameters in the tal	ble below. If the actual value	for any parameter is not known, you may use
Enter the net plant heat input rate (NPHR)	18 M	MBtu/MW	the def	ault values provided.		
			-	F	raction in	HUN/ (Dec./Ib)
If the NPHR is not known, use the default NPHR value:	Fuel Type De	efault NPHR		Bituminous	0 2.35	; 11,814
	Coal 10 Fuel Oil 11) MMBtu/MW L MMBtu/MW	Si	ub-Bituminous Lignite	1 0.2 0 0.91	6,534
	Natural Gas 8.	2 MMBtu/MW	Please	click the calculate butto	n to calculate weighted	
			values l	based on the data in the	e table above.	
Plant Elevation	450 Fe	et above sea level	For coal-fired b	poilers, you may use e	either Method 1 or Methor	12 to calculate
			the catalyst re	placement cost. The	equations for both method	ds are shown on
			rows 85 and 80 method:	6 on the Cost Estimat	e tab. Please select your p	Preferred ONot applicable
Enter the following design parameters for the proposed SCR	:					
Number of days the SCR operates (t_{scr})		Simpson, Aaro] n:	Number of SCR react	or chambers (n _{srr})	
Number of days the bailer energies $(t =)$	365 da	Assuming baselin New Source Perf	ne of 0.5 lb/MMBtu from ormance Standards,	Number of catalyst is	wors (P	1
Number of days the bolier operates (t _{plant})	365 da	Subpart Da – Ter Proposed Revisio	chnical Support for ons to NOx Standard, U.S.	Number of catalyst is	iyers (N _{layer})	3
Inlet NO _x Emissions (NOx _{in}) to SCR	0.37 lb	/MMBtu EPA, Office of Air Standards, EPA-4	r Quality Planning and 453/R-94-012, June 1997.	Number of empty cat	talyst layers (R _{empty})	1
NOx Removal Efficiency (EF) provided by vendor	80 pe	ercent Aurora: Emissio	n Inventory rate based or	Ammonia Slip (Slip) p	rovided by vendor	10 ppm
Stoichiometric Ratio Factor (SRF)	0.525	2011 source test	ing.	Volume of the catalyst layers (Vol _{catalyst}) (Enter "UNK" if value is not known) UNK Cybic feed		
*The SRF value of 0.525 is a default value. User should enter actual value, if known. S	impson, Aaron:			Flue gas flow rate (Q	_{luegas}) is not known)	Aurora: Source Test ds
	PA's Air Pollution Control To ontrol. https://www3.epa.g	echnology Fact Sheet indicati pv/ttncatc1/dir1/fscr.pdf	ing 70 - 90 percent			1/9,/03.2 dcffi 162098.5 dscf/(1-Bws)
_			1			acfm; Bws = 0.0984.
Estimated operating life of the catalyst (H _{catalyst})	24,000 ho	ours	-			
Estimated SCR equinment life	15 Ye	ars*		Gas temperature at t	he SCR inlet (T)	310 °F April 7, 2016 Source Test
* For industrial boilers, the typical equipment life is between 20 and 25 years.			3	Base case fuel gas vo	lumetric flow rate factor	516 ft ³ /min-MMBtu/hour
Concentration of reagent as stored (C)	50 pc	ercent*	1	(U _{fuel})		
Density of reagent as stored (p _{stored})	71 lb	/cubic feet*	*The reagent concentration default values for urea reag	n of 50% and density of 71 lb gent. User should enter actu	os/cft are al values for	
Number of days reagent is stored (t _{storage})	30 da	ays	reagent, if different from th	ne default values provided.	Densities of typi	cal SCR reagents:
			-		50% urea solutio	on 71 lbs/ft ³
					29.4% aqueous 19% aqueous N	NH ₃ 56 lbs/ft ³
Select the reagent used Urea	•				3440003 11	55 luspit
Enter the cost data for the proposed SCR:						
Desired dollar-year	2016					
CEPCI for 2016	536.4 En	ter the CEPCI value for 20	16 584.6 2012 C	EPCI CE	PCI = Chemical Engineering P	lant Cost Index
Annual Interest Rate (i)	5.25 Pe	ercent				
Reagent (Cost _{reag})	1.62 \$/	gallon for a 50 percent sol	lution of urea			
Electricity (Cost _{elect})	0.210 \$/	kWh GVEA rates. http://	/www.gvea.com/rates/rate	•S		
	\$/	cubic foot (includes removing talvst and installation of p	val and disposal/regene ew catalyst*	ration of existing	160/cf is a default value for the co	talvst cost. User should enter actual value, if known
Operator Labor Pat-	100.00 ta	hour (inclusive hour Ch.)		° ÷	Looper is a denaure volue for the Ca	angen ober sindere enter octuer volue, il Miluwii.
Operator Labor Kate	63.00 \$/	nour (including benefits)				

Adopted

November 19, 2019

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Operator Hours/Day

4.00 hours/day*

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:	
Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source
Reagent Cost (\$/gallon)	1.62	Based on the average of vendor quotes from 2011 - 2013.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for utilities is based on 2014 electricity production cost data for fossil-fuel plants compiled by the U.S. Energy Information (EIA). Available at http://www.eia.gov/tools/faqs/faq.cfm?id=19&t=3.	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Percent sulfur content for Coal (% weight)	0.31	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Higher Heating Value (HHV) (Btu/lb)	8,730	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Catalyst Cost (\$/cubic foot)	160	Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emissions Control Technologies", July 2013.	

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q_B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour]
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tscr/tplant) =	0.99	fraction	
Total operating time for the SCR (t_{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(NOxin- NOxout)/NOxin =	80.0	percent	
NOx removed per hour =	$NOx_{in} x EF x Q_B =$	147.11	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	636.77	tons/year	
NOx removal factor (NRF) =	EF/80	1.00		
Volumetric flue gas flow rate (q _{flue gas}) =	Q _{fuel} x QB x (460 + T)/(460 + 700)n _{scr}	179,783	acfm	
Space velocity (V _{space}) =	q _{flue gas} /Vol _{catalyst}	30.03	/hour	
Residence Time	1/V _{space}	0.03	hour	
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not applicable;
Atmospheric pressure at sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	does not apply to plants located at
Retrofit Factor (RF)	Retrofit to existing boiler	1.50		elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Adopted

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)(1/((1+ interest rate) ^Y -1), where Y =	0.216	Fraction
	H _{catalyts} /(I _{SCR} x 24 hours) rounded to the hearest integer	0.316	Fraction
Catalyst volume (Vol _{catalyst}) =	2.81 x Q_8 x EF _{adj} x Slipadj x Noxadj x Sadj x (Tadj/Nscr)	5,986.26	Cubic feet
Cross sectional area of the catalyst $(A_{catalyst}) =$	q _{flue gas} /(16ft/sec x 60 sec/min)	187	ft²
Height of each catalyst layer (H _{layer}) =	(Vol _{catalyst} /(R _{layer} x A _{catalyst})) + 1	12	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A _{SCR}) =	1.15 x A _{catalyst}	215	ft ²
Reactor length and width dimentions for a square	()0.5	14.7	foot
reactor =	(A _{SCR})	14.7	
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	84	feet

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole
		Density =	71 lb/ft ³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	(NOx _{in} x Q _B x EF x SFR x MW _R)/MW _{NOx} =	101	lb/hour
Reagent Usage Rate (m _{sol}) =	m _{reagent} /Csol =	202	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	21	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x t _{storage} x 24)/Reagent Density =	15,296	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n}-1=$	0.0980
	Where n = Equipment Life and i= Interest Rate	

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	A x 1,000 x 0.0056 x (CoalF x HRF) ^{0.43} =	365.95	kW
	where $A = (0.1 \times QB)$ for industrial boilers.		

Cost Estimate

Total Capital Investment (TCI)

For Coal-Fired Boilers: TCI = 1.3 x (SCR _{cost} + RPC + APHC + BPC) Capital costs for the SCR (SCR _{cost}) = \$14,132,761 in 2016 dollars Reagent Preparation Cost (RPC) = \$2,348,710 in 2016 dollars Air Pre-Heater Costs (APHC)* = \$0 in 2016 dollars Balance of Plant Costs (BPC) = \$3,333,099 in 2016 dollars Total Capital Investment (TCI) = \$25,758,941 in 2016 dollars	TCI for Coal-Fired Boilers				
TCI = 1.3 x (SCR _{cost} + RPC + APHC + BPC) Capital costs for the SCR (SCR _{cost}) = \$14,132,761 Reagent Preparation Cost (RPC) = \$2,348,710 Air Pre-Heater Costs (APHC)* = \$0 Balance of Plant Costs (BPC) = \$25,758,941 Total Capital Investment (TCI) =	For Coal-Fired Boilers:				
Capital costs for the SCR (SCR _{cost}) =\$14,132,761in 2016 dollarsReagent Preparation Cost (RPC) =\$2,348,710in 2016 dollarsAir Pre-Heater Costs (APHC)* =\$0in 2016 dollarsBalance of Plant Costs (BPC) =\$3,333,099in 2016 dollarsTotal Capital Investment (TCI) =\$25,758,941in 2016 dollars		TCI = 1.3 x (SCR _{cost} + RPC + APHC + BPC)			
Capital costs for the SCR (SCR _{cost}) =\$14,132,761in 2016 dollarsReagent Preparation Cost (RPC) =\$2,348,710in 2016 dollarsAir Pre-Heater Costs (APHC)* =\$0in 2016 dollarsBalance of Plant Costs (BPC) =\$3,333,099in 2016 dollarsTotal Capital Investment (TCI) =\$25,758,941in 2016 dollars					
Reagent Preparation Cost (RPC) =\$2,348,710in 2016 dollarsAir Pre-Heater Costs (APHC)* =\$0in 2016 dollarsBalance of Plant Costs (BPC) =\$3,333,099in 2016 dollarsTotal Capital Investment (TCI) =\$25,758,941in 2016 dollars	Capital costs for the SCR (SCR _{cost}) =	\$14,132,761	in 2016 dollars		
Air Pre-Heater Costs (APHC)* =\$0in 2016 dollarsBalance of Plant Costs (BPC) =\$3,333,099in 2016 dollarsTotal Capital Investment (TCI) =\$25,758,941in 2016 dollars	Reagent Preparation Cost (RPC) =	\$2,348,710	in 2016 dollars		
Balance of Plant Costs (BPC) = \$3,333,099 in 2016 dollars Total Capital Investment (TCI) = \$25,758,941 in 2016 dollars	Air Pre-Heater Costs (APHC)* =	\$0	in 2016 dollars		
Total Capital Investment (TCI) – \$25,758,941 in 2016 dollars	Balance of Plant Costs (BPC) =	\$3,333,099	in 2016 dollars		
	Total Capital Investment (TCI) =	\$25,758,941	in 2016 dollars		
* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 3lb/MMBtu of sulfur dioxide.	* Not applicable - This factor applies only to coal-fired bo	ilers that burn bituminous coal and emits equal to or greater than 3lb/MMBtu of sulfu	ur dioxide.		
		SCR Capital Costs (SCR _{cost})			
SCR Capital Costs (SCR _{cost})	For Coal-Fired Utility Boilers >25 MW:				

	$SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (B_{MW} \text{ x} HRF \text{ x} CoalF)^{0.92} \text{ x} ELEVF \text{ x} RF$
For Coal-Fired Industrial Boilers >250 MMBtu/hour:	

 $SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (0.1 \text{ x} Q_B \text{ x} CoalF)^{0.92} \text{ x} ELEVF \text{ x} RF$

SCR Capital Costs (SCR_{cost}) =

\$14,132,761 in 2016 dollars

	Reagent Preparation Costs (RPC)	
For Coal-Fired Utility Boilers >25 MW:		
	RPC = 490,000 x (NO x_{in} x B _{MW} x NPHR x EF) ^{0.25} x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	RPC = 490,000 x (NOx _{in} x Q _B x EF) ^{0.25} x RF	
Reagent Preparation Costs (RPC) =		\$2,348,710 in 2016 dollars
	Air Pre-Heater Costs (APHC)*	
For Coal-Fired Utility Boilers >25MW:		
	APHC = 69,000 x (B _{MW} x HRF x CoalF) ^{0.78} x AHF x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	APHC = 69,000 x (0.1 x Q ₈ x CoalF) ^{0.78} x AHF x RF	
Air Pre-Heater Costs (APH _{cost}) =		\$0 in 2016 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

	Balance of Plant Costs (BPC)
For Coal-Fired Utility Boilers >25MW:	
BPC = 460	000 x (B _{MW} x HRFx CoalF) ^{0.42} x ELEVF x RF
For Coal-Fired Industrial Boilers >250 MMBtu/hour:	
BPC = 46	$0,000 \times (0.1 \times Q_B \times CoalF)^{0.42} ELEVF \times RF$
Balance of Plant Costs (BOP _{cost}) =	\$3,333,099 in 2016 dollars

Annual Costs

Total Annual Cost (TAC) TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$1,193,040 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$2,528,093 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$3,721,132 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)

Annual Maintenance Cost =	0.005 x TCI =	\$128,795 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$297,936 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t _{op} =	\$665,284 in 2016 dollars
Annual Catalyst Replacement Cost =		\$101,026 in 2016 dollars
For coal-fired boilers, the following methods may be used to calcuate the catalyst replacement cost. Method 1 (for all fuel types): $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$ Method 2 (for coal fired utility boilors): $R_{res} \propto 0.4 \times (CoalE)^{2.9} \times (NPE)^{0.71} \times (CC_{res}) \times 25.2$		* Calculation Method 1 selected.
Direct Annual Cost =		\$1,193,040 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$4,305 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$2,523,788 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$2,528,093 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$3,721,132 per year in 2016 dollars
NOx Removed =	637 tons/year
Cost Effectiveness =	\$5,844 per ton of NOx removed in 2016 dollars

Air Pollution Control Cost Estimation Spreadsheet For Selective Non-Catalytic Reduction (SNCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Non-Catalytic Reduction (SNCR) control device. SNCR is a post-combustion control technology for reducing NOx emissions by injecting an ammonia-base reagent (urea or ammonia) into the furnace at a location where the temperature is in the appropriate range for ammonia radicals to react with NOx to form nitrogen and water.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SNCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SNCR control technology and the cost methodologoies, see Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SNCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM). The size and costs of the SNCR are based primarily on four parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, and the reagent consumption. This approach provides study-level estimates (±30%) of SNCR capital and annual costs. Default data in the spreadsheet is taken from the SNCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions, such as the boiler configuration and fuel type. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/power-sector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will reset the NSR, plant elevation, estimated equipment life, desired dollar year, cost index (to match desired dollar year), annual interest rate, unit costs for fuel, electricity, reagent, water and ash disposal, and the cost factors for maintenance cost and administrative charges. All other data entry fields will be blank.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SNCR is for new construction or retofit of an existing boiler. If the SNCR will be installed on an existing boiler, enter a retrofit factor equal to or greater than 0.84. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you selected coal, select the type of coal burned from the drop down menu. The NOx emissions rate, weight percent coal ash and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided.

Step 4: Complete all of the cells highlighted in yellow. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.015 and 0.03, repectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SNCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SNCR.

Adopted

November 19, 2019

							Data Inputs				
Enter the following	data for your combustion unit:										
Is the combustion unit a Is the SCR for a new boi	autility or industrial boiler? ler or retrofit of an existing boiler?	Industrial 💌]	Wh	at type of fuel does the unit l	burn? Co	al 🗸				
Please enter a retrofit fa difficulty. Enter 1 for pr	actor equal to or greater than 0.84 based on ojects of average retrofit difficulty.	the level of	1.5	* NOTE: You for the prope	must document why a retrofit facto ssed project.	or of 1.5 is appropria	te				
Complete all of the high	lighted data fields:										
				Pro	vide the following information	n for coal-fired be	oilers:				
What is the ma	ximum heat input rate (QB)?	497	MMBtu/hr	Тур	e of coal burned:	Sub-Bituminous	•				
What is the hig	her heating value (HHV) of the fuel?	7,560	Btu/lb	Ente	er the sulfur content (%S) =	0.3	20 percent by weight				
What is the esti	imated actual annual fuel consumption?	569,114,000	lbs/year	or Sele	ct the appropriate SO_2 emiss	ion rate:	Not Applicable				
Is the boiler a f	luid-bed boiler?	No		Ash	content (%Ash):		7 percent by weight				
Enter the net pl	lant heat input rate (NPHR) tot known, use the default NPHR value:	Fuel Type Coal Fuel Oil Natural Gas	MMBtu/MW Default NPHR 10 MMBtu/MW 11 MMBtu/MW 8.2 MMBtu/MW	For	units burning coal blends: Note: The table below is enter the actual values f parameter is not known, <u>Bituminous</u> <u>Sub-Bituminous</u> <u>Lignite</u> Please click the calculate values based on the data	pre-populated w for these parame you may use the Fraction in Coal Blend button to calcula a in the table abo	vith default values for HHV ters in the table below. If default values provided. 9 95 %Ash 0 2.35 10 1 0.2 0 0.91 14 ate weighted ve.	r, %S, %Ash and cost. Please the actual value for any HHV (Btu/Ib) (S/MMBtu) 4 11,814 2.79 7 7,560 2.79 3 6,534 1.85			
Enter the following	design parameters for the propose	ed SNCR:									
Number of day:	s the SNCR operates (t _{sNCR})	365	days		Plant Elevation	4	50 Feet above sea level				
Inlet NO _x Emiss	ions (NOx _{in}) to SNCR	0.37	lb/MMBtu								
NOx Removal "UNK" if value	Efficiency (EF) provided by vendor (Enter is not known)	40	percent								
Estimated Norn	nalized Stoichiometric Ratio (NSR)	1.05		*The NSR	value of 1.05 is a default valu	e. User should er	nter actual value, if known	L.			
Concentration of	of reagent as stored (C _{stored})	50	percent*	*The reag	ent concentration of 50% is a	default value. Us	ser should enter actual val	ue, if known.			
Denisty of reag	ent as stored (ρ _{stored})	71	lb/ft ³			1		-			
Concentration of day	of reagent injected (C _{inj})	50	percent		Densities of typic	al SNCR reagents	5: 71 lbs/ft ³				
Estimated equi	nment life	15	Years		29.4% ag	ueous NH ₂	56 lbs/ft ³				
Colort the re-	ant used	Urea]	19% aqu	Jeous NH ₃	58 lbs/ft ³				
Select the reage	ent used										

Enter the cost data for the proposed SNCR:

Desired dollar-year	2016	
CEPCI for 2016	536.4 Enter the CEPCI value for 2016 584.6 2012 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	5.25 Percent	
Fuel (Cost _{fuel})	2.79 \$/MMBtu*	
Reagent (Cost _{reag})	1.62 \$/gallon for a 50 percent solution of urea*	
Water (Cost _{water})	0.0088 \$/gallon*	
Electricity (Cost _{elect})	0.210 \$/kWh	
Ash Disposal (for coal-fired boilers only) (Cost _{ash})	18.00 \$/ton*	
	* The values marked are default values. See the table below for the default values used	_

and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance Cost Factor (MCF) = Administrative Charges Factor (ACF) =

0.015

Data Sources for Default Values Used in Calculations:

			If you used your own site-specific values, please enter the the value used and the reference source .
Data Element	Default Value	Sources for Default Value	
Reagent Cost	\$1.62/gallon of	Based on vendor quotes collected in 2014.	
	50% urea		
	solution		
Water Cost (\$/gallon)	0.0088	Average combined water/wastewater rates for industrial facilities in 2013 compiled by	
		Available at http://www.saws.org/who.we.are/community/RAC/docs/2014/50-largest	
		cities-brochure-water-wastewater-rate-survey odf	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for industrial plants is based on 2014 price data	\$0.210/kWh GVEA rates.
		compiled by the U.S. Energy Information Administration (EIA) from data reported on	http://www.gvea.com/rates/rates
		EIA Form EIA-861 and 861S, (http://www.eia.gov/electricity/data.cfm#sales).	
Fuel Cost (\$/MMBtu)	2.79	Weighted average cost based on average 2014 fuel cost data for power plants compiled	1
		by the U.S. Energy Information Administration (EIA) from data reported on EIA Form El	
		923, "Power Plant Operations Report." Available at	
		http://www.eia.gov/electricity/data/eia923/.	
Ash Disposal Cost (\$/ton)	18	Average ash disposal costs based on U.S. coal data for 2014 compiled by the U.S.	
		Energy Information Administration (EIA) from data reported on EIA Form EIA-923,	
		Power Plant Operations Report. Available at	
		http://www.eia.gov/electricity/data/eia923/.	
Percent sulfur content for Coal (% weight)	2.35	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy	0.20 percent (Typical Gross As Received). Coal data
		Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	
Percent ash content for Coal (% weight)	10.40	Average ash content based on U.S. coal data for 2014 compiled by the U.S. Energy	7 percent (Typical Gross As Received). Coal data
		Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	
Higher Heating Value (HHV) (Btu/lb)	11 814	2014 coal data compiled by the Office of Oil Gas, and Coal Supply Statistics, U.S. Energy	7 560 Btu/lb (Typical Gross As Received) Coal data
	11,014	Information Administration (FIA) from data reported on FIA Form FIA-923 Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q_B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tSNCR/365) =	0.99	fraction	
Total operating time for the SNCR (t _{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(Noxin - NOxout)/Noxin =	40.00	percent	
NOx removed per hour =	NOx _{in} x EF x Q _B =	73.56	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	318.39	tons/year	
Coal Factor (Coal _F) =	1 for bituminuous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not a
Atmospheric pressure at 450 feet above sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	apply 500 fe
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole

Density = 71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	$(NOx_{in} \times Q_B \times NSR \times MW_R)/(MW_{NOx} \times SR) =$	126	lb/hour
	(whre SR = 1 for NH_3 ; 2 for Urea		
Reagent Usage Rate (m _{sol}) =	mreagent/Csol =	252	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	27	gal/hour
Estimated tank volume for reagent storage =		19 121	gallons (storage needed to store a 30 day reagent supply)
	(m _{sol} x 7.4805 x tstorage x 24)/Reagent Density =	15,121	

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n} - 1 =$	0.0980
	Where n = Equipment Life and i= Interest Rate	

Parameter	Equation	Calculated Value	Units
Electricity Usage: Electrcity Consumption (P) =	(0.47 x NOx _{in} x NSR x Q _B)/NPHR =	5.04	kW/hour
Water Usage: Water consumption (q _w) =	$(m_{sol}/Density of water) \times ((C_{stored}/C_{inj}) - 1) =$	0	gallons/hour
Fuel Data: Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	Hv x m _{reagent} x ((1/C _{inj})-1) =	0.11	MMBtu/hour
Ash Disposal: Additional ash produced due to increased fuel consumption (Δash) =	(Δfuel x %Ash x 1E6)/HHV =	1.05	lb/hour

Cost Estimate

Total Capital Investment (TCI) For Coal-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$ For Fuel Oil and Natural Gas-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$ Capital costs for the SNCR (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* = \$0 in 2016 dollars Balance of Plant Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars Total Capital Investment (TCI) = \$6,208,948 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide. SNCR Capital Costs (SNCR_{cost}) For Coal-Fired Utility Boilers: $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$ For Coal-Fired Industrial Boilers: $SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: SNCR_{cost} = 147,000 x ((Q_B/NPHR)x HRF)^{0.42} x ELEVF x RF SNCR Capital Costs (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* For Coal-Fired Utility Boilers: $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$ For Coal-Fired Industrial Boilers: $APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$ Air Pre-Heater Costs (APH_{cost}) = \$0 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 0.3lb/MMBtu of sulfur dioxide. Balance of Plant Costs (BOP_{cost}) For Coal-Fired Utility Boilers: $BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $BOP_{cost} = 213,000 \text{ x} (B_{MW})^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x RF}$ For Coal-Fired Industrial Boilers: $BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: $BOP_{cost} = 213,000 \text{ x} (Q_{R}/NPHR)^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x} RF$ Balance of Plan Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars

Annual Costs

Total Annual Cost (TAC)

TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$477,565 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$611,129 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$1,088,694 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$93,134 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$372,444 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t_{op} =	\$9,166 in 2016 dollars
Annual Water Cost =	q _{water} x Cost _{water} x t _{op} =	\$0 in 2016 dollars
Additional Fuel Cost =	Δ Fuel x Cost _{fuel} x t _{op} =	\$2,739 in 2016 dollars
Additional Ash Cost =	$\Delta Ash x Cost_{ash} x t_{op} x (1/2000) =$	\$82 in 2016 dollars
Direct Annual Cost =		\$477,565 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,794 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$608,335 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$611,129 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$1,088,694 per year in 2016 dollars
NOx Removed =	318 tons/year
Cost Effectiveness =	\$3,419 per ton of NOx removed in 2016 dollars

Four Boilers Dry Sorbent Injection System - Chena Power Plant

Variable	Designation	Units	Value	Calculation		
Unit Size (Gross)	A	(MW)	27.5	< User Input (Gross Output based on sum of turbines rated size; 20MW, 5MW, and 2.5 MW)		
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)		
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input (Heat Rate is higher because district heating is not included in unit size)		
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input (Based on source testing 2011)		
Type of Coal	Е	, , ,	sub-bituminous	< User Input		
Particulate Capture	F		Baghouse	< User Input		
Milled Trona	G		TRUE	Based on in-line milling equipment		
	-			Maximum Removal Targets:		
				Unmilled Trona with an ESP = 65%		
				Milled Trona with an ESP = 80%		
Removal Target	н	(%)	70	Unmilled Trona with a Bachouse = 80%		
				Milled Trona with Bachouse = 90%		
				Simplified correlation: 70% removal with bachouse, S&L (2013)		
Heat Input		(Btu/hr)	495 000 000	A*C*1000		
nout input		(Dta/III)	400,000,000	1 browned transport in the set of the s		
				$\frac{1}{(1 + \sqrt{2})} = \frac{1}{(1 + \sqrt$		
NSB	K		1 55	$\lim_{n \to \infty} u_{nn}(u_{n+1}) - u_{n+1}(u_{n+1}) - u$		
NOR	ĸ		1.55	$\frac{1}{2} \frac{1}{2} \frac{1}$		
				$\frac{1}{155} = \frac{1}{1010} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{1000} \frac{1}{10000} \frac{1}{10000} \frac{1}{10000} \frac{1}{100000} \frac{1}{10000000000000000000000000000000000$		
		(i #)		1.35 Recommended for a bagnouse at a target of 70% removal. S&L (2013)		
Irona Feed Rate	M	(ton/hr)	0.28	(1.2011x10~06) K^ACD		
Sorbent Waste Rate	N	(ton/hr)	0.185	(0.7035-0.00073696*H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3.		
				(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV)		
				For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000		
Fly Ash Waste Rate	Р	(ton/hr)	0.92	For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400		
				For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200		
				< User Input (Usibelli Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,560)		
Aux Power	Q	(%)	0.20	=if Milled Trona M*20/A else M*18/A		
Trona Cost	R	(\$/ton)	550	< User Input (based on Stanley Consultant price reference)		
Waste Disposal Cost	S	(\$/ton)	50			
Aux Power Cost	T	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)		
Operating Labor Rate	U	(\$/hr)	63	< User Input (Labor cost including all benefits [AE 2016])		
IPM Model - Lindates to Cost and Performance for APC Technologies - Dry Spring Linetion for SQ2 Control Cost Development Methodology and and a 2013, prepared by Sarrent & Lundy LLC for LISEPAhttps://www.epa.gov/sites/production/files/2015						
		,,	07/	(documents/append5 4.pdf		
Capital Cost Calculation (2012 dollars)				Comments		
Includes - Equipment, installation, buildin	ng, foundations, electrical, an	nd a retrofit diffic	ulty factor of 1.5			
	.,,,,		,			
Base Module (BM) (\$)		=	\$ 14,169,111	Base DSI module includes all equipment from unloading to injection.but not including field installation		
Unmilled Trona = if(M >25 then (682.00	0*B*M) else 6.833.000*B*(M	^0.284)	•,,			
$Milled Trong = if(M_2 25 then (750,000 B^*M) else 7.516,000 B^*(M_2,284)$						
BM (\$/kW)	,	=	\$ 515	Base module cost per kW		
Total Project Cost						
A1 = 20% of BM		=	\$ 2,833,822	Engineering and construction management costs (CC Manual) (Stanley Consultants)		
A2 = 10% of BM		=	\$ 1,416,911	Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual)		
A3 = 10% of BM		=	\$ 1,416,911	Contractor profit and fees (CC Manual) (Stanley Consultants)		
CECC (\$) - Excludes Owner's Costs =	BM + A1 + A2 + A3	=	\$ 19,836,755	Capital, engineering, and construction costs subtotal		
CECC (\$/kW) - Excludes Owner's Cost	ts	=	\$ 721	Capital, engineering, and construction costst subtotal per kW		
B1 = 5% of CECC		=	\$ 991,838	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)		
			,			
TPC (\$) - Includes Owners Costs = CE	CC + B1	=	\$ 20,828,593	Total project cost without Allowance for Funds Used During Construction (AFUDC)		
TPC (\$/kW) - Include Owner's Costs		=	\$ 757	Total project cost per kW without AFUDC		
				• • • • • • • • • • • • • • • • • • • •		
B2 = 0% of (CECC + B1)		=		AFUDC (Zero for less than 1 year engineering and construction cycle)		
		_				
TPC (\$) = CECC + B1 + B2		=	\$ 20,682.000	Total project cost (Spreadsheet = \$20,828,523; Stanley Consultants cost estimate = \$20,682,000)		
TPC (\$/kW)		=	\$ 752	Total project cost per kW		
- (******)				· · · · · · · · · · · · · · · · · · ·		

Dry Sorbent Injection System - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (2 additional operators)*(2080)*U/(A*1000) FOMM (\$/kW yr) = BM*0.01/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM) FOM (\$/kW yr) = FOMO + FOMM + FOMA	= = =	\$ \$ \$	 9.53 Fixed O&M additional operating labor costs (2 additional operators is more realistic) 3.43 Fixed O&M additional maintenance material and labor costs 0.33 Fixed O&M additional administrative labor costs 13.29 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = M*R/A VOMW (\$/MWh) = (N+P)*S/A VOMP (\$/MWh) = Q*T*10 VOM (\$/MWh) = VOMR + VOMW + VOMP	= = =	\$ \$ \$	 5.53 Variable O&M costs for Trona reagent 2.00 Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection 0.423 Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above) 7.96 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$]i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$ \$	219,322 CC Manual 413,640 CC Manual 206,820 CC Manual 206,820 CC Manual Revise interest rate to prime (currently 5.25%) per EPA comment Reality is 10 years of useful life of the oldside; 30 years control equipment lifetime based on EPA comments on ADEC Prelim. BACT 2,026,363 CC Manual 3,072,965 5,356,087
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= =	\$	584.6 536.4 4,914,480
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= = =	\$	651 70 456 10,785

Four Boilers Spray Dry Absorber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on total heat input of 497 MMBtu/hour)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input (SDA FGD Estimation only valid up to 3lb/MMBtu SO2 Rate)
Type of Coal	E		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous=1.05, Lignite=1.07
Heat Rate Factor	G		1.800	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Lime Rate	К	(ton/hr)	0.101	(0.6702*(D^2)+13.42*D)*A*G/2000 (Based on 95% SO2 Removal)
Waste Rate	L	(ton/hr)	0.234	(0.8016*(D^2)+31.1917*D)*A*G/2000
Aux Power	М	(%)	2.461	(0.000547*(D^2)+0.00649*D+1.3)*F*G Should be used for model input
Makeup Water Rate	Ν	(1000 gph)	2.874	(0.04898*(D^2)+0.5925*D+55.11)*A*F*G/1000
Lime Cost	Р	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf) (GVEA Limestone cost)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article 11a2ba10-c211-562e-8da9-87dd16a7b104.htm)
Operating Labor Rate	Т	(\$/hr)	63	Labor cost including all benefits
IPM Mo	del - Undates to Cost and Performance for A		es - SDA EGD for	SO2 Control Cost Development Methodology, March 2013, prepared by Sargent & Lundy LLC for LIS EPA
	https://		ites/production/file	2012 Control Cost Destrophism methodology, match 2010, propared by Cargent & Editory ELC for CC ET A.
	https://	www.epa.gov/s	nes/production/me	sizo naonao naona ana ana ana ana ana ana a
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildin	g, foundations, electrical, and a retrofit diffice	ulty factor of 1.5		
BMR (\$) = if(A>600 then (A*92,000) else	566,000*(A^0.716))*B*(F*G)^0.6*(D/4)^0.01	=	\$ 13,004,722	Base module absorber island cost
BMF (\$) = if(A>600 then (A*48,700) else	300,000*(A^0.716))*B*(D*G)^0.2	=	\$ 4,268,968	Base module reagent preparation and waste recycle/handling cost
BMB (\$) = if(A>600 then (A*129,900) else	e 799,000*(A^0.716))*B*(F*G)^0.4	=	\$ 16,587,654	Base module balance of plan costs inlcuding: ID or booster fans, piping, ductwork, electrical, etc.
BM (\$) = BMR + BMF + BMB BM (\$/kW)		= =	\$ 33,861,344 \$ 1,231	Total base module cost including retrofit factor Base module cost per kW
Total Project Cost				
A1 = 10% of BM A2 = 10% of BM A3 = 10% of BM		= = =	 \$ 3,386,134 \$ 3,386,134 \$ 3,386,134 	Engineering and construction management costs Labor adjustment for 6 x 10 hour shift premium, per diem, etc. Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cost	BM + A1 + A2 + A3 s =	= =	\$ 44,019,747 \$ 1,601	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,200,987	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	CC + B1	= =	\$ 46,220,735 \$ 1,681	Total project cost without Allowance for Funds Used During Construction (AFUDC) Total project cost per kW without AFUDC
B2 = 10% of (CECC + B1)	B2 = 10% of (CECC + B1) = \$ 4,622,073 AFUDC (based on a 3 year engineering and construction cycle)			AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and TPC (\$/kW) - Includes Owner's Costs a	AFUDC = CECC + B1 + B2 and AFUDC =	= =	\$ 50,842,808 \$ 1,849	Total project cost Total project cost per kW

Spray Dry Absorber - Chena Power Plant

Direct Annual Costs	
Fixed Operating and Maintenance (O&M) Cost	
FOMO (\$/kW yr) = (4 additional operators)*(2080)*T/(A*1000) FOMM (\$/kW yr) = BM*0.015/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	 \$ 38.12 Fixed O&M additional operating labor costs \$ 12.31 Fixed O&M additional maintenance material and labor costs \$ 1.29 Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	= \$ 51.73 Total Fixed O&M costs
Variable O&M Cost	
VOMR (\$/MWh) = K⁺P/A	= \$ 0.88 Variable O&M costs for lime reagent
VOMW (\$/MWh) = L*Q/A	= \$ 0.25 Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	= \$ 5.17 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	= \$ 0.75 Variable O&M costs for makeup water
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM	= \$ 7.06 Total Variable O&M Costs
Indirect Annual Costs	
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [$i (1+i)^n]/[(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980	 \$ 853,468 CC Manual \$ 1,016,856 CC Manual \$ 508,428 CC Manual \$ 508,428 CC Manual \$ 508,428 CC Manual
TOTAL INDIRECT ANNUAL OPERATING COSTS	= \$ 7,868,614
TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= \$ 10,990,629
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= 584.6 = 536.4 = \$ 10,084,456
TOTAL UNCONTROLLED SO2 EMISSIONS, tons	= 651
SO ₂ REMOVAL EFFICIENCY, %	= 90
TOTAL SO ₂ REMOVED, tons	= 586
SO₂ COST-EFFECTIVENESS, \$/ton removed	= \$ 17,213

Four Boilers Wet Scrubber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on a total heat input of 497 MMBtu/hr)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0) Sargent and Lundy has a drop down menu for selection of an additional waste water treatment plant facility, but no capital or operational cost are implemented so it is not reproduced here.
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input
Type of Coal	E		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous = 1.05, Lignite = 1.07
Heat Rate Factor	G		1.8	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Limestone Rate	К	(ton/hr)	0.13	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	0.236	1.811*K
Aux Power	M	(%)	2.079	(1.05e^(0.155*D))*F*G
Makeup Water Rate	N	(1000 gph)	3.908	(1.674*D+74.68)*A*F*G/1000
Limestone Cost	P	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.html)
Operating Labor Rate	Ť	(\$/hr)	63	Labor cost including all benefits
IPM Model -	Updates to Cost and Performance for APC T https://www	Fechnologies - W .epa.gov/sites/p	et FGD for SO2 Co roduction/files/2015	ntrol Cost Development Methodology, August 2010, prepared by Sargent & Lundy LLC for US EPA. -07/documents/chapter_5_appendix_5-1a_wet_fgd.pdf
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildi BMR (\$) = 550 000*(B)*((E*G)00 6)*((D)	ng, foundations, electrical, minor physical/ch	emical waste wa _	ter treatment, and a	retrofit difficulty factor of 1.5
$BMF(\$) = 190,000^{*}(B)^{*}((D^{*}G)^{*}(0,3)^{*}(A^{*}))$	0.716)	_	\$ 2 542 315	Base reagent preparation cost
$BMW((\$) = 100,000^{*}(B)^{*}((D^{*}G)^{0}(45)^{*}(45))^{*}((D^{*}G)^{0}(45))^{*}(45)$	AAO 716)	_	\$ 1 220 076	Base waste handling cost
BMR(\$) = 1.010,000*(P)*((F*G)00,4)*(A	A0 716)	_	¢ 20.068.122	Pase balance of plan cast including: ID or bactor face, now wat chimpay, piping, ductwork, minor waste water treatment, etc.
D(0) = 1,010,000 (D) ((1 - G) + 0.4) (A - D) ((1 - G) + 0.4) (A - D)	(0.710)	_	¢ 20,900,123	Page value of plan cost including. ID of booster rais, new well chinney, piping, ductivois, minor waste water realment, etc
		=	ъ	
Base Module (BM) (\$) = BMR + BMF + BM (\$/kW)	BWM + BWB + BWMM	=	\$ 37,216,477 \$ 1,353	Total base cost including retrofit factor Base cost per kW
Total Project Cost				
A1 = 10% of BM A2 = 10% of BM		= =	\$ 3,721,648 \$ 3,721,648	Engineering and construction management costs (CC Manual) Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual)
A3 = 10% of BM		=	\$ 3,721,648	Contractor profit and fees (CC Manual)
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cost	BM + A1 + A2 + A3	=	\$ 48,381,420 \$ 1,759	Capital, engineering, and construction costs subtotal Capital engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2 419 071	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs - C	FCC + B1	_	\$ 50 800 491	Total project cost without Allowance for Funds Lised During Construction (AFLIDC)
TPC (\$/kW) - Include Owner's Costs =		=	\$ 1,847	Total project cost per kW without AFUDC
B2 = 10% of (CECC + B1)		=	\$ 5,080,049.08	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and TPC (\$/kW) - Includes Owner's Costs	AFUDC = CECC + B1 + B2 and AFUDC =	=	\$	Total project cost Total project cost per kW
Wet Scrubber - Chena Power Plant

		_	
Direct Annual Costs			
Fixed O&M Cost			
EOMO(\$/k/k/yr) = (6 additional operators)*(2080)*T/(4*1000)	_	¢	28.50. Fixed O&M additional operation labor costs
FOMO((5/kW yr) = (6 autilional operators) (2000) T/(A 1000) FOMM (5/kW yr) = BM*0.015/(B*A*1000)	_	¢ 2	20.55 Tixed Oak additional maintenance material and labor costs
FOMA (\$/k/(/yr) = 0.03*(FOMO+0.4*FOMM))	_	φ S	1.0.2 Fixed O&M additional amainteriance interiation and labor costs
FOMWW (\$/kW yr) = 0.03 (100000.4 100000)	-	\$	Fixed O&M costs for waterwater treatment facility
		Ψ	
FOM (\$/kW yr) = FOMO + FOMM + FOMA + FOMWW	=	\$	43.14 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = K*P/A	=	\$	1.14 Variable O&M costs for limestone reagent
	_	¢	0.20 Visible OPM sects for words diagonal
VOMW(S/MVVN) = L Q/A	=	Φ	U.26 Variable U&MI Costs for waste disposar
VOMP ($\%$ /MWh) = M*R*10	=	\$	4.37 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N* <mark>S</mark> /A	=	\$	1.02 Variable O&M costs for makeup water
		*	
VOMWW (\$/MVVn) =	=	\$	 Variable U&M costs for wastewater treatment facility
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW	-	\$	6.78 Total Variable O&M Costs (\$/MW vr)
	-	•	
Indirect Annual Costs			
		~	711 97E CC Monual
Overhead (60% of total labor and material costs)	=	\$	
Administrative charges (2% of total capital investment)	=	\$ \$	1,117,611 CC Manual
Administrative charges (2% of total capital investment) Property tax (1% of total capital investment)	= = =	л \$ \$ \$	1,117,611 CC Manual 558,805 CC Manual
Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment)	= = =	» % % %	1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1]	= = =	» % % %	11,17,610 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25	= = =	» % %	11,17,610 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 15	= = =	» % %	1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980	= = = =	» » » »	558,805 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980	= = = =	A (A (A) (A)	11,17,611 CC Manual 558,805 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS	= = = =	> \$ \$ \$ \$ \$	11,17,61 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980	= = = =	> \$ \$ \$	111,615 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)		> \$ \$ \$ \$ \$ \$	111,615 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = = =	ን\$\$\$ \$ \$	1,117,61 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)		∌\$\$\$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cert year of equation)	= = = = = =	∌\$\$\$\$ \$ \$	11,17,611 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 584.6
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	= = = = = = = =	♪\$\$\$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)		>>>>> \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Lospital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = = =	♪\$\$\$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Lospital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = = = = =	∌\$\$\$\$\$\$\$\$\$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons		↑\$\$\$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, %		\$ \$ \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)		\$ \$ \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Lospital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons		> S * \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST_EFEFECTIVENESS, \$/ton removed		> S * S * S * S	111,013 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644 16 005 Doce not include costs associated with building and maintaining a wastewater tratment facility.

Appendix C (Coal Analyses Summary)

	Co	oal Analyses Summary	(As Receive	d)	
Year	Report	Coal	HHV	Moisture	Sulfur
Units		(tons)	(btu/lb)	(%)	(%)
2013	А	103,122.35	7,670	27.22	0.15
2013	В	115,917.00	7,599	27.95	0.17
2014	А	117,659.65	7,652	27.89	0.15
2014	В	103,979.45	7,617	27.86	0.14
2015	А	103,904.80	7,599	29.16	0.14
2015	В	120,758.30	7,610	29.02	0.15
2016	А	115,282.20	7,683	31.21	0.12
2016	В	107,687.35	7,604	29.23	0.14
2017	А	106,040.35	7,567	32.20	0.11
2017	В	114,440.00	7,529	32.52	0.10
Weight	ed average	221,758.29	7,613	29.44	0.14

Rail Samples Analysis Results for 6/1/13 to 6/30/13

ETHERE BEST AND THE PROPERTY OF THE PROPERTY O						****						
Customer	Date	#Cars	вти	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	6/3/2013	8	7490	28.62	8.57	35.96	26.86	0.13	TII	V6	6	741.40
AURORA ENERGY LLC	6/4/2013	13	7552	28.06	8.58	36.44	26.93	0.12	Ťŧ	V6	6	1,177.90
AURORA ENERGY LLC	6/6/2013	14	7303	28.45	10.15	34.89	26.51	0.14	T II	V6	6	1,308.40
AURORA ENERGY LLC	6/10/2013	16	7414	28.08	9.77	35.36	26.78	0.13	TH	V6	6	1,513.40
AURORA ENERGY LLC	6/13/2013	19	7528	27.82	9.38	35.66	27.15	0.15	ΤH	V6	6	1,749.25
AURORA ENERGY LLC	6/17/2013	7	7626	27.41	9.41	35.51	27.67	0.15	ТШ	V6	6	656.20
AURORA ENERGY LLC	6/18/2013	23	7682	28.49	7.14	36.88	27.50	0.14	ТШ	V6	6	2,079.85
AURORA ENERGY LLC	6/20/2013	26	7386	27,49	10.19	35.92	26.40	0.13	ΤII	V6	6	2,365.55
AURORA ENERGY LLC	6/24/2013	14	7325	28.36	9.89	35.53	26.23	0.14	TII	V6	6	1,289.20
AURORA ENERGY LLC	6/26/2013	13	7522	28.53	8.56	34.56	28.35	0.19	ΤI	U4	4	1,202.85
AURORA ENERGY LLC	6/28/2013	19	7715	27.62	7.89	36.01	28.49	0.15	TII	U4	4	1,751.50
AURORA ENERGY LLC	6/28/2013	12	7593	28.46	7.84	35.39	28.32	0.14	TII	U4	4	1,071.10
Weighted Averages Summ	ary											
Customer	*******	Tons		BTU	Н	20	Ash		Volatiles	Cart	oon	Sulfur
AURORA ENERGY LLC	11155-222222222222222222222222222222222	16906.60)	7511.00	2	8.08	8.9) 5	35.75	5 2	7.23	0.14

Rail Samples Analysis Results for 1/1/13 to 6/30/13

Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2013	10	7504	27.93	9.16	34.93	27.98	0.20	ΤII	Τ4	4	961.05
AURORA ENERGY LLC	1/3/2013	11	7599	26.87	9.32	35.99	27.83	0.18	P2/STK	C1	6/N	1,000.35
AURORA ENERGY LLC	1/4/2013	9	7685	27.59	8.22	36.39	27.81	0.17	P2/STK	C1	6/N	816.20
AURORA ENERGY LLC	1/5/2013	13	7711	27.47	8.17	36.74	27.63	0.18	P2/STK	C1	6/N	1,263.55
AURORA ENERGY LLC	1/7/2013	11	7612	27.77	8.70	35.41	28.12	0.17	P2/STK	C1	6/N	1,057.50
AURORA ENERGY LLC	1/8/2013	9	7565	26.55	10.25	35.37	27.84	0.17	TII/P2	T4/C1	4/6	858.05
AURORA ENERGY LLC	1/9/2013	12	7584	27.03	9.43	35.53	28.01	0.18	T II/P2	T4/C1	4/6	1,113.90
AURORA ENERGY LLC	1/10/2013	6	7692	25.65	9.78	36.60	27.96	0.17	P2/STK	C1	6/N	562.40
AURORA ENERGY LLC	1/11/2013	13	7507	27.09	10.00	35.86	27.05	0.18	P2/STK	C1	6/N	1,223.50
AURORA ENERGY LLC	1/14/2013	9	7566	26.87	9.70	35.71	27.72	0.16	P2/STK	C1	6/N	872,75
AURORA ENERGY LLC	1/15/2013	14	7632	28.16	8.04	35.42	28.38	0.20	TII	Т4	4	1,261.60
AURORA ENERGY LLC	1/16/2013	12	7784	27.66	7.41	36.36	28.57	0.17	TII	Τ4	4	1,096.85
AURORA ENERGY LLC	1/17/2013	7	7758	27,48	8.08	35.70	28.75	0.19	P2/STK	C1	6/N	645.20
AURORA ENERGY LLC	1/18/2013	11	7788	26.88	7.92	36.52	28.68	0.16	P2/STK	C1	6/N	1,007.45
AURORA ENERGY LLC	1/21/2013	8	7678	26.95	8.63	35.72	28.71	0.17	T II/STK	T4	4/N	737.10
AURORA ENERGY LLC	1/22/2013	13	7709	27.10	8.34	35.59	28.98	0.18	T II/STK	Τ4	4/N	1,166.85
AURORA ENERGY LLC	1/23/2013	14	7746	27.10	8.39	36.04	28.47	0.17	P2/STK	C1	6/S	1,223.50
AURORA ENERGY LLC	1/25/2013	7	7754	27.88	7.45	36.79	27.89	0.15	P2/STK	C1	6/N	633.50
AURORA ENERGY LLC	1/25/2013	11	7585	26.81	9.72	36.20	27.28	0.15	P2/STK	C1	6/N	994.60
AURORA ENERGY LLC	1/28/2013	9	7484	26.40	11.09	35.58	26.94	0.15	P2/STK	C1	6/S	807.55
AURORA ENERGY LLC	1/29/2013	11	7691	26.62	9.22	36.11	28.05	0.15	P2/STK	C1	6/S	994.45
AURORA ENERGY LLC	1/30/2013	13	7482	28.23	9.21	35.05	27.52	0.16	P2/STK	C1	6/S	1,150.80
AURORA ENERGY LLC	1/31/2013	10	7460	26.87	10.25	34.89	27.99	0.15	TII/P2	T3/C1	3/6	920.60
AURORA ENERGY LLC	2/1/2013	8	7529	28.24	9.08	35.07	27.61	0.14	Ťŧ	Т3	3	763.65
AURORA ENERGY LLC	2/4/2013	7	7545	28.48	8.71	34.47	28.34	0.13	ТИ	Т3	3	629.95
AURORA ENERGY LLC	2/5/2013	11	7463	28.30	9.56	34.22	27.92	0.14	ΤI	Т3	3	1,015.15
AURORA ENERGY LLC	2/7/2013	8	7491	28.60	8.93	34.76	27.72	0.13	P2/TII	C1/T3	6/3	755.05
AURORA ENERGY LLC	2/8/2013	12	7637	27.97	8.09	36.09	27.86	0.14	P2/TII	C1/T3	6/3	1,113.25
AURORA ENERGY LLC	2/9/2013	12	7740	26.73	8.61	37.24	27.42	0.14	P2	C1	6	1,102.05
AURORA ENERGY LLC	2/11/2013	9	⁷⁵⁰⁶ App	endîx II	1. ⁹ .557	.7 - 4394	4 ^{28.38}	0.16	T II/P2	T3/C1	3/6	848.85

Rail Samples Analysis Results for 1/1/13 to 6/30/13

	******					NAVAALIINAA AMAANI			distant commencements (15)		*****	
AURORA ENERGY LLC	2/12/2013	15	7649	27.94	8.20	35.09	28.77	0.15	T II	T3	3	1,378.10
AURORA ENERGY LLC	2/13/2013	21	7556	27.99	9.13	34.51	28.38	0.15	ти	Т3	3	1,914.10
AURORA ENERGY LLC	2/14/2013	8	7819	26.40	8.38	36.31	28.91	0.14	P2/STK	C1	6/N	701.80
AURORA ENERGY LLC	2/15/2013	15	7437	27.31	10.59	34.59	27.51	0.15	P2/STK	C1	6/S	1,300.35
AURORA ENERGY LLC	2/18/2013	9	7616	27.77	8.69	34.75	28.80	0.14	TII	Т3	3	852.10
AURORA ENERGY LLC	2/19/2013	5	8065	26.73	6.36	37.32	29.59	0.13	P2/STK	C1	6/S	448.60
AURORA ENERGY LLC	2/20/2013	18	7824	27.32	7.48	37.11	28.09	0.15	P2/STK	C1	6/S	1,648.60
AURORA ENERGY LLC	2/21/2013	7	7607	26.43	10.17	36.29	27.11	0.15	P2/STK	C1	6/S	615.40
AURORA ENERGY LLC	2/22/2013	15	7510	28.05	9.42	35.26	27.28	0.14	TII	Т3	3	1,390.45
AURORA ENERGY LLC	2/25/2013	9	7697	28.21	7.72	34.80	29.27	0.14	TII	ТЗ	3	817.70
AURORA ENERGY LLC	2/26/2013	14	7588	28.23	8.43	35.08	28.26	0.14	TII/P2	T3/C1	3/6	1,275.05
AURORA ENERGY LLC	2/28/2013	17	7872	27.40	6.91	37.27	28.43	0.15	P2/STK	C1	6/S	1,587.05
AURORA ENERGY LLC	3/4/2013	11	7508	26.13	11.00	35.23	27.65	0.15	P2/TII	C1/T3	6/3	1,033.95
AURORA ENERGY LLC	3/5/2013	11	7682	26,99	8.13	36.34	28.55	0.14	P2/STK	C1	6/S	959.30
AURORA ENERGY LLC	3/6/2013	14	7648	27.25	7.96	36.56	28.23	0.15	P2/STK	C1	6/S	1,302.85
AURORA ENERGY LLC	3/7/2013	7	7717	26.40	8.27	37.82	27.53	0.15	P2/STK	C1	6/S	619.15
AURORA ENERGY LLC	3/8/2013	6	7469	26.55	9.86	37.18	26.41	0.16	P2/STK	C1	6/S	538.30
AURORA ENERGY LLC	3/11/2013	11	7857	27.02	7.45	37.34	28.20	0.15	P2/STK	C1	6/S	1,016.00
AURORA ENERGY LLC	3/12/2013	13	7868	26.99	7.27	37.32	28.43	0.14	P2/STK	C1	6/S	1,200.55
AURORA ENERGY LLC	3/13/2013	18	7437	28.70	8.86	35.07	27.37	0.14	P2/STK	C1	6/S	1,586.50
AURORA ENERGY LLC	3/15/2013	7	7253	25.91	13.37	35.02	25.70	0.14	P2/STK	C1	6/S	652.45
AURORA ENERGY LLC	3/19/2013	11	7570	26.44	10.41	36.24	26.91	0.16	P2/STK	C1	6/S	1,034.15
AURORA ENERGY LLC	3/19/2013	8	7723	26.43	9.14	36.80	27.63	0.14	P2/STK	C1	6/S	734.00
AURORA ENERGY LLC	3/20/2013	11	7812	26.67	8.36	36.58	28.40	0.15	P2/STK	C1	6/S	1,058.60
AURORA ENERGY LLC	3/21/2013	3	7805	26.35	8.46	36.75	28.44	0.15	P2/STK	C1	6/S	264.35
AURORA ENERGY LLC	3/22/2013	8	7580	26.59	10.17	36.01	27.24	0.15	P2/STK	C1	6/S	747.60
AURORA ENERGY LLC	3/25/2013	6	7835	26.61	7.98	37.07	28.35	0.15	P2/STK	C1	6/S	545.80
AURORA ENERGY LLC	3/26/2013	10	7873	26.37	7.94	37.21	28.48	0.16	P2/STK	C1	6/S	911.95
AURORA ENERGY LLC	3/27/2013	11	7633	26.67	9.68	35.80	27.86	0.16	P2/STK	C1	6/S	1,011.95
AURORA ENERGY LLC	3/28/2013	4	7776	26.70	8.29	37.09	27.93	0.15	P2/STK	C1	6/S	363.85
AURORA ENERGY LLC	4/1/2013	6	7964	26.30	7.22	37.59	28.89	0.15	P2/STK	C1	6/S	527.90
AURORA ENERGY LLC	4/2/2013	11	⁷⁹ A ipp	eridix I	∐ Ģ ₿ ⁸ 7.	73-24354	529.16	0.15	P2/STK	C1	6/S	993.45

Rail Samples Analysis Results for 1/1/13 to 6/30/13

					Store 1	00000 A 1000 1000 \$ 000 A 1100 \$	www.	***		****		*****
935.20	6/S	C1	P2/STK	0.14	28.33	36.64	7.75	27.29	7812	10	4/3/2013	AURORA ENERGY LLC
458.50	6/S	C1	P2/STK	0.14	27.92	36.84	8.53	26.72	7779	5	4/4/2013	AURORA ENERGY LLC
855.30	6/N	C1	P2/STK	0.15	28.28	36.80	8.67	26.26	7866	9	4/5/2013	AURORA ENERGY LLC
934.30	3 6/3	C1/C13	P2/JDRC	0.16	26.89	34.23	11.58	27.30	7363	10	4/8/2013	AURORA ENERGY LLC
1,269.45	6	V6	TII	0.14	26.86	35.20	8.61	29.34	7381	14	4/9/2013	AURORA ENERGY LLC
885.25	6	V6	ТІІ	0.15	27.97	36.44	7.26	28.34	7736	10	4/11/2013	AURORA ENERGY LLC
556.70	6	V6	ТІІ	0.14	26.95	36.55	7.89	28.62	7591	6	4/11/2013	AURORA ENERGY LLC
1,062.00	3/C	C13	JD/GRP	0.15	26.44	32.67	11.50	29.40	7286	11	4/16/2013	AURORA ENERGY LLC
939.50	3	C13	JDRC	0.17	27.25	33.14	10.61	29.01	7385	10	4/16/2013	AURORA ENERGY LLC
730.15	6	V6	ТΠ	0.15	28.31	36.17	7.98	27.55	7746	8	4/18/2013	AURORA ENERGY LLC
750.40	6/W	V6	T II/STK	0.16	28.28	35.88	9.01	26.84	7783	8	4/20/2013	AURORA ENERGY LLC
657.70	6/W	V6	T II/STK	0.16	27.74	36.27	8.10	27.90	7659	7	4/22/2013	AURORA ENERGY LLC
741.05	6/W	V6	T II/STK	0.16	27.61	36.53	8.38	27.47	7706	8	4/23/2013	AURORA ENERGY LLC
856.65	6	V6	ΤII	0.15	27.24	36.03	8.91	27.83	7589	9	4/25/2013	AURORA ENERGY LLC
640.30	6	V6	TII	0.14	26.69	36.16	10.26	26.90	7505	7	4/25/2013	AURORA ENERGY LLC
746.30	6	V6	TII	0.15	26.69	37.23	8.54	27.54	7601	8	4/26/2013	AURORA ENERGY LLC
915.65	6	V6	ТΠ	0.14	27.09	35.78	8.82	28.32	7495	10	4/29/2013	AURORA ENERGY LLC
1,130.20	6	V6	ΤII	0.14	25.21	34.60	12.55	27.64	7123	12	4/30/2013	AURORA ENERGY LLC
1,238.65	M/N		GRP/STK	0.17	28.95	35.05	11.11	24.90	7962	12	5/1/2013	AURORA ENERGY LLC
940.15	M/S		GRP/STK	0.17	28.51	34.52	11.77	25.21	7815	10	5/2/2013	AURORA ENERGY LLC
670.35	M/S		GRP/STK	0.18	27.66	33.39	13.91	25.05	7574	7	5/3/2013	AURORA ENERGY LLC
1,223.00	M/S		GRP/STK	0.18	29.14	34.49	11.80	24.57	8042	13	5/3/2013	AURORA ENERGY LLC
278.80	M/N		GRP/STK	0.19	30.41	34.73	10.98	23.89	8200	3	5/6/2013	AURORA ENERGY LLC
765.10	M/N		GRP/STK	0.16	28.19	36.04	9.72	26.05	7876	8	5/20/2013	AURORA ENERGY LLC
1,459.45	M/N		GRP/STK	0.18	30.78	35.53	8.98	24,71	8437	16	5/21/2013	AURORA ENERGY LLC
954.30	М		GRP	0.18	32.54	35.33	8.77	23.37	8746	10	5/23/2013	AURORA ENERGY LLC
1,064.60	Μ		GRP	0.17	31.45	34.57	9.96	24.03	8414	11	5/23/2013	AURORA ENERGY LLC
819.70	M/N		GRP/STK	0.18	31.31	35.49	9.27	23.93	8508	9	5/27/2013	AURORA ENERGY LLC
1,151.15	M/N		GRP/STK	0.18	31.38	35.30	9.27	24.06	8514	12	5/28/2013	AURORA ENERGY LLC
956.70	6	V6	ТΠ	0.13	27.05	36.48	8.56	27.91	7619	10	5/30/2013	AURORA ENERGY LLC
741.40	6	V6	TH	0.13	26.86	35.96	8.57	28.62	7490	8	6/3/2013	AURORA ENERGY LLC
1,177.90	6	V6	TH	0.12	626.93	7364544	[]] \$D \$7.	eratix]	75 A 2pp	13	6/4/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 1/1/13 to 6/30/13

***************************************	Q X Y X I J Y Y Y Y Y Y Y Y Y Y Y Y Y Y Y Y Y Y		*******	****	******		****	****	********************************	******	****	N-1/2010-00-00-00-00-00-00-00-00-00-00-00-00-
AURORA ENERGY LLC	6/6/2013	14	7303	28.45	10.15	34.89	26.51	0.14	ТП	V6	6	1,308.40
AURORA ENERGY LLC	6/10/2013	16	7414	28.08	9.77	35.36	26.78	0.13	TII	V6	6	1,513.40
AURORA ENERGY LLC	6/13/2013	19	7528	27.82	9.38	35.66	27.15	0.15	ΤII	V6	6	1,749.25
AURORA ENERGY LLC	6/17/2013	7	7626	27.41	9.41	35.51	27.67	0.15	тп	V6	6	656.20
AURORA ENERGY LLC	6/18/2013	23	7682	28.49	7.14	36.88	27.50	0.14	ΤII	V6	6	2,079.85
AURORA ENERGY LLC	6/20/2013	26	7386	27.49	10.19	35.92	26.40	0.13	ΤII	V6	6	2,365.55
AURORA ENERGY LLC	6/24/2013	14	7325	28.36	9.89	35.53	26.23	0.14	TII	V6	6	1,289.20
AURORA ENERGY LLC	6/26/2013	13	7522	28.53	8.56	34.56	28.35	0.19	ΤII	U4	4	1,202.85
AURORA ENERGY LLC	6/28/2013	19	7715	27.62	7.89	36.01	28.49	0.15	TH	U4	4	1,751.50
AURORA ENERGY LLC	6/28/2013	12	7593	28.46	7.84	35.39	28.32	0.14	TH	U4	4	1,071.10
Weighted Averages Sun	ımary											
Customer		Tons	Mantevaria	BTU	H	20	Ash		Volatiles	Cart	noc	Sulfur
AURORA ENERGY LLC		103122.35		7670.00	2	7.22	9.	05	35.76	2	7.98	0.15

This analysis is representative of the coal shipped using sulfur standard ASTM D4239-12

Coleen Shompson

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 7/1/13 to 12/31/13

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/1/2013	7	7360	26.50	11.80	35.40	26.30	0.15	TBR	C1	6	652.55
AURORA ENERGY LLC	7/2/2013	21	7675	26.40	9.51	36.33	27.77	0.15	TBR	C1	6	1,961.70
AURORA ENERGY LLC	7/5/2013	23	7565	27.34	9.39	34.94	28.34	0.19	ΤII	U4	4	2,171.90
AURORA ENERGY LLC	7/8/2013	10	7538	28.53	8.36	34.23	28.88	0.19	TII	U4	4	917.50
AURORA ENERGY LLC	7/9/2013	29	7645	28.51	7.49	35.44	28.57	0.16	ΤII	U4	4	2,700.95
AURORA ENERGY LLC	7/11/2013	13	7502	28.50	8.82	35.62	27.06	0.18	TBR	C1	6	1,224,95
AURORA ENERGY LLC	7/15/2013	12	7485	29.53	7.66	35.01	27.81	0.19	TII	U4	4	1,067.35
AURORA ENERGY LLC	7/16/2013	11	7317	27.95	10.29	34.12	27.68	0.25	ΤII	U4	4	1,019.50
AURORA ENERGY LLC	7/22/2013	11	7609	28.80	7.97	34.86	28.37	0.18	ΤII	U4	4	1,018.45
AURORA ENERGY LLC	7/24/2013	25	7467	28.43	8.50	34.68	28.41	0.19	ΤII	U4	4	2,303.20
AURORA ENERGY LLC	7/25/2013	13	7416	28.52	9.36	34.76	27.37	0.20	TII	U4	4	1,239.20
AURORA ENERGY LLC	7/29/2013	9	7339	29.30	9.16	33.88	27.67	0.20	тΠ	U4	4	836.20
AURORA ENERGY LLC	8/1/2013	27	7749	27.87	8.65	34.52	28.97	0.15	JR/GRP	C13	4/M	2,483.15
AURORA ENERGY LLC	8/5/2013	10	7833	27.43	9.00	34.23	29.35	0.17	JD/GRP	C13	4/M	948.40
AURORA ENERGY LLC	8/6/2013	18	7752	29.20	7.09	34.40	29.31	0.14	JR/GRP	C13	4/M	1,657.00
AURORA ENERGY LLC	8/8/2013	12	7737	28.58	7.91	34.30	29.22	0.14	JR/GRP	C13	4/M	1,172.25
AURORA ENERGY LLC	8/8/2013	16	7648	28.65	8.33	34.49	28.53	0.13	JR/GRP	C13	4/M	1,524.25
AURORA ENERGY LLC	8/9/2013	12	7552	28.48	8.20	35.34	27.99	0.20	ТΠ	U4	4	1,085.70
AURORA ENERGY LLC	8/12/2013	7	7610	28.79	7.51	34.66	29.05	0.16	TII	U4	4	657.40
AURORA ENERGY LLC	8/13/2013	17	7503	29.40	8.11	34.39	28.11	0.15	JR/T II	C13/U4	4/4	1,550.05
AURORA ENERGY LLC	8/19/2013	9	7696	28.53	8.03	34.46	29.00	0.16	JR	C13	4	834.85
AURORA ENERGY LLC	8/20/2013	17	7764	28.71	7.65	34.86	28.79	0.14	JR/GRP	C13	4/M	1,569.00
AURORA ENERGY LLC	8/22/2013	11	8309	24.18	10.01	34.82	31.00	0.20	GRP/ST	< Comparison of the second sec	M/N	1,008.60
AURORA ENERGY LLC	8/22/2013	15	8288	24.11	9.99	35.32	30.58	0.17	GRP/STM	c	M/N	1,412.05
AURORA ENERGY LLC	8/26/2013	5	7656	27.01	10.63	33.80	28.57	0.19	T II/GRP	U3	3/M	491.15
AURORA ENERGY LLC	8/27/2013	12	7557	27.38	10.91	33.44	28.26	0.15	T II/GRP	U3	3/M	1,141.90
AURORA ENERGY LLC	8/28/2013	10	7705	27.60	9.20	34.46	28.74	0.14	T II/GRP	U3	3/M	905.40
AURORA ENERGY LLC	8/29/2013	12	7822	26.89	10.18	34.14	28.79	0.15	TII/GRP	U3	3/M	1,149.70
AURORA ENERGY LLC	9/3/2013	11	7996	26.39	10.28	34.01	29.33	0.16	TII/GRP	U3	3/M	1,048.10
AURORA ENERGY LLC	9/5/2013	10	⁷⁶⁵⁴ App	efdîx II	I.D.7.	7 343 48	8 ^{28.61}	0.15	T II/GRP	U3	3/M	935.45

Rail Samples Analysis Results for 7/1/13 to 12/31/13

		UEITINATASSISSING		TERRET CONTRACTOR		****	*****	TO INTEREST CONTRACTOR OF CONTRACTOR		*****	29332/12122200////////////////////////////	7/7/10/10/10/10/10/10/10/10/10/10/10/10/10/
1,051.50	3	U3	ΤII	0.12	28.58	34.71	8.70	28.02	7566	12	9/5/2013	AURORA ENERGY LLC
808.00	3	U3	ΤII	0.12	28.01	35.10	8.73	28.16	7584	9	9/7/2013	AURORA ENERGY LLC
479.85	3	U3	ТΠ	0.13	28.66	34.02	8.44	28.89	7525	5	9/9/2013	AURORA ENERGY LLC
1,938.20	3	C13	JR	0.13	25.09	32.88	12.49	29.54	6894	20	9/11/2013	AURORA ENERGY LLC
1,900.70	3/N	U3	TII/STK	0.13	28.50	34.77	8.74	27.99	7578	20	9/13/2013	AURORA ENERGY LLC
769.35	3	U3	TII	0.12	28.43	34.53	9.36	27.68	7507	8	9/16/2013	AURORA ENERGY LLC
1,134.85	3	U3	тн	0.13	27.99	34.24	8.87	28.91	7474	12	9/18/2013	AURORA ENERGY LLC
1,756.50	3	U3	ΤIJ	0.12	28.06	34.11	9.45	28.38	7447	18	9/19/2013	AURORA ENERGY LLC
1,459.60	3	U3	ΤII	0.12	28.75	34.37	8.52	28.36	7567	15	9/20/2013	AURORA ENERGY LLC
2,034.85	6	C1	TBR	0.15	26.81	35.65	9.98	27.57	7503	21	9/24/2013	AURORA ENERGY LLC
1,425.25	6	C1	TBR	0.15	27.16	36.33	9.92	26.60	7615	15	9/25/2013	AURORA ENERGY LLC
1,261.65	6	C1	TBR	0.15	26.88	37.08	9.47	26.57	7626	13	9/26/2013	AURORA ENERGY LLC
572.95	6	C1	TBR	0.15	26.95	35.62	10.47	26.97	7556	6	9/30/2013	AURORA ENERGY LLC
758.30	6	C1	TBR	0.18	27.20	33.98	11.21	27.62	7354	8	10/2/2013	AURORA ENERGY LLC
1,009.45	4	V4	ТИ	0.16	28.69	34.36	9.13	27.82	7515	11	10/7/2013	AURORA ENERGY LLC
2,203.90	4	V4	ΤII	0.15	27.36	33.77	10.30	28.57	7298	23	10/10/2013	AURORA ENERGY LLC
1,618.40	4	V4	TII	0.21	27.32	34.26	10.17	28.25	7295	17	10/11/2013	AURORA ENERGY LLC
1,250.95	4	V4	T 11	0.21	29.43	34.47	8.67	27.43	7770	13	10/15/2013	AURORA ENERGY LLC
834.60	4	V4	ΤII	0.18	28.94	34.71	8.19	28.16	7622	9	10/16/2013	AURORA ENERGY LLC
1,448.90	4	V4	ΤII	0.19	28.78	34.73	7.77	28.73	7560	16	10/17/2013	AURORA ENERGY LLC
1,209.15	4	V4	TII	0.18	28.93	35.43	7.91	27.73	7582	13	10/18/2013	AURORA ENERGY LLC
1,476.80	4	V4	Т	0.20	28.53	34.45	9.19	27.84	7584	15	10/21/2013	AURORA ENERGY LLC
1,280.80	4	V4	ΤIJ	0.20	27.95	34.58	9.43	28.05	7492	13	10/22/2013	AURORA ENERGY LLC
1,756.85	4	V4	ТΙ	0.20	28.52	34.70	8.52	28.26	7557	18	10/23/2013	AURORA ENERGY LLC
1,307.25	4/4	V4/W4	T II/T II	0.20	27.88	34.75	9.52	27.86	7539	14	10/26/2013	AURORA ENERGY LLC
1,171.30	4	W4	ТШ	0.20	28.15	34.92	9.19	27.75	7536	13	10/28/2013	AURORA ENERGY LLC
1,070.25	3	Вx	Bdl	0.14	30.00	35.86	5.87	28.27	7871	12	10/29/2013	AURORA ENERGY LLC
1,251.70	3	C4	Bdl	0.12	29.52	34.73	8.16	27.59	7644	13	10/30/2013	AURORA ENERGY LLC
1,561.60	4	W4	ŤΠ	0.15	28.50	35.49	7.68	28.33	7709	17	11/2/2013	AURORA ENERGY LLC
828.45	3	C4	Bdl	0.17	29.13	35.46	7.16	28.25	7745	9	11/4/2013	AURORA ENERGY LLC
1,007.45	4	W4	ти	0.16	28.84	34.70	8.04	28.42	7603	11	11/5/2013	AURORA ENERGY LLC
1,280.20	4	W4	ΤH	0.18)28.52	73 4.3 \$	II. D .47.	eadix I	7 % p p	14	11/6/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 7/1/13 to 12/31/13

*****	and the second se	***				\$200011-0202-0202-020-020-020-020-020-020	****	*****		*****	IN 1998 IN 1999	TTY CONTRACTOR CONTRA TOR CONTRA TOR CONTRACTOR CONTRACTOR CONTRA TOR CONTRAC
939.25	4	W4	ТИ	0.13	28.70	35.74	6.91	28.65	7677	11	11/7/2013	AURORA ENERGY LLC
726.25	3	C4	Bdl	0.13	29.30	36.48	7.05	27.17	7833	8	11/8/2013	AURORA ENERGY LLC
1,230.50	4	W4	TII	0.21	28.19	34.66	9.12	28.03	7498	13	11/12/2013	AURORA ENERGY LLC
1,615.85	4	W4	ΤII	0.20	29.08	34.84	7.98	28.11	7622	17	11/13/2013	AURORA ENERGY LLC
1,368.50	4	W4	ТП	0.21	28.39	34.21	9.91	27.50	7466	15	11/14/2013	AURORA ENERGY LLC
1,137.60	4	W4	TII	0.20	28.78	34.44	8.72	28.08	7512	12	11/15/2013	AURORA ENERGY LLC
1,169.75	4	W4	ТІІ	0.21	28.65	34.26	9.39	27.70	7497	12	11/18/2013	AURORA ENERGY LLC
1,238.50	4	W4	TII	0.23	27.18	33.66	12.26	26.91	7183	13	11/19/2013	AURORA ENERGY LLC
928.10	4	W4	ТИ	0.25	27.13	33.17	12.16	27.55	7196	10	11/20/2013	AURORA ENERGY LLC
282.10	4	W4	ТП	0.25	27.65	33.48	11.04	27.84	7305	3	11/21/2013	AURORA ENERGY LLC
853.00	4	W4	TH	0.22	27.77	34.53	9.57	28,14	7444	9	11/22/2013	AURORA ENERGY LLC
2,370.10	4	W4	TII	0.19	28.54	34.72	7.91	28.84	7557	25	11/23/2013	AURORA ENERGY LLC
292.95	4	W4	TI	0.20	28.18	34.71	8.47	28.65	7521	3	11/26/2013	AURORA ENERGY LLC
1,322.45	4	W4	ΤII	0.20	27.89	34.31	9.06	28.74	7453	14	11/27/2013	AURORA ENERGY LLC
946.40	3/N	W4	TII/STK	0.16	29.09	34.71	8.86	27.34	7658	10	11/29/2013	AURORA ENERGY LLC
1,494.70	4	W4	TII	0.18	28.56	34.99	8.37	28.09	7630	17	12/2/2013	AURORA ENERGY LLC
869.90	4	W4	TT 11	0.20	28.63	34.80	8.08	28.49	7595	10	12/3/2013	AURORA ENERGY LLC
904.75	4	W4	ΤII	0.17	29.76	35.11	7.78	27.36	7734	10	12/4/2013	AURORA ENERGY LLC
763.85	3	C4	Bdl	0.13	30.10	35.21	6.95	27.74	7810	8	12/5/2013	AURORA ENERGY LLC
1,063.85	3/4	C4/W4	Bdl/Tll	0.13	29.57	34.53	7.91	27.99	7711	11	12/9/2013	AURORA ENERGY LLC
1,275.10	3	C4	Bdl	0.13	29.92	34.74	7.73	27.62	7739	13	12/10/2013	AURORA ENERGY LLC
881.40	3	C4	Bdl	0.13	29.71	34.24	8.60	27.46	7674	9	12/11/2013	AURORA ENERGY LLC
286.75	3/N	C4	Bdl/STK	0.11	29.51	34.21	8.39	27.89	7696	3	12/13/2013	AURORA ENERGY LLC
852.80	3	C4	Bdl	0.12	29.94	34.06	8.54	27.46	7702	9	12/16/2013	AURORA ENERGY LLC
776.85	4	C4	Bdl	0.13	30.05	34.58	7.89	27.48	7800	8	12/17/2013	AURORA ENERGY LLC
1,176.55	3	C4	Bdl	0.13	30.85	35.46	6.37	27.33	7960	12	12/18/2013	AURORA ENERGY LLC
966.55	3	C4	Bdl	0.12	30.10	34.92	6.73	28.26	7856	10	12/19/2013	AURORA ENERGY LLC
669.90	3/N	C4	Bdl/STK	0.13	29.92	34.88	7.58	27.63	7801	7	12/20/2013	AURORA ENERGY LLC
1,473.00	3/N	C4	Bdl/STK	0.12	30.09	34.75	7.12	28.04	7802	15	12/23/2013	AURORA ENERGY LLC
1,459.65	3/N	C4	Bdl/STK	0.15	29.65	34.17	8.37	27.81	7676	15	12/24/2013	AURORA ENERGY LLC
431.00	4	X4	TH	0.19	28.53	35.09	8.14	28.24	7632	5	12/27/2013	AURORA ENERGY LLC
547.85	4	X4	тн	0.22)27.70	73455([]]. D ?7	endix 1	7 ≸X ∮p	6	12/27/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 7/1/13 to 12/31/13

***************************************	****	****	X80010-007070097	******		****		1711122/14/1214144	1940-1149-1446-1446-1446-1446-1446-1446-1446	TERMINING STREET	*******	*****
AURORA ENERGY LLC	12/29/2013	27	7744	27.93	7.68	35.17	29.23	0.17	TII	X4	4	2,307.45
AURORA ENERGY LLC	12/30/2013	10	7520	27.94	9.09	34.77	28.20	0.22	ТШ	X4	4	942.95
AURORA ENERGY LLC	12/31/2013	8	7602	27.77	8.55	34.81	28.87	0.22	ΤII	X4	4	744.15
Weighted Averages Summ	ary											
Customer		Tons		BTU	Н	20	Ash		Volatiles	Cart	on	Sulfur
AURORA ENERGY LLC		115917.70)	7599.00	2	7.95	8.8	31	34.72	28	3.53	0.17

This analysis is representative of the coal shipped

using sulfur standard ASTM D4239-12

Colcen Shompson 1-3-14

Rail Samples Analysis Results for 1/1/14 to 6/30/14

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2014	15	7592	27.80	8.87	34.55	28.78	0.20	тп	X4	4	1,370.90
AURORA ENERGY LLC	1/3/2014	15	7615	29.16	7.32	35.00	28.52	0.17	TII	X4	4	1,440.35
AURORA ENERGY LLC	1/6/2014	8	7633	28.42	7.70	34.85	29.03	0.16	ΤII	X4	4	779.40
AURORA ENERGY LLC	1/7/2014	12	7642	28.93	7.31	34.80	28.97	0.17	ти	X4	4	1,137.10
AURORA ENERGY LLC	1/8/2014	13	7615	28.31	8.20	34.76	28.74	0.19	ти	X4	4	1,229.35
AURORA ENERGY LLC	1/9/2014	11	7538	28.03	8.94	34.41	28.63	0.23	ТШ	X4	4	1,070.75
AURORA ENERGY LLC	1/10/2014	13	7571	28.86	8.02	34.63	28.49	0.18		X4	4	1,216.15
AURORA ENERGY LLC	1/13/2014	10	7453	27.84	9.86	34.82	27.48	0.22	TII	X4	4	984.25
AURORA ENERGY LLC	1/14/2014	11	7489	28.42	8.99	34.32	28.27	0.22	Bdl	C4	3	1,031.80
AURORA ENERGY LLC	1/15/2014	8	7608	28.12	8.69	34.32	28.87	0.20	тп	X4	4	756.60
AURORA ENERGY LLC	1/16/2014	13	7588	28.25	8.55	34.40	28.80	0.20	ти	X4	4	1,251.05
AURORA ENERGY LLC	1/18/2014	16	7679	29.63	6.32	34.82	29.24	0.14	TII	X4	4	1,478.00
AURORA ENERGY LLC	1/20/2014	10	7735	28.53	7.06	34.71	29.71	0.16	ΤII	X4	4	953.85
AURORA ENERGY LLC	1/21/2014	9	7833	28.40	6.48	34.96	30.17	0.13	Bdl	C4	3	805.85
AURORA ENERGY LLC	1/22/2014	12	7767	27.95	7.35	34.72	29.99	0.13	Bdl	C4	3	1,168.20
AURORA ENERGY LLC	1/23/2014	3	7759	28.53	7.30	34.21	29.97	0.13	Bdl	C4	3	293.50
AURORA ENERGY LLC	1/27/2014	9	7379	28.65	9.78	33.16	28.41	0.12	Bdl/JR	C4/C13	3/3	853.10
AURORA ENERGY LLC	1/28/2014	9	7700	28.25	7.82	34.50	29.43	0.15	Bdl/JR	C4/C13	3/3	810.95
AURORA ENERGY LLC	1/29/2014	10	7721	28.70	7.00	34.48	29.82	0.14	Bdl/STK	C4	3/N	917.25
AURORA ENERGY LLC	1/30/2014	15	7737	28.41	7.34	34.81	29.44	0.13	Bdl	C4	3	1,357.75
AURORA ENERGY LLC	1/31/2014	22	7529	29.01	8.13	33.66	29.21	0.12	Bdl	C4	3	2,046.90
AURORA ENERGY LLC	2/3/2014	19	7560	28.92	8.26	33.56	29.26	0.14	Bdl	C4	3	1,809.10
AURORA ENERGY LLC	2/4/2014	12	7527	29.18	8.14	33.53	29.14	0.13	Bdl/ T II	C4/X3	3/3	1,138.90
AURORA ENERGY LLC	2/5/2014	6	7533	28.73	8.62	34.00	28.66	0.13	TII	X3	3	549.45
AURORA ENERGY LLC	2/6/2014	9	7582	28.26	8.89	33.92	28.93	0.12	тп	X3	3	833.35
AURORA ENERGY LLC	2/10/2014	11	7548	28.78	8.49	33.65	29.08	0.13	ΤIJ	X3	3	997.40
AURORA ENERGY LLC	2/12/2014	13	7669	28.02	8.03	34.85	29.10	0.13	ТИ	X 3	3	1,178.00
AURORA ENERGY LLC	2/12/2014	8	7568	27.51	9.42	34.40	28.68	0.12	ΤII	X 3	3	735.35
AURORA ENERGY LLC	2/13/2014	12	7810	26.92	8.17	35.24	29.67	0.19	Bdl	A	4	1,085.25
AURORA ENERGY LLC	2/15/2014	10	⁷⁸ A¹pt	oeffdfx II	1 ⁷ .D.7	.7°=4195	2 ^{29.07}	0.21	Bdl	А	4	964.15

Rail Samples Analysis Results for 1/1/14 to 6/30/14

GROOM WHEN COLUMN AND A												
AURORA ENERGY LLC	2/17/2014	8	7821	26.21	8.59	36.19	29.02	0.26	Bdl	А	4	771.90
AURORA ENERGY LLC	2/18/2014	12	7857	26.05	8.45	35.90	29.61	0.23	Bdl	А	4	1,099.50
AURORA ENERGY LLC	2/19/2014	16	7803	26.19	8.75	35.91	29.15	0.21	Bdl/STK	А	4/N	1,524.75
AURORA ENERGY LLC	2/20/2014	7	7738	26.33	9.11	35.75	28.82	0.20	Bdl/STK	А	4/N	670.45
AURORA ENERGY LLC	2/21/2014	18	7702	26.91	8.70	35.77	28.63	0.20	Bdl/STK	А	4/N	1,716.05
AURORA ENERGY LLC	2/24/2014	13	7721	27.34	8.35	35.25	29.07	0.19	Bdl/STK	А	4/N	1,244.25
AURORA ENERGY LLC	2/25/2014	14	7663	27.53	8.50	34.81	29.15	0.15	TII/BdI	X3/A	3/4	1,314.15
AURORA ENERGY LLC	2/27/2014	18	7704	27.80	7.88	35.13	29.20	0.14	TH	X3	3	1,743.25
AURORA ENERGY LLC	2/28/2014	19	7519	28.26	8.83	34.59	28.33	0.13	Bdl/T II	A/X3	4/3	1,856.75
AURORA ENERGY LLC	3/3/2014	11	7539	28.91	8.17	33.90	29.03	0.11	TII/Bdl	X3/A	3/4	1,078.75
AURORA ENERGY LLC	3/4/2014	13	7678	26.91	9.19	35.01	28.89	0.23	Bdl/STK	В	4/N	1,195.00
AURORA ENERGY LLC	3/5/2014	11	7784	26.75	8.53	35.75	28.96	0.21	Bdl/STK	В	4/N	1,084.80
AURORA ENERGY LLC	3/6/2014	7	7723	26.83	8.71	35.41	29.05	0.18	Bdl/STK	В	4/N	691.95
AURORA ENERGY LLC	3/7/2014	7	7758	26.72	8.49	35.58	29.20	0.19	Bdl/STK	в	4/N	666.20
AURORA ENERGY LLC	3/10/2014	7	7719	26.52	9.09	35.53	28.86	0.22	Bdl/STK	в	4/N	671.50
AURORA ENERGY LLC	3/11/2014	11	7675	27.64	8.15	35.24	28.97	0.20	Bdl/STK	В	4/N	1,016.05
AURORA ENERGY LLC	3/12/2014	4	7634	27.35	8.82	35.17	28.66	0.21	Bdl/STK	В	4/N	394.50
AURORA ENERGY LLC	3/13/2014	16	7120	26.15	14.55	33.06	26.25	0.25	Bdl/STK	в	4/N	1,555.45
AURORA ENERGY LLC	3/14/2014	12	7615	27.55	9.03	34.97	28.45	0.18	Bdl/STK	в	4/N	1,178.10
AURORA ENERGY LLC	3/17/2014	3	7872	26.97	7.37	36.05	29.62	0.18	Bdl	В	4	281.15
AURORA ENERGY LLC	3/18/2014	12	7750	27.82	7.64	34.83	29.70	0.16	BdI/STK	в	4/N	1,093.55
AURORA ENERGY LLC	3/19/2014	12	7798	27.45	7.40	35.78	29.38	0.18	Bdl/STK	в	4/N	1,128.70
AURORA ENERGY LLC	3/20/2014	10	7948	26.46	7.32	36.57	29.84	0.23	Bdl/STK	В	4/N	951.45
AURORA ENERGY LLC	3/21/2014	12	7916	27.92	6.00	35.87	30.22	0.12	Bdl	В	4	1,075.20
AURORA ENERGY LLC	3/24/2014	12	7882	27.38	6.81	35.69	15.13	0.14	BdI/STK	в	4/N	1,043.95
AURORA ENERGY LLC	3/25/2014	1	8057	26.46	6.27	36.20	31.04	0.13	Bdl/STK	В	4/N	85.90
AURORA ENERGY LLC	3/26/2014	15	7887	27.68	6.78	35.65	29.90	0.12	Bdl/T II	B/X3	4/3	1,414.80
AURORA ENERGY LLC	3/27/2014	26	7482	27.96	9.07	34.76	28.21	0.11	TH	X3	3	2,390.75
AURORA ENERGY LLC	3/31/2014	8	7310	27.68	11.54	33.38	27.41	0.13	ΤII	Х3	3	783.60
AURORA ENERGY LLC	4/1/2014	9	7832	28.80	5.23	35.61	30.37	0.10	Bdl	А	3	825.10
AURORA ENERGY LLC	4/2/2014	13	7776	28.29	5.87	35.47	30.37	0.11	Bdl/STK	А	3/N	1,226.70
AURORA ENERGY LLC	4/3/2014	9	75 A 9pp	oendix I	II8 D 77.	7344525	329.30	0.13	Bdl/STK	А	3/N	892.80

Rail Samples Analysis Results for 1/1/14 to 6/30/14

				THE REAL PROPERTY OF THE PROPE		*****	****	******	0-15-F11110-12-C-42-C-42-B-CC-44-18-2-A-41-3-1			
AURORA ENERGY LLC	4/4/2014	5	7695	28.07	7.91	34.98	29.05	0.11	T II/Bdl	X3/A	3/3	486.30
AURORA ENERGY LLC	4/7/2014	10	7899	28.09	5.97	35.24	30.71	0.12	Bdl	А	3	913.65
AURORA ENERGY LLC	4/8/2014	10	7861	28.29	6.32	34.97	30.43	0.12	Bdl/STK	А	3/N	951.00
AURORA ENERGY LLC	4/9/2014	14	7878	27.84	6.59	35.28	30.30	0.12	Bdl/STK	А	3/N	1,358.65
AURORA ENERGY LLC	4/10/2014	13	7734	28.36	7.47	34.44	29.73	0.12	Bdl/STK	A	3/N	1,286.85
AURORA ENERGY LLC	4/11/2014	9	7609	28.55	8.22	34.50	28.74	0.12	Bdl/STK	A	3/N	866.30
AURORA ENERGY LLC	4/14/2014	10	7769	27.99	7.38	34.83	29.80	0.11	Bdl/STK	А	3/N	938.10
AURORA ENERGY LLC	4/15/2014	12	7662	28.55	7.20	36.80	27.46	0.13	T II	LST	6	1,108.05
AURORA ENERGY LLC	4/16/2014	11	7262	27.55	11.33	35.30	25.83	0.13	T 11	LST	6	950.55
AURORA ENERGY LLC	4/17/2014	13	7462	28.02	9.11	36.75	26.14	0.10	TII	LST	6	1,131.00
AURORA ENERGY LLC	4/18/2014	13	7632	29.53	4.91	36.14	29.42	0.07	Bdl/STK	A	3/N	1,247.60
AURORA ENERGY LLC	4/21/2014	9	7627	27.72	7.25	35.32	29.71	0.11	Bdl/STK	В	3/N	832.25
AURORA ENERGY LLC	4/22/2014	11	7451	27.99	9.12	35.47	27.43	0.13	ТΠ	LST	6	1,070.80
AURORA ENERGY LLC	4/23/2014	11	7525	28.07	8.16	35.70	28.07	0.12	Bdl/STK	В	3/N	999.30
AURORA ENERGY LLC	4/24/2014	12	7570	28.32	8.11	36.21	27.36	0.12	ΤII	LST	6	1,162.05
AURORA ENERGY LLC	4/25/2014	13	7464	28.40	8.61	36.49	26.51	0.13	TH	LST	6	1,204.30
AURORA ENERGY LLC	4/28/2014	11	7451	27.57	9.55	35.68	27.20	0.13	ТИ	LST	6	1,083.20
AURORA ENERGY LLC	4/30/2014	12	7397	27.69	9.76	36.58	25.97	0.12	TII	LST	6	1,093.95
AURORA ENERGY LLC	5/1/2014	12	7464	27.86	9.03	36.29	26.82	0.13	TI	LST	6	1,094.60
AURORA ENERGY LLC	5/5/2014	11	7601	28.24	8.15	36.22	27.39	0.14	ΤII	LST	6	994.65
AURORA ENERGY LLC	5/6/2014	10	7735	27.79	7.63	36.55	28.04	0.14	ΤIJ	LST	6	906.90
AURORA ENERGY LLC	5/7/2014	12	7638	28.23	7.46	36.83	27.49	0.13	ΤII	LST	6	1,121.35
AURORA ENERGY LLC	5/8/2014	14	7544	28.57	8.21	35.22	28.00	0.13	T II/Bsl	LST/A	6/3	1,403.70
AURORA ENERGY LLC	5/12/2014	16	7796	27.50	8.05	35.31	29.14	0.13	Bdl/STK	А	3/N	1,548.15
AURORA ENERGY LLC	5/14/2014	12	7746	28.25	6.78	37.35	27.62	0.12	Bdl/TII	A/LST	3/6	1,055.15
AURORA ENERGY LLC	5/15/2014	9	7712	28.25	7.12	37.35	27.28	0.12	Bdl/TII	A/LST	3/6	858.05
AURORA ENERGY LLC	5/16/2014	10	7707	27.99	7.76	36.08	28.18	0.11	TII/Bdl	LST/A	6/3	974.80
AURORA ENERGY LLC	5/19/2014	8	7769	26.93	7.92	35.48	29.68	0.13	TII/Bdi	LST/B	6/3	769.15
AURORA ENERGY LLC	5/20/2014	11	7915	28.22	6.07	35.62	30.10	0.11	Bdl/STK	В	3/N	1,041.70
AURORA ENERGY LLC	5/21/2014	9	7761	27.26	8.12	35.07	29.56	0.12	Bdl/STK	в	3/N	891.85
AURORA ENERGY LLC	5/22/2014	7	7809	27.38	7.27	35.93	29.43	0.11	BdI/STK	в	3/N	693.85
AURORA ENERGY LLC	5/23/2014	8	77 A 6pp	oendix	III6 D 27.	7384355	426.52	0.12	TI	LST	6	724.90

Rail Samples Analysis Results for 1/1/14 to 6/30/14

AURORA ENERGY LLC		117659.6	5	7652.00	2	7.89	8.1	15	35.29	2	8.54	0.15
Customer		Tons		BTU		20	Ash		Volatiles	Carl	bon	Sulfur
Weighted Averages Su	mmary			2			******					
AURORA ENERGY LLC	6/30/2014	9	7695	28.75	7.46	34.73	29.06	0.11	Bdl/STK	С	3/N	829.70
AURORA ENERGY LLC	6/26/2014	12	7776	27.04	7.86	35.66	29.45	0.11	Bdl/STK	с	3/N	1,172.35
AURORA ENERGY LLC	6/25/2014	13	7751	28.21	7.20	34.95	29.64	0.11	Bdl/STK	С	3/N	1,259.45
AURORA ENERGY LLC	6/24/2014	10	7712	27.76	8.03	34.70	29.51	0.12	Bdl/STK	С	3/N	931.05
AURORA ENERGY LLC	6/23/2014	9	7311	28.02	10.34	35.77	25.87	0.15	тп	LST	6	867.60
AURORA ENERGY LLC	6/19/2014	18	7458	27.53	9.65	36.66	26.16	0.11	Τll	LST	6	1,681.40
AURORA ENERGY LLC	6/18/2014	16	7672	27.62	7.90	37.02	27.47	0.12	ΤII	LST	6	1,534.80
AURORA ENERGY LLC	6/16/2014	10	7632	27.40	8.88	36.76	26.96	0.12	тп	LST	6	964.10
AURORA ENERGY LLC	6/12/2014	5	7669	27.41	8.70	37.27	26.62	0.11	GRP/TII	LST	M/6	489.40
AURORA ENERGY LLC	6/11/2014	7	7704	26.60	10.00	35.94	27.47	0.14	T II/GRP	LST	6/M	683.90
AURORA ENERGY LLC	6/9/2014	5	7676	28.30	7.60	36.90	27.20	0.12	тн	LST	6	481.65
AURORA ENERGY LLC	6/5/2014	13	7690	28.12	7.45	36.87	27.56	0.13	ти	LST	6	1,236.80
AURORA ENERGY LLC	6/3/2014	8	7949	27.23	6.72	36.14	29.91	0.11	Bdl/STK	в	3/N	779.60
AURORA ENERGY LLC	6/2/2014	8	7688	27.53	8.31	34.79	29.39	0.11	Bdl/STK	В	3/N	793.70
AURORA ENERGY LLC	5/30/2014	12	7673	27.44	8.50	34.98	29.08	0.11	Bdl/STK	В	3/N	1,150.20
AURORA ENERGY LLC	5/29/2014	12	7514	27.86	9.02	34.63	28.50	0.13	Bdl/STK	В	3/N	1,174.15
AURORA ENERGY LLC	5/28/2014	14	7654	26.98	8.94	35.73	28.36	0.12	Bdl/STK	В	3/N	1,342.05
AURORA ENERGY LLC	5/20/2014	7	1123	20.31	0.70	38.02	20.90	0.12	111	LSI	6	014.05

This analysis is representative of the coal shipped using sulfur standard ASTM D4239 - 12 $\,$

Coleen Strompson 7-2-14

Appendix E (Coal Sulfur Summary)

Rail Samples Analysis Results for 7/1/14 to 12/31/14

Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/1/2014	17	7525	28.93	8.28	34.19	28.60	0.12	Bdl/STK	с	3/N	1,638.75
AURORA ENERGY LLC	7/2/2014	11	7442	29.33	8.64	34.80	27.23	0.13	Bdl/STK	С	3/N	1,079.80
AURORA ENERGY LLC	7/4/2014	7	7656	27.98	8.07	36.98	26.97	0.11	тн	LST	6	627.85
AURORA ENERGY LLC	7/7/2014	13	7622	28.13	7.79	37.11	26.97	0.12	TI	LST	6	1,239.90
AURORA ENERGY LLC	7/9/2014	33	7578	28.14	8.43	36.77	26.67	0.13	ΤII	LST	6	3,141.00
AURORA ENERGY LLC	7/14/2014	13	7395	27.68	9.60	36.03	26.72	0.13	ΤII	LST	6	1,276.45
AURORA ENERGY LLC	7/16/2014	18	7619	28.26	7.73	36.94	27.08	0.12	ΤII	LST	6	1,699.05
AURORA ENERGY LLC	7/17/2014	18	7570	28.11	8.29	36.76	26.84	0.12	ТΠ	LST	6	1,778.65
AURORA ENERGY LLC	7/21/2014	14	7442	28.16	9.30	36.11	26.43	0.13	тн	LST	6	1,346.20
AURORA ENERGY LLC	7/23/2014	16	7409	28.35	9.31	36.18	26.16	0.12	ТШ	LST	6	1,446.00
AURORA ENERGY LLC	7/24/2014	17	7621	27.21	8.61	37.30	26.88	0.11	TII	LST	6	1,544.95
AURORA ENERGY LLC	7/28/2014	5	7539	27.66	8.85	36.81	26.69	0.12	тι	LST	6	490.95
AURORA ENERGY LLC	7/30/2014	6	7675	26.58	9.28	36.70	27.45	0.14	Bdl	C1	6	569.15
AURORA ENERGY LLC	8/4/2014	8	7404	29.01	8.95	35.65	26.39	0.13	ŤΠ	LST	6	795.30
AURORA ENERGY LLC	8/5/2014	8	7750	27.08	8.18	37.34	27.40	0.13	TBR	C1	6	703.80
AURORA ENERGY LLC	8/6/2014	17	7586	26.84	9.66	36.79	26.71	0.14	TBR	C1	6	1,686.45
AURORA ENERGY LLC	8/7/2014	13	7425	27,57	10.25	36.28	25.91	0.13	TBR	C1	6	1,299.70
AURORA ENERGY LLC	8/11/2014	8	7702	27.08	8.56	36.95	27.42	0.13	TBR	C1	6	781.45
AURORA ENERGY LLC	8/13/2014	18	7601	26.69	9.52	36.64	27.16	0.13	TBR	C1	6	1,605.50
AURORA ENERGY LLC	8/14/2014	16	7510	26.42	10.35	36.71	26.53	0.12	TBR	C1	6	1,500.05
AURORA ENERGY LLC	8/16/2014	10	7952	25.09	10.53	36.52	27.87	0.19	GRP/STM	<	M/N	937.00
AURORA ENERGY LLC	8/18/2014	4	7846	25.81	10.48	35.39	28.33	0.17	GRP/ST	K	M/N	403.90
AURORA ENERGY LLC	8/20/2014	5	7972	25.66	10.21	34.89	29.25	0.16	GRP/STH	<	M/N	479.00
AURORA ENERGY LLC	8/21/2014	5	7947	25.16	10.86	35.53	28.45	0.16	GRP/STh	K	M/N	472.20
AURORA ENERGY LLC	8/25/2014	6	7585	26.17	11.19	35.79	26.86	0.14	GRP/STM	< C	M/N	575.15
AURORA ENERGY LLC	8/27/2014	5	7844	26.46	9.73	35.49	28.33	0.15	GRP/STK	< Comparison of the second sec	M/N	459.95
AURORA ENERGY LLC	8/28/2014	5	7573	27.55	9.51	35.82	27.13	0.13	TBR	C1	6	453.20
AURORA ENERGY LLC	9/2/2014	5	7853	25.68	10.15	35.75	28.43	0.16	GRP/STK	5	M/N	444.10
AURORA ENERGY LLC	9/3/2014	7	7595	27.30	9.44	35.06	28.21	0.23	Bdl	Е	4	599.15
AURORA ENERGY LLC	9/5/2014	9	⁷¹ Å4pr	pendix II	1. D .7	.7 ² 455	7 ^{24.76}	0.24	GRP/STK	ζ.	M/N	804.25

Rail Samples Analysis Results for 7/1/14 to 12/31/14

	INCREASED IN THE ADDRESS OF THE ADDR		*****		Second States and States	****	1999))))))))))))))))))))))))))))))))))	SCONDERCE STREET	WSNOW CONTRACTOR OF	***	en er sen en e	unzen underen schristlicherste
AURORA ENERGY LLC	9/5/2014	3	7828	23.73	14.19	34.29	27.79	0.22	GRP/STK		M/N	268.65
AURORA ENERGY LLC	9/5/2014	6	7651	23.59	15.37	33.86	27.19	0.23	GRP/STK		M/N	539.60
AURORA ENERGY LLC	9/8/2014	6	7455	27.39	10.16	36.70	25.75	0.13	Bdl	E	4	535.55
AURORA ENERGY LLC	9/10/2014	12	7336	28.02	10.03	35.87	26.09	0.13	ТН	LST	6	1,100.05
AURORA ENERGY LLC	9/11/2014	10	7155	27.65	12.33	34.95	25.08	0.13	ти	LST	6	941.35
AURORA ENERGY LLC	9/15/2014	5	7517	27.42	9.62	35.72	27.25	0.17	Bdl	E	4	464.40
AURORA ENERGY LLC	9/17/2014	7	7531	27.52	9.06	36.59	26.84	0.13	ТШ	LST	6	652.45
AURORA ENERGY LLC	9/18/2014	6	7493	27.99	8.91	35.72	27.39	0.19	ΤIJ	LST	6	539.45
AURORA ENERGY LLC	9/22/2014	5	7793	28.38	6.50	35.62	29.51	0.14	Bdl	E	4	481.40
AURORA ENERGY LLC	9/24/2014	9	7206	26.90	12.00	35.04	26.07	0.13	ТΠ	LST	6	864.35
AURORA ENERGY LLC	9/25/2014	10	7528	28.00	8.47	36.92	26.61	0.12	TII	LST	6	971.75
AURORA ENERGY LLC	9/27/2014	11	7739	28.34	6.81	36.34	28.51	0.18	Bdl	E	4	1,007.10
AURORA ENERGY LLC	9/29/2014	11	7739	28.09	6.87	35.86	29.18	0.19	Bdl	F	4	1,034.60
AURORA ENERGY LLC	9/30/2014	11	7749	28.54	6.60	35.47	29.41	0.16	Bdl	F	4	984.35
AURORA ENERGY LLC	10/1/2014	26	7815	28.29	6.55	35.84	29.32	0.16	Bdl	F	4	2,485.80
AURORA ENERGY LLC	10/6/2014	10	7591	28.11	8.20	36.05	27.65	0.16	Bdl/Tll	F/LST	4/6	856.70
AURORA ENERGY LLC	10/8/2014	9	7403	27.49	10.14	35.31	27.07	0.16	Bdl/T II	F/LST	4/6	810.80
AURORA ENERGY LLC	10/8/2014	11	7499	28.23	8.70	36.11	26.96	0.12	ΤII	LST	6	985.90
AURORA ENERGY LLC	10/9/2014	12	7495	28.17	8.40	36.91	26.52	0.12	ТП	LST	6	1,116.25
AURORA ENERGY LLC	10/11/2014	13	7566	28.43	7.85	38.08	25.65	0.12	ти	LST	6	1,133.10
AURORA ENERGY LLC	10/13/2014	7	7405	27.91	9.44	36,23	26.43	0.13	ΤII	LST	6	676.50
AURORA ENERGY LLC	10/15/2014	11	7971	26.15	9.33	35.38	29.13	0.15	GRP/STK		M/N	997.30
AURORA ENERGY LLC	10/16/2014	16	8040	25.93	8.50	36.45	29.13	0.16	GRP/STK		M/N	1,476.75
AURORA ENERGY LLC	10/20/2014	9	7629	27.68	8.84	36.03	27.45	0.14	ΤII	LST	6	864.20
AURORA ENERGY LLC	10/21/2014	12	7874	27.45	7.56	35.30	29.69	0.13	Bdl	D	3	1,113.15
AURORA ENERGY LLC	10/22/2014	15	7932	27.59	6.48	35.31	30.62	0.12	Bdl	E	3	1,424.60
AURORA ENERGY LLC	10/23/2014	14	7880	27.56	6.24	36.02	30.19	0.10	Bdl	Е	3	1,343.80
AURORA ENERGY LLC	10/24/2014	9	7169	30.71	6.85	34.67	27.79	0.12	Jumbo			783.45
AURORA ENERGY LLC	10/27/2014	12	7748	28.04	7.14	35,35	29.47	0.13	Bdl/STK	D	3/N	1,187.15
AURORA ENERGY LLC	10/28/2014	10	7616	28.45	7.79	35.64	28.13	0.12	BdI/T II	D/LST	3/6	922.05
AURORA ENERGY LLC	10/29/2014	10	7494	28.14	8.94	35.97	26.95	0.13	тμ	LST	6	939.80
AURORA ENERGY LLC	10/30/2014	11	7 4 4pp	eadáx I	11 8D 97.	73455	826.15	0.12	TI	LST	6	1,074.40

Rail Samples Analysis Results for 7/1/14 to 12/31/14

STATEMETERS AND A CONTRACTORS AND A CONTRACTORS AND A CONTRACT AND A CONTRACT AND A CONTRACT AND A CONTRACT AND	*************	EADE428-WATERATERSTR.8	HILL CARACTERING AND	355.566822362266666992965	*****************	*****		man and the second s	instruction in the second s	www.industry.industry.org	AND ADDRESS OF A DESCRIPTION OF A DESCRI	
AURORA ENERGY LLC	10/31/2014	10	7754	28.43	7.39	36.13	28.06	0.13	TII/BdI	LST/D	6/3	943.50
AURORA ENERGY LLC	11/3/2014	6	7675	29.16	6.72	34.86	29.26	0.12	Bdl/JD	D	3/4	566.40
AURORA ENERGY LLC	11/4/2014	13	7741	28.44	6.73	35.24	29.59	0.11	Bdl/JD	D	3/4	1,279.15
AURORA ENERGY LLC	11/5/2014	12	7651	28.22	7.68	35.38	28.73	0.12	Bdl/JD	D	3/4	1,176.25
AURORA ENERGY LLC	11/6/2014	9	7622	28.67	7.42	34.84	29.07	0.12	Bdl/JD	D	3/4	848.35
AURORA ENERGY LLC	11/7/2014	12	7769	28.00	7.20	35.32	29.48	0.11	Bdl/JD	D	3/4	1,064.60
AURORA ENERGY LLC	11/10/2014	7	7769	28.21	6.77	35.31	29.71	0.10	Bdl/JD	D	3/4	650.70
AURORA ENERGY LLC	11/11/2014	12	7739	28.65	6.64	35.20	29.52	0.11	Bdl/JD	D	3/4	1,141.50
AURORA ENERGY LLC	11/12/2014	12	7644	29.46	6.67	34.68	29.19	0.12	Bdl/JD	D	3/4	1,120.25
AURORA ENERGY LLC	11/13/2014	9	7613	29.14	6.79	35.81	28.27	0.11	Bdl/JD	D	3/4	840.50
AURORA ENERGY LLC	11/14/2014	7	7805	27.58	7.75	36.16	28.52	0.14	Bdl/JD	D	3/4	638.10
AURORA ENERGY LLC	11/17/2014	6	7749	26.36	10.84	34.65	28.16	0.19	GRP/STK		M/N	604.55
AURORA ENERGY LLC	11/18/2014	31	7295	26.35	14.74	33.00	25.91	0.17	GRP/STK		M/N	3,113.25
AURORA ENERGY LLC	11/19/2014	12	7822	25.92	11.05	34.90	28.14	0.17	GRP/Bdl	D	M/3	1,161.75
AURORA ENERGY LLC	11/21/2014	4	7765	27.96	9.54	34.70	27.80	0.14	GRP/JD		M/4	355.30
AURORA ENERGY LLC	11/24/2014	9	7821	29,00	5.59	36.00	29.41	0.11	Bdl/JD	F	3/4	792.50
AURORA ENERGY LLC	11/25/2014	12	7837	28.38	5.94	35.63	30.05	0.10	Bdl/JD	F	3/4	1,101.60
AURORA ENERGY LLC	11/26/2014	13	7636	29.62	6.57	35.03	28.79	0.09	Bdl/JD	D	3/4	1,157.55
AURORA ENERGY LLC	11/28/2014	9	7798	28.82	6.04	35.55	29.58	0.09	Bdl/JD	F	3/4	775.45
AURORA ENERGY LLC	12/1/2014	8	7814	28.53	6.40	35.39	29.68	0.10	Bdl/STK	F	3/N	742.55
AURORA ENERGY LLC	12/2/2014	11	7843	27.99	6.73	35.16	30.13	0.11	Bdl/STK	F	3/N	1,039.75
AURORA ENERGY LLC	12/3/2014	10	7718	28.26	7.17	35.07	29.51	0.10	Bdl/STK	F	3/N	862.65
AURORA ENERGY LLC	12/4/2014	8	7659	27.93	7.94	35.42	28.71	0.10	Bdl/STK	F	3/N	753.20
AURORA ENERGY LLC	12/5/2014	13	7660	27.86	8.23	35.41	28.51	0.12	Bdl/STK	F	3/N	1,222.65
AURORA ENERGY LLC	12/8/2014	11	7399	26.38	12.62	34.16	26.85	0.31	BdI/STK	G	4/N	1,068.05
AURORA ENERGY LLC	12/9/2014	10	7758	27.16	8.46	35.76	28.61	0.25	Bdl/STK	G	4/N	933.35
AURORA ENERGY LLC	12/10/2014	8	7671	27.12	8.79	35.30	28.79	0.23	Bdl/STK	G	4/N	730.55
AURORA ENERGY LLC	12/11/2014	9	7762	27.40	8.01	35.48	29.12	0.21	Bdl/Bdl	G/F	4/3	846.70
AURORA ENERGY LLC	12/12/2014	14	7657	27.61	8.26	35.28	28.85	0.15	Bdl/STK	F	3/N	1,285.70
AURORA ENERGY LLC	12/15/2014	12	7491	29.18	8.10	35.28	27.44	0.15	Bdl/JD	G	4/4	1,100.15
AURORA ENERGY LLC	12/16/2014	18	7630	28.23	8.32	35.71	27.74	0.19	Bdl/JD	G	4/4	1,705.05
AURORA ENERGY LLC	12/17/2014	8	76 A pp	endix l	II 7D \$7.	73\$\$\$5	9 28.40	0.16	Bdl/JD	G	4/4	770.15

Rail Samples Analysis Results for 7/1/14 to 12/31/14

		******		*********	190721725310570 //151//10	1		770CERTATURAR77561	*****	*****		
AURORA ENERGY LLC	12/18/2014	20	7528	31.48	6.44	34.37	27.71	0.13	JD		4	1,850.00
AURORA ENERGY LLC	12/19/2014	4	7626	28.89	7.57	35.42	28.12	0.15	Bdl/JD	G	4/4	372.05
AURORA ENERGY LLC	12/22/2014	10	7561	28.72	8.34	35.26	27.69	0.18	Bdl/JD	G	4/4	981.45
AURORA ENERGY LLC	12/23/2014	17	7598	28.65	8.05	35.35	27.95	0.18	Bdl/JD	G	4/4	1,535.65
AURORA ENERGY LLC	12/24/2014	12	7563	28.54	8.75	35.22	27.50	0.19	Bdl/JD	G	4/4	1,037.65
AURORA ENERGY LLC	12/26/2014	6	7418	26.62	12.03	34.98	26.37	0.28	Bdl/JD	G	4/4	550.45
AURORA ENERGY LLC	12/29/2014	8	7385	27.89	10.46	34.77	26.89	0.25	Bdl/JD	G	4/4	778.85
AURORA ENERGY LLC	12/30/2014	12	7568	29.02	8.07	34.65	28.26	0.21	Bdl/JD	G	4/4	1,145.15
AURORA ENERGY LLC	12/31/2014	10	7643	29.27	7.21	35.29	28.24	0.18	Bdl/JD	G	4/4	880.85
Weighted Averages Sun	nmary											
Customer		Tons	*****	BTU	۲. ۲	20	Ash		Volatiles	Car	bon	Sulfur
AURORA ENERGY LLC	eannan tan nan tan tan kana kan kan kan kan kan kan kan kan	103979.45		7617.00	2	7.86	8.1	67	35.66	2	7.82	0.14

This analysis is representative of the coal shipped using sulfur ASTM D4239-12

Colien Thompson 1-5-15

Appendix E (Coal Sulfur Summary)

Adopted

7/1/2015

Usibelli Coal Mine

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 1/1/15 to 6/30/15

Customer	Date	#Cars	BTU	%H20	% A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2015	10	7542	28.10	8.78	35.14	27.98	0.22	Bdl/JD	G	4/4	913.35
AURORA ENERGY LLC	1/5/2015	8	7586	29.30	7.87	34.51	28.33	0.21	Bdl/JD	G	4/4	761.95
AURORA ENERGY LLC	1/6/2015	15	7593	29.68	7.16	34.84	28.32	0.21	Bdl/JD	G	4/4	1,331.30
AURORA ENERGY LLC	1/7/2015	10	7609	29.88	6.82	34.57	28.74	0.19	Bdl/JD	G	4/4	913.10
AURORA ENERGY LLC	1/8/2015	13	7572	27.19	9.58	35.09	28.15	0.24	Bdl/JD	G	4/4	1,217.90
AURORA ENERGY LLC	1/9/2015	13	7658	28.66	7.66	35.64	28.04	0,20	Bdl/JD	G	4/4	1,270.65
AURORA ENERGY LLC	1/12/2015	8	7612	27.19	9.36	35.22	28.24	0.22	Bdl/ ⊤ II	G/LST	4/6	735.75
AURORA ENERGY LLC	1/13/2015	13	7605	27.86	8.81	35.00	28.33	0.21	Bdl/T II	G/LST	4/6	1,249.40
AURORA ENERGY LLC	1/14/2015	30	7355	26.04	12.63	34.27	27.07	0.31	Bdl/STK	G	4/N	2,906.30
AURORA ENERGY LLC	1/14/2015	10	7413	26.77	11.28	34.53	27.42	0.30	Bdl/STK	G	4/N	985.30
AURORA ENERGY LLC	1/19/2015	8	7722	27.69	7.86	35.65	28.80	0.15	BdI/S⊺K	G	4/N	710.60
AURORA ENERGY LLC	1/20/2015	13	7615	28.20	7.93	36.17	27.71	0.15	TII/STK	LST	6/N	1,225.25
AURORA ENERGY LLC	1/21/2015	10	7493	27.67	9.57	36.02	26.75	0.14	тΙΙ	LST	6	954,30
AURORA ENERGY LLC	1/22/2015	8	7625	27.33	8.98	35.40	28.28	0.22	BdI/STK	G	4/N	778.30
AURORA ENERGY LLC	1/26/2015	9	7635	27.97	7.73	35.95	28.36	0.15	Bdl/T II	F/LST	3/6	835.50
AURORA ENERGY LLC	1/27/2015	7	7516	28.18	8.81	36.32	26.69	0.14	тΠ	LST	6	645.20
AURORA ENERGY LLC	1/28/2015	5	7469	28.31	9.15	36.13	26.41	0.15	тп	LST	6	448,45
AURORA ENERGY LLC	1/29/2015	6	7515	28.38	8.44	36.63	26.56	0.13	тп	LST	6	554.05
AURORA ENERGY LLC	1/29/2015	5	7607	28.03	8.04	36.88	27.05	0.13	тш	LST	6	424.60
AURORA ENERGY LLC	1/30/2015	14	7541	28.33	8.44	37.02	26.22	0.13	тп	LST	6	1,209.20
AURORA ENERGY LLC	2/2/2015	9	7551	28.26	8.55	36.52	26.67	0.14	ТΙΙ	LST	6	834.90
AURORA ENERGY LLC	2/3/2015	31	7078	28.44	12.14	34.70	24.73	0.15	Т !!	LST	6	2,869.90
AURORA ENERGY LLC	2/3/2015	11	7036	27.65	12.98	35.06	24.32	0.14	ТΙΙ	LST	6	969.85
AURORA ENERGY LLC	2/4/2015	12	7065	28.03	12.16	34.62	25.20	0.15	тп	LST	6	1,138.45
AURORA ENERGY LLC	2/9/2015	9	7620	27.91	7.79	35.30	29.02	0.13	Bdl/JD	F	3/4	742.75
AURORA ENERGY LLC	2/10/2015	14	7917	27.82	5.80	35.90	30.48	0.12	Bdl/JD	F	3/4	1,277.15
AURORA ENERGY LLC	2/11/2015	8	7702	29.02	6.64	35.33	29.02	0.12	Bdl/JD	F	3/4	680.85
AURORA ENERGY LLC	2/12/2015	6	7618	28.59	7.59	35.98	27.84	0.12	Bdl/JD	F	3/4	525.70
AURORA ENERGY LLC	2/13/2015	8	7614	29.50	7.11	35.67	27.72	0.12	Bdl/JD	F	3/4	674.15
AURORA ENERGY LLC	2/16/2015	8	7681 Apj	29.80 pendix I	6.49 II.D.7	35.97 .7-456	27.74 2	0.11	T II/JD	LST	6/4	716.15

Rail Samples Analysis Results for 1/1/15 to 6/30/15

												0
871.10	4		JD	0.12	27.71	35.65	6.24	30.40	7645	10	2/17/2015	AURORA ENERGY LLC
775.50	6/4	LST	T II/JD	0.13	27.27	34.84	6.97	30.93	7411	9	2/18/2015	AURORA ENERGY LLC
893.10	4/6	LST	JD/T II	0.12	26.59	36.13	7.43	29.85	7474	10	2/19/2015	AURORA ENERGY LLC
1,087.75	6/4	LST	T II/JD	0.12	26.35	36.82	6.65	30.19	7556	12	2/20/2015	AURORA ENERGY LLC
756.30	6/4	LST	T II/JD	0.13	27.06	35.48	6.82	30.65	7490	8	2/23/2015	AURORA ENERGY LLC
975.50	4/6	LST	JD/TII	0.14	27.22	35.95	7.24	29.59	7576	11	2/24/2015	AURORA ENERGY LLC
1,033.85	6/4	LST	T II/JD	0.13	27.25	35.92	7.42	29.41	7551	11	2/25/2015	AURORA ENERGY LLC
1,003.80	6/4	LST	T II/JD	0.12	27.23	36.28	6.75	29.74	7582	11	2/26/2015	AURORA ENERGY LLC
1,039.00	6/4	LST	TII/JD	0.12	27.37	36.05	6.61	29.97	7588	11	2/27/2015	AURORA ENERGY LLC
730.55	6/4	LST	TII/JD	0.12	27.64	36.02	6.43	29.92	7571	8	3/2/2015	AURORA ENERGY LLC
910.05	6/4	LST	TII/JD	0.11	27.67	36.58	5.91	29.84	7698	10	3/3/2015	AURORA ENERGY LLC
356.15	6/4	LST	TII/JD	0.11	27.34	35.70	6.34	30.62	7547	4	3/4/2015	AURORA ENERGY LLC
927.65	6/4	LST	TII/JD	0.11	28.13	36.35	6.01	29.51	7705	10	3/5/2015	AURORA ENERGY LLC
1,032.00	6/4	LST	TII/JD	0.11	27.60	36.26	5.49	30.66	7662	11	3/6/2015	AURORA ENERGY LLC
549.70	6/4	LST	TII/JD	0.11	26.60	36.30	6.76	30.34	7505	6	3/10/2015	AURORA ENERGY LLC
2,416.95	6/4	LST	TII/JD	0.10	25.76	34.89	7.90	31.44	7109	26	3/11/2015	AURORA ENERGY LLC
620,10	6/4	LST	TII/JD	0.11	27.02	35.71	7.34	29.94	7483	7	3/12/2015	AURORA ENERGY LLC
370.10	6/4	LST	TII/JD	0.14	27.05	35.86	7.33	29.76	7525	4	3/16/2015	AURORA ENERGY LLC
463.30	6/4	LST	TII/JD	0.11	26.98	35.59	7.36	30.08	7468	5	3/17/2015	AURORA ENERGY LLC
1,088.95	6/4	LST	TII/JD	0.12	27.53	35.43	6.84	30.21	7545	12	3/18/2015	AURORA ENERGY LLC
1,105.10	6/4	LST	TII/JD	0.14	26.86	35.96	7.58	29.60	7549	12	3/19/2015	AURORA ENERGY LLC
680.20	6/4	LST	TII/JD	0.12	27.06	36.02	7.00	29.93	7620	7	3/20/2015	AURORA ENERGY LLC
453.55	6/4	LST	TII/JD	0.12	27.26	35.98	6.88	29.89	7555	5	3/23/2015	AURORA ENERGY LLC
641.55	4		JD	0.12	28.84	35.08	5.38	30.71	7727	7	4/2/2015	AURORA ENERGY LLC
908,40	4		JD	0.11	29.13	35.18	4.67	31.03	7763	10	4/6/2015	AURORA ENERGY LLC
1,081.35	4		JD	0.11	28.93	35.57	4.55	30.95	7826	12	4/7/2015	AURORA ENERGY LLC
1,022.50	4		JD	0.11	28.71	34.58	5.35	31.37	7669	11	4/8/2015	AURORA ENERGY LLC
1,161.20	4		JD	0.12	28.14	34.64	5.36	31.87	7561	13	4/9/2015	AURORA ENERGY LLC
660.95	4		JD	0.11	28.54	35.70	5.03	30.74	7759	7	4/10/2015	AURORA ENERGY LLC
798.25	4		JD	0.11	29.07	34.74	4.82	31.37	7711	9	4/13/2015	AURORA ENERGY LLC
1,105.30	4		JD	0.11	28.60	35.27	4.77	31.37	7710	12	4/14/2015	AURORA ENERGY LLC
836.95	4		JD	0.09	28.82 3	34.56 .7-456	5.99 III.D.7	30.63 pendix	7625 Apj	9	4/20/2015	AURORA ENERGY LLC

7/1/2015 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/15 to 6/30/15

			_	_		_	_	_				
AURORA ENERGY LLC	4/21/2015	11	7544	30.03	7.59	33.80	28.58	0.11	JD		4	989.35
AURORA ENERGY LLC	4/22/2015	8	7626	29.64	7.23	34.32	28.81	0.14	Bdi/JD	G	4/4	768.10
AURORA ENERGY LLC	4/27/2015	8	7881	29.30	5.28	35.34	30.09	0.11	JD/Bdl	G	4/3	745.75
AURORA ENERGY LLC	4/28/2015	10	7853	29.01	5.21	35.72	30.06	0.11	Bdl/JD	G	3/4	903.75
AURORA ENERGY LLC	4/29/2015	10	7620	31.74	4.50	35.15	28.61	0.10	JD		4	904.95
AURORA ENERGY LLC	4/30/2015	12	7648	28.84	7.36	34.53	29.28	0.11	Bdl/JD	G	3/4	1,151.95
AURORA ENERGY LLC	5/1/2015	8	7453	31.00	6.78	34.50	27.73	0.10	JD		4	733.95
AURORA ENERGY LLC	5/4/2015	10	7424	31.57	6.35	34.12	27.97	0.12	JD		4	891.35
AURORA ENERGY LLC	5/5/2015	8	7414	31.82	6.59	33.68	27.91	0.11	JD		4	747.95
AURORA ENERGY LLC	5/6/2015	11	7610	30.24	6.28	34.87	28.62	0.11	Bdl/JD	G	3/4	980.55
AURORA ENERGY LLC	5/7/2015	9	7511	31.23	6.16	34.56	28.05	0.11	JD		4	873.00
AURORA ENERGY LLC	5/8/2015	8	7743	29.92	5.94	35.21	28.94	0.12	JD		4	704.65
AURORA ENERGY LLC	5/12/2015	15	7685	29.76	6.46	35.56	28.22	0.11	JD		4	1,411.50
AURORA ENERGY LLC	5/13/2015	15	7530	29.73	7.50	35.02	27.76	0.12	Bdl/JD	G	3/4	1,361.45
AURORA ENERGY LLC	5/14/2015	1	7565	30.33	6.72	34.88	28.08	0.11	JD		4	99.55
AURORA ENERGY LLC	5/18/2015	13	7707	29.87	6.38	35.17	28.58	0.11	JD		4	1,253.45
AURORA ENERGY LLC	5/19/2015	8	7694	30.15	6.19	34.79	28.88	0.11	JD		4	704.35
AURORA ENERGY LLC	5/20/2015	12	7626	30.39	6.33	34.90	28.38	0.12	JD		4	1,155.60
AURORA ENERGY LLC	5/21/2015	12	7494	31.30	6.38	34.44	27.89	0.11	JD		4	1,157.45
AURORA ENERGY LLC	5/23/2015	18	7765	29.51	6.18	35.46	28.85	0.11	JD		4	1,660.70
AURORA ENERGY LLC	5/26/2015	8	7580	29.83	7.16	34.9 9	28.03	0.12	JD		4	732.30
AURORA ENERGY LLC	5/27/2015	14	7685	28.61	7.56	35.32	28.52	0.12	JD		4	1,376.90
AURORA ENERGY LLC	5/28/2015	14	7626	29.63	6.99	34.90	28.48	0.12	JD		4	1,353.00
AURORA ENERGY LLC	5/29/2015	6	7579	30.41	6.82	34.66	28.11	0.13	JD		4	565.25
AURORA ENERGY LLC	6/1/2015	9	7636	30.25	6.18	35.13	28.44	0.12	JD		4	857.75
AURORA ENERGY LLC	6/2/2015	8	7728	31.26	4.72	35.04	28.98	0.12	JD		4	727.00
AURORA ENERGY LLC	6/3/2015	12	7547	31.16	6.51	33.90	28.44	0.12	JD		4	1,199.65
AURORA ENERGY LLC	6/4/2015	13	7792	30.16	5.50	34.95	29.39	0.12	JD		4	1,262.20
AURORA ENERGY LLC	6/5/2015	13	7703	30.94	5.14	35.45	28.48	0.11	JD		4	1,158.10
AURORA ENERGY LLC	6/8/2015	10	7842	30.61	4.60	35.17	29.63	0.11	JD		4	944.15
AURORA ENERGY LLC	6/9/2015	8	7726	30.82	5.57	34.59	29.03	0.12	JD		4	772.90
AURORA ENERGY LLC	6/10/2015	9	7794 Apj	30.29 pendix l	4.94 [II.D.7	35.61 .7-456	29.16 4	0.12	JD		4	865.10

7/1/2015 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/15 to 6/30/15

						_					_	
AURORA ENERGY LLC	6/11/2015	2	7952	29.43	5.92	34.72	29.93	0.12	GRP/STK		M/N	194.00
AURORA ENERGY LLC	6/12/2015	11	7855	28.23	7.74	34.69	29.34	0.14	GRP/STK		M/N	1,098.10
AURORA ENERGY LLC	6/15/2015	10	7900	26.99	8.73	35.33	28.95	0.14	GRP/STK		M/N	996.05
AURORA ENERGY LLC	6/16/2015	6	7887	25.37	10.64	35.26	28.73	0.15	GRP/STK		M/N	588.95
AURORA ENERGY LLC	6/17/2015	29	7528	24.32	14.26	34.44	26.99	0.15	GRP/STK		M/N	2,832.55
AURORA ENERGY LLC	6/17/2015	9	7518	24.53	13.61	35.06	26.81	0.15	GRP/STK		M/N	868.65
AURORA ENERGY LLC	6/22/2015	10	7649	28.27	8.58	35.13	28.03	0.13	JD		4	976.50
AURORA ENERGY LLC	6/23/2015	12	7581	28.39	8.07	34.39	29.15	0.13	Bdl		3	1,185.10
AURORA ENERGY LLC	6/24/2015	9	7885	27.12	7.70	35.35	29.83	0.13	Bdl/STK		6/N	861.60
AURORA ENERGY LLC	6/25/2015	8	7813	27.83	6.96	35.60	29.62	0.11	Bdl/STK	Ĩ	3/N	748.55
AURORA ENERGY LLC	6/26/2015	10	8048	26.19	8.73	35.21	29.87	0.15	GRP/STK		M/N	959.85
AURORA ENERGY LLC	6/29/2015	14	8027	26.68	8.75	34.64	29.93	0.15	GRP/STK		M/N	1,393.95
AURORA ENERGY LLC	6/30/2015	14	7934	27.67	7.69	35.54	29.11	0.14	JD		4	1,330.30
Weighted Averages Sur	nmary											
Customer		Tons		BTU	F	120	Ast		Volatiles	Carbo	n	Sulfur
AURORA ENERGY LLC		103904.8	03904.80 75		2	29.16	7.	65	35.23	27.	96	0.14

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date 7-1-15

Colum

Date _________ Thompson

Signature

Appendix E (Coal Sulfur Summary)

1/7/2016 Adopted

Usibelli Coal Mine

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 7/1/15 to 12/31/15

Customer	Date	#Cars	BTU	%H20	%A	%∨	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/2/2015	5	7689	29.31	7.19	35.30	28.21	0.13	Bdl/GRF	Þ I	3/M	497.30
AURORA ENERGY LLC	7/6/2015	14	7636	28.59	7.92	35.01	28.49	0.15	Bld	£	4	1,372.10
AURORA ENERGY LLC	7/7/2015	14	7874	26.58	7.76	36.94	28.71	0.21	Bdl	Ĩ	4	1,382.00
AURORA ENERGY LLC	7/8/2015	3	7865	26.43	7.83	36.21	29.54	0.21	BLD	1	4	316.65
AURORA ENERGY LLC	7/9/2015	8	7770	26.23	8.84	36.65	28.29	0.23	Bdl	1	4	785.95
AURORA ENERGY LLC	7/10/2015	5	7921	25.95	8.00	36.75	29.31	0.19	Bdl	1	4	508.65
AURORA ENERGY LLC	7/13/2015	10	7931	25.76	7.97	36.81	29.47	0.18	Bdl	Ĩ	4	979.25
AURORA ENERGY LLC	7/14/2015	10	7750	26.64	8.53	36.28	28.56	0.21	Bdl	1	4	954.80
AURORA ENERGY LLC	7/15/2015	10	7867	26.76	7.54	36.58	29.13	0.21	Bdl	1	4	982.35
AURORA ENERGY LLC	7/16/2015	15	7868	26.59	7.56	36.90	28.95	0.21	Bdl	1	4	1,462.70
AURORA ENERGY LLC	7/17/2015	8	7832	26.21	7.83	37.22	28.75	0.22	Bdl	1	4	765.40
AURORA ENERGY LLC	7/20/2015	8	7860	27.03	7.13	36.27	29.58	0.19	Bdl	1	4	766.65
AURORA ENERGY LLC	7/21/2015	9	7694	27.61	7.96	35.51	28.93	0.20	Bdl/STI	< 1	4/N	908.35
AURORA ENERGY LLC	7/22/2015	9	7657	29.32	6.95	35.01	28.72	0.15	JD		4	877.65
AURORA ENERGY LLC	7/23/2015	9	7438	30.33	7.55	34.18	27.95	0.12	JD		4	859.90
AURORA ENERGY LLC	7/24/2015	8	7636	29.50	6.86	35.30	28.35	0.11	JD		4	772.45
AURORA ENERGY LLC	7/27/2015	9	7432	31.12	7.58	33.61	27.70	0.13	JD		4	899.50
AURORA ENERGY LLC	7/28/2015	11	7523	30.83	6.76	34.27	28.14	0.12	JD		4	1,073.20
AURORA ENERGY LLC	7/30/2015	7	7425	30.34	7.77	34.10	27.79	0.14	JD		4	693,90
AURORA ENERGY LLC	7/31/2015	8	7734	27.22	7.93	35.90	28.96	0.22	Bdl/Bd	I 1/1	3/4	724.30
AURORA ENERGY LLC	8/3/2015	9	7654	28.48	7.69	35,42	28.41	0.16	JD		4	867.75
AURORA ENERGY LLC	8/4/2015	10	7670	29.51	6.73	35.20	28.57	0.14	JD		4	937.50
AURORA ENERGY LLC	8/5/2015	12	7566	30.37	6.67	35.07	27.90	0.13	JD		4	999.75
AURORA ENERGY LLC	8/6/2015	11	7279	30.35	9.11	34.22	26.33	0.14	JD		4	1,037.80
AURORA ENERGY LLC	8/7/2015	11	7368	30.17	8.21	34.20	27.42	0.15	Bdl/JD) 1	4/4	1,056.30
AURORA ENERGY LLC	8/10/2015	18	7660	29.39	6.76	35.20	28.65	0.15	JD/Bd	1 /1	4/4	1,653.75
AURORA ENERGY LLC	8/12/2015	15	7359	31.58	7.10	33.94	27.40	0.14	JD		4	1,416.85
AURORA ENERGY LLC	8/13/2015	18	7510	30.41	6.79	34.63	28.16	0.17	Bdl/JC		4/4	1,775.95
AURORA ENERGY LLC	8/14/2015	15	7733	27.83	7.35	36.00	28.82	0.14	BdI	1	4	1,397.60
AURORA ENERGY LLC	8/17/2015	10	7663 App	29.07 pendix II	7.20 I.D.7.	35.01 7 - 456	28.73 7	0.13	JD		4	943.65

Rail Samples Analysis Results for 7/1/15 to 12/31/15

		_									and the second sec	
AURORA ENERGY LLC	8/18/2015	13	7658	28.80	7.07	35.38	28.76	0.16	JD		4	1,265.45
AURORA ENERGY LLC	8/20/2015	15	7311	31.47	7.37	33.83	27.33	0.12	Bdl/JD	1/	3/4	1,386.75
AURORA ENERGY LLC	8/22/2015	18	7564	31.72	6.35	34.30	27.63	0.10	JD		4	1,546.75
AURORA ENERGY LLC	8/26/2015	15	7740	28.52	8.85	34.07	28.56	0.17	JD/GRP		4/M	1,471.40
AURORA ENERGY LLC	8/28/2015	3	7642	28.09	8.57	35.40	27.94	0.15	GPR/BdI		M/6	261.50
AURORA ENERGY LLC	8/31/2015	8	7628	27.35	8.96	36.33	27.37	0.14	Bdl		6	720.95
AURORA ENERGY LLC	9/1/2015	17	7681	27.34	8.39	36.84	27.43	0.13	Bdi		6	1,651.15
AURORA ENERGY LLC	9/2/2015	19	7563	27.07	9.34	36.51	27,09	0.14	Bdl		6	1,898.00
AURORA ENERGY LLC	9/3/2015	27	7665	27.56	8.27	35.87	28.31	0.13	Bdl		6	2,698.95
AURORA ENERGY LLC	9/8/2015	17	7806	27.29	7.46	35.64	29.61	0.13	Bdl/STK	1/	3/N	1,594.85
AURORA ENERGY LLC	9/10/2015	20	7891	26.52	7.77	35.76	29.97	0.14	Bdl/GRP	1/	3/M	1,863.50
AURORA ENERGY LLC	9/11/2015	21	7710	26.65	9.21	35.53	28.61	0.14	Bdl/GRP	1	3/M	1,974.90
AURORA ENERGY LLC	9/15/2015	18	7420	26.03	13.40	33.43	27.10	0.16	Bdl/GRP	I	3/M	1,735.35
AURORA ENERGY LLC	9/16/2015	17	7697	26.35	10.77	36.32	26.56	0.16	GRP/Bdl		M/6	1,681.25
AURORA ENERGY LLC	9/17/2015	17	7519	26.86	10.99	35.61	26,55	0.16	Bdl/GRP		6/M	1,555.60
AURORA ENERGY LLC	9/22/2015	19	7186	27.11	12.93	34.08	25.88	0.17	Bdl/GRP		6/M	1,877.05
AURORA ENERGY LLC	9/23/2015	18	7544	27.46	9.76	34.45	28.34	0.15	Bdl	Ĩ	3	1,812.45
AURORA ENERGY LLC	9/24/2015	6	7573	26.47	10.49	34.19	28.85	0.14	Bdl	3	3	604.35
AURORA ENERGY LLC	9/29/2015	6	7141	28.88	11.36	33.89	25.87	0.15	Bdl/GRP)	3/M	603.55
AURORA ENERGY LLC	9/30/2015	5	7514	28.44	8.69	34.21	28.66	0.13	Bdl/Bdl	Ţ	3/6	490.85
AURORA ENERGY LLC	10/1/2015	10	7360	29.29	9.35	33.72	27.64	0.14	Bdl/Bdl	1	3/6	949.70
AURORA ENERGY LLC	10/6/2015	17	7434	28.25	9.47	34,75	27,54	0.14	Bdl		6	1,697.60
AURORA ENERGY LLC	10/7/2015	16	7427	28.14	9.75	33.75	28.48	0.13	Bdl/STK	1	3/N	1,590.90
AURORA ENERGY LLC	10/8/2015	16	7766	28.02	6.97	35.04	29.97	0.14	Bdl/STK	I	3/N	1,550.35
AURORA ENERGY LLC	10/12/2015	12	7509	28.74	8.47	34.02	28.77	0.11	Bdl/JD	1	3/4	1,188.55
AURORA ENERGY LLC	10/13/2015	14	7448	29.46	8.57	34.10	27.88	0.11	Bdl/JD	1	3/4	1,378.00
AURORA ENERGY LLC	10/14/2015	15	7329	31.93	7.28	33.16	27.63	0.11	Bdl/JD	I	3/4	1,487.05
AURORA ENERGY LLC	10/15/2015	5	7435	31.66	6.81	34.31	27.23	0.11	JD		4	472.55
AURORA ENERGY LLC	10/16/2015	6	7723	31.20	5.10	35.54	28.17	0.11	JD		4	564.80
AURORA ENERGY LLC	10/20/2015	15	7561	31.93	5.92	34.77	27.38	0.11	JD		4	1,442.25
AURORA ENERGY LLC	10/21/2015	14	7609	31.67	5.47	34.54	28.32	0.11	JD		4	1,346.70
AURORA ENERGY LLC	10/22/2015	13	7492 App	32.01 Dendix I	6.01 II.D.7.	34.29 7-4568	27.70 8	0.11	JD		4	1,264.45

100

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/15 to 12/31/15

the second s		_			_							
AURORA ENERGY LLC	10/23/2015	15	7347	32.39	6.71	33.49	27.42	0.12	JD		4	1,492.50
AURORA ENERGY LLC	10/27/2015	9	7404	30.15	8.49	34.36	27.00	0.18	Bdl	J	4	910.80
AURORA ENERGY LLC	10/28/2015	11	7586	30.32	6.73	35.02	27.93	0.14	Bld/JD	J/	4/4	1,018.90
AURORA ENERGY LLC	10/29/2015	9	7861	26.44	7.92	36.05	29.59	0.19	Bdl	J	4	922.55
AURORA ENERGY LLC	10/30/2015	11	7948	26.92	7.00	36.90	29.19	0.17	Bdl	J	4	1,070.45
AURORA ENERGY LLC	11/3/2015	10	7438	27.87	10.34	34.56	27.24	0.28	Bdl/JD	J/	4/4	994.40
AURORA ENERGY LLC	11/4/2015	16	7495	29.67	8.21	34.18	27.95	0.20	Bdl	J	4	1,577.40
AURORA ENERGY LLC	11/5/2015	11	7320	29.67	9.27	33.61	27.46	0.22	Bdl	J	4	1,052.25
AURORA ENERGY LLC	11/6/2015	12	7629	27.60	8.75	35.23	28.42	0.25	Bdl/JD	J/	4/4	1,175.00
AURORA ENERGY LLC	11/10/2015	12	7640	28.50	7.97	35.25	28.29	0.19	Bdl	J	4	1,130.35
AURORA ENERGY LLC	11/11/2015	14	7865	27.22	7.50	35.71	29.58	0.21	Bdł	J	4	1,331.05
AURORA ENERGY LLC	11/12/2015	12	7797	27.25	7.73	35.48	29.54	0.23	Bdl	J	4	1,146.35
AURORA ENERGY LLC	11/13/2015	14	7947	26.11	7.79	36.51	29.60	0.19	Bdl	J	4	1,368.95
AURORA ENERGY LLC	11/17/2015	9	7760	27.53	7.86	35.47	29.14	0.20	Bdl/JD	J/	4/4	848,40
AURORA ENERGY LLC	11/18/2015	11	7705	28.38	7.44	35.64	28.55	0.18	Bdl/JD	J	4/4	1,026.00
AURORA ENERGY LLC	11/19/2015	8	7644	30.78	6.20	34.89	28.13	0.15	Bdl/JD	J	4/4	714.95
AURORA ENERGY LLC	11/20/2015	10	7783	29.27	6.29	35.70	28.73	0.15	JD/Bdl	/J	4/4	863.55
AURORA ENERGY LLC	11/23/2015	11	7793	29.35	6.29	35.57	28.79	0.15	JD		4	1,046.45
AURORA ENERGY LLC	11/24/2015	16	7682	30.62	5.97	34.92	28.49	0,12	JD		4	1,518.80
AURORA ENERGY LLC	11/25/2015	13	7770	29.54	6.19	35.63	28.65	0.14	JD/Bdl	/J	4/4	1,206.80
AURORA ENERGY LLC	11/27/2015	12	7612	28.41	7.98	35.68	27.94	0.19	Bdl/STK	J/	4/N	1,178.80
AURORA ENERGY LLC	12/1/2015	21	7514	29.25	8.35	34.58	27.83	0.20	Bdl/STK	J/	4/N	1,971.15
AURORA ENERGY LLC	12/2/2015	9	7587	30.48	6.72	34.32	28.49	0.16	JD		4	834.10
AURORA ENERGY LLC	12/3/2015	12	7577	32.45	4.74	33.98	28.84	0.10	JD		4	1,097.45
AURORA ENERGY LLC	12/4/2015	10	7503	31.28	6.60	33.78	28.35	0,12	JD		4	915.25
AURORA ENERGY LLC	12/8/2015	13	7594	29.65	7.36	34.53	28.47	0.17	Bdl/JD	J/	4/4	1,204.60
AURORA ENERGY LLC	12/9/2015	13	7627	28.50	8.21	34.71	28.58	0.23	Bdl/JD	J/	4/4	1,254.80
AURORA ENERGY LLC	12/10/2015	12	7651	29.18	7.10	35.18	28.55	0.17	Bdl/JD	J/	4/4	1,090.15
AURORA ENERGY LLC	12/11/2015	10	7159	33.74	6.25	34.17	25.84	0.14	JD		4	935.95
AURORA ENERGY LLC	12/15/2015	14	7591	31.15	5.91	35.16	27.78	0.15	Bdl/JD	J	4/4	1,235.25
AURORA ENERGY LLC	12/16/2015	14	7527	31.73	6.00	35.00	27.27	0.16	Bdl/JD	J	4/4	1,288.80
AURORA ENERGY LLC	12/17/2015	14	7639 App	29.80 Dendix I	6.85 II.D.7.	35.24 7-456	28.12 9	0.16	Bdl/JD	J	4/4	1,258.85

1/7/2016 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/15 to 12/31/15

								_				
AURORA ENERGY LLC	12/18/2015	14	7571	30.68	6.58	34.72	28.03	0.13	Bdl/JD	J	4/4	1,314.95
AURORA ENERGY LLC	12/21/2015	14	7631	30.24	6.30	35.17	28.29	0.15	Bdl/JD	J	4/4	1,318.90
AURORA ENERGY LLC	12/22/2015	14	7549	31.19	5.71	34.71	28.39	0.13	Bdl/JD	J	4/4	1,250.95
AURORA ENERGY LLC	12/23/2015	14	7686	31.43	4.63	35.27	28.68	0.10	Bdl/JD	J	4/4	1,262.70
AURORA ENERGY LLC	12/24/2015	10	7627	31.52	4.92	35.64	27.93	0.11	Bdl/JD	J	4/4	933.25
AURORA ENERGY LLC	12/28/2015	14	7714	30.71	4.93	36.01	28.36	0.11	Bdl/JD	J	4/4	1,246.45
AURORA ENERGY LLC	12/29/2015	16	7780	30.08	5.31	35.97	28.65	0.12	Bdl/JD	j	4/4	1,424.70
AURORA ENERGY LLC	12/30/2015	11	7673	31.40	5.02	35.64	27.95	0.12	Bdi/JD	J	4/4	968.20
AURORA ENERGY LLC	12/31/2015	12	7705	31.63	4.47	35.57	28.34	0.12	Bdl/JD	J	3/4	1,059.70
Weighted Averages Sum	ema r y											
Customer		Tons		BTU	ŀ	120	Ash	1	Volatiles	Carl	oon	Sulfur
AURORA ENERGY LLC		120758.3	0	7610.00	2	29.02	7.	69	35.09	2	8.20	0.15

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Date

Coleen Thompson

1-7-16 nompson Coleer

Signature

Appendix E (Coal Sulfur Summary)

7/18/2016

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/16 to 6/30/16 Page 1 of 15

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/5/2016	12	7673	31.18	4.92	35.22	28.68	0.11	Bdl/JD	J	4/4	1,108.40
AURORA ENERGY LLC	1/6/2016	14	7682	32.31	4.20	34.85	28.65	0.11	JD		4	1,247.50
AURORA ENERGY LLC	1/7/2016	14	7643	32.35	3.60	35.28	28.78	0.09	JD		4	1,202.65
AURORA ENERGY LLC	1/8/2016	12	7757	31.14	4.23	36.17	28.47	0.11	JD		4	1,070.90
AURORA ENERGY LLC	1/12/2016	13	7631	32.21	4.40	35.14	28.22	0.11	Bdl/JD	J	4/4	1,200.75
AURORA ENERGY LLC	1/13/2016	18	7628	32.43	4.12	35.32	28,15	0.09	JD		4	1,613.00
AURORA ENERGY LLC	1/14/2016	14	7958	28.18	4.48	37.67	29.68	0.11	JD		4	1,188.40
AURORA ENERGY LLC	1/15/2016	16	7789	31.38	4.12	36.77	27.74	0.11	JD		4	1,385.20
AURORA ENERGY LLC	1/19/2016	18	7765	31.50	4.26	35.37	28.87	0.10	JD		4	1,604.95
AURORA ENERGY LLC	1/20/2016	5 16	7842	31,19	4.24	35.66	28,92	0.12	JD		4	1,439.05
AURORA ENERGY LLC	1/21/2016	5 15	7766	31.45	4.46	35.39	28,71	0.13	JD		4	1,348.85
AURORA ENERGY LLC	1/22/2016	5 22	7741	31.09	4.62	35.72	28.58	0.11	JD		4	1,962.55
AURORA ENERGY LLC	1/26/2016	5 14	7416	32.12	6.10	34.25	27.54	0.13	JD		4	1,350.60
AURORA ENERGY LLC	1/27/2016	5 12	7664	31.19	5.07	35.10	28.65	0.11	Bdl/JD	J	4/4	1,095.55
AURORA ENERGY LLC	1/28/2016	5 11	7741	31.54	4.52	35.16	28,79	0.10	Bdl/JD	J	4/4	982.50
AURORA ENERGY LLC	1/29/2016	5 13	7646	31.93	4.34	35.66	28.09	0.10	JD		4	1,140.40
AURORA ENERGY LLC	2/2/2016	12	7569	31,65	5,24	34.87	28.26	0.10	JD/Bdl	/J	4/3	1,088.10
AURORA ENERGY LLC	2/3/2016	13	7695	31.32	4.75	35.02	28.92	0.12	Bdl/JD	J	3/4	1,202.80
AURORA ENERGY LLC	2/4/2016	8	7549	30.72	6.88	34.43	27.98	0.18	Bdl/JD	J	4/4	705.70
AURORA ENERGY LLC	2/5/2016	11	7664	30.92	5.55	35.22	28,31	0.14	JD/Bd	/J	4/4	998.75
AURORA ENERGY LLC	2/9/2016	14	7572	31.26	6.21	34.69	27.85	0.13	JD		4	1,298.35
AURORA ENERGY LLC	2/10/2016	5 13	7785	29.54	6.19	35.63	28.65	0.15	Bdl/JC	J	4/4	1,191.45
AURORA ENERGY LLC	2/11/2010	5 11	7479	31.97	5.48	34.93	27.63	0.14	Bdl/JC	J J	4/4	1,023.95
AURORA ENERGY LLC	2/12/2010	6 15	7576	30.68	5.50	35.74	28.08	0.14	Bdl/JC) J	4/4	1,417.30
AURORA ENERGY LLC	2/16/2010	6 16	7634	30.60	5.38	36.09	27.93	0,14	JD/Bd	I /J	4/4	1,512.75
AURORA ENERGY LLC	2/17/201	6 14	7781	29.69	5.73	35.79	28.79	0.17	Bdl/JC) J	4/4	1,299.10
AURORA ENERGY LLC	2/18/201	6 11	7773	30.32	5.11	35.59	28.99	0.14	Bdl/JE) J	4/4	1,016.45
AURORA ENERGY LLC	2/19/201	6 16	7808	29.51	5.45	36.18	28.86	0.14	JD/Bd	/J	4/4	1,465.95
AURORA ENERGY LLC	2/23/201	6 21	7926 Appe	29.40 endix III	4.93 .D.7.7	36.36 7-4572	29.31	0.14	JD		4	1,903,35

7/18/2016

80

Usibelli Coal Mine

Page 2 of 15

Rail Samples Analysis Results for 1/1/16 to 6/30/16

					_				_			
AURORA ENERGY LLC	2/24/2016	16	7799	31.52	4.31	35.32	28.85	0.12	Bdl/JD	J	4/4	1,498.15
AURORA ENERGY LLC	2/25/2016	15	7794	31.50	4.13	35.15	29.22	0.10	JD		4	1,324.05
AURORA ENERGY LLC	3/1/2016	12	7806	30.97	4,49	36.14	28.40	0.12	JD		4	1,126.55
AURORA ENERGY LLC	3/2/2016	16	7805	31.54	4.14	35.52	28.80	0.11	JD		4	1,478.45
AURORA ENERGY LLC	3/3/2016	14	7717	32.25	4.14	35.10	28.52	0.11	JD		4	1,295.50
AURORA ENERGY LLC	3/4/2016	16	7828	31.13	4,14	36.06	28,67	0,11	JD		4	1,430.90
AURORA ENERGY LLC	3/8/2016	13	7701	29.55	6.64	34.82	28.99	0.12	JD/Bdl	/J	4/3	1,224.45
AURORA ENERGY LLC	3/9/2016	13	7732	30.28	5.88	34.95	28.89	0.11	JD/Bdl	/J	4/3	1,231.45
AURORA ENERGY LLC	3/15/2016	12	7823	29.23	5.87	35.65	29.26	0.11	JD/Bdl	/J	4/3	1,121.25
AURORA ENERGY LLC	3/16/2016	13	7871	30.17	4.64	35.79	29.39	0.11	JD		4	1,143.60
AURORA ENERGY LLC	3/17/2016	13	7767	28.41	7.14	35.19	29.27	0.12	Bdl/STK	J/	3/	1,222.65
AURORA ENERGY LLC	3/18/2016	14	7766	27.74	7.62	35.37	29.27	0.12	Bdl/STK	J/	3/	1,287.65
AURORA ENERGY LLC	3/22/2016	14	7719	29.44	6.41	35.32	28.84	0.11	Bdi/JD	J/	3/4	1,317.00
AURORA ENERGY LLC	3/23/2016	18	7696	30.24	5.71	34.71	29.36	0.10	Bdl/JD	J	3/4	1,647.95
AURORA ENERGY LLC	3/24/2016	16	7574	32.11	4.93	35.45	27.52	0.10	JD		4	1,413.40
AURORA ENERGY LLC	3/29/2016	12	7716	31.99	4.16	35.71	28.14	0.11	JD		4	1,091.50
AURORA ENERGY LLC	3/30/2016	13	7642	32.31	4.18	35.81	27.70	0.11	JD		4	1,222.60
AURORA ENERGY LLC	3/31/2016	15	7741	31.85	4.24	35.23	28.68	0.11	JD		4	1,385.25
AURORA ENERGY LLC	4/1/2016	12	7723	31.82	4.28	35.95	27.95	0.11	JD		4	1,102.80
AURORA ENERGY LLC	4/5/2016	12	7666	31.80	4.77	35.48	27.95	0.12	JD		4	1,153.20
AURORA ENERGY LLC	4/6/2016	13	7705	31.70	4.66	35.12	28.53	0.12	JD		4	1,206.05
AURORA ENERGY LLC	4/7/2016	12	7602	32.54	4.49	34.80	28.18	0.12	JD		4	1,156.65
AURORA ENERGY LLC	4/8/2016	13	7766	31.23	4.49	36.04	28,25	0.11	JD		4	1,227.00
AURORA ENERGY LLC	4/12/2016	10	7756	31.50	4.66	35.46	28.39	0.12	JD		4	960,30
	4/13/2016	11	7760	31.37	4.62	35.61	28.41	0.12	JD		4	1,069.45
AURORA ENERGY LLC	4/14/2016	9	7733	31.94	4.36	35.32	28.38	0.11	JD		4	854.95
AURORA ENERGY LLC	4/15/2016	9	7768	30.79	4.70	35.74	28.78	0.11	JD		4	839.70
AURORA ENERGY LLC	4/18/2016	12	7810	31.46	4.40	35.85	28.29	0.11	JD		4	1,126.80
AURORA ENERGY LLC	4/19/2016	11	7621	32.18	4.88	34.90	28.05	0.11	JD		4	1,035.05
AURORA ENERGY LLC	4/20/2016	13	7585	32.41	4.90	34.42	28,27	0.10	JD		4	1,274.85

Appendix III.D.7.7-4573

7/18/2016

Usibelli Coal Mine

Page 3 of 15

November 19, 2019

Rail Samples Analysis Results for 1/1/16 to 6/30/16

			_									
AURORA ENERGY LLC	4/21/2016	12	7648	31.78	4_97	34.64	28.61	0,10	JD		4	1,128.20
AURORA ENERGY LLC	4/25/2016	12	7804	30.65	5.06	35.23	29.07	0.11	JD		4	1,120.80
AURORA ENERGY LLC	4/26/2016	10	7794	30.80	4.83	35.24	29.13	0.10	JD		4	1,017.70
AURORA ENERGY LLC	4/27/2016	13	7792	31.50	4.34	35.33	28.84	0.10	JD		4	1,255.45
AURORA ENERGY LLC	4/28/2016	13	7717	31.14	4.83	35.23	28.80	0.11	JD		4	1,284.75
AURORA ENERGY LLC	5/2/2016	12	7733	31.54	4.44	35.22	28,81	0,10	JD		4	1,168.35
AURORA ENERGY LLC	5/3/2016	12	7747	31,52	4.43	35.40	28.66	0,11	JD		4	1,073.35
AURORA ENERGY LLC	5/9/2016	3	7772	30.90	5.16	34.88	29.06	0.13	JD		4	288.15
AURORA ENERGY LLC	5/10/2016	3	7870	29.71	5.13	36.25	28,91	0,12	JD		4	268.35
AURORA ENERGY LLC	5/11/2016	4	7720	33.22	3.17	34.91	28.70	0.08	JD		4	372.65
AURORA ENERGY LLC	5/13/2016	8	7504	33.43	4.57	34.09	27.91	0.10	JD		4	761.40
AURORA ENERGY LLC	5/17/2016	11	7630	32.79	4.33	34.71	28.17	0.10	JD		4	1,084.05
AURORA ENERGY LLC	5/18/2016	11	7466	34.38	4.30	33.98	27.35	0.10	JD/JD		3/4	1,050.25
AURORA ENERGY LLC	5/19/2016	11	7277	32.62	7.83	33.49	26.07	0.13	JD/JD		3/4	1,127.45
AURORA ENERGY LLC	5/20/2016	12	7552	31.48	6.32	34.89	27.32	0.12	JD/JD		3/4	1,176.40
AURORA ENERGY LLC	5/23/2016	14	7661	31,33	5.63	34.90	28.15	0.12	JD/JD		3/4	1,367.20
AURORA ENERGY LLC	5/24/2016	13	7685	31.62	5.34	35.25	27.80	0,12	JD/JD		3/4	1,229,45
AURORA ENERGY LLC	5/25/2016	13	7492	32.88	5,31	34.79	27.03	0.12	JD/JD		3/4	1,237.80
AURORA ENERGY LLC	5/26/2016	10	7627	31.34	5.59	35.37	27.71	0.13	JD/JD		3/4	996.95
AURORA ENERGY LLC	5/31/2016	13	7730	30.85	5.28	36.10	27.77	0.11	JD		4	1,246.35
AURORA ENERGY LLC	6/1/2016	13	7826	30.81	4.68	36.26	28.26	0.10	JD/JD		4/3	1,188.90
AURORA ENERGY LLC	6/2/2016	12	7791	31.02	4.90	35.82	28.26	0.12	JD/JD		3/4	1,073.70
AURORA ENERGY LLC	6/3/2016	14	7647	28.04	8.54	35.38	28.04	0.21	JD/Bdl	/K	3/4	1,360.65
AURORA ENERGY LLC	6/6/2016	13	7411	30.10	8.84	34.34	26.72	0.23	Bdl/JD	К	4/3	1,274.75
AURORA ENERGY LLC	6/7/2016	11	7464	31.52	6.83	34.18	27,47	0,11	Bdl/JD	к	4/3	1,035.45
AURORA ENERGY LLC	6/8/2016	11	7491	30.78	7.37	34.34	27.51	0.14	Bdl/JD	к	4/3	1,040.50
AURORA ENERGY LLC	6/9/2016	10	7613	30.80	6.31	35.15	27.74	0.13	Bdl/JD	к	4/3	993.00
AURORA ENERGY LLC	6/13/2016	12	7632	31.54	5.50	34.94	28.02	0.12	Bdl/JD		4/3	1,190.00
AURORA ENERGY LLC	6/14/2016	12	7599	31.45	5.87	34.93	27.76	0.12	JD/JD		3/4	1,177.30
AURORA ENERGY LLC	6/16/2016	24	7514	32.67	5.39	35.16	26.78	0,12	JD/JD		3/4	2,323.85

Appendix III.D.7.7-4574

Page 4 of 15

November 19, 2019

And a strength

Rail Samples	
Analysis Results for 1/1/16 to 6	5/30/ 1 6

					_							
AURORA ENERGY LLC	6/20/2016	16	7606	31.88	5.51	35.05	27.57	0.10	JD/JD		3/4	1,578.60
AURORA ENERGY LLC	6/21/2016	16	7641	31.29	6.01	34.95	27.75	0.12	JD/JD		3/4	1,540.35
AURORA ENERGY LLC	6/23/2016	15	7667	31.90	5.11	34.65	28.35	0.12	JD/JD		3/4	1,438.65
AURORA ENERGY LLC	6/27/2016	12	7480	31.07	6,90	34.53	27.50	0.11	JD/JD		3/4	1,109.05
AURORA ENERGY LLC	6/28/2016	11	7637	31.39	5.94	35.68	27.00	0.12	JD/JD		3/4	1,037.70
AURORA ENERGY LLC	6/29/2016	9	7577	30.69	7.06	35.22	27.03	0.13	JD/JD		3/4	863.15
AURORA ENERGY LLC	6/30/2016	13	7574	31.03	6.80	35.12	27.06	0.13	JD/JD		3/4	1,267.15
Customer Weighted Aver	rage				_				_			
Customer		Tons		BTU	۲	120	Ash		Volatiles	Cart	oon	Sulfur
AURORA ENERGY LLC		115282.2	0	7683.00	3	31.21	5,:	22	35.30	28	3.29	0.12
Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
EIELSON AFB - DFAS	1/5/2016	9	7520	31.96	5.18	34,80	28.07	0.12	Bdi/JD	J	4/4	840.80
EIELSON AFB - DFAS	1/6/2016	10	7660	32.32	4.25	34.80	28.64	0.11	JD		4	916.40
EIELSON AFB - DFAS	1/7/2016	10	7724	32.29	3.66	35.34	28.72	0.10	JD		4	908.10
EIELSON AFB - DFAS	1/12/2016	10	7633	32.22	4.49	35.25	28.05	0.12	Bdl/JD	J	4/4	927.90
EIELSON AFB - DFAS	1/13/2016	10	7661	32.66	3.66	35,37	28.32	0.08	JD		4	893.05
EIELSON AFB - DFAS	1/14/2016	10	7709	31.71	4.17	35.75	28.37	0.10	JD		4	888,45
EIELSON AFB - DFAS	1/15/2016	10	7778	31.00	4.60	36.33	28.08	0.12	JD		4	909.15
EIELSON AFB - DFAS	1/19/2016	12	7712	31.80	4.38	35.14	28.68	0.10	JD		4	1,071.20
EIELSON AFB - DFAS	1/20/2016	11	7723	32.23	4.18	35.17	28.42	0.12	JD		4	973.20
EIELSON AFB - DFAS	1/21/2016	15	7638	32.53	4.44	34.87	28.17	0.13	JD		4	1,379.00
EIELSON AFB - DFAS	1/22/2016	12	7624	31.93	4.92	35.16	28.00	0.11	JD		4	1,105.20
EIELSON AFB - DFAS	1/26/2016	12	7490	32.32	5.40	34.27	28.01	0.11	JD		4	1,134.75
EIELSON AFB - DFAS	1/27/2016	13	7533	31.49	5.77	34.90	27.85	0.12	Bdl/JD) J	4/4	1,215,95
EIELSON AFB - DFAS	1/28/2016	15	7573	32.67	4.75	34.63	27.96	0.10	Bdl/JD) J	4/4	1,350.75
EIELSON AFB - DFAS	2/2/2016	12	7557	32.09	4.95	35,17	27.80	0.10	JD/Bd	I /J	4/3	1,112.15
EIELSON AFB - DFAS	2/3/2016	12	7717	31.10	5.07	34.90	28.93	0.14	Bdi/JD	L (3/4	1,124.55
EIELSON AFB - DFAS	2/4/2016	13	7624	30.85	5.97	34.68	28.51	0.17	Bdl/JD) J	4/4	1,191.10
EIELSON AFB - DFAS	2/5/2016	12	7616	31.11	5.83	35.41	27.65	0.13	JD/Bd	I /J	4/4	1,132.75

Appendix III.D.7.7-4575
Page 15 of 15

Rail Samples Analysis Results for 1/1/16 to 6/30/16

Customer Weighted Average							
Customer	Tons	BTU	H2O	Ash	Volatiles	Carbon	Sulfur
UNIVERSITY OF ALASKA	31802.70	7662.00	31.27	5.37	35.30	28.06	0.12

Weighted Averages Summary

Customer	Tons	BTU	H2O	Ash	Volatiles	Carbon	Sulfur
AURORA ENERGY LLC	115282.20	7683.00	31.21	5.22	35.30	28.29	0.12
EIELSON AFB - DFAS	80214.85	7611.00	31.53	5.47	34.99	28.02	0.12
FORT WAINWRIGHT ACCOUNTING	126389.60	7620.00	31.49	5.41	35.01	28.08	0.12
OTHER COAL SALES	70008.05	7699.00	29.94	6.15	35.52	28.38	0.13
UNIVERSITY OF ALASKA	31802.70	7662.00	31.27	5.37	35.30	28.06	0,12
Total	423697.4	7651.59	31.15	5.49	35.19	28,17	0.12

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date 7 - 18 - 16

Coleen Shompson

Signature

Appendix E (Coal Sulfur Summary)

November 19, 2019 *Page 1 of 3*

Rail Samples Analysis Results for 7/1/16 to 12/31/16

			_	_			_					
Customer	Date	#Cars	BTU	%H20	%A	%∨	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/5/2016	15	7570	30.93	6.78	34.59	27.71	0.13	JD/JD		3/4	1,417.10
AURORA ENERGY LLC	7/6/2016	10	7661	30.50	6.07	35.20	28.23	0.11	JD/JD		3/4	999.55
AURORA ENERGY LLC	7/8/2016	15	7588	31.27	6.06	35.54	27.13	0.11	JD/JD		3/4	1,368.70
AURORA ENERGY LLC	7/11/2016	19	7496	32.08	6.04	34.43	27.45	0.11	JD/JD		3/4	1,782.30
AURORA ENERGY LLC	7/12/2016	14	7507	30.39	7.57	35.14	26.90	0.16	Bdl/JD	к	4/3	1,387.10
AURORA ENERGY LLC	7/14/2016	18	7561	29.88	7.43	35.07	27.62	0.16	Bdl/JD	К/	4/3	1,766.80
AURORA ENERGY LLC	7/18/2016	17	7711	29.16	7.11	35.83	27.90	0.17	JD/Bdl	/K	3/4	1,594.70
AURORA ENERGY LLC	7/19/2016	15	7689	29.26	6.72	35.46	28.56	0.17	Bdl/JD	к	4/3	1,378.10
AURORA ENERGY LLC	7/21/2016	18	7652	29.41	6.98	35.14	28.47	0.17	Bdl/JD	к	4/3	1,724.10
AURORA ENERGY LLC	7/25/2016	12	7689	29.04	7.41	34.83	28.73	0.17	Bd!/JD	к	4/3	1,116.65
AURORA ENERGY LLC	7/26/2016	11	7590	29.91	7.20	34.97	27.92	0.16	Bdl/JD	к	4/3	1,036.20
AURORA ENERGY LLC	7/28/2016	11	7616	29.35	7.50	35.18	27.97	0.18	Bdl/JD	к	4/3	1,042.70
AURORA ENERGY LLC	8/1/2016	14	7596	29.24	8.06	34.84	27.87	0.15	Bdl/JD	к	4/3	1,351.50
AURORA ENERGY LLC	8/2/2016	14	7456	30.31	8.00	34.62	27.08	0.15	Bdl/JD	К/	4/3	1,371.25
AURORA ENERGY LLC	8/4/2016	13	7543	30.45	7.11	34.97	27.47	0.14	Bdl/JD	К	4/3	1,234.55
AURORA ENERGY LLC	8/8/2016	19	7554	29.57	8.13	34.64	27.67	0.15	Bdl/JD	К	4/3	1,829.20
AURORA ENERGY LLC	8/9/2016	17	7555	29.32	8.20	34.99	27.50	0.16	Bdl/JD	K/	4/3	1,727.15
AURORA ENERGY LLC	8/12/2016	17	7518	28.78	8.93	35.37	26.93	0.22	JD/Bd	/K	3/4	1,641.20
AURORA ENERGY LLC	8/15/2016	17	7662	28.43	8,18	35.09	28.30	0.21	Bdl/JD	к	4/3	1,541.00
AURORA ENERGY LLC	8/16/2016	17	7663	29.02	7.89	35.79	27.31	0.18	Bdl/JD	к	4/3	1,617.55
AURORA ENERGY LLC	8/18/2016	16	7544	29.54	7.80	35.74	26.92	0.17	Bdl/JD	к	4/3	1,515.30
AURORA ENERGY LLC	8/23/2016	19	7487	29.32	8.70	36.15	25.83	0.18	Bdl/JC	к	4/3	1,860.65
AURORA ENERGY LLC	8/24/2016	19	7632	29.26	7.19	36.57	26.99	0.16	Bdl/JC) К	4/3	1,808-85
AURORA ENERGY LLC	8/25/2016	18	7590	31.48	5.63	35.08	27.81	0.13	JD/JD	•	4/3	1,682.30
AURORA ENERGY LLC	8/29/2016	19	7289	30.74	9.14	34.44	25.70	0.22	JD/JD	1	4/3	1,838.20
AURORA ENERGY LLC	8/30/2016	18	7582	30.55	6.91	35.46	27.09	0.15	JD/JD)	3/4	1,697.80
AURORA ENERGY LLC	9/2/2016	26	7500	30.40	7.65	35.22	26.74	0.14	JD/JC)	3/4	2,510.75
AURORA ENERGY LLC	9/6/2016	18	7450	32.43	6.09	34.66	26.83	0.12	JD/JC)	- 4/3	1,694.70
AURORA ENERGY LLC	9/7/2016	17	7524	31.76	5.90	35.65	26.70	0.12	JD/Bd	I /K	3/4	1,605.50
AURORA ENERGY LLC	9/8/2016	10	7550 App	30.91 endix II	6.94 I.D.7.	34.82 7-4578	27.35 3	0.13	JD/Bd	II /K	4/4	953.55

Rail Samples Analysis Results for 7/1/16 to 12/31/16

				_			_					
AURORA ENERGY LLC	9/9/2016	10	7573	30.37	6.68	35.37	27.58	0.12	Bdl/JD	к	4/3	959.50
AURORA ENERGY LLC	9/27/2016	7	7558	29.53	7.77	36.09	26.62	0.14	JD/JD		3/4	660.95
AURORA ENERGY LLC	9/30/2016	18	7663	29.00	7.19	36.55	27.26	0.12	JD/Bdl	/K	3/4	1,783.60
AURORA ENERGY LLC	10/3/2016	24	7551	30.59	7.00	35.86	26.56	0.11	JD/Bdl	/K	3/4	2,244.55
AURORA ENERGY LLC	10/5/2016	28	7514	30.13	7.52	34.79	27.56	0.12	Bdl/JD	к	4/3	2,682.10
AURORA ENERGY LLC	10/10/2016	20	7615	29.98	6.97	35.09	27.97	0.12	Bdl/JD	к	4/3	1,895.45
AURORA ENERGY LLC	10/11/2016	21	7415	29.36	9.27	34.88	26.50	0.12	JD		4	1,974.25
AURORA ENERGY LLC	10/17/2016	14	7725	30.51	5.80	35.47	28.22	0.11	JD		4	1,327.05
AURORA ENERGY LLC	10/18/2016	10	7666	30.86	5.74	35.75	27.65	0.11	JD/JD		3/4	910.90
AURORA ENERGY LLC	10/19/2016	11	7674	30.61	5.79	35.44	28.17	0.10	JD/JD		3/4	940.90
AURORA ENERGY LLC	10/24/2016	12	7760	29.11	6.56	36.37	27.97	0.12	JD/JD		3/4	1,137.45
AURORA ENERGY LLC	10/25/2016	12	7729	29.22	6.51	36.28	27.99	0.12	Bdl		6	1,063.15
AURORA ENERGY LLC	10/26/2016	14	7708	28.38	7.47	36.44	27 .71	0.12	Bdl/JD		6/4	1,171.40
AURORA ENERGY LLC	10/27/2016	14	7765	27.43	7.69	37.53	27.36	0.13	Bdl/JD		6/4	1,243.80
AURORA ENERGY LLC	10/31/2016	14	7742	26.38	8.92	37.76	26.94	0.14	Bdl		6	1,220.95
AURORA ENERGY LLC	11/1/2016	15	7705	26.55	9.09	38.27	26.09	0.14	Bdl		6	1,290.10
AURORA ENERGY LLC	11/2/2016	14	7726	26.53	8.80	37.76	26.91	0.14	BdI		6	1,238.05
AURORA ENERGY LLC	11/3/2016	13	7774	26.33	8.55	37.90	27.23	0.14	Bdl		6	1,100.70
AURORA ENERGY LLC	11/7/2016	15	7680	27.17	8.92	37.45	26.47	0.13	Bdl		6	1,346.80
AURORA ENERGY LLC	11/8/2016	15	7646	26.81	9.38	37.93	25.89	0.14	Bdl		6	1,315.35
AURORA ENERGY LLC	11/9/2016	15	7631	27.00	9.17	37.46	26.37	0.14	Bdl		6	1,316.60
AURORA ENERGY LLC	11/10/2016	16	7714	26.75	8.56	37.61	27.09	0.13	Bdl		6	1,394.90
AURORA ENERGY LLC	11/14/2016	16	7658	26.44	9.11	37.77	26.68	0.14	Bdl		6	1,432.15
AURORA ENERGY LLC	11/16/2016	16	7680	27.17	8.40	37.84	26.60	0.14	Bdl		6	1,436.00
AURORA ENERGY LLC	11/17/2016	15	7748	27.26	7.86	37.64	27.24	0.13	Bdl		6	1,320.90
AURORA ENERGY LLC	11/21/2016	16	7710	27.01	8.43	37.84	26.73	0.13	BdI		6	1,456.15
AURORA ENERGY LLC	11/22/2016	19	7751	27.30	8.01	38.35	26.34	0.13	Bdl		6	1,754.65
AURORA ENERGY LLC	11/23/2016	17	7736	27.32	7.92	38.15	26.61	0.13	Bdl		6	1,432.75
AURORA ENERGY LLC	11/28/2016	10	7705	27.45	7.89	37.39	27.28	0.13	Bdl		6	876.20
AURORA ENERGY LLC	11/29/2016	10	7464	27.88	9.89	36.20	26.04	0.13	Bdl		6	923.55
AURORA ENERGY LLC	11/30/2016	10	7586	29.83	6.92	36.51	26.75	0.13	JD		4	881.80
AURORA ENERGY LLC	12/1/2016	11	6899 App	28.06 endix II	14.52 II.D.7.	32.87 7-4579	24.55	0.12	Bdl/JD		6/4	913.05

1/11/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/16 to 12/31/16

Customer		Ions		010	Г	120			Volatiles		
		-		DTU		120	Act		Volatiles	Carbon	Sulfur
Weighted Averages Sum	mary										
AURORA ENERGY LLC	12/31/2016	14	7668	27.72	8.27	37.22	26.79	0.14	Bdl/JD	6/4	1,292.4
AURORA ENERGY LLC	12/29/2016	4	7427	30.47	7.75	35.36	26.42	0.13	Bdl/JD	6/4	355.05
AURORA ENERGY LLC	12/29/2016	14	7656	30.08	6.37	36.50	27.06	0.13	Bdl/JD	6/4	1,242.95
AURORA ENERGY LLC	12/28/2016	13	7774	30.23	5.76	36.52	27.49	0.13	JD/BdI	4/6	1,132.75
AURORA ENERGY LLC	12/27/2016	13	7617	30.42	6.60	35.98	27.01	0.12	JD	4	1,202.80
AURORA ENERGY LLC	12/22/2016	7	7498	30.41	6.92	35.74	26.93	0.13	JD	4	625.90
AURORA ENERGY LLC	12/21/2016	8	7177	33.28	5.98	34.15	26.60	0.11	JD	4	702.25
AURORA ENERGY LLC	12/20/2016	23	7529	28.73	8.36	36.18	26.74	0.13	Bdl	6	2,003.15
AURORA ENERGY LLC	12/19/2016	18	7626	27.91	8.63	37.07	26.40	0.14	Bdl/JD	6/4	1,625.50
AURORA ENERGY LLC	12/15/2016	8	7679	27.93	7.85	36.68	27.55	0.15	JD/Bdl	4/6	735.90
AURORA ENERGY LLC	12/14/2016	15	7683	27.72	7.99	36.90	27.40	0.14	JD	4	1,347.60
AURORA ENERGY LLC	12/13/2016	15	7656	27.80	8.19	37.25	26.77	0.14	JD	4	1,297.80
AURORA ENERGY LLC	12/12/2016	15	7734	28.36	7.03	36.54	28.08	0.16	JD	4	1,336.05
AURORA ENERGY LLC	12/8/2016	12	7684	29.22	7.21	37.06	26.52	0.12	JD	4	1,028.90
AURORA ENERGY LLC	12/7/2016	11	7691	30.39	5.66	35.64	28.32	0.12	Bdl/JD	6/4	934.95
AURORA ENERGY LLC	12/6/2016	12	7635	29.90	6.82	35.74	27.54	0.14	JD	4	1,034.60
AURORA ENERGY LLC	12/5/2016	12	7660	30.15	6.54	35.11	28.21	0.15	JD	4	1,048.05

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date ____/-//-/7___

Coleen Thompson

Signature

Appendix E (Coal Sulfur Summary)

7/5/2017

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

November 19, 2019 *Page 1 of 4*

						_					
Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench Seam	Tons
AURORA ENERGY LLC	1/3/2017	18	7477	30.01	7.72	36.14	26.13	0.14	JD	4	1,692.15
AURORA ENERGY LLC	1/4/2017	19	7629	29.79	6.61	35.98	27.62	0.14	JD	4	1,625.15
AURORA ENERGY LLC	1/5/2017	19	7546	29.25	7.60	35.83	27.32	0.16	JD/ST	K 4/L	1,722.00
AURORA ENERGY LLC	1/6/2017	19	7556	32.13	5.19	35.58	27.11	0.12	JD	4	1,667.00
AURORA ENERGY LLC	1/10/2017	16	7711	31.53	4.83	35.98	27.66	0.11	JD	4	1,414.60
AURORA ENERGY LLC	1/11/2017	11	7587	32.46	4.80	35.38	27.37	0.12	JD	4	960.60
AURORA ENERGY LLC	1/12/2017	15	7557	32.36	5.01	35.04	27.60	0.12	JD	4	1,360.55
AURORA ENERGY LLC	1/13/2017	10	7657	31.58	5.05	35.99	27.38	0.15	JD	4	911.65
AURORA ENERGY LLC	1/16/2017	11	7484	33.02	5.28	34.59	27.11	0.13	JD	4	953.00
AURORA ENERGY LLC	1/17/2017	7	7796	31.16	4.49	35.71	28.65	0.11	JD	4	560.65
AURORA ENERGY LLC	1/19/2017	8	7453	32.25	5.64	35.11	27.00	0.13	JD	4	622.05
AURORA ENERGY LLC	1/20/2017	7	7517	33.70	4.45	34.77	27.08	0.11	JD	4	636.35
AURORA ENERGY LLC	1/21/2017	14	7599	33.03	4.28	34.94	27.75	0.10	JD	4	1,222.40
AURORA ENERGY LLC	1/23/2017	11	7669	32.37	4.38	35.00	28.26	0.10	JD	4	970.45
AURORA ENERGY LLC	1/24/2017	11	7726	32.24	4.34	35.68	27.75	0.10	JD	4	941.95
AURORA ENERGY LLC	1/25/2017	11	7644	32.08	4.71	35.28	27.94	0.09	JD	4	974.55
AURORA ENERGY LLC	1/26/2017	8	7572	32.05	5.46	34.92	27.57	0.10	JD	4	718.10
AURORA ENERGY LLC	1/27/2017	11	7639	31.03	5.90	36.14	26.94	0.12	JD	4	981.45
AURORA ENERGY LLC	1/30/2017	11	7572	32.29	5.53	35.74	26.45	0.12	JD	4	953.15
AURORA ENERGY LLC	1/31/2017	11	7217	32.88	6.93	34.88	25.31	0.14	JD	4	975.95
AURORA ENERGY LLC	2/1/2017	24	6822	34.48	8.09	32.84	24.60	0.14	JD	4	2,255.10
AURORA ENERGY LLC	2/1/2017	4	7170	33.55	6.67	33.62	26.17	0.13	JD	4	355.30
AURORA ENERGY LLC	2/1/2017	3	7252	33.71	5,99	33.75	26.56	0.13	JD	4	267.25
AURORA ENERGY LLC	2/6/2017	9	7551	32.85	4.86	34.74	27.55	0.12	JD	4	790.05
AURORA ENERGY LLC	2/7/2017	10	7554	33.29	4.68	34.92	27.12	0.11	JD	4	877.60
AURORA ENERGY LLC	2/8/2017	10	7691	32.19	4.46	35.15	28.22	0.11	JD	4	869.65
AURORA ENERGY LLC	2/9/2017	9	7651	32.24	4.61	35.16	28.01	0.12	JD	4	796.00
AURORA ENERGY LLC	2/10/2017	10	7729	31.63	4.62	35.76	28.00	0.11	JD	4	875.35
AURORA ENERGY LLC	2/13/2017	9	7625	32.37	4.69	35.17	2 7.77	0.13	JD	4	790.10
AURORA ENERGY LLC	2/14/2017	8	7567 App	32.56 bendix II	4.97 I.D.7.	35.16 7-4582	27.32	0.11	JD	4	692.50

7/5/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

V											
869.00	4	JD	0.11	27.61	35.36	4.49	32.54	7634	10	2/15/2017	AURORA ENERGY LLC
717.70	4	JD	0.12	26.82	35.17	4.98	33.04	7498	8	2/16/2017	AURORA ENERGY LLC
814.60	4	JD	0.12	27.50	34.31	5.10	33.10	7463	9	2/17/2017	AURORA ENERGY LLC
701.75	4	JD	0.12	27.48	35.18	4.85	32.49	7588	8	2/21/2017	AURORA ENERGY LLC
980.00	4	JD	0.11	27.66	34.73	4.44	33.17	7557	11	2/22/2017	AURORA ENERGY LLC
1,045.50	4	JD	0.10	27.69	35.22	4.14	32.96	7563	12	2/23/2017	AURORA ENERGY LLC
957.20	4	JD	0.11	27.98	35.42	4.22	32.39	7688	12	2/24/2017	AURORA ENERGY LLC
1,176.20	4	JD	0.11	27.28	35.99	4.51	32.22	7690	14	2/27/2017	AURORA ENERGY LLC
1,197.25	4	JD	0.11	26.32	34.38	5.52	33.78	7165	13	3/1/2017	AURORA ENERGY LLC
1,089.10	4	JD	0.11	25.75	34.70	5.95	33.61	7074	12	3/2/2017	AURORA ENERGY LLC
1,454.95	4	JD	0.11	27.21	35.09	5.88	31.82	7451	17	3/3/2017	AURORA ENERGY LLC
2,389.10	4	JD	0.11	26.19	35.29	6.16	32.35	7216	26	3/6/2017	AURORA ENERGY LLC
1,072.30	4/6	JD/Bdl	0.12	27.20	35.34	6.36	31.11	7505	13	3/8/2017	AURORA ENERGY LLC
2,582.40	4/6	JD/Bdl	0.12	26.24	35.01	5.39	33.37	7281	28	3/11/2017	AURORA ENERGY LLC
1,076.05	4/6	JD/Bdl	0.10	27.04	36.18	4.79	32.00	7569	12	3/11/2017	AURORA ENERGY LLC
1,119.25	4	JD	0.11	27.69	35.87	4.89	31.55	7651	13	3/14/2017	AURORA ENERGY LLC
1,321.40	4	JD	0.12	27.32	35.77	5.01	31.90	7583	15	3/15/2017	AURORA ENERGY LLC
1,120.40	4	JD	0.12	27.04	35.84	4.83	32.29	7524	13	3/20/2017	AURORA ENERGY LLC
1,035.50	4	JD	0.12	27.42	35.78	4.66	32.14	7579	12	3/21/2017	AURORA ENERGY LLC
1,045.35	4	JD	0.11	28.20	35.51	4.11	32.19	7667	12	3/22/2017	AURORA ENERGY LLC
1,240.20	4/C	JD/GRP	0.13	27.97	34.77	5.88	31.37	7595	14	3/23/2017	AURORA ENERGY LLC
1,246.80	4/C	JD/GRP	0.13	27.81	35.39	5.35	31.46	7651	14	3/27/2017	AURORA ENERGY LLC
1,254.00	4/M	JD/GRP	0.13	28.47	34.76	5.57	31.21	7626	14	3/28/2017	AURORA ENERGY LLC
902.05	4/M	JD/GRP	0:13	27.8 1	34.86	5.59	31.75	7571	10	3/29/2017	AURORA ENERGY LLC
1,119.90	4/M	JD/GRP	0.12	27.65	35.40	5.45	31.50	7577	13	3/30/2017	AURORA ENERGY LLC
1,123.15	4	JD	0.11	27.36	36.24	4.45	31.95	7646	13	4/3/2017	AURORA ENERGY LLC
1,148.05	4	JD	0.10	27.52	36.07	4.28	32.13	7653	13	4/4/2017	AURORA ENERGY LLC
1,164.90	4/C	JD/GRP	0.13	27.97	35.50	5.21	31.32	7681	13	4/5/2017	AURORA ENERGY LLC
726.65	4	JD	0.10	27.12	35.95	4.35	32.59	7615	8	4/6/2017	AURORA ENERGY LLC
977.45	4	JD	0.11	26.49	37.03	4.28	32.21	7682	11	4/10/2017	AURORA ENERGY LLC
1,085.65	4	JD	0.10	27.69	35.97	4.39	31.95	7681	12	4/11/2017	AURORA ENERGY LLC
674.75	4	JD	0.11	27.60	7-4583	1.D.7.7	33.01 endix II	7552 App	7	4/12/2017	AURORA ENERGY LLC

7/5/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

AURORA ENERGY LLC	4/13/2017	11	7385	34.02	4.57	34.56	26.86	0.10	JD	4	1,018.95
AURORA ENERGY LLC	4/18/2017	15	7644	32.05	4.35	36.70	26.91	0.11	JD	4	1,391.00
AURORA ENERGY LLC	4/19/2017	7	7663	31.22	5.39	35.74	27.64	0.13	JD	4	624.95
AURORA ENERGY LLC	4/20/2017	15	7624	32.50	4.35	35.84	27.31	0.11	JD	4	1,314.50
AURORA ENERGY LLC	4/21/2017	17	7590	31.89	4.70	35.91	27.50	0.11	JD	4	1,591.90
AURORA ENERGY LLC	4/24/2017	15	7675	31.63	4.45	36.49	27.44	0.10	JÐ	4	1,391.90
AURORA ENERGY LLC	4/25/2017	13	7577	33.14	4.06	35.38	27.44	0.11	JD	4	1,272.55
AURORA ENERGY LLC	4/26/2017	9	7592	33.84	3.51	35.03	27.62	0.10	JD	4	894.20
AURORA ENERGY LLC	4/27/2017	8	7621	32.87	3.81	36.16	27.16	0.10	JD	4	775.45
AURORA ENERGY LLC	5/1/2017	7	7734	31.63	4.44	36.23	27.71	0.12	JD	4	645.70
AURORA ENERGY LLC	5/2/2017	6	7739	30.89	4.60	36.41	28.10	0.11	JD	4	563.10
AURORA ENERGY LLC	5/3/2017	4	7825	30.98	4.22	36.19	28.62	0.11	JD	4	371.55
AURORA ENERGY LLC	5/8/2017	4	7461	33.26	4.78	35.09	26.88	0.12	JD	4	381.75
AURORA ENERGY LLC	5/9/2017	6	7489	32.64	5.06	34.89	27.42	0.11	JD	4	517.50
AURORA ENERGY LLC	5/11/2017	4	7538	31.86	5.27	35.86	27.02	0.11	JD	4	359.75
AURORA ENERGY LLC	5/15/2017	9	7599	31.85	4.95	36.29	26.91	0.10	JD	4	807.40
AURORA ENERGY LLC	5/16/2017	8	7633	31.97	4.66	36.40	26.98	0.10	JD	4	739.40
AURORA ENERGY LLC	5/17/2017	5	7574	33.83	4.08	34.88	27.20	0.09	JD	4	466.55
AURORA ENERGY LLC	5/18/2017	4	7650	33.31	3.42	35.81	27.47	0.09	JD	4	354.65
AURORA ENERGY LLC	5/19/2017	7	7656	32.09	4.24	35.89	27.79	0.10	JD	4	603.30
AURORA ENERGY LLC	5/22/2017	16	7756	31.40	4.24	36.49	27.87	0.10	JD	4	1,430.45
AURORA ENERGY LLC	5/23/2017	12	7512	33.57	4.17	35.75	26.51	0.13	JD	4	1,090.40
AURORA ENERGY LLC	5/24/2017	12	7669	32.70	3.95	35.99	27.36	0.12	JD	4	1,097.30
AURORA ENERGY LLC	5/26/2017	14	7657	31.91	4.59	36.48	27.02	0.11	JD	4	1,311.30
AURORA ENERGY LLC	5/30/2017	9	7675	31.80	4.72	36.29	27.19	0.11	JD	4	835.35
AURORA ENERGY LLC	5/31/2017	8	7693	31.83	4.71	36.93	26.53	0.11	JD	4	747.65
AURORA ENERGY LLC	6/1/2017	3	7701	31.47	4.41	37.05	27.07	0.10	JD	4	265.40
AURORA ENERGY LLC	6/2/2017	4	7777	31.10	4.13	36.64	28.13	0.10	JD	4	346.30
AURORA ENERGY LLC	6/5/2017	12	7650	32.12	4.55	35.36	27.98	0.10	JD	4	1,061.75
AURORA ENERGY LLC	6/6/2017	13	7594	32.33	4.47	35.40	27.81	0.11	JD	4	1,165.40
AURORA ENERGY LLC	6/8/2017	12	7636	32.08	4.40	35.99	27.53	0.10	JD	4	1,067.80
AURORA ENERGY LLC	6/9/2017	11	7674 App	31.80 endix II	4.30 I.D.7.7	36.21 7-4584	27.70	0.11	JD	4	1,011.25

7/5/2017 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/17 to 6/30/17

AURORA ENERGY LLC		106040.3	5	7567.00		32.20	4.	98	35.56	27.26	0.11
Customer	Ē.	Tons		BTU	ŀ	120	Ast	1	Volatiles	Carbon	Sulfur
Weighted Averages Sum	mary										
AURORA ENERGY LLC	6/29/2017	8	7760	31.78	4.09	36.29	27.85	0.10	JD	4	696.20
AURORA ENERGY LLC	6/28/2017	8	7711	31.90	4.58	36.91	26.61	0.11	JD	4	752.00
AURORA ENERGY LLC	6/27/2017	8	7754	31.81	4.08	36.33	27.78	0.11	JD	4	701.85
AURORA ENERGY LLC	6/26/2017	8	7699	32.23	4.30	35.95	27.52	0.12	JD	4	701.50
AURORA ENERGY LLC	6/23/2017	13	7642	32.79	4.37	35.68	27.17	0.12	JD	4	1,163.90
AURORA ENERGY LLC	6/22/2017	12	7555	33.32	4.39	35.52	26.77	0.12	JD	4	1,083.45
AURORA ENERGY LLC	6/20/2017	12	7714	32.35	4.07	35.98	27.60	0.10	JD	4	1,115.05
AURORA ENERGY LLC	6/19/2017	11	7699	32.34	3.91	36.45	27.31	0.10	JD	4	982.95
AURORA ENERGY LLC	6/16/2017	13	7665	32.28	4.53	35.98	27.21	0.12	JD	4	1,167.30
AURORA ENERGY LLC	6/15/2017	12	7675	31.97	4.75	36.23	27.06	0.12	JD	4	1,093.80
AURORA ENERGY LLC	6/13/2017	13	7682	31.87	4.25	36.35	27.54	0.09	JD	4	1,140.90
AURORA ENERGY LLC	6/12/2017	12	7609	32.30	4.32	36.00	27.38	0.10	JD	4	1,063.85
			_					_			

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date 7-5-17

Date 7-5-17 Colum hompson

Signature

Appendix E (Coal Sulfur Summary)

Rail Samples Analysis Results for 7/1/17 to 12/31/17

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/3/2017	12	7517	32.85	4.69	35.25	27.22	0.11	JD		4	1,086.15
AURORA ENERGY LLC	7/5/2017	13	7551	33.12	4.11	35.68	27.09	0.11	JD		4	1,188.30
AURORA ENERGY LLC	7/6/2017	13	7595	33.11	4.06	35.63	27.20	0.11	JD		4	1,252.50
AURORA ENERGY LLC	7/7/2017	12	7494	33.16	4.13	35.09	27.62	0.11	JD		4	1,164.50
AURORA ENERGY LLC	7/10/2017	11	7516	34.02	4.15	34.55	27.28	0.10	JD		4	1,011.85
AURORA ENERGY LLC	7/11/2017	12	7258	33.79	5.22	35.08	25.92	0.10	JD		4	1,161.40
AURORA ENERGY LLC	7/13/2017	12	6947	34.61	6.24	34.51	24.64	0.10	JD		4	1,145.45
AURORA ENERGY LLC	7/14/2017	11	6816	34.98	6.18	34.21	24.63	0.11	JD		4	1,072.45
AURORA ENERGY LLC	7/17/2017	12	7074	34.52	5.03	34.87	25.58	0.10	JD		4	1,122.60
AURORA ENERGY LLC	7/18/2017	13	7306	33.58	4.88	35,16	26.38	0.11	JD		4	1,222.85
AURORA ENERGY LLC	7/20/2017	13	7165	33.99	5.19	35.42	25.40	0.10	JD		4	1,243.85
AURORA ENERGY LLC	7/25/2017	9	7331	33.62	4.81	35.34	26.24	0.11	JD		4	853.00
AURORA ENERGY LLC	7/26/2017	8	7372	33.16	4.93	35.34	26.58	0.11	JD		4	766.70
AURORA ENERGY LLC	7/27/2017	9	7444	33.20	4.78	35.50	26.53	0.11	JD		4	862.10
AURORA ENERGY LLC	7/28/2017	8	7326	33.62	5.09	35.23	26.07	0.11	JD		4	772.70
AURORA ENERGY LLC	7/31/2017	12	7067	34.65	5.05	34.54	25.77	0.11	JD		4	1,152.10
AURORA ENERGY LLC	8/1/2017	12	7141	33.99	4.94	34.81	26.27	0.11	JD		4	1,150.10
AURORA ENERGY LLC	8/3/2017	12	7164	33.98	5.14	34.57	26.31	0.11	JD		4	1,147.95
AURORA ENERGY LLC	8/4/2017	12	7286	33.90	4.79	35.05	26.27	0.11	JD		4	1,145.30
AURORA ENERGY LLC	8/7/2017	9	7378	33.17	5.03	34.99	26.81	0.11	JD		4	782.15
AURORA ENERGY LLC	8/10/2017	19	7253	33.46	5.18	35.37	25.99	0.11	JD		4	1,810.35
AURORA ENERGY LLC	8/11/2017	20	7318	33.17	5.03	35.36	26.46	0.12	JD		4	1,908.20
AURORA ENERGY LLC	8/14/2017	11	7460	33.07	4.73	35.90	26.91	0.11	JD		4	1,010.35
AURORA ENERGY LLC	8/15/2017	12	7178	34.62	5.07	34.00	26.32	0.12	JD		4	1,140.70
AURORA ENERGY LLC	8/17/2017	12	7233	35.07	4.27	34.48	26.19	0.11	JD		4	1,118.45
AURORA ENERGY LLC	8/18/2017	11	7230	34.34	4.20	35.09	26.38	0.10	JD		4	1,012.25
AURORA ENERGY LLC	8/21/2017	12	7183	34.66	4.57	34.70	26.08	0.10	JD		4	1,132.10
AURORA ENERGY LLC	8/22/2017	11	6965	35.25	5.44	33.99	25.32	0.11	JD		4	1,063.00
AURORA ENERGY LLC	8/24/2017	13	7340	33.83	4.89	35.51	25.78	0.11	JD		4	1,237.30
AURORA ENERGY LLC	8/25/2017	12	7298 Ap r	33.44 Dendix II	4.79 I.D.7	35.35 . 7-458	26.43 7	0.10	JD		4	1,143.30

Rail Samples Analysis Results for 7/1/17 to 12/31/17

ETAKSAN MANANANAN MANANANAN MANANAN MANANAN MANANANAN			*****	*************		STATISTICS STREET	TATING STREET, STRE				
AURORA ENERGY LLC	8/29/2017	13	7624	32.09	3.98	36.19	27.75	0.09	JD	4	1,160.75
AURORA ENERGY LLC	8/30/2017	12	7693	31.67	4.26	35.95	28.12	0.11	JD	4	1,089.50
AURORA ENERGY LLC	8/31/2017	13	7679	31.66	4.54	36.00	27.81	0.12	JD	4	1,198.20
AURORA ENERGY LLC	9/1/2017	16	7556	31.91	4.68	35.57	27.85	0.10	JD	4	1,489.65
AURORA ENERGY LLC	9/5/2017	15	7539	32.49	4.50	35.78	27.23	0.10	CL	4	1,313.40
AURORA ENERGY LLC	9/6/2017	14	7605	32.58	4.13	35.67	27,62	0.10	JD	4	1,306.00
AURORA ENERGY LLC	9/7/2017	14	7651	32.11	4.32	35.95	27.62	0.09	JD	4	1,299.30
AURORA ENERGY LLC	9/8/2017	10	7585	31.81	4.55	35.94	27.71	0.10	JD	4	909.40
AURORA ENERGY LLC	9/11/2017	13	7579	32.39	4.29	35.79	27.54	0.10	JD	4	1,150.80
AURORA ENERGY LLC	9/12/2017	14	7570	32.66	4.03	35.18	28.14	0.09	JD	4	1,235.95
AURORA ENERGY LLC	9/14/2017	14	7678	31.81	4.31	35.96	27.92	0.10	JD	4	1,318.55
AURORA ENERGY LLC	9/18/2017	9	7664	31.53	4.49	35.95	28.03	0.11	JD	4	813.25
AURORA ENERGY LLC	9/19/2017	10	7672	31.57	4.48	35.65	28.30	0.10	JD	4	900.45
AURORA ENERGY LLC	9/21/2017	10	7631	31.22	4.92	36.67	27.20	0.10	JD	4	922.80
AURORA ENERGY LLC	9/22/2017	9	7661	31.07	5.17	36.47	27.30	0.12	JD	4	832.35
AURORA ENERGY LLC	9/25/2017	14	7589	32.54	4.30	35.50	27.67	0.09	JD	4	1,297.15
AURORA ENERGY LLC	9/26/2017	14	7566	32.73	4.36	35.38	27.54	0.10	JD	4	1,304.80
AURORA ENERGY LLC	9/28/2017	12	7661	32.02	4.42	36.00	27.57	0.11	JD	4	1,105.45
AURORA ENERGY LLC	9/29/2017	8	7647	31.64	4.46	35,89	28.01	0.10	JD	4	747.05
AURORA ENERGY LLC	10/2/2017	9	7605	32.57	4.32	35.30	27.82	0.10	JD	4	844.05
AURORA ENERGY LLC	10/5/2017	9	7616	32.89	4.09	35.23	27.80	0.10	JD	4	818.45
AURORA ENERGY LLC	10/6/2017	8	7615	32.44	4.76	35.48	27.33	0.11	JD	4	735.40
AURORA ENERGY LLC	10/9/2017	17	7741	31.67	4.13	36.41	27.80	0.11	JD	4	1,505.25
AURORA ENERGY LLC	10/12/2017	18	7559	32.46	4.67	35.40	27.48	0.11	JD	4	1,721.25
AURORA ENERGY LLC	10/13/2017	17	7502	33.04	4.45	35.28	27.23	0.11	JD	4	1,610.35
AURORA ENERGY LLC	10/16/2017	16	7505	32.67	4.78	35.05	27.50	0.09	JD	4	1,462.45
AURORA ENERGY LLC	10/19/2017	16	7635	32.62	4.06	35.25	28.08	0.09	JD	4	1,483.05
AURORA ENERGY LLC	10/20/2017	16	7771	30.64	4.79	36.18	28.40	0.11	JD	4	1,506.45
AURORA ENERGY LLC	10/23/2017	11	7512	32.84	4.78	34.95	27.43	0.11	JD	4	1,055.65
AURORA ENERGY LLC	10/24/2017	10	7659	32.80	3.76	35.58	27.85	0.10	JD	4	960.95
AURORA ENERGY LLC	10/26/2017	10	7778	31.71	3.93	36.18	28.18	0.11	JD	4	935.50
AURORA ENERGY LLC	10/27/2017	12	76 A epp	oendix I	II4 D 77	.73-54598	8 28.56	0.11	JD	4	1,090.80

Rail Samples Analysis Results for 7/1/17 to 12/31/17

\$1055911287201110111111212124334511101111111111111111111111111111111				,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		A SUPPORT AND A DURING WATCHING TO A DURING WATCHING WA	****	NEEDINALANANANANANANANANANANANA			
AURORA ENERGY LLC	10/30/2017	17	7638	31.96	4.43	35.98	27.64	0.10	JD	4	1,583.00
AURORA ENERGY LLC	10/31/2017	15	7737	32.08	3.80	35.41	28.72	0.09	JD	4	1,398.05
AURORA ENERGY LLC	11/2/2017	15	7695	31.20	4.63	36.13	28.04	0.10	JD	4	1,375.15
AURORA ENERGY LLC	11/3/2017	16	7568	31.90	5.28	35.76	27.07	0.10	JD	4	1,498.40
AURORA ENERGY LLC	11/6/2017	17	7608	31.44	5.45	34.85	28.27	0.10	JD	4	1,507.55
AURORA ENERGY LLC	11/7/2017	25	7199	33.84	6.32	33.54	26.31	0.09	JD	4	2,432.20
AURORA ENERGY LLC	11/9/2017	7	7639	32.53	4.28	35.73	27.47	0.08	JD	4	600.95
AURORA ENERGY LLC	11/10/2017	17	7717	30.82	4.79	36.38	28.02	0.09	JD	4	1,518.10
AURORA ENERGY LLC	11/13/2017	6	7373	33.38	5.42	34.41	26.79	0.11	JD	4	560.55
AURORA ENERGY LLC	11/14/2017	7	7599	32.39	4.85	35.41	27.35	0.13	JD	4	677.50
AURORA ENERGY LLC	11/16/2017	9	7624	31.94	4.82	35.41	27.84	0.11	JD	4	820.35
AURORA ENERGY LLC	11/20/2017	11	7626	32.25	4.95	35.18	27.62	0.11	JD	4	995.15
AURORA ENERGY LLC	11/21/2017	12	7635	31.90	4.96	35.51	27.63	0.10	JD	4	1,060.50
AURORA ENERGY LLC	11/22/2017	11	7629	31.87	4.81	35.55	27.77	0.10	JD	4	943.05
AURORA ENERGY LLC	11/24/2017	9	7651	31.86	5.02	35.92	27.20	0.12	JD	4	822.90
AURORA ENERGY LLC	11/27/2017	14	7651	31.89	4.89	35.59	27.65	0.12	JD	4	1,257.20
AURORA ENERGY LLC	11/28/2017	20	7615	31.98	4.99	35.71	27.32	0.12	JD	4	1,793.75
AURORA ENERGY LLC	11/30/2017	21	7709	30.84	5.07	35.82	28.27	0.11	dL	4	1,894.15
AURORA ENERGY LLC	12/1/2017	21	7729	30.82	4.85	35.86	28.47	0.12	JD	4	1,908.30
AURORA ENERGY LLC	12/4/2017	17	7826	30.71	4.58	35.95	28.76	0.11	JD	4	1,546.15
AURORA ENERGY LLC	12/5/2017	17	7744	31.15	4.70	35.94	28.21	0.11	JD	4	1,532.85
AURORA ENERGY LLC	12/7/2017	16	7705	31.63	4.59	36.11	27.68	0.11	JD	4	1,428.20
AURORA ENERGY LLC	12/8/2017	15	7601	32.26	4.91	35.14	27.70	0.11	JD	4	1,388.25
AURORA ENERGY LLC	12/11/2017	15	7797	31.63	3.60	35.87	28.90	0.09	JD	4	1,388.65
AURORA ENERGY LLC	12/12/2017	15	7660	30.94	5.44	36.04	27.59	0.10	JD	4	1,419.85
AURORA ENERGY LLC	12/14/2017	16	7730	30.96	5.02	35.96	28.06	0.10	JD	4	1,446.45
AURORA ENERGY LLC	12/18/2017	13	7651	32.79	3.74	34.77	28.71	0.09	JD	4	1,162.00
AURORA ENERGY LLC	12/19/2017	14	7671	32.52	3.99	35.38	28.13	0.09	JD	4	1,281.55
AURORA ENERGY LLC	12/21/2017	14	7678	32.56	4.03	35.53	27.89	0.08	JD	4	1,276.25
AURORA ENERGY LLC	12/22/2017	13	7713	32.05	3.93	35.61	28.41	0.09	DL	4	1,194.20
AURORA ENERGY LLC	12/26/2017	10	7713	32.68	3.47	35.50	28.34	0.08	JD	4	900.45
AURORA ENERGY LLC	12/27/2017	11	77 A %pp	endix II	[I 4 D 27.	7-5458	9 28.38	0.10	D	4	972.05

Rail Samples Analysis Results for 7/1/17 to 12/31/17

n an		1111-1011-1011-00100000000000000000000	477.00000000000000000000000000000000000	*******	*****	*****	*****	0.049.040000000000000000000000000000000	2019/11/2019/11/2019/01/2019/10/2019/10/2019/2019	NATION OF CONTRACTOR OF CONT	**************************************
AURORA ENERGY LLC	12/28/2017	11	7766	31.21	4.38	35.91	28.51	0.09	JD	4	975.75
AURORA ENERGY LLC	12/29/2017	10	7711	31.41	4.64	35.99	27.96	0.10	JD	4	876.15
Weighted Averages Sum	nary										
Customer		Tons		BTU	H	20	Ash		Volatiles	Carbon	Sulfur
AURORA ENERGY LLC		114440.00	}	7529.00	3	2.52	4.(58	35.45	27.36	0.10

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239.

Ben Ziegman

Ben Ziegman Date: 1/4/18 Ben Clegner Signature

Appendix D (Professional Memos)



November 19, 2019 ENVIRONMENT & HEALTH

MEMO

To From Subject David Fish, Aurora Energy LLC Till Stoeckenius Summary of issues related to SO₂ precursor demonstration for Fairbanks

The Alaska Department of Environmental Conservation (ADEC) is currently developing a State Implementation Plan (SIP) for the Fairbanks North Star Borough serious $PM_{2.5}$ nonattainment area (NAA). Fairbanks was reclassified from a moderate $PM_{2.5}$ NAA to a serious $PM_{2.5}$ NAA in June 2017; the serious area SIP is due by December 2018.

As provided for in 40 CFR 51.1006, states can reduce the regulatory burden of complying with $PM_{2.5}$ NAA requirements in the Clean Air Act by conducting $PM_{2.5}$ precursor demonstrations showing that one or more precursors involved in formation of secondary $PM_{2.5}$ do not significantly contribute to violations of the $PM_{2.5}$ National Ambient Air Quality Standard (NAAQS). The current ADEC draft serious area SIP preparation plan includes precursor demonstrations for ammonia (NH₃), nitrogen oxides (NO_x), and volatile organic compounds (VOCs) which conclude that each of these three precursors do not significantly contribute to nonattainment. ADEC did not perform a precursor demonstration for sulfur dioxide (SO₂).

A draft Best Available Control Technology (BACT) demonstration completed by the ADEC as required by the CAA for serious NAAs identifies dry sorbent injection as BACT for the four major SO₂ sources in the Fairbanks NAA. In recognition of the possibility that the SIP may include a requirement for SO₂ controls on their sources without a clear indication of the potential benefits of such controls for reducing ambient $PM_{2.5}$ concentrations, owners of the four major SO₂ sources in the Fairbanks NAA requested (via Aurora Energy) Ramboll's assistance with evaluating possible approaches to conducting a successful major source SO₂ precursor demonstration for Fairbanks.

In accordance with our letter agreement with Aurora of 18 September, Ramboll performed research and analysis related to an SO_2 precursor demonstration for the Fairbanks 24-hour PM_{2.5} serious nonattainment area (NAA). Ramboll reviewed documents describing data analysis and modeling conducted by ADEC and its contractors for the 2014 Fairbanks moderate area SIP and draft analyses

Date November 15, 2018

Ramboll 7250 Redwood Boulevard Suite 105 Novato, CA 94945 USA

T +1 415 899 0700 F +1 415 899 0707 https://ramboll.com





and plans for developing the serious NAA SIP. This included detailed descriptions of emission inventory development, meteorological and photochemical dispersion modeling methods and related sensitivity analyses, air monitoring data analyses and receptor modeling studies and other related materials. Representatives from Ramboll, Aurora Energy and owners of the other major SO₂ sources located within the Fairbanks NAA, along with ADEC and EPA Region X, participated in a conference call to discuss issues involved in conducting a successful major source SO₂ precursor demonstration. We also had several one-on-one conversations with David Fish of Aurora and Robert Ellerman of EPA Region X. A common theme in these discussions was a significant level of skepticism by ADEC and EPA regarding the likelihood of success in developing an approvable major source SO₂ precursor demonstration for the Fairbanks Serious area SIP given uncertainties about sulfate formation mechanisms under Fairbanks winter conditions. A summary of our findings is provided below.

A key element of a NAA SIP is a demonstration that planned emission reductions will result in attainment of the NAAQS in future years. ADEQ uses a computer model (CMAQ) to carry out this attainment demonstration. CMAQ is a photochemical dispersion model which simulates the transport, dispersion, and chemical transformation of emissions from all sources of $PM_{2.5}$ and $PM_{2.5}$ precursors (NH₃, NO_x, VOC, SO₂) affecting the NAA. In order to complete its work within the available time and resources, ADEC is planning to use the same base year $PM_{2.5}$ episodes (Episode 1: 23 January – 11 February 2008 and Episode 2: 2 – 17 November 2008) and modeling approach for the serious NAA SIP attainment demonstration as were used in the moderate area SIP attainment demonstration. This is despite the limited amount of air quality monitoring data available during these episodes and the fact that air quality conditions in Fairbanks have changed significantly since 2008 due to emission reductions during the intervening years. Monitoring of $PM_{2.5}$ component species was conducted at the State Office Building (SOB) in downtown Fairbanks during the 2008 episodes. These data were used in the moderate area SIP to evaluate the ability of CMAQ to accurately reproduce the observed concentrations of $PM_{2.5}$ and its component species.

As shown in Table 1, comparisons of CMAQ predicted PM_{2.5} with observed PM_{2.5} showed over prediction of organic carbon (OC) and elemental carbon (EC) and under predictions of other PM species, including sulfate (SO₄). These over and underpredictions fortuitously balanced each other out, resulting in an apparently accurate prediction of PM_{2.5} total mass. The prediction errors for individual PM species may be the result of an inaccurate emissions inventory or errors in CMAQ (or in the WRF model used to provide meteorological inputs to CMAQ). Of particular note is that CMAQ predicted very little in situ formation of sulfate from SO₂ emissions due to the lack of available oxidizing agents in the model. In technical documents prepared for the Fairbanks moderate area PM_{2.5} SIP, ADEC concluded that CMAQ is under predicting the amount of secondary sulfate formation under the unique Fairbanks winter conditions due to some unknown SO₂ oxidation pathway.



Species	Observed (µg/m³)	Predicted (µg/m³)	Bias (%)
PM _{2.5} (total)	36.1	35.7	-1%
OC	17.0	24.5	44%
EC	2.3	4.3	87%
SO ₄	6.2	2.1	-66%
NO ₃	1.6	1.3	-19%
NH ₄	3.1	1.2	-61%
ОТН	6.3	2.3	-63%

Table 1. Comparison of observed and predicted PM species concentrations at State Office Building monitoring site (average over days with FRM measurements in both 2008 episodes).

Source: Addressing the precursor gases for Fairbanks PM_{2.5} State Implementation Plan. D. Huff, Alaska Department of Environmental Conservation, 25 September 2014, in Reasonably Available Control Measure (RACM) Analysis (Appendix III.D.5.7 to the Fairbanks PM_{2.5} Moderate State Implementation Plan).

In accordance with EPA's precursor demonstration guidelines, a successful precursor demonstration (in this case for SO₂) must show that SO₂ emissions do not contribute significantly to violations of the PM_{2.5} NAAQS. More specifically, for a major source SO₂ precursor demonstration, the guidance requires a demonstration that eliminating SO₂ emission from all major sources within the NAA would not lower PM_{2.5} concentrations by more than an insignificant amount (defined in the guidance as an amount not exceeding 1.5 μ g/m³).¹ If this "contribution-based" analysis indicates that the impact of major source SO₂ emissions on PM_{2.5} exceeds 1.5 μ g/m³, then a "sensitivity-based" analysis may be conducted to show that a reduction of SO₂ emissions in the range of 30 – 70% would have only an insignificant impact on lowering PM_{2.5} (also defined as an impact of less than 1.5 μ g/m³).

The primary obstacle to conducting a credible SO_2 precursor demonstration for Fairbanks cited by ADEC and EPA results from a combination of two facts:

- 1. the relatively large contribution of sulfate to total $PM_{2.5}$ mass (approximately 17-18% at the SOB) which results in an ammonium sulfate contribution to $PM_{2.5}$ design value² that is well in excess of the "insignificant" concentration threshold (1.5 µg/m³) cited in EPA's precursor demonstration guidance document and which thus implicates the combined impact of major and minor SO₂ sources as significant contributors to peak PM_{2.5} levels; and
- 2. the large under prediction of sulfate mass by CMAQ for the 2008 episodes (normalized mean bias of -66%)³ which leads to the conclusion that the current modeling system (consisting of CMAQ and the emissions estimates and meteorological modeling results used as inputs to CMAQ) does not accurately characterize the contributions of SO₂ sources to the PM_{2.5} design value.

In other words, SO_2 sources are observed to contribute significantly to $PM_{2.5}$ nonattainment and the current modeling system is not sufficiently accurate to provide a reliable estimate of the impacts of emission reductions from SO_2 sources. This makes it difficult to develop a precursor attainment

 $^{^{1}}$ While the 2016 guidance document recommends using 1.3 µg/m3, EPA recently updated and finalized the technical basis document used to set the recommended level and revised the significance threshold to 1.5 µg/m3.

² The design value is the pollutant concentration that is compared to the level of the NAAQS. For the 24-hour PM_{2.5} NAAQS, the design value is the annual 98th percentile daily average concentration averaged over three years.

³ "Addressing the precursor gases for Fairbanks PM_{2.5} State Implementation Plan", D. Huff 9/25/14, Table 1 (p. 125) in Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7.

Adopted



demonstration for major sources of SO_2 based on the current data and modeling system that otherwise would be considered sufficiently reliable to gain approval by EPA. We note that this also brings into question the reliability of a modeled attainment demonstration that includes SO_2 controls on major sources.

Despite the difficulties noted above with formulating an approvable major source SO_2 precursor demonstration, data analyses and modeling conducted for the Fairbanks moderate area SIP^4 provide some significant information which suggests that in fact major source SO_2 emissions may not contribute significantly to $PM_{2.5}$ nonattainment. We summarize these key results below:

- Analysis of CMAQ model results by UAF show almost no secondary SO₄ production during the modeled periods. Thus, nearly all of the modeled SO₄ is from primary SO₄ emissions.
- CMAQ underpredicted the SO₄ concentration at the SOB by an average of 3.22 µg/m³ on days with FRM measurements during the 2008 winter episodes (the average observed SO₄ was 5.25 µg/m³ while the average predicted SO₄ was 2.03 µg/m³; note that these values are taken from Table 2 of *Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7* and differ slightly from the values in Table 1; we are still trying to determine the reason for these small differences).⁵
- ADEC concluded that there is likely sufficient excess NH₄ present under episode conditions so that reductions of secondary SO₄ would not lead to significant increases in other secondary species such as ammonium nitrate.⁶
- Both CMAQ point source SO₂ "zero out" runs in which results from the base case CMAQ run are compared with a CMAQ run in which point source SO₂ emissions are reduced to zero and CALPUFF model runs show that point sources contribute approximately 22% of the total modeled SO₂ from all sources at the SOB monitor with nearly all of the remaining SO₂ coming from heating oil combustion.
 ⁷ Note that the modeled point sources consist of the six major SO₂ sources in the nonattainment area.
- CMAQ zero out runs also show that 5% of primary SO₄ is from point sources. The CMAQ SO₄ prediction at SOB is 2.1 μ g/m³ (Table 1) so the modeled point source primary SO₄ contribution is no more than 0.05 * 2.1 = 0.1 μ g/m³.
- Comparisons of total PM_{2.5} mass concentration to the NAAQS are made using data from a Federal Reference Method (FRM) monitor. However, PM_{2.5} species composition data are obtained from a SASS sampler. PM_{2.5} measurements from these two different monitoring methods are not directly comparable due to various unavoidable sampling artifacts. In accordance with EPA guideline procedures, ADEC applied adjustments to the PM_{2.5} species composition data from the SASS sampler at the SOB using the SANDWICH algorithm to more accurately reflect the composition of PM_{2.5} samples collected by the FRM monitor. These adjustments account for differences in the amount of nitrate, ammonium, carbon, other primary PM_{2.5} components (OPP), and particle bound water (PBW) captured by the two instruments.
- For purposes of developing the moderate area SIP, ADEC used the available ambient monitoring data processed through the SANDWICH algorithm to develop a "design day" PM_{2.5} composition representative of the average composition of PM_{2.5} during high wintertime PM_{2.5} episodes. ADEC also calculated the applicable PM_{2.5} "design value" which represents the PM_{2.5} total mass concentration that is compared to the level of the NAAQS. For the moderate area SIP, the PM_{2.5} design value at the

⁴ <u>https://dec.alaska.gov/air/anpms/communities/fbks-pm2-5-moderate-sip</u>

⁵ See Table 2, p. 129 in Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7

⁶ Amendments to State Air Quality Control Plan, Vol. II, Sec. D.5, Appendix III.D.5.7, p. 131.

⁷ Note that the CALPUFF point source modeling showed that on average only 0.1% of modeled point source SO₂ at SOB during the during Jan. 23rd – Feb 9th 2008 episode days was from the Flint Hills refinery, whereas 36% was from the four power plants and 64% from Ft. Wainwright.

Adopted





SOB site was determined to be 44.7 μ g/m³. Applying the design day composition to the design value results in the design day PM_{2.5} component concentrations shown in Figure 1.

Figure 1. Design day PM_{2.5} speciation at SOB used for the moderate area SIP (source: Appendix III.5.7, p. 122).

- For the design day, the 0.1 μ g/m³ primary sulfate contribution from point sources estimated from the CMAQ zero-out runs noted above scales up to 0.16 μ g/m³ (= 0.1 * 8.17/5.25) where 8.17 μ g/m³ is the amount of SO₄ on the design day and 5.25 μ g/m³ is the average observed amount of SO₄ for the modeled episodes.
- The design day PM composition shown in Figure 1 includes 8.17 μ g/m³ SO₄. The correspondingly scaled SO₄ that is unaccounted for in the CMAQ results is 3.22 * (8.17/5.25) = 5.01 μ g/m³. At one extreme, all of this "unexplained" SO₄ could be attributed to emissions from point sources (i.e., the major SO₂ sources). Perhaps more realistically, one could estimate that 22% of the unexplained SO₄ (0.22 * 5.01 = 1.1 μ g/m³) is from point sources, in keeping with the modeled 22% contribution of point sources to SO₂ noted above. Assuming all SO₄ is in the form of ammonium sulfate, this would be equivalent to a 1.1 * (132/96) = 1.51 μ g/m³ contribution to PM_{2.5}, where the factor 132/96 represents the molecular weight ratio of ammonium sulfate to sulfate. Adding to this the amount of particle bound water (PBW) associated with ammonium sulfate assumed in the SANDWICH estimate of FRM measurement (2/3 * 2.70 μ g/m³ = 1.80 μ g/m³ assumed to be associated with 8.17 μ g/m³ of SO₄ so 1.1 μ g/m³ * (1.80/8.17) = 0.24 μ g/m³ of PBW associated with the point source SO₄) results in a total point source ammonium sulfate with associated PBW contribution of 1.51 + 0.24 = 1.75 μ g/m³.
- The above simple "contribution-based" precursor demonstration result indicates that the major source SO₂ contribution is slightly above the "insignificant contribution" threshold (1.5 μ g/m³) cited



in EPA's Precursor Demonstration Guidance. <u>However</u>, the EPA guidance allows for a "sensitivitybased" precursor demonstration in which the reduction in $PM_{2.5}$ concentration resulting from a 30, 50, or 70% reduction in SO₂ emissions is compared to the 1.5 µg/m³ significance threshold. Based on a linear extrapolation from the above analysis, a maximum 70% reduction in <u>major source</u> SO₂ emissions would be expected to produce a 1.23 µg/m³ decrease in PM_{2.5}, which is below the 1.5 µg/m³ significance threshold. In other words, the PM_{2.5} design value is relatively insensitive to even a large (70%) reduction in major source SO₂ emissions.

Although the above result for a sensitivity-based SO_2 precursor demonstration is encouraging, it must be noted that the precursor demonstration guideline suggests that ADEC may still need to include consideration of the feasibility of major source SO_2 reduction measures in its SIP, even if the sensitivitybased demonstration produces a result below the significance threshold. This may be particularly important for Fairbanks given uncertainties about the amount of SO_4 actually contributed by the major sources.

It is also important to keep in mind that conditions have changed in Fairbanks since 2008 and the new Serious area SIP will use a base year of 2013 to represent "current conditions". Updated area source emissions will be modeled but episodic point source emissions will be based on the 2008 point source inventory. Modeling results are not yet available, so it is not possible to know how the above results might differ for the new base year.

November 19, 2019 Department of Environmental Conservation

DIVISION OF AIR QUALITY Director's Office

410 Willoughby Avenue, Suite 303 PO Box 111800 Juneau, Alaska 99811-1800 Main: 907-465-5105 Toll Free: 866-241-2805 Fax: 907-465-5129 www.dec.alaska.gov

CERTIFIED MAIL: 7017 1450 0002 0295 9745 Return Receipt Requested

GOVERNOR BILL WALKER

November 16, 2017

dopted

David Fish, Environmental Manager Aurora Energy, LLC 100 Cushman St., Ste. 210 Fairbanks, AK 99701

THE STATE

of

Subject: Request for additional information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant by December 22, 2017

Dear Mr. Fish:

A portion of the Fairbanks North Star Borough (FNSB) has been in nonattainment with the 24hour National Ambient Air Quality Standard for fine particulate matter ($PM_{2.5}$) since 2009. In a letter dated April 24, 2015, I requested that the Aurora Chena Power Plant and other affected stationary sources voluntarily provide the Alaska Department of Environmental Conservation (ADEC) with a Best Available Control Technology (BACT) analysis in advance of the nonattainment area being reclassified to a Serious Area. On May 10, 2017, the US Environmental Protection Agency (EPA) published their determination that the FNSB $PM_{2.5}$ nonattainment area would be reclassified from a Moderate Area to a Serious Area effective June 9, 2017.¹

Once the nonattainment area was reclassified to Serious, it triggered the need for Best Available Control Measure (BACM)/BACT analyses. A BACM analysis requires that ADEC review potential control measure options for the various sectors that contribute to the PM_{2.5} air pollution in the nonattainment area. A BACT analysis must be conducted for applicable stationary sources such as the Aurora Chena Power Plant. BACM and BACT are required to be evaluated regardless of the level of contribution by the source to the problem or its impact on the areas ability to attain.² The BACT analysis is a required component of a Serious State Implementation Plan (SIP).³ ADEC sent an email to Mr. Fish at Aurora on May 11, 2017 notifying him of the reclassification to Serious and

Clean Air

¹ Federal Register, Vol. 82, No. 89, Wednesday May 10, 2017 (<u>https://dec.alaska.gov/air/anpms/comm/docs/2017-09391-CFR.pdf</u>)

² https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf, Clean Air Act 189 (b)(1)(B) and 189 (e) and CFR 51.1010(4)(i) require the implementation of BACT for point sources and precursors emissions and BACM for area sources.

³ <u>https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf</u>, Clean Air Act 189 (b)(1)(B) and 189 (e) require the implementation of BACT for point sources and precursors emissions and BACM for area sources

Aurora Energy, LLC

included a request for the BACT analysis to be completed by August 8, 2017. The BACT analysis from Aurora, which included emission units found in Operating Permits AQ0315TVP03 Revision 1, was submitted by email to the Department on March 20, 2017.

ADEC and EPA reviewed the BACT analysis provided for the Aurora Chena Power Plant and ADEC is requesting additional information to assist it in making a legally and practicably enforceable BACT determination for the source. Both the ADEC and EPA comments are enclosed in this letter. ADEC requests a response by December 22, 2017. If ADEC does not receive a response to this information request by this date, ADEC will make a preliminary BACT determination based upon the information originally provided. However, ADEC does not have the in depth knowledge of your facility's infrastructure and without additional information, may select a more stringent BACT for your facility in order to be approvable by EPA. It is ADEC's intent to release the preliminary BACT determinations for public review along with any precursor demonstrations and BACM analysis before the required public comment process for the Serious SIP. In order to provide this additional comment opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated.

After ADEC makes a final BACT determination for Aurora, it must include the determination in Alaska's Serious SIP that then ultimately requires approval by EPA.⁴ In addition, the BACT implementation 'clock' was also triggered by the EPA reclassification of the area to Serious on June 9, 2017. Therefore, the control measures that are included in the final BACT determination will be required to be fully implemented prior to June 9, 2021 - 4 years after reclassification.⁵

As indicated in a meeting on September 21, 2017 between ADEC Air Quality staff and the stationary sources affected by the BACT requirements, ADEC will also be using the information submitted or developed to support the BACT determinations for Most Stringent Measure (MSM) consideration. MSMs will be a required element of the state implementation plan if the State applies for an extension of the attainment date from EPA. Therefore, the information you submit will be used for both analyses.

ADEC appreciates the cooperation that we've received from Aurora. ADEC staff would like to continue periodic meetings to keep track of timelines and progress. If you have any questions related to this request, please feel free to contact us. Deanna Huff (email: <u>Deanna.huff@alaska.gov</u>) and Cindy Heil (email: <u>Cindy.heil@alaska.gov</u>) are the primary contacts for this effort within the Division of Air Quality.

Sincerely,

Denie Lab

Denise Koch, Director Division of Air Quality

⁴ <u>https://www.gpo.gov/fdsys/pkg/USCODE-2013-title42/html/USCODE-2013-title42-chap85-subchapI-partD-subpart4-sec7513a</u>

⁵ 40. CFR 51.1010(4)

Page 2 of 3

Adopted Aurora Energy, LLC

Enclosures:

November 16, 2017	ADEC Request for Additional Information for Aurora Energy LLC, BACT Analysis
November 15, 2017	EPA Aurora Energy - Chena Power Plant BACT Analysis Review Comments
May 11, 2017	Serious SIP BACT due date email
April 24, 2015	Voluntary BACT Analysis for Aurora Energy, LLC

cc: Larry Hartig, ADEC/ Commissioner's Office Alice Edwards, ADEC/ Commissioner's Office Cindy Heil, ADEC/Air Quality Deanna Huff, ADEC/ Air Quality Jim Plosay, ADEC/ Air Quality Aaron Simpson, ADEC/Air Quality David Fish/Aurora Energy, LLC Tim Hamlin, EPA Region 10 Dan Brown, EPA Region 10 Zach Hedgpeth, EPA Region 10

Page **3** of **3**

ADEC Request for Additional Information Aurora Energy LLC. – Chena Power Plant BACT Analysis Review Environmental Resources Management Report, March 2017

November 16, 2017

Please address the following comments by providing the additional information identified by December 22, 2017. Following the receipt of the information the Alaska Department of Environmental Conservation (ADEC) intends to make its preliminary Best Available Control Technology (BACT) determination and release that determination for public review. In order to provide this additional review opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated. Additional requests for information may result from comments received during the public review period or based upon the new information provided in response to this information request.

This document does not represent a final BACT determination by ADEC. Please contact Aaron Simpson at <u>aaron.simpson@alaska.gov</u> with any questions regarding ADEC's comments.

- 1. <u>Alternative Fuel Source</u> Page 17 of the analysis indicates that it is assumed that use of another type of coal would not reduce NOx emissions, and use of an alternate fuel is considered technically infeasible, but did not include a substantive analysis. As indicated in the Approval and Promulgation the State of Washington's Regional Haze State Implementation Plan¹, the use of SNCR and Flex Fuel² was selected as BART for the TransAlta coal-fired power plant. Evaluate alternative coal sources as a potential control option for the coal-fired boilers and identify energy, environmental, and economic impacts and other costs that would affect the selection of an alternative source of coal as a technically feasible control option. Evaluate the control efficiency of alternative coal sources based on a comparison of the coal's heat content as well as nitrogen and sulfur content.
- 2. Low Excess Air (LEA) and Overfire Air (OFA) Operating at LEA involves reducing the amount of combustion air to the lowest possible level while maintaining efficient and environmentally compliant boiler operation. NOx formation is inhibited because less oxygen is available in the combustion zone. Overfire air is the injection of air above the main combustion zone. Implementation of these techniques may also reduce operational flexibility; however, they may reduce NOx by 10 to 20 percent from uncontrolled levels.³ Evaluate these technically feasible control technologies using EPA's top down approach.
- 3. <u>Additional SO₂ Control Technologies</u> The BACT analysis does not include a substantive analysis of spray-dry scrubbing, dry flue gas desulfurization, dry scrubbing, or dry sorbent injection (DSI). All of these technologies have the potential to offer SO₂ removal, and therefore must be included in the analysis. Page 32 of the analysis indicates that the combined exhaust from the Chena Power Plant is currently controlled by a common baghouse and that installation of a dry injection or spray drying operation would require the existing baghouse be retrofit with a new PM control system to accommodate the much greater PM loading produced by a dry

¹ EPA-R10-OAR-2012-0078, FRL-9675-5

² Flex Fuel is the "switch from Centralia, Washington coal to coal from the Power River Basin in Wyoming. Powder River Basin coal has a higher heat content requiring less fuel for the same heat extraction, as well as a lower nitrogen and sulfur content than coal from Centralia. Flex Fuel also required changes to boiler design to accommodate Powder River Basin coal."

³ https://www3.epa.gov/ttn/chief/ap42/ch01/final/c01s01.pdf

injection or spray dry system. It further states that the installation of such technologies would be cost-prohibitive and therefore technically infeasible. However, the BACT analysis must include rigorous site-specific evaluation of the technical feasibility and cost effectiveness of these technologies.

The EPA cost manual does not currently include a chapter covering dry sorbent injection (DSI). However, as part of their Regional Haze FIP for Texas, EPA Region 6 developed cost estimates for DSI as applied to a large number of coal fired utility boilers. See the Technical Support Documents for the Cost of Controls Calculations for the Texas Regional Haze Federal Implementation Plan (Cost TSD) for additional information. The Cost TSD and associated spreadsheets are located at: <u>https://www.regulations.gov/document?D=EPA-R06-OAR-2014-0754-0008</u>. Please update the cost analysis for these technologies and provide technical justifications for all assumptions used in the analysis submitted as part of the BACT analysis (i.e., direct and indirect contingency costs, startup costs, initial performance test costs, electricity rate, and reagent costs). Provide in the analysis: the control efficiency associated with the technologies, Captured Emissions (tons per year), Emissions Reduction (tons per year), Capital Costs (2017 dollars), Operating Costs (dollars per year), Annualized Costs (dollars per year), and Cost Effectiveness (dollars per ton) using EPA's cost manual. Please see Comments 5, 6, and 7 for additional information related to retrofit costs, baseline emissions, and factor of safety.

- 4. <u>BACT limits</u> BACT limits by definition, are numerical emission limits. However regulation allows a design, equipment, or work/operational practices if technological or economic limitations make a measurement methodology infeasible. Provide numerical emission limits (and averaging periods) for each proposed BACT selection, or justify why a measurement methodology is technically infeasible and provide the proposed design equipment, or work/operational practices for pollutant for each emission unit included in the analysis. Startup, Shutdown, and Malfunction (SSM) must be addressed in the BACT analysis. Measures to minimize the occurrence of these periods, or to minimize emissions during these periods are control options. Combinations of steady-state control options and SSM control options can be combined to create distinct control strategies. In no event shall application of BACT result in emissions of any pollutant which would exceed the emissions allowed by an applicable standard under 40 C.F.R. parts 60 (NSPS) and 61 (NESHAP).
- 5. <u>Retrofit Costs</u> EPA's Control Cost Manual indicates that study-level cost estimates (± 30 percent) should not include a retrofit factor greater than 30 percent, so detailed cost estimates (± 5 percent) is required for higher factors. High retrofit cost factors (50 percent or more) may be justified in unusual circumstances (e.g., long and unique ductwork and piping, site preparation, tight fits, helicopter or crane installation, additional engineering, and asbestos abatement). Provide detailed cost analyses and justification for difficult retrofit (1.6 1.9 times the capital costs) considerations used in the BACT analysis.
- 6. <u>Baseline Emissions</u> Include the baseline emissions for all emission units included in the analysis. Typically, the baseline emission rate represents a realistic scenario of upper bound uncontrolled emissions for the emissions unit (unrestricted potential to emit not actual emissions). NSPS and NESHAP requirements are not considered in calculating the baseline emissions. The baseline is usually the legal limit that would exist, but for the BACT determination. Baseline takes into account the effect of equipment that is part of the design of the unit (e.g., water injection and LNBs) because they are considered integral components to the unit's design. If the uncontrolled emission rate is 'soft,' run the cost effectiveness calculations using two or three different baselines.

- 7. <u>Factor of Safety</u> If warranted, include a factor of safety when setting BACT emission limitations. The safety factor is a legitimate method of deriving a specific emission limitation that may not be exceeded. These limits do not have to reflect the highest possible control efficiencies, but rather, should allow the Permittee to achieve compliance with the numerical emission limit on a consistent basis.
- 8. <u>Good Combustion Practices</u> –For each emission unit type (coal boilers, distillate boilers, engines, and material handling) for which good combustion practices was proposed as BACT, describe what constitutes good combustion practices. Include any work or operational practices that will be implemented and describe how continuous compliance with good combustion practices will be achieved.

Aurora Energy - Chena Power Plant

BACT Analysis Review Comments Report dated March 2017 – Environmental Resources Management

Zach Hedgpeth, PE EPA Region 10 – Seattle November 15, 2017

- 1. <u>Equipment Life</u> Some of the calculations¹ submitted with the analysis use a 10 year equipment life at ten percent interest rate. The analysis must use a reasonable estimate of the actual life of the control equipment for each control technology, based on the best evidence available. The analysis must also provide written basis for the interest rate assumed if it differs from the standard seven percent rate used in the EPA Air Pollution Control Cost Manual.
- 2. <u>SO₂ Control Technologies</u> The BACT analyses must include substantive analysis of the following four SO₂ control technologies, at a minimum: wet scrubbing (such as limestone slurry forced oxidation), spray-dry scrubbing, dry flue gas desulfurization (dry scrubbing), and dry sorbent injection. The BACT analysis must include rigorous site-specific evaluation of the technical feasibility and cost effectiveness of these technologies.
- 3. <u>Control Technology Availability</u> Technically feasible control technologies may only be eliminated based on lack of availability if the analysis includes documented information from multiple control equipment vendors (who provide the technology in question) which confirms the technology is not available for the emission unit in question.
- 4. <u>Basis for Costs and Assumptions</u> Documents cited in the analyses which form the basis for costs used in the analyses and assumptions made in the analyses must be provided.
- 5. <u>EPA Cost Spreadsheets</u> The EPA has recently updated the cost manual chapters pertaining to SCR and SNCR, and developed cost spreadsheets to be used for evaluation of this technology for cost effectiveness². The cost analyses for these technologies must be consistent with the updated cost manual chapter and cost spreadsheet.
- 6. <u>Space Constraints</u> In order to establish a control technology as not technically feasible due to space constraints or other retrofit considerations, detailed site specific information must be submitted in order to establish the basis for such a determination, including detailed drawings, site plans and other information to substantiate the claim.
- 7. <u>Retrofit Costs</u> EPA Region 10 believes that installation factors which would complicate the retrofit installation of the control technology should be evaluated by a qualified control equipment vendor and be reflected in a site-specific capital equipment purchase and installation cost estimate or quote. Lacking site-specific cost information, all factors that the facility believes complicate the retrofit installation of each technology should be described in detail, and detailed substantiating information must be submitted to allow reasonable determination of an appropriate retrofit factor.
- 8. <u>Potential vs. Actual Emissions</u> All BACT cost effectiveness calculations must use potential-toemit (PTE), regardless of the emission unit usage history or actual historical emission rates. The

¹ See for example, NOx cost calcs-MARCH 2017 FINAL.xlsx

² <u>https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution</u>

facility should consider operating limits in cases where certain emission units do not need to retain relatively high PTE for facility operational purposes.

9. <u>Control Efficiency</u> – Cost effectiveness calculations for each control technology must be based on a reasonable and demonstrated high end control efficiency achievable by the technology in question at other emission units, or as stated in writing by a control equipment vendor. If a lower pollutant removal efficiency is used as the basis for the analysis, detailed technical justification must be provided.

November 19, 2019 Department of Environmental Conservation

DIVISION OF AIR QUALITY Director's Office

410 Willoughby Avenue, Suite 303 PO Box 111800 Juneau, Alaska 99811-1800 Main: 907-465-5105 Toll Free: 866-241-2805 Fax: 907-465-5129 www.dec.alaska.gov

CERTIFIED MAIL: 7014 0510 0001 9932 8880 Return Receipt Requested

GOVERNOR BILL WALKER

April 24, 2015

Adopted

David Fish, Environmental Manager Aurora Energy, LLC 100 Cushman St., Ste. 210 Fairbanks, AK 99701

THE STATE

oţ

Subject: Voluntary BACT Analysis for Chena Power Plant

Dear Mr. Fish:

Portions of the Fairbanks North Star Borough are in nonattainment with the 24-hour National Ambient Air Quality Standard for Fine Particulate Matter (PM 2.5). The Alaska Department of Environmental Conservation (ADEC) expects that the Environmental Protection Agency (EPA) will change the nonattainment designation from a Moderate Area to a Serious Area in June 2016. Once EPA designates the area as Serious, an 18-month clock begins for submittal of an implementation plan that includes best available control technologies (BACT) analysis and determination for stationary sources with over 70 tons per year (TPY) potential to emit (PTE) for PM2.5 or its precursors.

ADEC has neither the funding nor the in depth knowledge of your facility's infrastructure to determine the most appropriate BACT for your facility. Without the information or resources necessary to conduct detailed cost analysis and produce supporting documentation, ADEC may select a more stringent BACT for your facility in order to be approvable by EPA. In addition, 18 months is likely not adequate to complete a thorough BACT analysis.

Therefore, ADEC requests that your facility voluntarily begin the BACT analysis. We request that you submit an initial BACT analysis to ADEC by December 2015 and the final BACT analysis by March 2016 to ADEC. ADEC is required to make a BACT determination for every eligible facility within the designated PM2.5 nonattainment area and final BACT determinations are ultimately reviewed by EPA and subject to federal approval as part of the federally required PM2.5 implementation plan.

Background

EPA required that ADEC submit a State Implementation Plan (SIP) because portions of the Fairbanks North Star Borough (FSNB) are in nonattainment with the health based 24-hour National

Clean Air

Ambient Air Quality Standard for PM2.5. ADEC submitted an initial, Moderate Area PM2.5 SIP for FNSB to EPA on December 31, 2014.

Unfortunately, this Moderate Area SIP was developed as an impracticable SIP because modeling was unable to demonstrate that attainment with the health standard was possible by December 30, 2015. Preliminary air monitoring results also indicate that FNSB will not demonstrate attainment in 2015. Attainment is calculated on a rolling three year average of the highest 98th percentile concentration at each monitor. When those monitoring results become final in May 2016 and an official three year design value is calculated, the FNSB non-attainment area will remain over the 24-hr PM 2.5 standard of 35 μ g/m³. The final determination of this design value will result in the FNSB non-attainment area being reclassified from a Moderate Area to a Serious Area¹ (40 CRF Parts 50, 51 and 93). This reclassification will happen by operation of law as outlined in Clean Air Act Sections 188 and 189. It is anticipated that the formal designation to Serious Area will occur in June 2016.

A Serious Area designation will result in several new, more stringent requirements, one of which is that all source categories in the nonattainment area that meet the BACT threshold of 70 TPY PTE for PM_{2.5} and its precursor pollutants (NOx, SO2, VOC, NH3) must be analyzed for Best Available Control Measures (BACM). As part of BACM, a Best Available Control Technologies (BACT) analysis will be required. The Serious Area BACT trigger requires the same approach as a PSD/NSR BACT project. A Serious non-attainment area BACT limit is set using a top-down analysis on a case-by-case basis taking into account energy, environmental and economic impacts, and costs. The analysis must include all emission units at the source.

The timelines for completion of the BACT analysis, subsequent BACT determination, and the submittal of the Serious Area SIP are outlined in the preamble of the Particulate Matter 10 (PM10) rule and reconfirmed in the newly proposed $PM_{2.5}$ Implementation Rule². Both rules require a completed SIP 18 months after designation to Serious. This 18 month time period does not allow enough time to thoroughly evaluate BACT, update the emission inventory, complete the modeling and allow for development and processing for a Serious Area SIP.

ADEC believes that it is best for facilities to complete the BACT analysis for their own facilities. ADEC does not have the funding to develop the analysis nor the in depth knowledge of each sources' infrastructure. ADEC would therefore base the cost analysis on the installation of control equipment without being able to factor in all the costs associated with retrofitting existing equipment. Without the detailed cost analysis and supporting documentation to support less stringent BACT options, it is doubtful that the BACT portions of the Serious SIP will be approvable without using the most stringent measures.

By requesting an early BACT analysis for facilities before the official Serious Area designation, it will help ADEC meet the following timelines and ultimately submit a Serious Area SIP to EPA by the required due date. Early analysis also has the potential to increase flexibility for each Stationary Source under the rules.

 $\operatorname{Page} 2 \operatorname{of} 3$

¹ 40 CFR Parts 50,51 and 93 <u>http://www.epa.gov/airquality/particlepollution/actions.html</u>

² <u>http://www.epa.gov/airquality/particlepollution/actions.html</u>

- Serious Area SIP inventory development starts:
- BACT kick off meeting:
- Submit initial BACT results to ADEC:
- Submit complete/final BACT analysis to ADEC:
- Serious Area SIP modeling by ADEC starts:
- Serious Area designation by EPA (Expected):
- Serious Area SIP draft:
- Serious Area SIP public notice period:
- Serious Area SIP submitted by ADEC to EPA:

January, 2015 March 5, 2015 December, 2015 March, 2016 March, 2016 June, 2016 December, 2016 February, 2017 December, 2017

Meeting the BACT analysis requirements is a major component of a Serious SIP. This is a challenging issue. It is important that ADEC accurately reflect the contributions of industrial sources to the air pollution problem and the potential improvements available within this emission sector along with the other emission sources in the community.

ADEC staff would like to continue periodic meetings to keep track of timelines and progress. If you have any questions related to this request, please feel free to contact us. Deanna Huff (email: <u>Deanna.huff@alaska.gov</u>) and Cindy Heil (email: <u>Cindy.heil@alaska.gov</u>) are the primary contacts for this effort within the Division of Air Quality.

Sincerely,

sine Min

Denise Koch, Director Division of Air Quality

cc: Larry Hartig, ADEC/ Commissioner's Office Alice Edwards, ADEC/ Commissioner's Office John Kuterbach, ADEC/ Air Quality Cindy Heil, ADEC/Air Quality Deanna Huff, ADEC/ Air Quality

Page 3 of 3

November 19, 2019

Adopted



December 22, 2017

Denise Koch Director, Division of Air Quality Alaska Department of Environmental Conservation PO Box 111800 Juneau, AK 99811-1800

Subject: Response to November 16, 2017 request for additional information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant by December 22, 2017

Dear Ms. Koch:

Aurora is responding to the request for additional information to supplement the Best Available Control Technology (BACT) Technical Memorandum provided to the Alaska Department of Environmental Conservation (ADEC) on March 20, 2017. In response, a detailed BACT analysis for sulfur controls is included as an addendum to the original BACT analysis. We are confident that our initial submittal and enclosed response are sufficient to make a preliminary BACT determination consistent with our selected BACT. Aurora is convinced expending additional and substantial resources to provide further analysis is not warranted considering that ADEC has established, through moderate area planning efforts, that our facility's contribution to ground level particulate matter during air quality events is minimal.

Aurora realizes that a BACT analysis must be conducted for applicable stationary sources regardless of the level of contribution to the problem or impact on the area's ability to achieve attainment. However, the request for additional information hints at the Departments next steps of requiring heat and power producers, such as Aurora, to install technology which will have minimal impact on bringing the area into attainment.

Collectively, the large stationary sources contribute less than 10% of the total $PM_{2.5}$ concentration as illustrated by ADEC.¹ According to the moderate area planning efforts, Aurora makes up less than 1% of the contribution from large stationary sources.² The cost to mitigate Aurora's less than one percent contribution to ground-level particulate matter would require tens of millions of dollars in capital investments and annualized operating costs which would be passed on to the consumer in increased power and district heat rates. Current electric rates in the Interior are already some of the highest in the country. Market competition dictates that district heating costs are priced to be competitive with oil and natural gas. An increase in district heat

¹ Clear the Air Conference. 2017. <u>http://co.fairbanks.ak.us/transportation/Pages/AQConference2017.aspx</u>, Source Apportionment Presentation, Slide 21, accessed 11/29/2017.

² State Implementation Plan, ADEC. 2014. <u>http://dec.alaska.gov/air/anpms/comm/docs/fbxSIPpm2-5/III.D.5-</u> PM2.5 SIP Sections-Adopted 09.07.16.pdf, pg 167 of 233. Accessed 11/29/2017.

Adopted ADEC D. Koch Page 2

rates could encourage consumers to switch to ground-level heating sources, such as oil and wood, which would exacerbate the area's air quality problems and impede local progress toward attainment.

In short, BACT is prohibitively costly, impractical, and ineffective in this situation. The implementation of additional control technology on Aurora would, at best, provide minimal benefit to air quality and would likely result in unintended consequences. Aurora believes that ADEC, EPA and Aurora could work together to identify a mechanism in the planning process that recognizes the air quality benefit of Aurora's district heating system which displaces the equivalent of over two million gallons of wintertime ground-level heating oil emissions. As such, district heating is a proven solution to Fairbanks' air quality issues. Aurora hopes that ADEC will take these points into consideration in anticipation of the Department's preliminary BACT determination for public review.

16 Wrst Sincerely, Buki-Wright

President



Prepared for: Aurora Energy, LLC

Addendum to Best Available Control Technology Analysis

Chena Power Plant Fairbanks, Alaska

December 2017

www.erm.com


Addendum to Best Available Control Technology Analysis

Chena Power Plant Fairbanks, Alaska

Prepared for: Aurora Energy, LLC 100 Cushman St., Suite 210 Fairbanks, Alaska 99701-4674

December 2017

Kelley Kand

Kelley Hand Project Manager

J.D. Gibbs Partner-in-Charge

Environmental Resources Management

200 East Campus View Boulevard, Suite 200 Columbus, Ohio 43235 Phone: (513) 830-9030

TABLE OF CONTENTS

1	INT	RODUCT	ION	1
	1.1	ADDIT	TONAL SO ₂ CONTROLS SELECTED FOR EVALUATION	3
	1.2	SPRAY	´DRYER/ABSORBER	4
		1.2.1	Site-specific Considerations for Using SDA at Chena	5
	1.3	DRY S	ORBENT INJECTION	10
		1.3.1	Sorbent Type	11
		1.3.2	Flue Gas Temperature at the Injection Location	12
		1.3.3	Sorbent Particle Size	12
		1.3.4	Sorbent Injection Rate (or NSR)	12
		1.3.5	PM Control Device Type	13
		1.3.6	Flue Gas Properties	14
		1.3.7	Site-specific Considerations for Using DSI at Chena	14
	1.4	REVIE	W OF SO ₂ BACT DATABASE	17
	1.5	SUMM	ARY OF TECHNICAL FEASIBILITY	21
2	ECO	NOMIC	EVALUATION OF SO ₂ CONTROL OPTIONS	23
	2.1	SDA E	CONOMIC EVALUATION	23
	2.2	DSI EC	CONOMIC EVALUATION	24
3	DIS ENE	CUSSION RGY ASP	I OF SITE-SPECIFIC TECHNICAL, ENVIRONMENTAL, AND PECTS OF DRY SCRUBBING TECHNOLOGY USE AT CHENA	1
	POV	VER PLA	NT	35
	3.1	SUMM	ARY OF TECHNICAL FEATURES AND CHALLENGES	35
	3.2	LOCAT	TION CONSIDERATIONS	38
	3.3	ENVIR	ONMENTAL CONSIDERATIONS	39
	3.4	ENERC	<i>GY CONSIDERATIONS</i>	46

	3.5	SUMMARY OF ENVIRONMENTAL AND ENERGY CONSIDERATION	NS46
4	ANA	LYSIS OF ASPECTS RELATED TO BACT	47
	4.1	DETERMINATION OF BACT FOR SO ₂	4 8

LIST OF TABLES

Table 1. Summary of SO2 BACT Permit Reviews	8
Table 2. CUECost Input and Calculation Summary for SDA	5
Table 3. Annualized Cost Summary for DSI for the Combined Boiler Exhaust	0
Table 4. Annualized Cost Summary for DSI for the Large Boiler Exhaust	2
Table 5. Summary of Cost Effectiveness of SO ₂ Control Options	4
Table 6. Summary of Technical Challenges Associated with Dry SO2 Scrubbing at Chena Power Plant 36	6

LIST OF FIGURES

Figure 1.	Aerial View of Chena Power Plant.	. 2
Figure 2.	Chena Power Plant exhaust plume	44

ACRONYMS AND ABBREVIATIONS

ADEC	Alaska Department of Environmental Conservation
BACT	best available control technology
CAA	Clean Air Act
CMB	chemical mass balance
EPA	Environmental Protection Agency
FGD	flue gas desulfurization
FNSB	Fairbanks North Star Borough
ft	foot or feet
GVEA	Golden Valley Electric Association
LAER	Lowest Achievable Emission Rate
lb/hr	pound per hour
MW	megawatt
NAAQS	National Ambient Air Quality Standard
NOx	oxides of nitrogen
NSPS	New Source Performance Standards
NSR	Normalized stoichiometric ratio
OH	hydroxyl
PM	particulate matter
ppm	parts per million
PSD	Prevention of Significant Deterioration
RACT	reasonable available control technology
SIP	State Implementation Plan
SO ₂	sulfur dioxide
ton/yr	tons per year
U.S.	UnitedStates
VOC	volatile organic compounds
µg/m³	micrograms per cubic

Adopted

1 INTRODUCTION

As described in the original Best Available Control Technology (BACT) Analysis report, Aurora Energy, LLC (Aurora) operates four coal-fired boilers, three similarly-sized smaller units and one larger unit, at the facility known as the Chena Power Plant (Chena).¹ The combined exhaust from the four boilers at Chena is currently directed to a single fabric filter for control of particulate matter (PM). Figure 1 presents an aerial view of the Chena facility where the four coal-fired boilers are located. The duct work from the three smaller boilers can be seen coming out of two different buildings along 1st Avenue. The duct work from the larger boiler is not clearly visible, but comes out of a third building and connects to the other combined ducts just prior to entering the south side of the fabric filter housing. The fabric filter housing, visible as a blue structure in the figure, is one of the larger individual structures that occupies the site. The PM collected in the fabric filter is conveyed to the adjacent ash silo for storage until trucked off site.

The four Chena boilers combust low sulfur coal to achieve a sulfur dioxide (SO_2) emission rate equivalent to 0.39 pounds of SO_2 per million Btu of heat input (lb $SO_2/MMBtu$). The coal is "local" coal mined at the Usibelli Coal Mine in Healy, Alaska.

The techniques available for controlling SO_2 emissions from a coal-fired boiler include the following:

- Use of flue gas desulfurization (FGD) technology
 - Wet scrubber
 - Dry scrubber (lime injection and spray dryer/absorber)
 - Limestone or other dry sorbent injection

Most wet FGD systems employ two stages: one for fly ash removal and the other for SO₂ removal. In wet scrubbing systems, the flue gas first passes through a fly ash removal device, either an electrostatic

¹ Environmental Resources Management, Inc., Best Available Control Technology Analysis, Chena Power Plant, Fairbanks, AK, revised March 2017.







Figure 1. Aerial View of Chena Power Plant.

precipitator (ESP) or a fabric filter, and then into the SO₂ absorber. Due to cost constraints, wet FGD systems are not commonly used to reduce SO₂ emissions from boilers combusting low-sulfur coal. The original Chena Power Plant BACT Analysis presented a detailed discussion of the technical feasibility and cost of using a wet scrubber at Chena. Wet scrubbing technology was discounted as BACT in the original analysis due to the high cost-effectiveness (although many other technical challenges, such as space constraints, exist when considering wet scrubber technology at Chena). Additional discussion of FGD using a wet scrubber is therefore not needed at this time.

1.1 ADDITIONAL SO₂ CONTROLS SELECTED FOR EVALUATION

This BACT Addendum concentrates on evaluation of dry FGD technology, which consists of the spray dryer/absorber (SDA) option and the dry sorbent injection (DSI) option. In SDA or DSI operations, the SO_2 is first reacted with the sorbent, and then the flue gas passes through a PM control device.

The ability of a SDA or DSI system to achieve any reasonable degree of SO₂ control is highly influenced by the presence of other constituents in the gas stream that will compete with the calcium or sodium injected into the gas. In the case of coal-fired boiler flue gases, the primary competing constituent is chlorine. Chlorine present in the coal will form hydrochloric acid (HCl) in the flue gas and consume a portion of the injected lime. In an SDA system, actual sorbent consumption is influenced by the discharge temperature selected for the system, as this controls the amount of water sprayed into the flue gas.

The ability to employ an add-on SO₂ control system also is influenced by site-specific factors, including space limitations. Use of a SDA or DSI system in concert with the somewhat peculiar equipment orientation at Chena, i.e., four boilers controlled by a single fabric filter, would require major alterations of the existing ductwork and possibly the fabric filter. The boiler houses and ducts would need to be retrofit with various equipment items to accommodate the sorbent delivery systems and PM handling systems required by a SDA or DSI system.

The following paragraphs present an overview of these two selected dry FGD technologies in general and a description of some of the site-specific issues associated with their use at Chena.

1.2 SPRAY DRYER/ABSORBER

A U.S. EPA Air Pollution Control Technology Fact Sheet for FGD technologies states that scrubbers are capable of reduction efficiencies in the range of 50 to 98%.² The highest removal efficiencies are achieved by wet scrubbers, and the lowest by dry scrubbers (typically less than 80%). Low SO₂ loadings to a dry absorber, as are obtained when using low sulfur coal, tend to produce lower removal efficiencies, between 40% and 70%. For comparison, the Consent Decree between the Golden Valley Electric Association, Inc. (GVEA) and the US EPA (dated November 19, 2012) and the subsequent Minor Permit issued by the Alaska Department of Environmental Conservation (ADEC) specified a 30-day SO₂ emission rate of no greater than 0.10 lb/MMBtu for Healy Power Plant (Healy) Unit 2 in Healy, AK while using SDA.³ The Healy facility combusts similar coal as the Chena Power Plant, which produces an average uncontrolled emission rate of 0.39 lb SO₂/MMBtu. Achieving an emission rate of 0.10 lb SO₂/MMBtu thus represents a 74% reduction of average uncontrolled SO₂ emissions, which generally falls within the published range of performance for a SDA system.

In SDA systems, a slurry of sorbent material and water is fed to a spray dryer tower. In the tower, the slurry is atomized and injected into the gas, where droplets react with SO_2 as the liquid evaporates. This action produces a dry product that is collected in the bottom of the spray dryer and in the downstream PM removal equipment (i.e., fabric filter or electrostatic precipitator, ESP). The majority of the reaction takes place in the spray dryer. When a fabric filter is used, as the PM collects on the filter cloth, a filter cake would develop and allow the gas a second chance to react with the reagent, thus increasing utilization of the reagent and control efficiency. The fabric filter or ESP, downstream of the spray dryer, removes the PM, ash, reaction products (e.g., CaSO₃, CaSO₄, Na₂SO₄), and unreacted sorbent. The waste product can be disposed, sold as a byproduct (depending on its quality), or recycled to the slurry. Various calcium and sodium-based reagents can be utilized as sorbent. SDA systems typically inject lime because it is more reactive than limestone and less expensive than sodium-based reagents. SO₂ control efficiencies

² US EPA, Air Pollution Control Technology Fact Sheet, Flue Gas Desulfurization,

EPA-452/F-03-034, <u>https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf</u>, accessed December 18, 2017. ³ Technical Analysis Report – Permit AQ0173MSS01, April 14, 2014, Golden Valley Electric Association-Healy Power Plant.

are somewhat comparable for wet limestone scrubbers and spray dry systems, however, the capital and operating cost for spray dryer systems are lower than for wet systems, because equipment for handling liquid reagent and wet waste products is not required. In addition, carbon steel can be used to manufacture the absorber because the flue gas is less humid.

It is reasonable to expect that SDA technology performance depends on the facility-specific process characteristics. The properties most important for a SDA application are an inlet gas temperature that allows the slurry to be evaporated in the flue gas (a necessity for a spray dry scrubber), adequate mixing and residence time that allow the sorbent to react with the SO_2 in the gas, and the use of a PM control device to separate the reaction products from the gas stream.

1.2.1 Site-specific Considerations for Using SDA at Chena

*Flue Gas Take-off Point--*The Chena plant employs a fabric filter to remove the PM from the combined flue gases of the four boilers operating at the site. A very short duct run, only about 10 feet, exists between the location where the flue gases are combined and the combined gas enters the fabric filter housing. At this point, the flue gas from Boiler 5 combines with the previously-combined flue gas from Boilers 1, 2, and 3. Three general SDA equipment orientations are possible for taking off flue gas for treatment in a spray dryer tower at Chena. The first orientation would take the flue gas from the point where all boiler flue gases have been combined prior to entering the fabric filter, i.e., in the 10-foot (ft) duct run. A second orientation would take the flue gas from Boiler 5 only (at some point prior to the 10-ft duct run) and provide control only of the SO₂ emitted by the larger boiler. A third orientation would take the combined flue gas as it exits the fabric filter. In any of these orientations, construction of duct work needed to deliver flue gas to the spray dryer tower would be complicated. Major changes to the gas flue flow regime would occur for any take-off point prior to the fabric filter. Major structural modifications of the fabric filter housing would be needed to accommodate a take-off point downstream of the fabric filter.

Spray Dryer Tower Location-- The Chena site is extremely congested, and very little vacant space is available for new construction. Therefore, spatial considerations are necessary when locating a spray dryer tower. A similarly sized boiler facility exists at the Golden Valley Electric Association (GVEA) plant in Healy, Alaska. The Healy Unit #2 boiler (683 MMBtu/hr) employs a SDA system, which is a similarly sized boiler

burning run-of-mine coal from Usibelli. The spray dryer tower at the GVEA plant is 34 ft 9 in in diameter and stands 36 ft 9 in from the ground with a 29 ft 4 in, 60° Cone Hopper. Because of the congested area at Chena, a spray dryer tower would have to be located on the northern boundary of the property south of the river on the east or west of the outfall house. That location would situate the tower approximately 150 to 250 ft away from the combined flue gas junction just prior to the fabric filter inlet. After exiting the spray dryer tower, the treated gas would be redirected back to the 10-ft duct run at the fabric filter inlet for removal of PM. The baghouse design for the flue gas temperature at the inlet is 350 °F. Typically, the combined flue gases are between 300 and 315 °F at the inlet of the baghouse. The outlet temperature varies between 285 and 300 °F. The optimal temperature for SO₂ removal in a SDA is 10 to 15 °C below the saturation temperature to maximize the removal of SO₂. At approximately 15% moisture of Chena's flue gas, the saturation temperature would be around 88 °C (190 °F). This would cause wet solids to deposit on the absorber and downstream equipment. For spray dry systems, the temperature of the flue gas exiting the absorber must be 10 to 15 °C (20 to 50 °F) above the adiabatic saturation temperature.⁴ The Healy plant inlet temperature is 300 °F and exists at 175 °F; however the O&M manual for the SDA references 185 °F as the outlet set point. Regardless, the long return duct run from the tower to the fabric filter would require reheating.to prevent moisture from condensing out of the gas. The reheating requirements will add to the increase in energy consumption from the control technology.

In a second option, Boiler 5 flue gas would be treated independently with a SDA system. For this option, the flue gas take-off point could be closer to the boiler, but the tower itself will still need to be located at a spot with available space approximately 100 to 200 ft away, and gas reheat would still be required as described for option 1. A separate spray tower for the combined flue gases from Boilers 1, 2, and 3 would have to be situated in the same area on the north side of the property as described above with ducting between 150 and 250 ft. This configuration is essentially the same as described in option 1 and therefore is not considered independently as an option.

⁴ Ibid (Air Pollution Control Technology Fact Sheet).

A third option would place the spray dryer tower after the fabric filter. This orientation would require a second fabric filter housing to be constructed at the facility. Based on an air-to-cloth ratio of 10 ft/min for lime⁵, 0.39 lb/MMBtu SO₂ in the flue gas, a stoichiometric conversion from SO₂ to CaSO₃ (1.875), and a 75% removal efficiency, the filter area required of the secondary baghouse would be 25,000 ft². The current baghouse has a filter area of 61,000 ft² and a footprint of 35,035 ft² (not including the ducting and ID fans). Assuming the profile would be similar for the secondary baghouse, a footprint of 14,360 ft² would be required. Space is not available on Aurora's property for the installation of a second baghouse which would be about 40% the size of the current baghouse.

*Existing PM Collection and Storage Equipment--*A SDA placed upstream of the existing Chena fabric filter would have several negative operational impacts. First, the amount of additional PM generated and sent to the existing fabric filter could cause the existing filter system to clean more continuously. The baghouse cleans when the differential pressure drop between inlet and outlet reaches 6 inches water column. The baghouse currently cycles through cleaning about 24 times a day. Assuming 4% fly ash is generated at an average operating load of 220,000 ton/yr of coal (2,000 lb/hour fly ash), the increase in fly ash at the projected maximum coal input rate of 283,824 ton/yr (2,592 lb/hour fly ash) would cause the baghouse to cycle 31 times a day (24 cycles/day x 2,592 lb/hr ÷ 2000 lb/hr). The additional particulate generation could increase the ash load to the baghouse by 267 lb/hr (0.39 lb SO_2 /MMBtu at 75% removal efficiency). The additional load would increase the baghouse daily cleaning cycle to 34. The additional cycling of the system would require an increase in electrical consumption and operational maintenance.

While the particle loading could be accommodated by the existing baghouse, it is unlikely that additional airflow from added control technologies could be accommodated through the baghouse at maximum load. A stoichiometric analysis of the combustion flue gas, with 7% oxygen yields 11.1 lb of exhaust/lb of coal. The density of the exhaust air

⁵ EPA. 2002. Air Pollution Cost Control Manual: Section 6, Particulate Matter Controls. <u>https://www3.epa.gov/ttncatc1/dir1/c_allchs.pdf</u>. Research Triangle Park, North Carolina.

from the plant, based on average test data, is 0.048 lb/ft^{3.6} If a maximum projected heat input rate of 486 MMBtu/hr (283,824 ton/yr coal) were realized, the air flow through the baghouse would be 250,000 ft³/min, which is the rated capacity of the baghouse. The stoichiometric analysis does not consider air infiltration which would increase the air flow to the baghouse beyond its capacity. Additional airflow needed for add-on control technologies would exceed the design air flow of the existing baghouse.

The duct reconstruction at the flue gas take-off point as well as the point where the treated flue gas is re-introduced to the fabric filter inlet also will require additional gas-handling equipment. Therefore, the additional PM load to the fabric filter and silo would necessitate an increase in electricity consumption and operational maintenance necessary to address potential plugging and filter replacement.

A take-off point after the existing fabric filter would alleviate the excessive PM loading issue. This orientation would require that a new outlet gas duct be retrofit onto the existing fabric filter housing to deliver the outlet gas to a second fabric filter. The existing filter vents through a roof monitor (also referred to as a monovent). In order to direct the fabric filter outlet gas to a downstream SDA system, one would need to open the top of the existing filter housing, weld new gas distribution plates to the outlet plenum, and construct a single gas outlet duct. This outlet duct would then be directed to the downstream SDA system, new fabric filter, and PM silo. The structural stability of the existing filter housing may be inadequate for handling the additional stress of the gas distribution components, in which case, extensive structural reinforcement would be needed. Construction of these items would demand more space than is available. As is clearly apparent by looking at Figure 1, the site has no extra space in which to build any such equipment for PM collection and storage. Additionally, operation of such a system orientation would increase the electric consumption at the facility. The average total electrical power consumption for the SDA system at the Healy Clean Coal

⁶ Airflow Sciences Corporation. Chena PJFF Inlet Ductwork Flow Modeling. Fairbanks, Alaska. October 2015.

Project for their Healy Unit #2 during a performance test was 550.5 kW.⁷ The Chena Power Plant baghouse power consumption is 460 kW. An SDA would potentially double the pollution control load of the plant and decrease the net sales of power approximately 2.4%.

*Contamination of Collected Particulate--*The ash constituent loading would change as a result of adding sorbents used in the process. This change could render the ash unsuitable for beneficial use as a fill material. Fly ash collected at Chena is beneficially used as a construction fill material. The addition of sorbents could compromise the leaching characteristics of the ash which is a metric to determine its suitability for beneficial structural fill. Without adequate testing, there is uncertainty as to the impact of the sorbents on the leaching characteristics of the ash. Use of an SDA system downstream of the exiting fabric filter could alleviate this issue if the sorbent byproducts were addressed separately from combustion ash.

Facility Space Limitations for Ancillary Equipment-- Regardless of whether a SDA is placed upstream or downstream of the existing fabric filter, the spatial requirement of the system and auxiliary equipment will be difficult to accommodate. A SDA system would employ lime, Trona, or sodium bicarbonate as the scrubbing reagent. Extensive preliminary engineering would need to be performed to define space requirements for the scrubber tower(s); raw reagent receiving areas, piping, conveyors, and storage tanks and silos, and reagent mills; as well as similar equipment for handling the solid waste material generated in the system. The GVEA Healy plant, in addition to the SDA vessel, houses conveyors, recycle surge bin (12-ft diameter), slurry feed tank (7.5-ft diameter), slurry mixing tank (10.5-ft diameter), mill classifier, and a storage silo for the sorbent.

Much of the equipment needed for an SDA system would be large items that occupy a substantial footprint. As can be seen in Figure 1, very little unused space exists at the facility. No space exists for an enclosed spray tower, and therefore a tower would need to be sited outdoors. No space exists between the combined boiler ducts and the fabric filter (as seen in Figure 1) to insert a spray tower. Because all of these duct runs are located

⁷ Alaska Industrial Development and Export Authority. 1999. Spray Dryer Absorber System Performance Test Report, Healy Clean Coal Project. Healy, AK.

outdoors, maintaining the flue gas temperatures needed for the reaction and preventing moisture in the fabric filter will be expensive and difficult. Finally, as can be visualized by looking at Figure 1, the site does not have enough unused area to accommodate a dry material receiving operation and slurry preparation area. There is a likelihood that material receiving would have to occur on the north side of the Chena River. This would necessitate another river crossing which adds another layer of complexity to the process. Ultimately, the spatial considerations for the equipment would require a building to house the technology and heat to maintain the temperatures needed for the application. The parasitic load from electrical consumption and heating for the application would be substantial; at the least greater than 2.5% of current net generation.

1.3 DRY SORBENT INJECTION

In the utility industry, SO₂ may be removed by injecting a dry sorbent (limestone, Trona, or sodium bicarbonate are the common sorbents) into the combustion gases, typically above the burners or in the backpass before or after the air heater. Furnace DSI involves injection of the sorbent into the boiler system at a location downstream of the combustion zone through special injection ports. In DSI, the sorbent contacts the hot gas, decomposes, and reacts in suspension with SO₂ to form reaction products, such as calcium sulfate (CaSO₄), when using lime or limestone, or sodium sulfate (Na₂SO₄) when using Trona (sodium sesquicarbonate) or sodium bicarbonate. The reaction products, unreacted sorbent, and fly ash are removed at the PM control device (either an ESP or fabric filter) downstream from the boiler.

DSI has historically been used for reducing concentrations of hydrochloric acid (HCl), mercury, and sulfates (SO₃) from coal-fired boiler flue gas. Recently, DSI has seen greater use primarily as a system to comply with the Maximum Achievable Control Technology (MACT) requirements for boilers, aka, Boiler MACT. As operators began using DSI for HCl control in response to Boiler MACT, incidental removal of SO₂ was also being observed. SO₂ removal efficiencies of 30% to 70% have been reported for DSI in the utility industry when sorbent is injected and mixed at optimum conditions, and higher removals have been demonstrated in test/pilot operations. However these performance levels have yet to be widely demonstrated on a long-term continuous basis at permanent installations. For comparison, the Consent Decree between GVEA and the US EPA and the subsequent Minor Permit issued by the ADEC specified a 30-day SO₂ emission rate of no greater than 0.30 lb/MMBtu commencing

September 30, 2015 or 18 months after Healy Unit 2 first fired coal.⁸ This emission rate represents a 23% reduction of average uncontrolled SO₂ emissions through the use of a DSI system.

In practice, the reaction chemistry of a DSI system is very straight forward. As a result, some level of SO_2 removal should be obtained when conditions exist that allow the reaction to take place. The performance of a DSI system for SO_2 removal is a function of several factors:

- Sorbent type
- Flue gas temperature at the injection location
- Sorbent particle size
- Sorbent injection rate, or Normalized Stoichiometric Ratio (NSR)
 - Extent of sorbent-to-gas mixing
 - Reaction residence time prior to the PM collection device
- PM control device type
- Flue gas properties
 - \circ Concentrations of other acid gases competing with SO₂ reaction chemistry
 - Flow distribution and moisture content

Discussion of some of the more important aspects of DSI system performance is provided in the following paragraphs.

1.3.1 Sorbent Type

It is generally accepted that sodium-based sorbents (Trona and sodium bicarbonate) produce higher SO₂ removal rates than calcium-based sorbents (lime or limestone). This observation has been borne out by the operations at the Healy, AK coal-fired boiler facility. When first implemented, the DSI system at the Healy facility was based on limestone injection. After a period of operation, the limestone-based DSI system was replaced with a Trona-based system to improve performance. The Trona-based system was subsequently replaced with a sodium bicarbonate DSI system to further improve performance. As was the case at Healy, coal-fired boiler installations seem to be moving to use of the sodium sorbents to achieve SO₂ removal efficiencies of at least 40%. Therefore, no additional discussion of calcium sorbents is provided herein.

⁸ Ibid (Technical Analysis Report).

1.3.2 Flue Gas Temperature at the Injection Location

Flue gas temperature will have a direct effect on reaction kinetics. A higher efficiency can be achieved when DSI is injected at a location where the flue gas temperature is approximately 500° F, and removal becomes less as the injection location is cooler or hotter. When a sorbent particle is introduced into a hot flue gas, it decomposes to sodium carbonate and the surface area of the particle increases. As reported in a recent Technical Report, the particle surface area begins to increase at 300° F (the minimum recommended sorbent injection temperature) and peaks at 500° F (the "optimum" temperature).⁹ Above 500° F the particle structure begins to change and particle sintering may begin, effectively decreasing the activity of the particle. As the particle surface areas increases, a greater portion of the sorbent material is available to participate in the reaction with SO₂, thus producing an increased removal rate.

1.3.3 Sorbent Particle Size

Sorbent consumption and acid gas removal rates have been improved over the past several years with the understanding of the importance of uniform sorbent particle size and high sorbent surface areas. To effect these improvements, most DSI systems now employ in-line milling equipment for all sodium sorbents.

1.3.4 Sorbent Injection Rate (or NSR)

The NSR reflects the sorbent utilization rate, or the efficiency by which the injected sorbent is utilized in the SO₂ removal reaction. All else being equal, the SO₂ removal rate increases (up to an upper limit) as the NSR is increased. In addition to the particle size factor discussed above, sorbent-to-gas mixing and residence time prior to entering the PM control device will influence the NSR needed to achieve a desired removal rate. Poor mixing conditions and low residence (i.e., reaction) times will produce the situation where a greater NSR is needed to achieve the same level of performance as observed in a well-mixed, adequately timed duct system. A DSI cost model defines its typical NSR for milled Trona with an ESP as

⁹ Dr. Sahu, Ranajit, Technical Report on Dry Sorbent Injection (DSI) and Its Applicability to TVA's Shawnee Fossil Plant, Commissioned by the Southern Alliance for Clean Energy, Knoxville, TN, April 2013.

1.40 (target removal is 50%), and its typical NSR for milled Trona with a fabric filter as 1.55 (target removal is 70%).¹⁰ These NSR represent sorbent injection rates of 40% and 55% above the stoichiometric amount of Trona needed for the SO₂ reaction. When other than optimum conditions exist for DSI use (such as poor mixing or inadequate residence time), the NSR must be increased to account for less than optimum sorbent utilization. The actual performance of a DSI system can vary from 0% to 90% depending on the NSR and other operating characteristics.¹¹

A separate operating issue has been observed when DSI systems operate with a high NSR. As the NSR increases, a brown nitrogen oxide (NOx) plume begins to be generated and emitted from the stack. This situation produces an undesirable environmental impact of using a DSI system.

1.3.5 PM Control Device Type

One of the more influential DSI system parameters is the PM collection system. This influence is important because the sorbent remains available to participate in the SO_2 reaction while in the ESP or fabric filter used to collect the PM in the flue gas. A system that employs a fabric filter will inherently achieve a greater SO_2 removal rate than one that employs an ESP because a dust cake that builds on the surface of the filter bags provides additional surface area upon which the SO_2 can react. Although studies on the effect of bag cleaning mechanisms could not be found, a pulse air jet bag cleaning system would appear to produce a lesser (secondary) SO_2 removal rate than a shaker system due to the fact that the pulse air system is designed to periodically completely break the dust cake from the cloth, as opposed a shaker cleaning system in which some remnant dust particles would remain on the surface and in the weave of the cloth after cleaning.

 ¹⁰ Sargent & Lundy, IPM Model – Updates to Cost and Performance for APC Technologies, Dry Sorbent Injection for SO₂ Control Cost Development Methodology (Final report), prepared for Systems Research and Applications Corporation, March 2013.
 ¹¹ Ibid (Sargent & Lundy).

1.3.6 Flue Gas Properties

The ability of DSI system to achieve any reasonable degree of SO_2 control is highly influenced by the presence of other constituents in the gas stream that will compete with the sodium injected into the gas. In the case of coal-fired boiler flue gases, the primary competing constituent is chlorine. Chlorine present in the coal will form HCl in the flue gas and consume a portion of the injected sorbent. Careful consideration of the chlorine content of the coal, therefore, is needed when sizing the system and defining the NSR.

Distribution of flow with the flue gas duct work is important for at least two reasons: 1) the distribution influences in-duct mixing, and 2) flow distribution may contribute to sorbent deposition within the duct or impaction and plating upon the walls. Many DSI equipment vendors offer Computational Fluid Dynamic (CFD) modeling of plant duct flows to predict and enhance sorbent distribution in flue gas, thereby maximizing performance and minimizing sorbent usage.

1.3.7 Site-specific Considerations for Using DSI at Chena

Two aspects of boiler operation at Chena are good for considering a DSI system: 1) the facility uses a fabric filter for PM control, which improves DSI performance by allowing for continued contact between SO₂ and sorbent, and 2) the flue gas temperature entering the fabric filter is approximately 300° F, which is near the minimum recommended temperature at the sorbent inject location. Some aspects of the Chena operation and site, however, are less than optimum for retrofitting a DSI system, and some of these aspects (i.e., constraints) are discussed below.

Stoker Design — Many of the initial DSI systems were demonstrated on fluidized bed combustion units and employed sorbent injection into the boiler combustion zone. Unlike a fluidized bed combustor, the old traveling grate stokers used at Chena are not designed for suspension burning. Sorbent injected into the combustion zone in a stoker unit would settle onto the stoker coal bed and become unavailable for reaction. This would result in dead burning of the sorbent. For this reason, sorbent injection would need to occur outside of the combustion zone in downstream duct locations that are cooler than in the combustion zone. As noted above, however, adequate temperature exists in other duct locations to allow DSI use at Chena.

Alternative DSI System Orientations – Three basic DSI system orientations exist at Chena. Sorbent could either be injected into duct work for each individual boiler (four injection locations), a single injection location where all four duct systems converge just prior to entering the fabric filter, or at two locations – one for the large boiler and one for the three combined small boilers. The simplest of these options would be a single injection point. This option could, however, impact sorbent utilization (see NSR discussion below). Regardless of the selected orientation, a DSI system could be provided that employs a single sorbent receiving and storage area and associated conveying system with or without splitters to convey sorbent to more than one injection location. Assuming that the sorbent is milled in-line, immediately prior to injection, at least two sorbent mills would be needed for each injection location (one mill for use and one redundant mill). Therefore, between two and eight sorbent mills (depending on the number of injection points and ease of moving redundant equipment between injection points when needed) would be required depending on the DSI system orientation.

Factors Influencing NSR – The congested site layout will potentially adversely impact the amount of sorbent needed (i.e., NSR) to achieve reasonable reductions using DSI. Figure 1 previously showed the arrangement of flue gas duct work for Boiler 1, 2, and 3. Although not visible in Figure 1, these three duct systems combine with the flue gas duct work for Boiler 5 just prior to entering the fabric filter. If a single sorbent injection location is specified, this location would provide a short mixing zone with a low residence time prior to the fabric filter. Approximately 10 ft of duct is available between the location where the flue gas ducts converge and the combined gas enters the fabric filter. Gas velocities between 55 ft per second (ft/s) and 75 ft/s exist at this location, indicating that the sorbent and flue gas would be afforded only between 0.1 and 0.2 seconds of mixing/residence time prior to entering the fabric filter housing. The GVEA Healy plant's Unit #1 (305 MMBtu/hr boiler) has a 100-ft run prior to the baghouse from the injection point. Assuming GVEA maintains similar duct velocity as Chena, the GVEA DSI system operates with a reaction time of 1 or 2 seconds of mixing prior to entering the fabric filter housing. The mixing zone and residence time at the Chena plant would be very short (10 times less) in comparison and will potentially require additional sorbent be injected to achieve any sort of SO₂ removal. This will, in turn, reduce the cost effectiveness of a DSI system (i.e., increase the operating cost and reduce the removal rate).

Sorbent injection into individual boiler duct will eliminate the short mixing zone and residence time, but this equipment orientation may also

adversely impact NSR. The flue gas from each boiler goes through several turns (up to seven) prior to entering the fabric filter housing. While this duct orientation yields good mixing, it may also promote particle deposition and plating on to the inside of the duct work, thereby causing some of the injected sorbent to be wasted and unavailable for reaction.

Existing PM Collection and Storage Equipment – Similar to the issues introduced when discussing SDA, additional PM load to the fabric filter and silo would necessitate an increase in electricity consumption and operational maintenance.

Also, potential changes to the constituent loading and leaching characteristics of the ash due to sorbent use could render the ash unsuitable for beneficial use fill material. Aurora currently provides its collected ash to developers in the area for beneficial use as a fill material. The incorporation of sorbent to the ash could alter the properties of the ash such that it no longer meets the metric used to evaluate its benefit. If the ash from the Chena plant were to be treated as a waste product, significant disposal costs would be realized through either coal ash landfill development or tipping fees at the municipal solid waste landfill.

Facility Space Limitations – A DSI system is rather simple and requires lesser space for equipment than does a SDA system. Eielson Air Force Base (EAFB) recently installed new 120,000 lb/hr steam boilers which were designed with DSI to mitigate sulfate emissions. EAFB uses sodium bicarbonate as the sorbent, which they receive via rail from Solvay Chemical in Wyoming. The system includes two silos with storage capacity of 518 tons each for the sorbent. Each silo is 37 ft tall with a diameter of 21 ft and a 70 inch cone. The silos each hold a volume of 16,777 ft³. EAFB's current rate of sorbent utilization is 1 lb of sorbent/1,600 lb of steam. At that rate, Aurora could expect a maximum use of 220 lb of sorbent/hr (350,000 lb steam/hr). The location of the injection point is at the outlet breaching of the boiler and the temperature of the flue gas at that point is 450°F. As previously discussed, 500°F at the injection point is optimal. While the silos do not occupy an extremely large area, the only available area on the Chena site would be in the northwest corner of the property. An adequate space exists in the northwest portion of the Chena site, but space for truck traffic to deliver the sorbent is extremely limited and may prevent actual truck movement in this area of the facility. Sorbent receiving would likely be sited north of the Chena River along with the coal receiving facilities. Sorbent would have to be received by rail or truck and conveyed across the river to storage silos on the south side of the river.

1.4 REVIEW OF SO₂ BACT DATABASE

The RACT/BACT/LAER (RBLC) Clearinghouse was searched again for this addendum (an original search was conducted and reported in the original BACT report) to identify similar sources with SO₂ BACT determinations within the past 10 years. The RBLC Clearinghouse lists 23 facilities with large (i.e., greater than 250 MMBtu/hr) coal-fired boilers with SO_2 BACT determinations and two facilities with small (i.e., less than 100 MMBtu/hr) coal-fired boilers with SO₂ BACT determinations. Table 1 summarizes the projects in the database search that are pertinent to the Chena Power Plant BACT Analysis. One additional facility is included, the Healy Power Plant, but was not identified in the RBLC search. When looking at reported performance at existing operations, one must acknowledge that the level of control claimed at existing facilities using SDA and DSI or as reported in the Clearinghouse database may not have actually been demonstrated by the facility and may not be achievable at the Chena facility. Additionally, other systems may have been installed that are not yet included in the RBLC Clearinghouse.

Ten of the 23 determinations for large boilers were for SDA and/or DSI systems, and the range of control reported for these determinations was:

- SDA: 0.06 to 0.10 lb/MMBtu (five facilities)
- DSI: 0.035 to 0.3 lb/MMBtu (four facilities)
- Combination SDA/DSI: 0.055 to 0.075 lb/MMBtu (three facilities)

Table 1. Sur	nmary of SO ₂	BACT Permi	Reviews
--------------	--------------------------	------------	---------

		Facility Name		Process Name										
Search Criteria	Facility ID		Permit Issuance		Combustion Practices	Low Sulfur Coal	Wet FGD	Limestone Forced Oxidation	Dry FGD	FGD - Scrubber	Dry FGD - Spray Dry Adsorber	Limestone Injection ⁽¹⁾	Circulating Dry Scrubber	
Permit Date = 1/1/2007 to 10/24/2017	AR-0094	John W. Turk Power Plant	11/5/2008	6,000 MMBtu/hr PRB sub-bituminous pulverized coal (PC) boiler							X			0.08 lb/MM
Process = coal-fired,														weight sulfu (PSD and Ca
>250 MMBtu/hr	AZ-0055	Navajo Generating Station	2/6/2012	3, 7,725 MMBtu/hr PC boilers						X				
Pollutant	CA-1206	Stockton Cogen Company	9/16/2011	730 MMBtu/hr coal-fired circulating fluidized bed (CFB) boiler								X		70% remova
Name = SO_2	IA-0091	Ottumwa Generating Station	2/27/2007	6,370 MMBtu/hr coal-fired Boiler #1		x								1.2 lb/MMB
	KY-0100	J.K. Smith Generating Station	4/9/2010	3,000 MMBtu/hr CFB boilers CFB1 and CFB2							x	x		0.075 lb/MM (Based on PF SO ₂ /MMBtu
	MI-0389	Karn Weadock Generating Complex	12/29/2009	8,190 MMBtu/hr PRB coal or 50/50 blend PC boiler		x		x						Permit termi 0.06 lb/MMI
	MI-0399	Detroit EdisonMonroe	12/21/2010	7,624 MMBtu/hr coal-fired Boiler Units 1, 2, 3 and 4			x							0.107 lb/MN
	MI-0400	Wolverine Power	6/29/2011	2, 3,030 MMBtu/hr, petcoke/coal-fired CFB Boilers (CFB1 & CFB2)							x			0.06 lb/MMI shutdown
	MO-0077	Norborne Power Plant	2/22/2008	(Excluding Startup & Shutdown) Supercritical PC boiler with steam turbine generator with a nominal net electric output of 689 MW					X					
	ND-0024	Spiritwood Station	9/14/2007	1,280 MMBtu/hr lignite coal-fired atmospheric CFB boiler							x	x		0.06 lb/MMI 98.7% remov 98.8% remov

Emission Limit
Btu, 30-day average
MBtu when burning coal <= 0.45% by r content.
se-by-Case MACT permit decision.)
· · · · · · · · · · · · · · · · · · ·
l (3-hr average)
tu, 3-hr rolling average
jected at \$29,797/ton (2007 dollar basis).) ⁄IBtu, 30-day average
RB coal - 0.54% S; bituminous coal - 1.58% S; and 1.4 lb 1 at wet FGD inlet.)
inated due to legal challenge.
Btu, 30-day rolling average
1Btu each, 24-hr rolling average
Btu, 30-day rolling average; excluding startup &
Btu, 30-day rolling average;
val for worst case 30-day lignite; val for worst case 24-br lignite

Table 1. Summary of SO2 BACT Permit Reviews (continued)

				it Process nce Name	Control Method Description									
Search Criteria	Facility ID	Facility Name	Permit Issuance		Combustion Practices	ow Sulfur Coal	Vet FGD	imestone Forced Dxidation	Dry FGD	GD - Scrubber	Dry FGD - Spray Dry Adsorber	imestone njection ⁽¹⁾	Circulating Dry Scrubber	
	OH-0310	American Municipal Power Generating Station	10/8/2009	2, 5,191 MMBtu/hr, PC boilers			x		<u> </u>	H				0.15 lb/MM 0.184 lb/MM 0.2400 lb/M
	OH-0314	Smart Papers Holdings, LLC	1/31/2008	420 MMBtu/hr coal-fired pulverized dry bottom boiler and 249 MMBtu/hr coal-fired spreader stoker coal-fired boiler										1.7 lb/MMB
	OK-0118	Hugo Generating Station	2/9/2007	750 MW coal-fired steam EGU boiler (HU-Unit 2)			Х							0.065 lb/MN
	PA-0257	Sunnyside Ethanol, LLC	5/7/2007	496.8 MMBtu/hr coal-fired CFB boiler					Х			Х		0.2 lb/MMB
	TX-0554	Coleto Creek Unit 2	5/3/2010	6,670 MMBtu/hr PRB coal-fired Boiler Unit 2							Х			0.06 lb/MM
	TX-0577	White Stallion Energy Center	12/16/2010	3,300 MMBtu/hr coal & pet coke-fired CFB Boiler							x			0.114 lb/MN 0.086 lb/MN 0.063 lb/MN
	TX-0585	Tenaska Trailblazer Energy Center	12/30/2010	8,307 MMBtu/hr sub-bituminous coal-fired boiler			X							0.06 lb/MM
	TX-0593	Texas Clean Energy Project	12/28/2010	400 MW PRB coal-fired Integrated Gasification Combined Cycle power plant	x									10 ppm sulft
	TX-0601	Gibbons Creek Steam Electric Station	10/28/2011	5,060 MMBtu/hr coal-fired boiler			X							1.2 lb/MMB
	UT-0070	Bonanza Power Plant Waste Coal Fired Unit	8/30/2007	2, 1,445 MMBtu/hr waste coal/bituminous blend-fired CFB boiler							x	X		0.055 lb/MN
	VA-0311	Virginia City Hybrid Energy Center	6/30/2008	2, 3,132 MMBtu/hr coal and coal refuse-fired CFB boilers (Sulfur content of coal/coal refuse to CFB boilers not to exceed 2.28% as-fired and 1.5% on annual basis)								x		0.035 lb/MN 0.029 lb/MN 0.022 lb/MN
	WY-0063	Wygen 3	2/5/2007	1,300 MMBtu/hr sub-bituminous coal-fired PC boiler					Х					0.09 lb/MM
	WY-0064	Dry Fork Station	10/15/2007	Coal-fired PC Boiler (ES1-01)									X	0.07 lb/MM

Emission Limit
Btu, 30-day rolling average;
/Btu, 24-hr rolling average;
MBtu, 3-hr average
nit mod 10/09 to add Case-by-Case MACT for Boilers
tu
/Btu, 30-day rolling average
tu, 30-day rolling average
Btu, 30-day rolling average
/Btu pet coke, 30-day rolling average;
/Btu, pet coke 12-mo rolling average;
/Btu coal, 30-day and 12-mo rolling average
Btu, 30-day rolling average
ur in syngas
tu
ABtu, 30-day rolling average
/Btu, 3-hr average;
/Btu, 24-hr average;
/Btu, 30-day rolling average
Btu, 12-mo rolling average
Btu, 12-mo rolling average

Table 1. Summary of SO₂ BACT Permit Reviews (continued)

					Control Method Description					n			
Search Criteria	Facility ID	Facility Name	Permit Issuance	Process Name	Combustion Practices	Low Sulfur Coal	Wet FGD	Limestone Forced Oxidation	Dry FGD FGD - Scrubber	Dry FGD - Spray Drv Adsorber	Limestone Injection ⁽¹⁾	Circulating Dry Scrubber	
	N/A (not in RBLC)	Golden Valley Electric Association – Healy Power Plant (HPP)	11/19/2012 Consent Decree and 4/14/2014	2, existing PC-fired steam generators: a 25 MW Foster-Wheeler Boiler (Unit #1) and a 50 MW TRW Entrained Combustion System PC-fired steam generator (Unit #2).							x		Unit #1 (DSI - Improve e after Unit #2 - After 1/1/ rolling avera
			Minor Permit							X			Unit #2 (SD. - SO ₂ emissi
Permit Date = 1/1/2007 to 10/24/2017 Process = coal-fired, <100 MMBtu/hr	OH-0315	New Steel International Inc., Haverhill	5/6/2008	6, 60 MMBtu/hr waste heat, PC boilers						x			0.1760 lb/M The facility i NOx, SO ₂ , ar furnaces was PM ₁₀ was us used for all I instead.
Pollutant Name = SO ₂	VA-0309	Georgia Pacific Wood Products - Jarratt	5/15/2008	86.6 MMBtu/hr coal-fired Keeler Boiler	x	Х							

1. Limestone Injection presumed to be equivalent to DSI.

Emission Limit

[system):

xisting DSI system no later than 9/30/2015 or 18 months 2 first fires coal after 11/19/2012 whichever is later. 2016, SO₂ emission limit of 0.30 lb/MMBtu, 30-day age A system):

ion limit of 0.10 lb/MMBtu, 30-day rolling average

/MBtu as a rolling 3-hour average

is non-attainment for $PM_{2.5}$ and PSD for PM, PM_{10} , CO, nd VOC. A production rate restriction on the electric arc as requested to keel lead below PSD and Title V thresholds. sed as the limit in the permit. However, since $PM_{2.5}$ was LAER determinations the limits were entered under PM_{2.5}

It should be noted that SDA or DSI were required only on circulating fluidized bed (CFB) or pulverized coal (PC) boilers. In contrast, the Chena boilers are stoker boilers for which the boiler operation is quite different than a CFB or PC boiler and present unique retrofit challenges. In addition, the sizes of these units range from approximately 2 to 25 times larger than the large Chena boiler.

One small boiler was identified with an SDA system required to meet 0.1760 lb $SO_2/MMBtu$.

1.5 SUMMARY OF TECHNICAL FEASIBILITY

Regardless of the achievable level of control afforded by a dry scrubbing system, this control technology (SDA and DSI) is considered technically feasible for controlling SO₂ emissions from coal fired boilers, and the RBLC identifies several in use on larger coal-fired boilers. A detailed evaluation of constraints posed by site-specific factors, however, is needed before either specific technology can be considered feasible for use at the Chena facility. These detailed site-specific evaluations/design factors are beyond the scope of the current BACT analysis.

In the absence of a detailed control system design for Chena, a level of 0.10 lb SO₂/MMBtu was selected for SDA for the BACT analysis, which is comparable with that required for the Healy Unit #2. This represents a 74% reduction from Aurora's actual SO₂emission rate of 0.39 lb/MMBtu. Independent discussions with SDA equipment vendors, however, indicate that vendors do not like to select design removal rates above 0.12 lb/MMBtu (equivalent to 70% removal). The Healy performance requirement is considered most relevant to Chena because the boilers at Healy are of similar size to Chena's and the coal feed is the same.

Selection of an appropriate design basis for a DSI system for Chena is much less straight forward. One primary reason is that DSI systems reported in the RBLC Clearinghouse are for lime injection into fluidized bed combustors, which are very different that the Chena stokers. A DSI system performance level of 0.30 lb SO₂/MMBtu has been specified for the Healy DSI system, representing a 23% reduction from average uncontrolled SO₂ emissions. Interestingly, the Technical Analysis Report (TAR) for Healy Permit AQ0173MSS0, which requires the facility to "improve" the DSI system performance currently on Healy Unit No. 1, specifies the improved emission rate of 0.30 lb SO₂/MMBtu. This statement in the TAR, therefore, suggests that the original Healy DSI system was achieving less than 23% reduction of SO₂. Literature, however, commonly reports a lower end of DSI system performance at 40%, and discussions with vendors indicate that this level of removal (without knowing the exact coal used) is generally achievable using DSI. Because of discrepancies in reported DSI system performance, therefore, one could easily define DSI system performance when using Usibelli coal as less than 23% removal. For the current assessment, DSI system performance was selected to be between 0.23 and 0.30 lb SO₂/MMBtu (i.e., between 23% and 40% removal).

2 ECONOMIC EVALUATION OF SO₂ CONTROL OPTIONS

Despite the technical challenges described in Section 1 associated with installation of SDA or DSI at the Chena Power Plant, an economic evaluation was prepared for each technology under the assumption that these challenges could possibly be mitigated during a detailed design.

2.1 SDA ECONOMIC EVALUATION

Capital and operating costs associated with the installation of a SDA system are based on cost estimating procedures developed by U.S. EPA in the Coal Utility Environmental Cost (CUECost) tool. The CUECost tool is an Excel workbook (an interrelated set of spreadsheets) that produces rough-order-of-magnitude (ROM) cost estimates (+/-30% accuracy) of the installed capital and annualized operating costs for air pollution control systems installed on coal-fired power plants, including those to control emissions of SO₂. The SO₂ emission control technologies currently in the workbook include: limestone FGD system with forced oxidation (i.e., wet scrubber) and lime spray drying FGD system (i.e., dry scrubber).

The wet scrubber portion of the CUECost tool was used in the original BACT Analysis. The spray drying portion of the tool was used for this addendum and was used for two scenarios – control of the combined boiler exhaust and control of the large boiler exhaust only. The CUECost tool included the following site-specific information:

- Net Plant Heat Rate (Btu/kWhr) = 11,571
- Retrofit Factor = 2.0 (difficult)
- Coal ultimate and proximate analysis data and ash analysis data obtained from http://www.usibelli.com/Coal-data.php
- Site specific SO₂ emission rate
 - Combined exhaust = 0.39 lb SO₂/MMBtu
 - Large boiler only = $0.32 \text{ lb } SO_2/MMBtu$
- Reagent price is \$215/ton delivered
- Cost basis = 2015
- SO₂ removal required = 74 percent
- Annual SO₂ removed based on full load at 8,760 hr/year

All other values used were default values.

No attempt was made to incorporate location-specific cost adjustment factors into the CUECost tool.

The cost-effectiveness of the SO₂ control system is calculated in the CUECost tool by dividing the total annual cost by the annual (potential) tons of pollutant removed. Costs were corrected to 2015 dollars using the Chemical Engineering Composite Price Index. Table 2 presents a summary of the CUECost inputs and calculation summary for the lime spray dryer scrubber.

Table 5 presents the cost effectiveness of the SDA technology (as well as the DSI technology discussed in the next section).

2.2 DSI ECONOMIC EVALUATION

Capital and operating costs associated with the installation of a DSI system are based on a DSI cost model developed by Sargent & Lundy and referred to as the IPM Model.¹² In developing the IPM Model, the authors reviewed cost data for several DSI systems and developed a relationship for the capital costs based on the sorbent feed rate. The Total Project Cost output by the IPM Model includes the base installed cost, the fixed operating and maintenance (O&M) cost, and the variable O&M cost. The base installed cost includes:

- All equipment
- Installation
- Buildings
- Foundations
- Electrical
- Retrofit difficulty factor
- Engineering and construction management

The Model uses 2012 pricing. Escalation is not included in the estimate.

¹² Ibid (Sargent & Lundy).

	CUECost		
Coal Ut	ility Environmental Cost		
Version 1, November 25, 1998 (revised 2-9-00	as CUECost3.xls)		
APC Technology Choices			
Description	Units	Combined Exhaust	Large Boiler only
FGD Process	Integer	2	2
(1 = LSFO, 2 = LSD)			
Particulate Control	Integer	1	1
(1 = Fabric Filter, 2 = ESP)			
INPUTS			
Description	Units	Combined Exhaust	Large Boiler only
Description	Cinto	Combine a Exhilust	Large Doner only
General Plant Technical Inputs			
Location - State	Abbrev.	AK	AK
MW Equivalent of Flue Gas to Control System	MW	142.4	74.6
Net Plant Heat Rate	Btu/kWhr	11,571	11,571
Plant Capacity Factor	%	65%	65%
Total Air Downstream of Economizer	%	120%	120%
Air Heater Leakage	%	12%	12%
Air Heater Outlet Gas Temperature	°F	350	350
Inlet Air Temperature	°F	80	80
Ambient Absolute Pressure	In. of Hg	29.4	29.4
Pressure After Air Heater	In. of H2O	-12	-12
Moisture in Air	lb/lb dry air	0.013	0.013
Ash Split:	0/	40.9/	40.9/
Fly Ash Bottom Ash	70	40%	40%
Seismic Zone	/0 Integer	1	1
Retrofit Factor	Integer	2	2
(1.0 = new, 1.3 = medium, 1.6 = difficult)	Integer	_	_
Select Coal	Integer	8	8
Is Selected Coal a Powder River Basin Coal?	Yes / No	No	No
Economic Inputs			
Cost Basis -Year Dollars	Year	2015	2015
Sevice Life (levelization period)	Years	10	10
Inflation Rate	%	3%	3%
After Tax Discount Rate (current \$'s)	%	9%	9%
AFDC Rate (current \$'s)	%	11%	11%
First-year Carrying Charge (current \$'s)	%	22%	22%
Levelized Carrying Charge (current \$'s)	%	17%	17%
First-year Carrying Charge (constant \$'s)	%	16%	16%
Levelized Carrying Charge (constant \$'s)	%	12%	12%
Sales Tax	%	6%	6%
Escalation Rates:	0/	2.0/	2.0/
Consumations (Octivi)	70	3%	3%
Le Chem Eng Cost Index available?	Vos / No	Vac	Voc
If "Yes" input cost basis CF Plant Index	Integer	578.4	578.4
If "No" input escalation rate	%	3%	3%
Construction Labor Rate	\$/hr	\$60	\$60
Prime Contractor's Markup	*/ %	3%	3%
Operating Labor Rate	\$/hr	\$63	\$63
Power Cost	Mills/kWh	25	25
Steam Cost	\$/1000 lbs	3.5	3.5

Table 2. CUECost Input and Calculation Summary for SDA

Note: 'MW Equivalent of Flue Gas to Control System' is heat input capacity converted to MW.

Lime Snrau Dryer (LSD) Inputs			
SO2 Removal Required (removal required to reach 0.1 lb/MMBtu)	%	74%	69%
Adiabatic Saturation Temperature	°F	127	127
Flue Gas Approach to Saturation	°F	20	20
Sprav Drver Outlet Temperature	°F	147	147
Reagent Feed Ratio	Factor	0.76	0.70
(Mole CaO / Mole Inlet SO2)			
Recvcle Rate	Factor	30	30
(lb recvcle / lb lime feed)			
Recvcle Slurry Solids Concentration	Wt. %	35%	35%
Number of Absorbers	Integer	1	1
(Max. Capacity = 300 MW per spray dryer)			
Absorber Material	Integer	1	1
(1 = alloy, 2 = RLCS)			
Spray Dryer Pressure Drop	in. H2O	5	5
Reagent Bulk Storage	Days	60	60
Reagent Cost (delivered)	\$/ton	\$215	\$215
Dry Waste Disposal Cost	\$/ton	\$30	\$30
Maintenance Factors by Area (% of Installed Cost)			
Reagent Feed	%	5%	5%
SO2 Removal	%	5%	5%
Flue Gas Handling	%	5%	5%
Waste / Byproduct	%	5%	5%
Support Equipment	%	5%	5%
Contingency by Area (% of Installed Cost)			
Reagent Feed	%	20%	20%
SO2 Removal	%	20%	20%
Flue Gas Handling	%	20%	20%
Waste / Byproduct	%	20%	20%
Support Equipment	%	20%	20%
General Facilities by Area (% of Installed Cost)			
Reagent Feed	%	10%	10%
SO2 Removal	%	10%	10%
Flue Gas Handling	%	10%	10%
Waste / Byproduct	%	10%	10%
Support Equipment	%	10%	10%
Engineering Fees by Area (% of Installed Cost)			
Reagent Feed	%	10%	10%
SO2 Removal	%	10%	10%
Flue Gas Handling	%	10%	10%
Waste / Byproduct	%	10%	10%
Support Equipment	%	10%	10%

SUMMARY OF COSTS			
Description	Units	Combined Exhaust	Large Boiler only
ADC To do a la sina			
APC Technologies		LCD	LCD
SO2 Control		LSD	LSD
		Combined Exhaust	Large Poiler only
602 Control Cooto			
SU2 Control Costs	ŕ	LSD	LSD
Total Capital Requirement (TCR)	\$ (* /1 147	\$74,161,357	\$62,173,057
Eirst Voor Cooke	Φ/ Κνν	\$321	\$000
First Tear Costs	¢	¢2 700 419	¢0.7(7.089
Fixeu OBM	⊅ ¢ /1.747 √	\$5,709,418	\$2,707,900 27.10
	φ/ KVV-11 Mille / LW/H	20.05	6.52
	\$ /top SO2 removed	4.57	\$17.351.0
Variable O&M	\$	\$415.100	\$203.435
Vurnuble 001vi	φ \$/LW-Vr	2 92	2 73
	Mills/kWH	0.51	0.48
	\$/ton SO2 removed	\$1 039 5	\$1 275 2
Fixed Charges	\$	\$16 537 983	\$13,864,592
Tixeu Chingeo	\$/kW-Yr	116.14	185.85
	Mills/kWH	20.40	32.64
	\$/ton SO2 removed	\$41,415,5	\$86,909,6
TOTAL	\$	\$20.662.501	\$16.836.015
	\$/kW-Yr	145.10	225.68
	Mills/kWH	25.48	39.64
	\$/ton SO2 removed	\$51,744	\$105,536
Levelized Current Dollars			
Fixed O&M	\$/kW-Yr	30.11	42.89
	Mills/kWH	5.29	7.53
	\$/ton SO2 removed	\$10,737.6	\$20,056.1
Variable O&M	\$/kW-Yr	3.37	3.15
	Mills/kWH	0.59	0.55
	\$/ton SO2 removed	\$1,201.6	\$1,474.0
Fixed Charges	\$/kW-Yr	88.01	140.85
	Mills/kWH	15.46	24.74
	\$/ton SO2 removed	\$31,386.6	\$65,864.3
TOTAL	\$/kW-Yr	121.49	186.89
	Mills/kWH	21.34	32.82
	\$/ton SO2 removed	\$43,325.8	\$87,394.4
Levelized Constant Dollars			
Fixed O&M	\$/kW-Yr	26.05	37.10
	Mills/kWH	4.57	6.52
	\$/ton SO2 removed	\$9,289.4	\$17,351.0
Variable O&M	\$/kW-Yr	2.92	2.73
	Mills/kWH	0.51	0.48
	\$/ton SO2 removed	\$1,039.5	\$1,275.2
Fixea Charges	\$/kW-Yr	60.93	97.51
	Mills/kWH	15.20	24.32
TOTAL	¢ /1.147 V-	\$30,863.7	\$64,/67.1
IUIAL	۵/ ۲۷۷ - ۲۲ ۱۰ (۱۰۵۸ ۲۲	09.90	21.22
	¢/ton SO2 romayed	£41 102 6	\$83 202 2
	φ/ ton 302 removed	ψ±1,194.0	φ05,595.5

The O&M cost includes:

- Fixed
 - Operating labor for the DSI system (two operators needed)
 - Maintenance materials and labor
 - o Administrative labor
- Variable
 - Sorbent use
 - Waste production and disposable cost
 - o Additional required power

The IPM Model used for this addendum included two equipment orientations: 1) sorbent injection into the combined boiler exhaust just immediately prior to the fabric filter, and 2) sorbent injection into the individual exhaust from the large boiler near the combustion zone. The IPM Model tool included the following site-specific information:

- Gross heat input
 - Combined = 486 MMBtu/hr
 - Large boiler = 255 MMBtu/hr
 - Small boilers = 77 MMBtu/hr each
- Retrofit Factor = 2.0 (difficult)
- Location Adjustment Factor = 2.2 (for Fairbanks, Alaska)
 - The location adjustment factor (LAF) is applied to the base installed cost and reflects the average statistical differences in normal labor, material, and equipment costs for similar facilities built in different geographical locations. The factor also makes allowances for weather, seismic, climatic, normal labor availability, labor productivity, life support/mobilization, and contractor's overhead and profit conditions. The factor does not reflect abnormal differences due to unique site consideration, such as historical preservation.¹³ (The CUECost model has no way to accommodate this factor, and LAF was not applied for SDA.)
- Site specific SO₂ emission rate
 - $\circ~~0.39$ lb/MMBtu (combined)
 - 0.32 lb/MMBtu (large boiler only)
 - o 0.49 lb/MMBtu (each small boiler)

¹³ Programming Cost Estimates for Military Construction, UFC3-370-01, 6 June 2011.

- Cost Basis = 2015
- SO₂ removal required = 40 percent
- Annual SO₂ removed based on full load at 8,760 hr/year
- Minimum Normalized Stoichiometric Ratio (NSR) = 1.5 (to account for less than optimum mixing and residence time in the combined orientation; deposition in the individual orientation; and breaking the filter cake in all orientations.
- Sorbent price based on delivered price paid by Healy in 2015/2016

All other values used were default values.

The cost-effectiveness of the SO₂ control system is calculated in the IPM Model by dividing the total annualized operating cost by the annual (potential) tons of pollutant removed. Costs were corrected to 2015 dollars using the Chemical Engineering Composite Price Index. Table 3 and Table 4 present summaries of the IPM Model inputs and cost effectiveness calculation summaries for the DSI system.

Variable	Designation	Units	Value	Calculation	
Unit Size (Gross)	Ā	(MW)	142.4	< User Input	
Retrofit Factor	В		2	< User Input (An "average" retrofit has a factor of 1.0.)	
Gross Heat Rate	С	(Btu/kWh)	3,415	< User Input	
SO2 Rate	D	(lb/MMBtu)	0.39	< User Input	
Particulate Conture	E		Sub-bituminous Bagbouse	< User Input	
Farticulate Capture	F		Bagnouse		
Milled I rona	G		TRUE	Based on in-line milling equipment	
Removal Target	н	(%)	40	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with a Baghouse = 80% Milled Trona with Baghouse = 90%	
Heat Input	.I	(Btu/hr)	486 000 000	A*C*1000 or User Input	
NSR	ĸ	(8(0)11)	1.50	 to account for less than optimum mixing and residence time in the combined orientation and breaking the filter cake in all orientations) 	
Trona Feed Rate	М	(ton/hr)	0.34	(1.2011x10^06)*K*A*C*D	
Sorbent Waste Rate	N	(ton/hr)	0.246	(0.7387-0.0007696'H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3. Waste product adjusted for a maximum of 5% inert in the Trona sorbent.	
Fly Ash Waste Rate Include in VOM?	Ρ	(ton/hr)	0.90	$\label{eq:constraint} \begin{array}{l} (A^*C)^*Ash incoal^*(1-Boiler Ash Removal)/(2^*HHV) \\ For Biturninous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, \\ HHV = 11,000 \\ For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, \\ HHV = 8,400 \\ For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, \\ HHV = 7,200 \\ \hline \begin{array}{c} \mbox{Usibelli Coal: } Ash in Coal = 0.07; Boiler Ash Removal = 0.6; \\ HHV = 7,560 \\ \end{array} \right.$	
Aux Power Include in VOM?	Q	(%)	0.05	=if Milled Trona M*20/A else M*18/A	
Trona Cost	R	(\$/ton)	451	< User Input (based on delivered price paid by Healy)	
Waste Disposal Cost	S	(\$/ton)	50	< User Input (Disposal cost with fly ash = \$50. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)	
Aux Power Cost	Т	(\$/kWh)	0.09385	< User Input	
Operating Labor Rate	U	(\$/hr)	63	< User Input (Labor cost including all benefits)	
Location Adjusment Factor	LAF		2.2	Factor applied to Base Module Cost - Location Adjusment Factor for Fairbanks, AK from DoD Facilities Pricing Guide/2/2/, UFC 3-701-01, Change 8, July 2015.	
IPM Model - Updates to Cost and Performa Sargent & Lundy LLC for USEPA.	nce for APC Technologies -	Dry Sorbent In	jection for SO2 C	control Cost Development Methodology, March 2013, prepared by	
Capital Cost Calculation (2012 dollars)				Comments	
Includes - Equipment, installation, building, foundations, electrical, and retrofit difficulty					
Base Module (BM) (\$)		=	\$ 26,915.857	Base DSI module includes all equipment from unloading to injection	
Date module (LVm, (v) = = = 20,910,037 base DST include includes all equipment from unicating to injection Unmilled Trona = IF(M>25,(820000*B*M*LAF),(830000*B*LAF*M*0.284) Milled Trona = IF(M>25,(820000*B*M*LAF),(830000*B*LAF*M*0.284) = <td< td=""><td></td></td<>					
Total Project Cost					
A1 = 5% of BM		=	\$ 1,345,793	Engineering and construction management costs	
A2 = 5% of BM		=	\$ 1,345,793	Labor adjustment for 6 x 10 hour shift premium, per diem, etc.	
A3 = 5% of BM		=	\$ 1,345,793	Contractor profit and fees	
CECC (\$) - Excludes Owner's Costs = BM + A1 + A2 + A3		=	\$ 30,953,236	Capital, engineering, and construction costst subtotal	
B1 = 5% of CECC		=	\$ 1,547,662	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)	
TPC (\$) - Includes Owners Costs = CECC + B1		=	\$ 32,500,898	Total project cost without AFUDC	
B2 = 0% of (CECC + B1)		=	0	AFUDC (Zero for less than 1 year engineering and construction cycle)	
TPC (\$) = CECC + B1 + B2		-	\$ 32,500,898	Total project cost	

Table 3. Annualized Cost Summary for DSI for the Combined Boiler Exhaust

Note: 'Unit Size (Gross)' is heat input capacity converted to MW.
Table 3. Annualized Cost Summary for DSI for the Combined BoilerExhaust (continued)

Direct Annual Costs					
Fixed O&M Cost					
FOMO (\$/kW yr) = (2 additional operators)	*(2080)*U/(A*1000)	=	\$	1.84	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.01/(B*A*1000)		=	\$	0.95	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOM	M)	=	\$	0.07	Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOM	A.	=	\$	2.85	Total Fixed O&M costs
Variable O&M Cost					
VOMR (\$/MWh) = M*R/A		=	\$	1.08	Variable O&M costs for Trona reagent
VOMW (\$/MWh) = (N+P)*S/A		=	\$	0.40	Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWh) = Q*T*10		=	\$	0.045	Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + VOM	P	=	\$	1.53	
Indirect Annual Costs					
Overhead (80% of total operation and main	ntenance labor)	=	\$	324,909	
Administrative charges (2% of total capital	investment)	=	\$	650.018	
Insurance (1% of total capital investment)	,	=	\$	325.009	
Property tax (1% of total capital investment	t)	=	\$	325,009	
Capital recovery		=	\$	5,289,521	
(16.275% of total capital investment: 10	yr at 10% interest)				
TOTAL INDIRECT ANNUAL OPERATING	COSTS	=	\$	6,914,466	
TOTAL ANNUALIZED OPERATING COS	TS (2012 \$)	=	\$	9,227,624	
Composite CE Index for 2012 (cost vear of	equation)	=	_	584.6	· · · · · · · · · · · · · · · · · · ·
Composite CE Index for 2015 (cost year of	review)	=		578.4	
TOTAL ANNUALIZED OPERATING COS	TS (2015 \$)	=	\$	9,129,760	
				830	
SO REMOVAL FEEDENCY %	NO, 1011S	=		40	
TOTAL SO ₂ REMOVED, tons		=		332	
SO2 COST-EFFECTIVENESS, \$/ton rem	oved	=	\$	27,493	

/ariable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	74.6	< User Input
Retrofit Factor	В		2	< User Input (An "average" retrofit has a factor of 1.0.)
Gross Heat Rate	C	(Btu/kWh)	3,415	< User Input
SO2 Rate	D	(lb/MMBtu)	0.32	< User Input
Type of Coal	E		sub-bituminous	< User Input
Particulate Capture	F		Baghouse	< User Input
Milled Trona	G		TRUE	Based on in-line milling equipment
Removal Target	н	(%)	40	Maximum Removal Targets: Unmilled Trona with an ESP = 65% Milled Trona with an ESP = 80% Unmilled Trona with a Baghouse = 80% Milled Trona with Baghouse = 90%
Heat Input	J	(Btu/hr)	255,000,000	A*C*1000 or User Input
NSR	К		1.50	1.5 (to account for deposition in the individual orientation)
Trona Feed Rate	М	(ton/hr)	0.147	(1.2011x10^06)*K*A*C*D
Sorbent Waste Rate	Ν	(ton/hr)	0.106	(0.7387-0.00073696'H/K)'M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3. Waste product adjusted for a maximum of 5% inert in the Trona sorbent.
Fly Ash Waste Rate nclude n VOM?	Ρ	(ton/hr)	0.47	(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV) For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000 For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400 For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200 Usibelli Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,560
Aux Power Include in VOM?	Q	(%)	0.04	=if Milled Trona M*20/A else M*18/A
Trona Cost	R	(\$/ton)	451	< User Input (based on delivered price paid by Healy)
Waste Disposal Cost	S	(\$/ton)	50	< User Input (Disposal cost with fly ash = \$50. Without fly ash, the sorbent waste alone will be more difficult to dispose = \$100)
Aux Power Cost	Т	(\$/kWh)	0.09385	< User Input
Operating Labor Rate	U	(\$/hr)	63	< User Input (Labor cost including all benefits)
Location Adjusment Factor	LAF	gies - Dry Sorbe	2.2 ent Injection for SO2	Factor applied to Base Module Cost - Location Adjusment Factor for Fairbanks, AK from DoD Facilities Pricing Guide\2\/2/, UFC 3-701-01, Change 8, July 2015. Control Cost Development Methodology, March 2013, prepared by
Sargent & Lundy LLC for USEPA.				
Capital Cost Calculation (2012 dollar	rs)			Comments
ncludes - Equipment, installation, build	ding, foundations, electrical,	and retrofit diff	culty	
Base Module (BM) (\$)		-	¢ 21 186 505	Base DSI module includes all equipment from unleading to injection
Unmilled Trona = IF(M>25,(745000 Milled Trona = IF(M>25,(820000*B*	*B*M*LAF),(7500000*B*LAF *M*LAF),(8300000*B*LAF*N	= *M^0.284) 1^0.284)	φ 21,100,595	Base DSI module includes all equipment nom unicating to injection
Total Project Cost				
A1 = 5% of BM		=	\$ 1,059,330	Engineering and construction management costs
A2 = 5% of BM		=	\$ 1,059,330	Labor adjustment for 6 x 10 hour shift premium, per diem, etc.
A3 = 5% of BM		=	\$ 1,059,330	Contractor profit and fees
CECC (\$) - Excludes Owner's Costs	= BM + A1 + A2 + A3	_	\$ 24 364 585	Capital engineering and construction costet subtatal
CECC (\$) - Excludes Owner's Costs	= DWI + AT + AZ + A3	-	φ 24,304,365	Capital, engineering, and construction costst subiotal
B1 = 5% of CECC		=	\$ 1,218,229	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = 0	CECC + B1	=	\$ 25,582,814	Total project cost without AFUDC
B2 = 0% of (CECC + B1)		=	0	AFUDC (Zero for less than 1 year engineering and construction cycle)
TPC (\$) = CECC + B1 + B2		=	\$ 25,582,814	Total project cost
S7			,,.,.,.	

Table 4. Annualized Cost Summary for DSI for the Large BoilerExhaust

Note: 'Unit Size (Gross)' is heat input capacity converted to MW.

Direct Annual Costs					
Fixed O&M Cost					
FOMO (\$/kW vr) = (2 additional operational	ators)*(2080)*U/(A*1000)	=	\$	3.51	Fixed Q&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.01/(B*A*1000)		=	\$	1.42	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW vr) = 0.03*(FOMO+0.4*	FOMM)	=	\$	0.12	Fixed O&M additional administrative labor costs
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	,				
FOM (\$/kW yr) = FOMO + FOMM +	FOMA	=	\$	5.06	Total Fixed O&M costs
Variable O&M Cost					
VOMR (\$/MWh) = M*R/A		=	\$	0.889	Variable O&M costs for Trona reagent
VOMM (\$/MMb) = (N+P)*S/A		_	¢	0.30	Variable O&M costs for waste disposal that includes both the sorbent
00000 (\$/100001) = (14+P) 3/A		=	φ	0.39	and the fly ash waste not removed prior to the sorbent injection
VOMP (\$/MWb) - 0*T*10		_	\$	0.037	Variable O&M costs for additional auxiliary power required (Refer to
		-	Ψ	0.037	Aux Power % above)
VOM (\$/MWh) = VOMR + VOMW + V	VOMP	=	\$	1.31	
Indirect Annual Costs					
Overhead (80% of total operation and	I maintenance labor)	=	\$	301,717	
Administrative charges (2% of total ca	ipital investment)	=	\$	511,656	
Insurance (1% of total capital investm	ent)	=	\$	255,828	
Property tax (1% of total capital invest	tment)	=	\$	255,828	
Capital recovery	10	=	\$	4,163,603	
(16.275% of total capital investment	nt: 10 yr at 10% Interest)				
				E 400 C22	
TOTAL INDIRECT ANNUAL OPERA		=	Þ	5,466,633	
	COSTS (2012 \$)	_		6 722 006	
TOTAL ANNOALIZED OF ERATING	CO313 (2012 \$)	-	ş	0,723,900	
Composite CE Index for 2012 (cost ve	par of equation)	=		584.6	
Composite CE Index for 2015 (cost ye	ar of review)	=		578.4	
				0.0.1	
TOTAL ANNUALIZED OPERATING COSTS (2015 \$)		-	\$	6.652.596	
			-	-,,	
TOTAL UNCONTROLLED SO 4 EMIS	SIONS, tons	=		357	
SO ₄ REMOVAL EFFICIENCY %	,	=		40	
		_		143	
101AL 302 REIVIOVED, IONS		=		40 524	
SU2 COST-EFFECTIVENESS, \$/ton	removéd	=	Þ	40,534	
		1			

Table 5 presents a summary of the cost effectiveness of all SO₂ control options considered, including the wet scrubber considered in the original BACT Analysis. As seen in the individual cost model spreadsheets, the model-derived cost-effectiveness values are based on the potential SO₂ emissions from the Chena boilers. The combined SO₂ emission rate from all four boilers is equal to 814.5 tons/yr (potential) and 700 tons/yr (actual). The value for actual emissions is based 1.9 tons SO₂ per day as specified in the State Implementation Plan (SIP). Therefore, to derive cost-effectiveness values output by the cost models were adjusted by the ratio of actual emissions to potential emissions.

Table 5 presents the calculated SO_2 removal cost effectiveness on both a potential emission reduction and actual emission reduction basis. These values are not considered cost effective for the retrofit options at Chena Power Plant.

Rank	Control Option	Control Orientation	Cost Effe (\$ per ton per yea Potential	Expected SO ₂ Emission Rate (lb/MMBtu)	
1	Low sulfur coal	combined exhaust	(alread	y used)	0.39
2	Dry scrubber – DSI	combined exhaust	27,493	31,990	0.23 (40% removal)
3	Dry scrubber – SDA	combined exhaust	41,193	47,931	0.10 (74% removal)
4	Dry scrubber – DSI	large boiler only	46,534	54,146	0.19 (40% removal)
5	Wet scrubber	combined exhaust	75,672	88,050	0.20 (50% removal)
6	Dry scrubber – SDA	large boiler only	83,393	97,034	0.10 (69% removal)

Table 5. Summary of Cost Effectiveness of SO₂ Control Options

3 DISCUSSION OF SITE-SPECIFIC TECHNICAL, ENVIRONMENTAL, AND ENERGY ASPECTS OF DRY SCRUBBING TECHNOLOGY USE AT CHENA POWER PLANT

3.1 SUMMARY OF TECHNICAL FEATURES AND CHALLENGES

Table 6 presents a summary of some technical features of SDA and DSI technologies evaluated herein and some challenges associated with their potential use at Chena. Section 1 of this report identified several SDA and DSI applications for coal-fired boilers. The quality of the information varies considerably, and the information acquired was used as best as possible to hypothesize performance expectations from each evaluated technology. Nonetheless, no true assurances exist that the evaluated technologies will actually perform as stated when applied to the Chena facility. While the technical concepts are valid, demonstration of the technology employed as retrofit technology on units and equipment orientations such as those observed at the Chena facility cannot reliably be predicted, thus raising doubts over the accuracy of technology transfer, particularly for sorbent injection. Perhaps the best example of this uncertainty can be found when reviewing the history of the DSI system operation at the Healy Power Plant in Healy, AK. The subject of a Consent Decree, Healy was ordered to "improve" the DSI system in use on Unit No. 1 to achieve a controlled SO₂ emission rate of 0.30 lb/MMBtu. Even with extensive testing under the US Department of Energy Clean Coal program, this marginal mandated performance level is indicative of technological uncertainties associated with retrofit technology applied to control coal-fired boiler emissions.

Coupled with the technological uncertainties associated with these technologies applied as a retrofit solution are other factors that obscure the practicality of applying retrofit dry scrubber technology at the Chena facility. One of these factors, the economics of the technologies, was discussed in detail in Section 2 of this report and led to the observation that application of SDA or DSI at Chena was not a cost-effective means to reduce SO_2 emissions. Other factors, discussed in the following sections, include:

- Facility location limitations
- Environmental considerations
- Energy considerations

Factor	Spray Dry Absorber Technology	Dry Sorbent Injection Technology
Demonstrated use under conditions similar to Chena Plant	 Spray dry absorber technology is available and used to reduce SO₂ emissions from coal- fired boiler flue gas streams. The U.S. EPA's air pollution control cost manual indicates that SDA technology can be reduce SO₂ by 50% up to over 90%. Finding a suitable outlet for the particulate captured in the fabric filter following dry scrubbing is an important consideration to the feasibility of this option. 	 Dry sorbent injection is becoming more prevalent for reducing acid gas concentrations in coal-fired boiler flue gas streams. Although DSI technology is discussed in the industry, the only DSI systems presented in the RBLC Clearinghouse are lime/limestone injection systems into fluidized bed combustors. No DSI systems are listed when the boiler is a stoker, as at Chena. Sorbent injection into the duct work downstream of the coal combustion zone is also becoming more prevalent in the industry, as reported by equipment vendors. No such systems, however, are presented in the RBLC Clearinghouse.
Technical considerations	 Depending on equipment orientation, a SDA system would lower the flue gas temperature, which could then cause plugging of the downstream fabric filter. A SDA system placed upstream of the fabric filters would potentially contaminate the ash and cause the loss of a useable by-product. A SDA system would require gas reheating to prevent plugging in the fabric filter, thus increasing station service load. The temperature of water used to prepare the lime slurry can impact the hydrated lime reactivity. Adequate facilities must be included (indoors) to prevent issues associated with slurry preparation, delivery, and use. The pulse jet cleaning system in the existing fabric filter will periodically break the filter cake, thus temporarily reducing the additional sorbent reaction time with SO₂ and ultimately reducing the overall SO₂ removal that can be achieved. 	 The existing duct work at Chena is very complicated and winding. Sorbent injection into a section of combined flue gas would have less than optimum mixing and less than 0.2 seconds of residence time prior to entering the fabric filter. These two situations will increase the sorbent consumption rate by reducing sorbent utilization. Sorbent injection into the large boiler alone would provide adequate mixing time, but the flue gas would continue through seven turns in which sorbent loss through deposition on the interior duct work could occur, thus increasing sorbent consumption. The pulse jet cleaning system in the existing fabric filter will periodically break the filter cake, thus temporarily reducing the additional sorbent reaction time with SO₂ and ultimately reducing the overall SO₂ removal that can be achieved. Use of sorbent materials may render the collected ash no longer suitable for use as a fill material. The current beneficial use of collected ash as a fill material would have to be replaced with landfill disposal of the collected PM.

Table 6. Summary of Technical Challenges Associated with Dry SO2Scrubbing at Chena Power Plant

Table 6. Summary of Technical Challenges Associated with Dry SO2Scrubbing at Chena Power Plant (continued)

Factor	Spray Dry Absorber Technology	Dry Sorbent Injection Technology	
Structural considerations	 The structural stability of the existing ash silo would have to be improved prior to storing any additional PM. Any system placed downstream of the existing fabric filter would necessitate major structural modifications to the existing filter housing to alter the exhaust configuration of the treated flue gas from a monovent, roof monitor arrangement to a gas duct section that delivers gas to the dry scrubber system. 		
	1. A SDA system would require additional fans to overcome the increased distance needed to convey the flue gas. The entire air emissions control systems would need to be rebalanced as well. The existing system potentially may not meet design requirements for baghouse air flow.	1. The history of DSI operation at the Healy facility of GVEA has been anything but stable. The need to retrofit the system on two different occasions draws into question the reliability of the DSI technology.	
Operational considerations	 2. The Chena boilers are reaching the end of their commissioned by Aurora determined that Che with expenditure of significant capital. An add SO₂ emissions over a 10-year period represents 3. The U.S. Corps of Engineers estimates that add incurred for projects in Alaska when compared difficult to assess in an analysis such as this BA 4. A dry scrubber placed at the outlet of the exist exhaust gases to an optimum temperature; this generation, heating, or station service. A secon the particulate matter formed during scrubbing 5. The Trona or sodium bicarbonate reagent mill sorbent particle prior to use. 6. Reagent receiving and processing would likely Chena River and a conveyor over the Chena Ri to be conveyed over relatively long distances. 7. The PM collected in the fabric filter may becom as fill. 8. The PM collected in the fabric filter may require waste. 	useful lives. A life extension study na operations could be extended to the year 2030 d-on emission control program aimed at reducing an unwise capital expenditure at this time. litional construction and operating costs are to mainland US. These considerations are CCT. ing fabric filter would require re-heating the would reduce steam available for power d fabric filter would be then needed to remove g. would be required to produce a uniformly-sized require construction of building(s) north of the ver. Raw and processed materials would need at a waste product and no longer able to be used e pre-treatment prior to disposal as a solid	

Factor	Spray Dry Absorber Technology	Dry Sorbent Injection Technology
	1. A minimal amount of open space is available a equipment needed to support dry scrubbing te	t the Chena facility to house additional chnology.
Availability of infrastructure and space for equipment	 The location of a reagent storage area for an SDA system will need to be determined. A preliminary estimate, based on a similarly-sized facility in Colorado, is that the spray tower will need to be at least 40 ft in diameter. The only available space at the Chena facility for this tower would be in the northwest corner of the facility. The flue gas would need to be rerouted approximately 250 ft to the location of the spray tower and then return another 250 ft to the inlet of the fabric filter. This gas rerouting would be needed whether the SDA was oriented as a combined flue gas treatment system or one devoted only to the large boiler. Space for additional fans would then be needed. Availability of land area for the reagent silos and slurry preparation is uncertain. 	 The short duct run after combination of flue gases makes sorbent inject extremely difficult and leads to poor mixing and short residence time. An area of approximately 50 ft x 50 ft would be needed to house the sorbent receiving and storage area. This area would need to be located in the northwest corner of the facility. This area of the facility has minimal truck traffic at present, and routine deliveries of sorbent by truck would disrupt the normal operations in the area.

Table 6. Summary of Technical Challenges Associated with Dry SO2Scrubbing at Chena Power Plant (continued)

These factors are discussed in the following sections. These factors also were discussed in the original BACT Analysis, and some of the discussion presented below is taken from the original analysis.

3.2 LOCATION CONSIDERATIONS

Several issues related to space limitations at Chena were presented in Section 1 or this report. An important aspect of operating on an older, small industrial site is the ability to actually place additional equipment needed to operate add-on control equipment. The SDA and DSI technologies require installation of silos for reagent storage, facilities for preparing the sorbent for treatment of the flue gas, and the technology itself must be erected in available space. The congested nature of the existing Chena Power Plant site is such that the retrofit installation costs are likely to be higher than those estimated and presented in the cost tables provided earlier. Additionally, lack of available space on site could make installation of additional equipment completely infeasible. This limitation would not be completely understood prior to preliminary design of any identified system. Each of the identified SO₂ technologies also requires routine delivery of reagents to operate the system and will require removal of residues produced by the process. The congested nature of the Chena facility makes on-site truck traffic patterns somewhat problematic. Additionally, Fairbanks is approximately 400 miles from Anchorage, which is a logical location for origination of raw materials. Delivery of necessary sorbents over potentially icy roadways may interrupt raw material deliveries to the point where interruptions in plant operations could occur. The hazardous driving conditions also may cause the transportation costs for raw materials or process equipment to be greater than presented in the cost sheets, thereby causing the cost effectiveness of control to be a larger value than calculated.

Climate considerations factor into the BACT evaluation in two ways: 1) climate causes the costs to become inflated due to the need for additional insulation, heated vessels, and heat tracing, and 2) climate affects the ability of the precursor emissions from the Chena Power Plant to react in the atmosphere and form PM_{2.5}. However, no site factors are included in the SDA control cost calculations. Thus, the SDA SO₂ control costs, while already extremely high, may be underestimated. The atmospheric factor, which may limit atmospheric reaction rates, is briefly discussed in the next section on environmental considerations.

3.3 ENVIRONMENTAL CONSIDERATIONS

Environmental factors must be considered in a BACT evaluation. With respect to nonattainment BACT, precursor control options that are determined to be economically feasible may not yield the desired objective of improving PM_{2.5} air quality. (This statement is true even though none of the control options evaluated in this BACT evaluation were found to be economically feasible.) A rash conclusion to implement a (economically feasible) precursor control as BACT may in fact produce insignificant environmental benefits and at the same time produce adverse energy or environmental impacts. The environmental topics are discussed below, and energy considerations in the following section. Much of the following discussion was presented in the original BACT Analysis.

The rationale for ensuring that benefits of a precursor control option are indeed real and significant is founded in the Clean Air Act (CAA). CAA section 189(e) explicitly requires that the control requirements applicable for major stationary sources of direct PM_{2.5} emissions must also apply to major stationary sources of PM_{2.5} precursors, unless the state provides a

demonstration that emissions of a particular precursor from major stationary sources do not contribute significantly to levels that exceed the standard in the nonattainment area of concern. Thus, the statute generally requires control of all $PM_{2.5}$ precursors in a nonattainment area, but it provides an express exception applicable to major stationary sources in such areas if an appropriate demonstration is made.¹⁴

A key conclusion derived by looking at the chemical mass balance (CMB) evaluations for PM filters collected in the Fairbanks North Star Borough (FNSB) is that control of Chena Power Plant PM_{2.5} precursors will not provide significant reduction of ambient PM_{2.5}. This conclusion can easily be validated by looking solely at the wood smoke contribution and comparing it to the PM_{2.5} standard. As is seen on many episode days, the standard is exceeded solely due to contribution from wood smoke, while the impact of sulfates on episode days is minor.

Although the CMB results included in the SIP provide some insight into establishing source contributions in the FNSB, no straightforward procedures can be used to determine a specific source contribution to ambient PM_{2.5} concentrations and, by extension, the air quality improvements in PM_{2.5} air quality should one or more control measures be implemented at the Chena Power Plant. Because no one procedure answers every question one may have, a variety of procedures are often employed. This is a key issue that relates the magnitude of reductions in daily precursor emissions to commensurate reductions in PM_{2.5} concentrations. In many cases, indirect procedures must be employed to estimate air quality benefits resulting from installation of precursor emission controls. For example, DSI (the SO₂ control option identified herein that has the best cost-effectiveness) was estimated to be able to achieve a 40 percent reduction in SO₂ emissions from the Chena Power Plant boilers. As provided in the background information for the ADEC SIP, on average, Chena Power Plant boilers emitted 1.9 ton/day of SO₂ in 2015 on days when the PM_{2.5} standard was exceeded.¹⁵ Thus, application of DSI at Chena would result in an average SO₂ reduction of 0.76 ton/day.

¹⁴ Federal Register, Volume 81, page 58091, August 24, 2016, 40 CFR Parts 50, 51, and 93, Fine Particulate Matter National Ambient Air Quality Standards: State Implementation Plan Requirements; Final Rule.

¹⁵ ADEC, Amendments to: State Air Quality Control Plan Volume II: Analysis of Problems, Control Actions; Section III: Area-wide Pollutant Control Program; D: Particulate Matter; 5: Fairbanks North Star Borough PM_{2.5} Control Plan, Section 5.06, page III.D.5.6-27.

This reduction represents only 6.2 percent of the estimated NOx and SO_2 nonattainment area-wide emissions, respectively, estimated to occur on $PM_{2.5}$ episode days in 2008.

ADEC included CMB results in the SIP to provide some insight into establishing source contributions in the FNSB.¹⁶ The CMB analysis estimated a maximum sulfate contribution of 28.8 micrograms per cubic meter (μ g/m³) (at most) in downtown Fairbanks on high PM_{2.5} concentration days between 2005 and 2013. Assuming that all of the precursor emission reductions noted above for Chena Power Plant culminate in the same level of ambient PM_{2.5} reductions, use of DSI technologies at Chena would benefit ambient air quality in downtown Fairbanks by only 1.8 μ g/m³ for sulfates (i.e., 28.8 μ g sulfate/m³ times 6.2 percent reduction in daily SO₂ emissions). The improvements on an average basis would be about half these amounts.

Another environmental factor impacting the true effectiveness of a control option is the atmospheric reaction process that leads to conversion of precursor emissions to PM_{2.5}. Three major issues must be considered when evaluating the Chena Power Plant's contribution to PM_{2.5} levels within the FNSB air basin: 1) precursor reaction chemistry in arctic wintertime conditions when exceedances of the PM_{2.5} NAAQS occur, 2) possible increases in nitrate formation as ammonium ions become available, and 3) transport and dispersion of the Chena Power Plant boiler stack plume above and beyond the capped inversion layer that encapsulates the FNSB air basin causing accumulation of ground-level PM_{2.5} within the air basin.

Formation of secondary $PM_{2.5}$ depends on numerous factors including the concentrations of precursors; the concentrations of other gaseous reactive species; atmospheric conditions including solar radiation, temperature, and relative humidity; and the interactions of precursors with preexisting particles and with cloud or fog droplets. The relative contribution to ambient $PM_{2.5}$ concentrations from each precursor pollutant varies by

¹⁶ ADEC, Amendments to: State Air Quality Control Plan SIP, Vol. III: Appendix III.D.5.7, Appendix to Volume II. Analysis of Problems, Control Actions; Section III. Area-wide Pollutant Control Program; D. Particulate Matter; 5. Fairbanks North Star Borough PM_{2.5} Control Plan, December 24, 2014, page III.D.5.7-66.

climatological area. The relative effect of reducing emissions of these pollutants is also highly variable.¹⁷

Sulfates are typically formed in the atmosphere by formation of sulfuric acid from SO_2 that subsequently reacts with ammonia to form ammonium sulfate. There are three different pathways for the transformation of SO_2 to sulfuric acid¹⁸:

- 1. Gaseous SO_2 can be oxidized by the hydroxyl radical (OH) to create sulfuric acid. This gaseous SO_2 oxidation reaction occurs slowly and only in the daytime.
- 2. SO₂ can dissolve in cloud water (or fog or rainwater), and there it can be oxidized to sulfuric acid by a variety of oxidants, or through catalysis by transition metals such as manganese or iron. If ammonia is present and taken up by the water droplet, then ammonium sulfate will form as a precipitate in the water droplet.
- 3. SO₂ can be oxidized in reactions in the particle-bound water in the aerosol particles themselves. This process takes place continuously, but only produces appreciable sulfate in alkaline (dust, sea salt) coarse particles.

These climatological conditions that are conducive to sulfate formation from transformation of SO_2 are not consistent with the conditions that typically generate high $PM_{2.5}$ concentrations in the FNSB.

Some researchers have reported an increase in nitrate formation associated with ambient SO₂ reductions. This association is strongest in low temperature areas of low humidity and exists because additional ammonium ions will become available for reaction with NOx emissions.¹⁹ Although the net PM_{2.5} concentration will likely be lower after SO₂ reductions, a linear reduction of the ambient PM_{2.5} concentration is not

 $^{^{17}}$ Federal Register, Volume 73, page 28325, May 16, 2008, 40 CFR Parts 51 and 52, Implementation of the New Source Review (NSR) Program for Particulate Matter Less Than 2.5 Micrometers (PM_{2.5}).

¹⁸ NARSTO (2004) Particulate Matter Science for Policy Makers: A NARSTO Assessment. P. McMurry, M. Shepherd, and J. Vickery, eds. Cambridge University Press, Cambridge, England. ISBN 0 52 1842875.

¹⁹ Ibid (NARSTO).

expected, and less $PM_{2.5}$ reduction will be observed than expected because of the increase in the nitrate concentration.

An issue also arises in the FNSB related to the dispersion of precursor emissions from the Chena Power Plant boiler stack and the ability of the dispersed emissions to actually impact the ambient air quality monitors. It has been observed, and it is reasonable to expect, that the boiler stack plume is carried above the winter inversion layer. As such, transport of the precursor pollutants occurs above the inversion layer, where the concentrations of the pollutants can be transported and dispersed by the stronger aloft winds. In addition, the Fairbanks PM_{2.5} Source Apportionment Research Study²⁰ concluded that dominant aloft wind direction during PM_{2.5} episodes is from the northeast, which would transport the Chena Power Plant emissions away from the ambient air quality monitors located in downtown Fairbanks and North Pole. Figure 2 presents a photograph showing the Chena Power Plant boiler stack exhaust plume height well above the inversion layer. The original BACT Analysis presented an evaluation of Chena coal consumption on high PM_{2.5} concentration days between 2013 and 2015 and revealed a very poor (or no) correlation between Chena Power Plant coal consumption and observed ambient PM_{2.5} levels. This poor correlation is believed to be due to plume entrapment above the wintertime inversion layer.

The poor correlations reported in the original BACT Analysis indicate that changes in Chena Power Plant emissions do not explain the majority of the changes in ambient $PM_{2.5}$ levels. Because the Chena Power Plant emissions are not seemingly influencing the ambient $PM_{2.5}$ concentrations to any significant extent, the ambient levels must be the result of other emission sources in the FNSB.

²⁰ The Fairbanks, Alaska PM_{2.5} Source Apportionment Research Study Winters 2005/2006-2012/2013, and Summer 2012; Final Report, Amendments 6 and 7, December 23, 2013, Tony J. Ward, Ph.D., University of Montana – Missoula, Center for Environmental Health Sciences.



Figure 2. Chena Power Plant exhaust plume.²¹

²¹ The exhaust from the Aurora Energy power plant breaks through an inversion layer as seen from the Hagelbarger Road pullout off the Steese Highway. Photo credits: Frank DeGenova, January 30, 2008, <u>http://marcvaldez.blogspot.com/2008/05/wintertime-smokestack-plumes-in.html</u>, accessed December 22, 2017.

This observation can be further illustrated using the following example for the highest PM_{2.5} day (early January) in 2015 at downtown Fairbanks monitors when Chena Power Plant coal consumption was at its greatest rate (2.2 million pounds/day). If this was during one of the coldest days, then the Chena Power Plant impact at ground level would have been less than on other days because: 1) the buoyancy term for the Chena Power Plant boiler plume would be at its greatest because the temperature differential between stack and ambient air temperatures would have been greatest, and 2) the momentum term for the boiler plume would also have been at its greatest because the exhaust gas flow rate would be greater than at lesser coal combustion rates. Because the impact of Chena Power Plant emissions would likely have been less on this episode day than other days, the PM_{2.5} mass on the filters in question would had to have been contributed by other sources in the FNSB.

To summarize these environmental considerations related to photochemistry and precursor transport within the FNSB, the U.S. EPA makes the following corroborating points:

"Major stationary sources with elevated stacks emit most of their precursors into the extremely stable atmosphere present during wintertime pollution events. Only a fraction of the elevated plumes returns to ground level in the FNSB where air quality monitors are located and much less than might be expected in most parts of the lower 48 states."²²

In conclusion, and as noted earlier herein, use of DSI technologies at Chena is estimated to benefit ambient $PM_{2.5}$ air quality in downtown Fairbanks by only $1.8 \ \mu g/m^3$ at the most due to reduction of ambient sulfates (i.e., $28.8 \ \mu g$ sulfate/m³ times 6.28 percent reduction in daily SO₂ emissions). The actual improvement will likely be less due to the environmental considerations noted herein. The maximum estimated sulfate improvements in $PM_{2.5}$ air quality presented here are only slightly above the U.S. EPA-recommended 24-hour significant level of $1.3 \ \mu g/m^3$ as presented in the recent Draft Precursor Guidance and could actually be less than the significant level. This reduction would possibly be accompanied by other increases in fuel combustion emissions, production

 $^{^{22}}$ Federal Register, Volume 82, page 9043, February 2, 2017, Air Plan Approval; AK, Fairbanks North Star Borough; 2006 $\rm PM_{2.5}$ Moderate Area Plan, Proposed Rule.

of a brown NOx cloud in the Chena plant stack, and elimination of the beneficial use of fly ash collected at the plant as fill material. These observations indicate that the environmental benefit of installing SO_2 controls at Chena Power Plant will produce no noticeable improvement in ambient $PM_{2.5}$ air quality and may produce negative associated environmental impacts.

3.4 ENERGY CONSIDERATIONS

Retrofit BACT as a means to reduce the pollutant load in an air basin must necessarily look at the effect that employing BACT on a specific source would have on other sources in the air basin and whether this effect would negatively impact the air quality improvement that is presumed to occur when BACT is employed. The original BACT Analysis presented a detailed discussion of energy considerations arises from the use of add-on air pollution control equipment. The reader is referred to that document for additional information regarding energy considerations for additional fuel and electricity consumption.

3.5 SUMMARY OF ENVIRONMENTAL AND ENERGY CONSIDERATIONS

The environmental considerations associated with installation of SO_2 controls on the Chena Power Plant produce uncertain assurances that any improvement in FNSB air quality will result. In fact, the data suggest that insignificant environmental improvements at best could occur. The energy considerations point to a likely lack of an air quality benefit in FNSB in the event that SO_2 controls are implemented at Chena Power Plant. In fact, such implementation could actually increase the air pollutant load in FNSB from sources more likely to produce a $PM_{2.5}$ ambient impact than Chena Power Plant.

Adopted

4 ANALYSIS OF ASPECTS RELATED TO BACT

The supplemental information presented herein supports and enhances the SO₂ BACT determination presented in the original BACT Analysis. The previous sections of this supplement analyzed the several aspects that must be considered in a BACT determination, those being technical feasibility, economics, environment, and energy. This analysis yielded the following findings:

- 1. The technical feasibility of employing add-on SO₂ controls at Chena is highly questionable due to lack of available space at the facility for the equipment needed to scrub the flue gas as well as raw material receiving and processing equipment. Furthermore, the degree of control afforded by SDA and DSI technology is highly variable and difficult to define for conditions existing at Chena.
- 2. The economic analysis shows that use of SDA or DSI technology for SO₂ control is does not make economic sense as a retrofit option at Chena Power Plant.
- 3. The environmental considerations demonstrated that no significant ambient $PM_{2.5}$ improvement would be obtained by requiring SO_2 controls on Chena Power Plant. ADEC also recognizes that controlling direct $PM_{2.5}$ emissions (such as from wood stoves) is 13 times more effective at reducing ambient $PM_{2.5}$ concentrations than controlling precursor air pollutants that produce secondary $PM_{2.5}$. Furthermore, the actual ambient $PM_{2.5}$ benefit that can be achieved by reducing SO_2 emissions is extremely uncertain and difficult to calculate.
- 4. From an energy standpoint, installing an add-on SO₂ control device would increase the parasitic load at the Chena Power Plant. Loss of this energy output would require supplemental energy consumption at other sources within the FNSB or acquired through the grid from Anchorage to compensate for this parasitic load. This supplemental energy consumption at other sources may actually produce an increase in direct PM_{2.5} emissions if the lost capacity were to be offset by fuel consumption for sources such as woodburning stoves or oil-fired boilers, which tend to emit more direct PM_{2.5} than Chena Power Plant, and at lower elevations. Furthermore, ADEC has already concluded, based on CMB

evaluations of PM filters in the FNSB, that these lower level sources are the more significant contributors to ambient $PM_{2.5}$ concentrations. Thus, the energy impacts of requiring SO_2 controls on Chena Power Plant could potentially have the exact opposite effect as desired and produce increases in ambient $PM_{2.5}$ concentrations in the FNSB.

4.1 DETERMINATION OF BACT FOR SO₂

Alaska coal has very low sulfur content, and uncontrolled sulfur emissions are four times lower than at a plant burning "low sulfur coal" in the lower 48 states.²³ The result is that the cost-effectiveness of SO₂ control technologies is poorer in Alaska than the lower 48 states. Current SO₂ emission rates from the Chena Power Plant are comparable to those identified as BACT in the most recent BACT determinations included in the RBLC database.

Therefore, as concluded in the original BACT Analysis, BACT for SO₂ emissions from Chena Power Plant is determined to be the continued use of low-sulfur coal.

²³ ADEC, Amendments to: State Air Quality Control Plan SIP, Vol. III: Appendix III.D.5.7, Appendix to Volume II. Analysis of Problems, Control Actions; Section III. Area-wide Pollutant Control Program; D. Particulate Matter; 5. Fairbanks North Star Borough PM_{2.5} Control Plan, December 24, 2014, page III.D.5.7-78.

Vovember 19, 2019

Adopted

Department of Environmental Conservation

DIVISION OF AIR QUALITY Director's Office

410 Willoughby Avenue, Suite 303 PO Box 111800 Juneau, Alaska 99811-1800 Main: 907-465-5105 Toll Free: 866-241-2805 Fax: 907-465-5129 www.dec.alaska.gov

CERTIFIED MAIL: 7017 3040 0000 4359 5189 Return Receipt Requested

GOVERNOR BILL WALKER

September 13, 2018

David Fish, Environmental Manager Aurora Energy, LLC 100 Cushman St., Ste. 210 Fairbanks, AK 99701

THE STATE

Subject: Second request for additional information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant by November 1, 2018

Dear Mr. Fish:

A portion of the Fairbanks North Star Borough (FNSB) has been in nonattainment with the 24hour National Ambient Air Quality Standard for fine particulate matter (PM_{2.5}) since 2009. In a letter dated April 24, 2015, I requested that the Aurora Chena Power Plant and other affected stationary sources voluntarily provide the Alaska Department of Environmental Conservation (ADEC) with a Best Available Control Technology (BACT) analysis in advance of the nonattainment area being reclassified to Serious Non-Attainment Area. On May 10, 2017, the US Environmental Protection Agency (EPA) published their determination that the FNSB PM_{2.5} nonattainment area would be reclassified from a Moderate Area to a Serious Area effective June 9, 2017.¹

Once the nonattainment area was reclassified to Serious, it triggered the need for Best Available Control Measures (BACM)/BACT analyses. A BACM analysis requires that ADEC review potential control measure options for the various sectors that contribute to the PM₂₅ air pollution in the nonattainment area. A BACT analysis must be conducted for applicable stationary sources such as the Aurora Chena Power Plant. BACM and BACT are required to be evaluated regardless of the level of contribution by the source to the problem or its impact on the areas ability to attain.² The BACT analysis is a required component of a Serious State Implementation Plan (SIP).³ ADEC sent an email to Mr. Fish at Aurora on May 11, 2017 notifying him of the reclassification to Serious and

¹ Federal Register, Vol. 82, No. 89, Wednesday May 10, 2017 (https://dec.alaska.gov/air/anpms/comm/docs/2017-09391-CFR.pdf)

² <u>https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf</u>, Clean Air Act 189 (b)(1)(B) and 189 (e) and CFR 51.1010(4)(i) require the implementation of BACT for point sources and precursors emissions and BACM for area sources.

³ <u>https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf</u>, Clean Air Act 189 (b)(1)(B) and 189 (e) require the implementation of BACT for point sources and precursors emissions and BACM for area sources

Adopted ish Aurora Energy, LLC

included a request for the BACT analysis to be completed by August 8, 2017. The BACT analysis from Aurora, which included emission units found in Operating Permits AQ0315TVP03 Revision 1, was submitted by email to the Department on March 20, 2017.

On March 22, 2018, ADEC released a preliminary draft of the BACT determination for the Chena Power Plant for public discussion on its website at:

http://dec.alaska.gov/air/anpms/communities/fbks-pm2-5-serious-sip-development. As indicated in the release, this document is a work in progress. ADEC received additional information from the EPA on the preliminary draft BACT determination and expects to make changes to the determination based upon this input. Therefore, ADEC is requesting additional information from Aurora to assist it in making a legally and practicably enforceable BACT determination for the source.

Specifically, ADEC requests that Aurora review the cost effectiveness spreadsheet provided as a part of the preliminary SO₂ BACT determination which was originally developed by Sargent & Lundy (S&L) in 2010. The spreadsheet includes a link to the S&L white paper that provides a basis for the cost effectiveness calculations and indicates that the model is intended to calculate estimated total project cost (total capital cost of installation), as well as direct and indirect annual operating costs. These calculations are largely based on the estimated usage of sorbent and the gross generating capacity of the plant. Please use this spreadsheet to calculate the cost effectiveness of SO₂ removal in dollars per ton and identify all assumptions and technical justifications used in the analysis.

If ADEC does not receive a response to this information request by November 1, 2018, ADEC will make a preliminary BACT determination based upon the information originally provided. However, ADEC does not have the in depth knowledge of your facility's infrastructure and without additional information, may select a more stringent BACT for your facility in order to be approvable by EPA. It is ADEC's intent to release the preliminary BACT determinations for public review along with any precursor demonstrations and BACM analyses before the required public comment process for the Serious SIP. In order to provide this additional comment opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated.

After ADEC makes a final BACT determination for Aurora, it must include the determination in Alaska's Serious SIP which ultimately requires approval by EPA.⁴ In addition, the BACT implementation 'clock' was also triggered by the EPA reclassification of the area to Serious on June 9, 2017. Therefore, the control measures that are included in the final BACT determination will be required to be fully implemented prior to June 9, 2021 - 4 years after reclassification.⁵

As indicated in a meeting on September 21, 2017 between ADEC Air Quality staff and the stationary sources affected by the BACT requirements, ADEC will also be using the information submitted or developed to support the BACT determinations for Most Stringent Measure (MSM) consideration. MSMs will be a required element of the state implementation plan if the State applies for an extension of the attainment date from EPA. Therefore, the information you submit will be used for both analyses.

⁴ https://www.gpo.gov/fdsys/pkg/USCODE-2013-title42/html/USCODE-2013-title42-chap85-subchap1-partD-subpart4-sec7513a

⁵ 40. CFR 51.1010(4)

Adopted David Fish Aurora Energy, LLC

ADEC appreciates the cooperation that we've received from Aurora. ADEC staff would like to continue periodic meetings to keep track of timelines and progress. If you have any questions related to this request, please feel free to contact us. Deanna Huff (email: <u>Deanna.huff@alaska.gov</u>) and Cindy Heil (email: <u>Cindy.heil@alaska.gov</u>) are the primary contacts for this effort within the Division of Air Quality.

Sincerely, wat BY SIR Denise Koch, Director

Division of Air Quality

Enclosures:

September 10, 2018	ADEC Request for Additional Information for Chena Power Plant BACT Analysis
May 21, 2018	EPA Comments on ADEC Preliminary Draft Serious SIP Development Materials for the Fairbanks Serious PM-2.5 nonattainment Area
November 16, 2017	ADEC Request for Additional Information for Aurora Energy LLC, BACT Analysis
November 15, 2017	EPA Aurora Energy – Chena Power Plant BACT Analysis Review Comments
May 11, 2017	Serious SIP BACT due date email
April 24, 2015	Voluntary BACT Analysis for Aurora Energy, LLC

cc: Larry Hartig, ADEC/Commissioner's Office Alice Edwards, ADEC/Commissioner's Office Cindy Heil, ADEC/Air Quality Deanna Huff, ADEC/Air Quality Jim Plosay, ADEC/Air Quality Aaron Simpson, ADEC/Air Quality David Fish/Aurora Energy, LLC Tim Hamlin/EPA Region 10 Dan Brown/EPA Region 10 Zach Hedgpeth/EPA Region 10

ADEC Request for Additional Information Aurora Energy LLC. – Chena Power Plant BACT Analysis Review Environmental Resources Management Report, March 2017

September 10, 2018

Please address the following comments by providing the additional information identified by November 1, 2018. Following the receipt of the information the Alaska Department of Environmental Conservation (ADEC) intends to make its preliminary Best Available Control Technology (BACT) determination and release that determination for public review. In order to provide this additional review opportunity, ADEC must adhere to a strict schedule. Your assistance in providing the necessary information in a timely manner is greatly appreciated. Additional requests for information may result from comments received during the public review period or based upon the new information provided in response to this information request.

This document does not represent a final BACT determination by ADEC. Please contact Aaron Simpson at <u>aaron.simpson@alaska.gov</u> with any questions regarding ADEC's comments.

- 1. <u>Alternative Fuel Source</u> Page 17 of the analysis indicates that it is assumed that use of another type of coal would not reduce NOx emissions, and use of an alternate fuel is considered technically infeasible, but did not include a substantive analysis. As indicated in the Approval and Promulgation of the State of Washington's Regional Haze State Implementation Plan¹, the use of SNCR and Flex Fuel² was selected as BART for the TransAlta coal-fired power plant. Evaluate alternative coal sources as a potential control option for the coal-fired boilers and identify energy, environmental, and economic impacts and other costs that would affect the selection of an alternative coal sources based on a comparison of the coal's heat content as well as nitrogen and sulfur content.
- 2. Low Excess Air (LEA) and Overfire Air (OFA) Operating at LEA involves reducing the amount of combustion air to the lowest possible level while maintaining efficient and environmentally compliant boiler operation. NOx formation is inhibited because less oxygen is available in the combustion zone. Overfire air is the injection of air above the main combustion zone. Implementation of these techniques may also reduce operational flexibility; however, they may reduce NOx by 10 to 20 percent from uncontrolled levels.³ Evaluate these technically feasible control technologies using EPA's top down approach.
- 3. <u>Additional SO₂ Control Technologies</u> The BACT analysis does not include a substantive analysis of spray-dry scrubbing, dry flue gas desulfurization, dry scrubbing, or dry sorbent injection (DSI). All of these technologies have the potential to offer SO₂ removal, and therefore must be included in the analysis. Page 32 of the analysis indicates that the combined exhaust from the Chena Power Plant is currently controlled by a common baghouse and that installation of a dry injection or spray drying operation would require the existing baghouse be retrofit with a new PM control system to accommodate the much greater PM loading produced by a dry injection or spray dry system. It further states that the installation of such technologies would

¹ EPA-R10-OAR-2012-0078, FRL-9675-5

² Flex Fuel is the "switch from Centralia, Washington coal to coal from the Power River Basin in Wyoming. Powder River Basin coal has a higher heat content requiring less fuel for the same heat extraction, as well as a lower nitrogen and sulfur content than coal from Centralia. Flex Fuel also required changes to boiler design to accommodate Powder River Basin coal."

³ https://www3.epa.gov/ttn/chief/ap42/ch01/final/c01s01.pdf

be cost-prohibitive and therefore technically infeasible. However, the BACT analysis must include rigorous site-specific evaluation of the technical feasibility and cost effectiveness of these technologies.

The EPA cost manual does not currently include a chapter covering DSI. However, as part of their Regional Haze FIP for Texas, EPA Region 6 developed cost estimates for DSI as applied to a large number of coal fired utility boilers. See the Technical Support Documents for the Cost of Controls Calculations for the Texas Regional Haze Federal Implementation Plan (Cost TSD) for additional information. The Cost TSD and associated spreadsheets are located at: https://www.regulations.gov/document?D=EPA-R06-OAR-2014-0754-0008. Please update the cost analysis for these technologies and provide technical justifications for all assumptions used in the analysis submitted as part of the BACT analysis (i.e., direct and indirect contingency costs, startup costs, initial performance test costs, electricity rate, and reagent costs). Provide in the analysis: the control efficiency associated with the technologies, captured emissions (tons per year), emissions reduction (tons per year), capital costs (2017 dollars), operating costs (dollars per year), and cost effectiveness (dollars per ton) using EPA's cost manual. Please see comments 5, 6, and 7 for additional information related to retrofit costs, baseline emissions, and factor of safety.

- 4. <u>BACT limits</u> BACT limits by definition, are numerical emission limits. However regulation allows a design, equipment, or work/operational practices if technological or economic limitations make a measurement methodology infeasible. Provide numerical emission limits (and averaging periods) for each proposed BACT selection, or justify why a measurement methodology is technically infeasible and provide the proposed design equipment, or work/operational practices for pollutant for each emission unit included in the analysis. Startup, Shutdown, and Malfunction (SSM) must be addressed in the BACT analysis. Measures to minimize the occurrence of these periods, or to minimize emissions during these periods are control options. Combinations of steady-state control options and SSM control options can be combined to create distinct control strategies. In no event shall application of BACT result in emissions of any pollutant which would exceed the emissions allowed by an applicable standard under 40 C.F.R. parts 60 (NSPS) and 61 (NESHAP).
- 5. <u>Retrofit Costs</u> EPA's Control Cost Manual indicates that study-level cost estimates (± 30 percent) should not include a retrofit factor greater than 30 percent, so detailed cost estimates (± 5 percent) are required for higher factors. High retrofit cost factors (50 percent or more) may be justified in unusual circumstances (e.g., long and unique ductwork and piping, site preparation, tight fits, helicopter or crane installation, additional engineering, and asbestos abatement). Provide detailed cost analyses and justification for difficult retrofit (1.6 1.9 times the capital costs) considerations used in the BACT analysis.
- 6. <u>Baseline Emissions</u> Include the baseline emissions for all emission units included in the analysis. Typically, the baseline emission rate represents a realistic scenario of upper bound uncontrolled emissions for the emissions unit (unrestricted potential to emit not actual emissions). NSPS and NESHAP requirements are not considered in calculating the baseline emissions. The baseline is usually the legal limit that would exist, but for the BACT determination. Baseline takes into account the effect of equipment that is part of the design of the unit (e.g., water injection and LNBs) because they are considered integral components to the unit's design. If the uncontrolled emission rate is 'soft,' run the cost effectiveness calculations using two or three different baselines.
- 7. <u>Factor of Safety</u> If warranted, include a factor of safety when setting BACT emission limitations. The safety factor is a legitimate method of deriving a specific emission limitation that may not be exceeded. These limits do not have to reflect the highest possible control

efficiencies, but rather, should allow the Permittee to achieve compliance with the numerical emission limit on a consistent basis.

- 8. <u>Good Combustion Practices</u> For each emission unit type (coal boilers, distillate boilers, engines, and material handling) for which good combustion practices was proposed as BACT, describe what constitutes good combustion practices. Include any work or operational practices that will be implemented and describe how continuous compliance with good combustion practices will be achieved.
- 9. <u>Interest Rate</u> All cost analyses must use the current bank prime interest rate. This can be found online at <u>https://www.federalreserve.gov/releases/h15/</u> (go to bank prime rate in the table). Please revise the cost analyses as appropriate.
- 10. Provide an economic analysis for circulating dry scrubber (CDS) SO₂ technology for the coal fired boilers (EUs 1-6). Provide in the analysis: the control efficiency associated with CDS, captured emissions (tons per year), emissions reduction (tons per year), capital costs (2017 dollars), operating costs (dollars per year), annualized costs (dollars per year), and cost effectiveness (dollars per ton) using EPA's cost manual. Please provide technical justifications for all assumptions used in the analysis submitted as part of the BACT analysis (i.e., direct and indirect contingency costs, startup costs, initial performance test costs, electricity rate, and reagent costs).
- 11. Review the cost effectiveness spreadsheet provided as a part of the preliminary SO₂ BACT determination which was originally developed by Sargent & Lundy (S&L) in 2010. The spreadsheet includes a link to the S&L white paper that provides a basis for the cost effectiveness calculations and indicates that the model is intended to calculate estimated total project cost (total capital cost of installation), as well as direct and indirect annual operating costs. These calculations are largely based on the estimated usage of sorbent and the gross generating capacity of the plant. Please use this spreadsheet to calculate the cost effectiveness of SO₂ removal in dollars per ton and identify all assumptions and technical justifications used in the analysis. In this analysis use a bottom-up cost estimating approach based on actual plant conditions. These conditions would include SO₂ emission rates based on current PTE, permit constraints (where applicable and enforceable), available space, ambient conditions, and local factors such as construction logistics, labor wage rates, and local sorbent costs.
- 12. Site-Specific Quotes Needed The cost analyses, particularly for SO₂ control technologies, must be based on emission unit-specific quotes for capital equipment purchase and installation costs at each facility. These are retrofit projects which must be considered individually in order to obtain reliable study/budget level (+/- 30%) cost estimates which are appropriate to use as the basis for decision making in determining BACT.

Attachment: EPA comments on ADEC Preliminary Draft Serious SIP Development materials for the Fairbanks serious PM_{2.5} nonattainment area

<u>General</u>

The attached comments are intended to provide guidance on the preliminary drafts of SIP documents in development by ADEC. We expect that there will be further opportunities to review the more complete versions of the drafts and intend to provide more detailed comments at that point

 <u>Statutory Requirements</u> - This preliminary draft does not address all statutory requirements laid out in Title I, Part D of the Clean Air Act or 40 C.F.R. Part 51, Subpart Z. The submitted Serious Area SIP will need to address all statutory and regulatory requirements as identified in Title I, Part D of the Clean Air Act, 40 C.F.R. Part 51, Subpart Z, the August 24, 2016 PM_{2.5} SIP Requirements Rules (81 FR 58010, also referred to at the PM_{2.5} Implementation Rule), and any associated guidance.

In the preliminary drafts, notable missing elements included: Reasonable Further Progress, Quantitative Milestones, and Conformity. This is not an exhaustive list of required elements.

The NNSR program is a required element for the serious area SIP. We understand ADEC recently adopted rule changes to address the nonattainment new source review element of the Serious SIP, and that ADEC plans to submit them to the EPA separately in October 2018. Thank you for your work on this important plan element.

- 2. Extension Request This preliminary draft does not address the decision to request an attainment date extension and the associated impracticability demonstration. On September 15, 2017, ADEC sent a letter notifying the EPA that it intends to apply for an extension of the attainment date for the Fairbanks PM_{2.5} Serious nonattainment area. The Serious Area SIP submitted to EPA will need to include both an extension request and an impracticability demonstration that meet the requirements of Clean Air Act section 188(e). In order to process an extension request, the EPA requests timely submitted of your Serious Area SIP to allow for sufficient time to review and take action prior to the current December 2019 attainment date, so as to allow, if approvable, the extension of the attainment date as requested/appropriate. For additional guidance, please refer to 81 FR 58096.
- 3. <u>Split Request</u> We support the ADEC and the FNSB's decision to suspend their request to the EPA to split the nonattainment area. We support the effort to site a monitor in the Fairbanks area that is more representative of neighborhood conditions and thus more protective of community health. This would provide additional information on progress towards achieving clean air throughout the nonattainment area.
- 4. <u>BACM (and BACT), and MSM</u> Best Available Control Measures (including Best Available Control Technologies) and Most Stringent Measures are evaluative processes inclusive of steps to identify, adopt, and implement control measures. Their definitions are found in 51.1000, 51.1010(a).

All source categories, point sources – area sources – on-road sources – non-road sources, need to be evaluated for BACM/BACT and MSM. De minimis or minimal contribution are not an allowable rationale for not evaluating or selecting a control measure or technology.

The process for identifying and adopting MSM is separate from, yet builds upon, the process of selecting BACM. Given that Alaska is intent on applying for an extension to the attainment date, Alaska must identify BACM and MSM for all source categories. These processes are described in 51.1010(a) and 51.1010(b) and in the PM_{2.5} Implementation Rule preamble at 81 FR 58080 and 58096. We further discuss this process in the "BACM (and BACT), MSM" section that starts on page 3 below.

- 5. <u>Resources and Implementation</u> The serious area PM_{2.5} attainment plan will be best able to achieves its objectives when all components of the SIP, both the ADEC statewide and FNSB local measures, are sufficiently funded and fully implemented.
- 6. <u>Use of Consultants</u>- For the purpose of clarity, it will be important to identify that while contractors are providing support to ADEC, all analyses are the responsibility of the State.

Emissions Inventory

- 1. <u>Extension Request Emission Inventories</u> Emissions inventories associated with the attainment date extension request will need to be developed and submitted. Table 1 of the Emissions Inventory document is one example where the submittal will need to include the additional emissions inventories, including RFP inventories, extension year inventories for planning and modeling, and attainment year planning and modeling inventories, associated with the attainment date extension request.
- <u>Modeling Requirements</u> Related to emissions inventory requirements, the serious area SIP will need to model and inventory 2023 and 2024, at minimum. We recommend starting at 2024 and modeling earlier and earlier until there is a year where attainment is not possible. That would satisfy the requirement that attainment be reached as soon as practicable.
- 3. <u>Condensable Emissions</u> All emissions inventories and any associated planning, such as Reasonable Further Progress schedules, need to include condensable emissions as a separate column or line item, where available. Where condensable emissions are not available separately, provide condensable emissions as included (and noted as such) in the total number. The following are examples of where this would need to be incorporated in to the Emissions Inventory document:
 - *a.* Page 20, paragraph 5 (or 2^{nd} from the bottom).
 - b. Page 34, Table 8. Include templates.

Precursor Demonstration

- 1. <u>Ammonia Precursor Demonstration</u> The draft Concepts and Approaches document, Table 4 on page 9, states that a precursor demonstration was completed for ammonia and that the result was "Not significant for either point sources or comprehensively." The Precursor Demonstration chapter does not include an analysis for ammonia. Please include the precursor demonstration for ammonia in the Serious Plan or amend this table.
- 2. <u>Sulfur Dioxide Precursor Description</u> The draft Concepts and Approaches document, Table 4 on page 9, states that sulfur dioxide was found to be significant. All precursors are presumptively considered significant by default and the precursor demonstration can only show that controls on a precursor are not required for attainment. Suggested language is, "No precursor demonstration possible."

BACM (and BACT), MSM

Overall

The EPA appreciates ADECs efforts to identify and evaluate BACM for eventual incorporation into the Serious Area SIP. The documents clearly display significant effort on the part of the state and are a good first step in the SIP development process. In particular, we are supportive of ADECs efforts to evaluate BACT for the major stationary sources in the nonattainment area, as control of these sources is required by the CAA and PM_{2.5} SIP Requirements Rule.

- <u>BACM/BACT and MSM: Separate Analyses</u> The "Possible Concepts and Potential Approaches" document appears to conflate the terms BACM/BACT and MSM, as well as, the analyses for determining BACM/BACT and MSM. BACM and MSM have separate definitions in 40 CFR 51.1000. By extension, the processes for selecting BACM and MSM are laid out separately in the PM_{2.5} SIP Requirements Rule (compare 40 CFR 51.1010(a) for BACM and 40 CFR 51.1010(b) for MSM). Accordingly, the serious area SIP submission will need to have both a BACM/BACT analysis and an MSM analysis. We believe that there is flexibility in how these analyses can be presented, so long as the submission clearly satisfies the requirements of both evaluations, methodologies, and findings.
- Selection of Measures and Technologies The CAA and the PM_{2.5} SIP Requirements Rule requires that <u>all</u> available control measures and technologies that meet the BACM (including BACT) and MSM criteria need to be implemented. All source categories need to be evaluated including: point sources (including non-major sources), area sources, on-road sources, and non-road sources.
- 3. <u>Technological Feasibility</u> All available control measures and technologies include those that have been implemented in nonattainment areas or attainment areas, or those potential measures and technologies that are available or new but not yet implemented. Similarly, Alaska may not automatically eliminate a particular control measure because other sources or nonattainment areas have not implemented the measure. The regulations do not have a quantitative limit on number of controls that should be implemented.

For technological feasibility, a state may consider factors including local circumstances, the condition and extent of needed infrastructure, or population size or workforce type and habits, which may prohibit certain potential control measures from being implementable. However, in the instance where a given control measure has been applied in another NAAQS nonattainment area, the state will need to provide a detailed justification for rejecting any potential BACM or MSM measure as technologically infeasible (81 FR 58085).

A Borough referendum prohibiting regulation of home heating would not be an acceptable consideration to render potential measures technologically infeasible. The State would be responsible for implementing the regulations in the case that the Borough was not able. We believe that the most efficient path to clean air in the Borough is through a local, community effort.

- 4. <u>Economic Feasibility</u> The BACM (including BACT) and MSM analyses need to identify the basis for determining economic feasibility for both the BACM and MSM analyses. In general, the PM_{2.5} SIP Requirements Rule requires the state apply more stringent criteria for determining the feasibility of potential MSM than that used to determine the feasibility of BACM and BACT, including consideration of higher cost/ton values as cost effective.
- 5. <u>Timing</u> The evaluations will need to identify the time for selection, adoption, and implementation for all measures. BACT must be selected, adopted, and implemented no later than 4 years after reclassification (June 2021). MSM must be selected, adopted, and implemented no later than 1 year prior to the potentially extended attainment date (December 2023 at latest). The RFP section of the serious area plan will need to identify the BACM and MSM control measures, their time of implementation, and the time(s) of expected emissions reductions. Timing delays in selection, adoption, implementation are not considered for BACM and MSM.

As mentioned in the comment above in the "General" comment section, there are three criteria distinguishing between BACM and MSM, not one.

BACM - General

1. <u>BACM definition, evaluations</u> - The definition of BACM at 40 CFR 51.1000 describes BACM as any measure "that generally can achieve greater permanent and enforceable emissions reductions in direct PM_{2.5} and/or PM_{2.5} plan precursors from sources in the area than can be achieved through the implementation of RACM on the same sources." We believe that potential measures that are no more stringent than existing measures already implemented in FNSB, those that do not provide additional direct PM_{2.5} and/or PM_{2.5} precursors emissions reductions, do not meet the definition of BACM. These would need to be evaluated in the BACM and MSM analysis.

For measures that are currently being implemented in Fairbanks that provide equivalent or more stringent control, we recommend identifying the ADEC or Borough implemented measure as part of the BACM control strategy. These implemented measures should be listed in their BACM findings at the end of the document. This comment applies to all of the measures that were screened out from consideration due to not being more stringent than the already implemented measure.

The analyses for a number of measures (e.g., Measure 30, Distribution of Curtailment Program information at time of woodstove sale) conclude that the emission reductions would be insignificant and difficult to quantify and, therefore, the measure is not technologically feasible. These measures may be technologically feasible. However, if existing measures constitute a higher level of control or if implementation of the measures is economically infeasible those would be valid conclusions if properly documented. De minimis or minimal contribution is not a valid rationale for not considering or selecting a control measure or technology.

The conclusion "not eligible for consideration as BACM" is not valid as all assessments for BACM and MSM are part of the evaluation. More appropriate conclusions could include that existing measures qualify as BACM or MSM, or are more stringent. Additional conclusions could include that evaluated measures were not technologically feasible, economically feasible, or could not practically be adopted and implemented prior to the required timeframe for BACM or MSM.

- 2. <u>BACM and MSM, Ammonia</u> In the Approaches and Concepts document, Table 5 references that there are no applicable control measures or technologies for the PM_{2.5} precursor ammonia. No information to substantiate this claim are found in the preliminary draft documents. Unless NH₃ is demonstrated to be insignificant for this area, the serious area plan will need to include an evaluation of NH₃ and potential controls for all source categories including points sources.
- 3. <u>Backsliding Potential</u> When benchmarking the BACM and MSM analyses for stringency, ensure that the evaluation is based on the measures approved into the current Moderate SIP. This will relate primarily to the current ADEC/FNSB curtailment program but also other related rules. Many wood smoke control measures are interrelated, and changes to those measures may affect determinations on stringency of directly related and indirectly related measures. Examples of this can be found in multiple measures including, but not limited to Measures 5, 7, and 16.
- 4. <u>Transportation Control Measures</u> The Approaches and Concepts document, on Page 13, states that the MOVES2014 model does not estimate a PM benefit as a result of an I/M program, and therefore the I/M is not technologically feasible. This is not a valid conclusion given that the Fairbanks area operated an I/M program to reduce carbon monoxide and the Utah Cache Valley nonattainment areas has an I/M program for VOC control. This measure will need to be evaluated. Referring to the 110(l) analysis for the Fairbanks CO I/M program may provide insight into how to quantify the emissions associated with an I/M program.

With regard to control measures related to on-road sources, we have received inquiries from the community regarding idling vehicles and further evaluation emission benefits would be responsive to citizen concern and may provide additional air quality benefit.

BACM - Specific Measures

• Measure 16, page 34-35. Date certain Removal of Uncertified Devices. The "date certain" removal of uncertified woodstoves in Tacoma, Washington appears more stringent than the current Moderate SIP approved Fairbanks ordinance in terms of the regulation and in practice. While the current ordinance appears to provide similar protection during stage 1 alerts, this is dependent on 100% compliance and the curtailment program remaining in its current form. Removal of uncertified stoves guarantees reductions in emissions in the airshed during both the curtailment periods and throughout the heating season. The information provided does not support the conclusion that the Fairbanks controls provides equivalent or more stringent control. Date certain removal of uncertified wood stoves needs to be considered for the area.

Measures R4, R9, and R12, page 64, 68 and 71. These measures do not reference the Puget Sound Clean Air Agency (Section 13.07) requirement for removal of all uncertified stoves by September 30, 2015. This is equivalent to having all solid fuel burning appliances be certified and would be more stringent than the current SIP approved rules in Fairbanks. We believe that these measures need to be evaluated in the BACM and MSM analyses.

Measure R4 and R9, page 64 and 68. All Wood Stoves Must be Certified. These measure should be evaluated.

- Measure 19-20 and 25, page 36-38 and 39. Renewal and Inspection Requirements. ADEC has not adequately demonstrated their conclusion that Fairbanks has a more stringent measure than Missoula and San Joaquin. We believe that the renewal requirements and inspection/maintenance requirements associated with the Missoula alert permits and San Joaquin registrations allows the local air agency an opportunity to verify on a regular basis that the device operates properly over times. Wood burning appliances require regular maintenance in order to achieve the certified emissions ratings. The FNSB Stage 1 waivers do not have an expiration and do not have an inspection and maintenance component making it less stringent.
- Measure 31, page 43. While the Borough has SIP approved dry wood requirements that prohibit the burning of wet wood and moisture disclosure requirements by sellers, we believe that a measure limiting the sale of wet wood during the winter months should be further analyzed for BACM (and MSM) consideration.
- Measures 33, 35, 36, 37, 43. Multiple Measures identify that recreational fires have been exempted from existing regulations. Small unregulated recreational fires, bonfires, fire pits,

and warming fires have the potential to contribute emissions during a curtailment period. The FNSB and ADEC regulations should be re-evaluated for removing this exclusion.

- Measure 49, page 58. Ban on Coal Burning. We believe the regulations in Telluride are more stringent than in Fairbanks. Telluride prohibits coal burning all year whereas in Fairbanks an existing coal stove can burn when there is no curtailment which could contribute additional emissions to the airshed, especially during poor conditions when a curtailment may not have been called. We do not agree with the conclusion that the PM₁₀ controls are ineligible for consideration for control of PM_{2.5}.
- Measure R20, page 76. Transportation Control Measures related to Vehicle Idling. We have received multiple inquiries regarding community interest in controlling emissions from idling vehicles. These types of control measures should be further evaluated in the BACM and MSM analyses.
- Measure 1, page 79-81. Surcharge on Solid Fuel Burning Appliances. For purposes of implementing an effective program to reduce PM_{2.5} in the Borough we believe that a surcharge may be a helpful way to supplement limited funds. Implementation efforts within the nonattainment area could benefit from \$24,000 of additional funding whether used for a code enforcer or other support of the wood smoke programs.
- Additional controls that should be further evaluated for BACM and MSM include:
 - Measure R1, page 63: Natural gas fired kiln or regional kiln.
 - Measure R12, page 71: Replace uncertified stoves in rental units.
 - Measure R17, page 75: Ban use of wood stoves
 - Measure R6, page 65: Remove Hydronic Heaters at Time of Home Sale & Date certain removal of Hydronic heaters. We suggest evaluating these measures at the state and local level.
 - Weatherization / heat retention programs should be evaluated. These should be evaluated for existing homes through energy audits and increasing insulation and energy efficiency. For new construction, building codes (Fairbanks Energy Code) should be evaluated with reference to the IECC Compliance Guide for Homes in Alaska <u>http://insulationinstitute.org/wp-content/uploads/2015/12/AK_2009.pdf</u>, and the DOE R-value recommendations, <u>http://www.fairbanksalaska.us/wp-content/uploads/2011/07/ENERGY-CODE.pdf</u>. (Note: More recent information may be available.)
 - Fuel oil boiler upgrades / operation & maintenance programs should be evaluated.

BACM - Ultra-Low Sulfur Fuel

1. <u>Incomplete Analysis</u> - The report findings provide analysis of the demand curve over a relatively short (12 month) time frame. This analysis appears to be based on a partial equilibrium model. This is a misleading time frame given the volatility of demand side fuel oil pricing. Also, in order to determine the equilibrium price, the analysis must also analyze

the supply curve. The report does not include information about the future supply side costs but needs to in order to make conclusions about the cost to the community of ultra-low sulfur heating oil.

- <u>Analysis of Increased Supply, Consumption</u> The report does not address future change in the market nor potential economies of scale to be achieved by an increase in ultra-low sulfur fuel consumption. Page 3 of the report identifies that, "the additional premium to purchase ULS over HS, decreased significantly since 2008-2010. It is likely that, this can be attributed to increased ULS capacity." We believe that the report should further explore the supply side costs.
- 3. <u>Supply Cost Analysis</u> A supply side cost analysis is necessary to better understand the cost to the supplier to produce and provide ULS heating fuel. The BACM analysis must start with a transparent and detailed economic analysis of exclusively supplying ultra-low sulfur heating oil to the nonattainment area.
- 4. <u>BACM Assessment</u> The current analysis does not provide information needed to assess BACM economic feasibility. The report should analyze the total cost to industry of delivering ultra-low sulfur heating oil to the entire community in terms of standard BACM metrics, \$/ton.

BACT

General Comments

At this time, EPA is providing general comments based on review of the draft BACT analyses prepared by ADEC as well as addressing certain issues discussed in earlier BACT comments provided by EPA. Detailed comments regarding each individual analysis are not being provided at this time. While EPA appreciates the time and effort invested by ADEC staff in preparing the draft BACT analyses, the basic cost and technical feasibility information needed to form the basis for retrofit BACT analyses at the specific facilities has not been prepared. In other words, analyses which are adequate to guide decision making regarding control technology decisions for these rather complex retrofit projects cannot be prepared without site specific evaluation of capital control equipment purchase and installation costs, and site specific evaluation of retrofit considerations. EPA will conduct a thorough review of any future BACT or MSM analyses which are prepared based on adequate site specific information, and will provide detailed comments relative to each emission unit and pollutant at that time.

- 1. <u>Level of Analysis</u> The analyses are presented as "preliminary BACT/MSM analyses" on the website, but the documents themselves are titled only as BACT analyses and the conclusions only reflect BACT. Additionally, the determinations may not be stringent enough to be considered BACT given that better performing SO₂ control technologies have not been adequately analyzed. These analyses cannot be considered to provide sufficient basis to support a selection of MSM.
- 2. <u>Site-Specific Quotes Needed</u> The cost analyses, particularly for SO₂ control technologies, must be based on emission unit-specific quotes for capital equipment purchase and

installation costs at each facility. These are retrofit projects which must be considered individually in order to obtain reliable study/budget level (+/- 30%) cost estimates which are appropriate to use as the basis for decision making in determining BACT and potentially MSM. EPA believes that control decisions of this magnitude justify the relatively small expense of obtaining site-specific quotes.

- <u>SO₂ Control Technologies</u> The analyses must include evaluation of circulating dry scrubber (CDS) SO₂ control technology. This demonstrated technology can achieve SO₂ removal rates comparable to wet flue gas desulfurization (FGD) at lower capital and annual costs, and is more amenable to smaller units and retrofits. Modular units are available.
- 4. <u>Control Equipment Lifetime</u> The analyses must use reasonable values for control equipment lifetime, according to the EPA control cost manual (EPA CCM). EPA believes that the following equipment lifetimes reflect reasonable assumptions for purposes of the cost analysis for each technology as stated in the EPA control cost manual and other EPA technical support documents. Use of shorter lifetimes for purposes of the cost analysis must include evidence to support the proposed shortened lifetime. One example where EPA agrees a shortened lifetime is appropriate would be where the subject emission unit has a federally enforceable shutdown date. Certain analyses submitted in the past have claimed shortened equipment lifetimes based on the harshness of the climate in Fairbanks. In order to use an equipment life that is shortened based on the harsh climate, evidence must be provided to support the claim. This evidence could include information regarding the actual age of currently operating control equipment, or design documents for associated process equipment such as boilers. Lacking adequate justification, all cost analyses must use the following values for control equipment lifetime:
 - a. SCR, Wet FGD, DSI, CDS, SDA 30 years
 - b. SNCR 20 years
- 5. <u>Availability of Control Technologies</u> Technologically feasible control technologies may only be eliminated based on lack of availability if the analysis includes documented information from multiple control equipment vendors (who provide the technology in question) which confirms the technology cannot be available within the appropriate implementation timeline for the emission unit in question.
- <u>Assumptions and Supporting Documents</u> All documents cited in the analyses which form the basis for costs used and assumptions made in the analyses must be provided. Assumptions made in the analyses must be reasonable and appropriate for the control technologies included in the cost analysis.
- <u>Interest Rate</u> All cost analyses must use the current bank prime interest rate according to the revised EPA CCM. As of May 10, 2018, this rate is 4.75%. See <u>https://www.federalreserve.gov/releases/h15/</u> (go to bank prime rate in the table).
- 8. <u>Space Constraints</u> In order to establish a control technology as not technologically feasible due to space constraints or other retrofit considerations, detailed site specific information must be submitted in order to establish the basis for such a determination, including detailed drawings, site plans and other information to substantiate the claim.
- 9. <u>Retrofit Factors</u> All factors that the facility believes complicate the retrofit installation of each technology should be described in detail, and detailed substantiating information must be submitted to allow reasonable determination of an appropriate retrofit factor or whether installation of a specific control technology is technologically infeasible. EPA Region 10

believes that installation factors which would complicate the retrofit installation of the control technology should be evaluated by a qualified control equipment vendor and be reflected in a site-specific capital equipment purchase and installation quote. Lacking site-specific cost information, all factors that the facility believes complicate the retrofit installation of each technology should be described in detail, and detailed substantiating information must be submitted to allow reasonable determination of an appropriate retrofit factor. One example of the many retrofit considerations that must be evaluated is the footprint required for each control technology. A vendor providing a wet scrubber will be able to estimate the physical space required for the technology, and evaluate the existing process equipment configuration and available space at each subject facility. The determination of whether a specific control technology is feasible and what the costs will be may be different at each facility based on this and other factors. Site-specific evaluation of these factors must be conducted in order to provide a reasonable basis for decision making.

- 10. <u>Control Efficiency</u> Cost effectiveness calculations for each control technology must be based on a reasonable and demonstrated high end control efficiency achievable by the technology in question at other emission units, or as stated in writing by a control equipment vendor. If a lower pollutant removal efficiency is used as the basis for the analysis, detailed technical justification must be provided. For example, the ability of SCR to achieve over 90% NOx reduction is well established, yet the ADEC draft analyses assume only 80% control. Use of this lower control efficiency requires robust technical justification.
- 11. <u>Condensable Particulate Matter</u> Although the existing control technology on the coal fired boilers may be evaluated as to whether it meets the requirement for BACT for particulate matter, baghouses primarily reduce emissions of filterable particulate matter rather than condensable PM. Given that all condensable PM emitted by the coal fired boilers would be classified as PM_{2.5}, the BACT analyses must include consideration of control options for these emissions. Where control technologies evaluated for control of other pollutants may provide a collateral benefit in reducing emissions of PM_{2.5}, this should be evaluated as well.
- <u>Guidance Reference</u> The steps followed to perform the BACT analysis mentioned in section 2 are from draft NSR/PSD guidance. The correct reference should be 81 FR 58080, 8/24/2016. As a result of this, some of the steps outlined in the BACT analysis need to be updated.
- 13. <u>Community Burden Estimate</u> The concepts and approaches document labels capital purchase and installation costs for air pollution control technology at the major source facilities as "community burden" (see Tables 7 and 8, pages 10-11). EPA believes it is important to properly label the cost numbers being used as capital purchase and installation costs, since presenting them as community burden appears to attribute the entire initial capital investment for the various control technologies to the community in a single year, and also ignores annual operation and maintenance costs. As described in the EPA CCM, the cost methodology used by EPA for determining the cost effectiveness of air pollution control technology amortizes the initial capital investment over the expected life of the control device, and includes expected annual operating and maintenance expenses. EPA believes presentation of this annualized cost over the life of the control technology more accurately represents the actual cost incurred and is consistent with how cost effectiveness is estimated in the context of a BACT analysis.
- 14. <u>Conversion to Natural Gas</u> For any emission units capable of converting to natural gas combustion (with the requisite changes to the burners, etc), the MSM analysis in particular

should thoroughly evaluate the feasibility of this option. For example, GVEA has stated the combustion turbines at its North Pole Expansion Power Plant have the ability to burn natural gas, and the IGU has indicated the intent to expand the supply of natural gas to Fairbanks and North Pole.

APPENDIX:

Additional Comments and Suggestions

Possible Concepts and Potential Approaches

Throughout all SIP documents references to design values should include a footnote to the source of the information (e.g., "downloaded from AQS on XX/XX/XXX" or "downloaded from [state system] on XX/XX/XXX") and how exceptional events were treated.

We suggest referencing the August 24, 2016 81 FR 58010 Fine Particulate Matter NAAQS: State Implementation Plan Requirements rule with one consistent term. We suggest the 2016 $PM_{2.5}$ Implementation Rule.

Page 4, Figure 1. The comparative degree days and heating related information is better suited for the sections evaluating BACM and economic feasibility. If intending on using this information to differentiate Fairbanks from other cold climates and/or nonattainment areas, depicting comparative home heating costs would be more supportive.

Page 4, Table 1. The design values in the table and in the discussion need to be updated for 2015-2017.

Page 6-7: The "Totals" row in Table 3 (non-attainment areas emissions by source sector) does not appear to be the sum of the individual source sector emissions.

Page 7: The statement about FNSB experiencing high heating energy demand per square foot needs to be referenced.

Page 7: The discussion of Eielson AFB growth needs a reference to the final EIS.

Page 9: Table 4's title should be changed to "Preliminary Precursor Demonstration Summary"

Page 9: Table 4 includes a column "Modeling Assessment". Not all precursors were assessed with modeling, and modeling is just one tool for the precursor demonstration. A suggestion for the column title is "Result of Precursor Demonstration."

Page 9: Table 5's title should be changed to "Preliminary BACT Summary." Table 5 also needs to update the title to reference "Precursor Demonstration" as the term "Precursor Significance Evaluation" is the incorrect terminology for this analysis.

Page 10: ADEC's proposal to only require one control measure per major stationary source to meet BACT and MSM for SO₂, is not consistent with the Act or rule. As discussed above, BACM and MSM have separate definitions in 40 CFR 51.1000. By extension, the processes for
selecting BACM and MSM are laid out separately in the PM2.5 SIP Requirements Rule (compare 40 CFR 51.1010(a) for BACM and 40 CFR 51.1010(b) for MSM).

Page 10: Table 6 should identify the specific dry sorbent injection selected as BACT.

Page 11: Suggest changing "less sources" to "fewer sources."

Page 13: The statement about an I/M program providing PM benefit needs to be clarified. Is this referring just to NOx and VOC precursor contribution to PM2.5, or also direct PM2.5 benefits?

Page 14: The statement "ADEC interprets the main difference between BACT/BACM and MSM as the time it takes to implement a control" is inaccurate. As discussed above, although the rule sets our different schedules for implementation of MSM and BACM, this is not the only major difference between those concepts. Notably, the rule contemplates a higher stringency for MSM as well as a higher cost/ton threshold for determining economic feasibility of the measure.

Technical Analysis Protocol

Page 2: The design values at the top of the page need to be updated to 2015-2017.

Page 2: Recommend removing the sentence "This site will be included in the Serious SIP's attainment plan…" as the North Pole Elementary will be involved in the redesignation to attainment in the sense that all past and current monitoring data will be a part of an unmonitored area analysis to show that the entire area has attained the standard in addition to the regulatory monitor locations.

Page 2: Remove the discussion of the nonattainment area split.

Page 2: Paragraph 2, sentence 3 should refer to the unmonitored area analysis.

Page 2: The timeline described at the bottom of the page needs to be modified to reflect a current schedule. No projected year modeling was included in the preliminary draft documents. Control scenario modeling will likely not be completed in Q2 2018.

Page 3: We suggest a sentence overview of the unmonitored area analysis in Section 3.1.

Page 3: Section 3.2 needs to refer to the SPM data and how that will be used in the Serious Plan unmonitored area analysis. This section should discuss current DEC efforts to site a new monitor in Fairbanks.

Page 3: Section 3.4 needs to describe the CMAQ domain in addition to the WRF domain. A figure (map) would help.

Page 4: Section 3.5 needs a more developed discussion of the WRF assessment, including describing the criteria that were used to assess the state-of-the-art, what the current version is, and what version was used.

Page 4: Section 3.6 needs to reference all emission inventories in development, including potential attainment date extension years and RFP years.

Page 4: In Section 4.1, the statement about the Moderate SIP covering the relevant monitors for the Serious SIP is inaccurate. The statement needs to qualify whether it is referring to regulatory monitors or non-regulatory monitors. In addition, the North Pole Fire Station, NCore, and North Pole Elementary monitors were not included in the Moderate SIP.

Page 5: Table 4.1-1's title suggests that all SPM sites are listed, but only sites with regulatory monitors are listed. Please list all the SPM sites used in the unmonitored area analysis in a separate table and modify this title of Table 4.1-1 to reflect that it lists sites that are regulatory.

Page 5: North Pole Elementary was a regulatory site for a part of the baseline period and was NAAQS comparable. Table 4.1-1 needs to be updated.

Page 8: Table 4.2-1 should be updated to include 2011-2017 98th percentiles. Table 4.2-2 should be updated to include 3-year design values for 2013-2017. For clarity, we recommend the 3-year design values include the full period in order to better distinguish from Table 4.2-1. For instance, "2013" would be "2011-2013".

Page 8: The statement starting, "a clear indication..." needs to be amended or removed. It is inaccurate. The prevalence of organic carbon does not indicate the dominance of wood burning, much less a clear indication. Many sources in Fairbanks emit organic carbon.

Page 8: The statement starting "The concentration share…" need to be amended or removed. Suggest removing "drastically". There is no scientific definition of a drastic change in percentages of PM_{2.5} species, nor does the different 56% to 80% appear "drastic."

Page 9: The detailed description of the Simpson and Nattinger analysis does not reflect that SANDWICH process and it is preliminary data. It should be included within the body of the Serious Plan appendix on monitoring, but is out of place in a summary TAP.

Page 9: there are two different tables with the same table number (Table 4.3-1).

Page 10: Please clarify Table 4.4-1. This appears to be the design value calculation for the 5-year baseline design value, 2011-2015. If correct, then please label the 3-year design values according to the three years (e.g., "2011-2013"), clarify the table heading as being the "Five Year Baseline Design Value, 2011-2015 (μ g/m3)", and clarify that the last column is the 5 Year Baseline Design Value associated with the table heading.

Page 11: At the end of section 5, please refer to the emission inventory chapter's meteorological discussion of the episodes.

Page 11: Section 6 needs to justify the extent, resolution, and vertical layer structure of the CMAQ domain (and the WRF domain) or refer to where that is included in the Moderate Plan.

Page 13: We suggest changing "PMNAA" to "NAA" to be consistent with the EI chapter.

Page 15, Section 8.1: There needs to be mention of how the F-35 deployment will be considered, with a reference to the final EIS.

Page 15-19: section 8.2-8.6 use the future tense for tasks that have been completed and are inconsistent with the schedule at the beginning of the TAP. Please adjust based on current status.

Page 20, section 9.2 states that "a BACT analysis is an evaluation of all technically available control technologies for equipment emitting the triggered pollutants and a process for selecting the best option based on feasibility, economics, energy, and other impacts." This sentence should be revised to reflect that the technological feasibility assessment occurs after identification of all potential control measures for each source and source category.

Page 20, section 9.3 the second sentence should read: "BACM measures found to be economically infeasible for BACM *must* be analyzed for MSM."

Page 21: Section 10.1 needs to be updated to reflect the current CMAQ version (5.2.1) and a discussion of why that model has not been used.

Page 21: Suggest sentence starting "There will be a gap…" be changed to "There is a gap in terms of assessing the performance at the North Pole Fire Station monitor for the Serious Plan because the State Office Building in Fairbanks was the only regulatory monitor at the time of the 2008 base case modeling episodes."

Page 23: Please explain the solid and dashed lines in the soccer plot.

Page 23: Please be sure to include a full discussion of North Pole performance in this section. Even though we lack measurements, we can discuss the ratio of the modeling results at NPFS versus SOB versus that ratio from more recent monitoring data (2011-2015 baseline design value period).

Page 23: Please clarify what is meant by "Moderate Area SIP requirements."

Page 24: The discussion of the 2013 base year discusses representative meteorological conditions without describing what the representative meteorological conditions are for high PM_{2.5}. Please reference the discussion of representative meteorological conditions that will be found elsewhere in the SIP.

Page 24: The discussion of the modeling years needs to be consistent and reflect the extension request past 2019. The attainment year cannot be earlier than 2019. Each extension year must be individually requested. For modeling efficiency, we recommend starting with 2024. If that year attains, then 2023 and so on until we have one year that attains and the year before that does not. This should give us the information about what is the earliest year for attainment.

Page 25: We suggest changing "modeling design value" to "design value for modeling"

Page 26: Please clarify the "SMAT" label in the tables. They may be the SANDWICH concentrations and the "5-yr DV" rows are the SMAT concentrations. Please clarify the units in the rows.

Emission Inventory

Clarification – In the EI document we would like to understand the functional difference between the base year, and baseline year

Please identify the methodology for generating ammonia and condensable PM emissions numbers.

Page 1: Please be consistent in "emission inventory" versus "emissions inventory".

Page 1: "CAA" to "Clean Air Act" for clarity

Page 3: It would be helpful to refer to 172(c)(3) in Section 1.2, bullet 1 as the planning and reporting requirements.

Page 5: Please include extension years and RFP years in Table 1's calendar years similar to what was done for Table 2. There should be one RFP projected inventory and QM beyond the extended attainment date. It would be helpful to include basic information about extension years and RFP years to better foreshadow Table 2.

Page 7: Please clarify the "winter season" inventory as the "seasonal" inventory that represents the daily average emissions across the baseline episodes.

Page 7, paragraph 1. Please include reference documentation for the following statement, "results in extremely high heating energy demand per square foot experienced in no other location in the lower-48."

Page 9: Please change "Violations" to "Exceedances." Exceedance is the term for concentrations over the standard. Violations is the term for dv over the standard.

Page 9: Add "No exceedances were recorded outside the months tabulated in Table 3 that were not otherwise flagged by Alaska DEC as Exceptional Events.", to the end of the last paragraph on the page.

Page 13: Please clarify the provenance of the BAM data (e.g., "downloaded from [state database or AQS] on XX/XX/XXXX). In particular, it is important to note if the data has been calibrated to the regulatory measurement (aka, corrected BAM).

Page 17-18. Sentence Unclear "For example, a planning inventory based on average daily emissions across the entire six-month nonattainment season will likely reflect a relatively lower fraction of wood use-based space heating emissions than one based on the modeling episode day average since wood use for space heating Fairbanks tends to occur as a secondary heating source on top of a "base" demand typically met by cleaner home heating oil when ambient temperatures get colder."

Page 19: Remove "Where appropriate,". All source sectors should be re-inventoried for 2013, even if the emissions for the sector ends up being the same as in 2008.

Page 19: Change "projected forward" to "re-inventoried", or similar wording. Reserve "project" for when the emission inventory is estimating emissions in a future year.

Page 20: Please refer to EPA's memo on the use of MOVES2014a for the plug in adjustment. As a reminder, this information is sufficient only for development of the emissions inventory, not for SIP credit.

Page 20: Please submit the technical appendix referenced on page 20. When that is submitted, we expect to provide additional comment. To allow for review, we request expedited submission.

Page 21: At bottom of page, "project" should be "re-inventoried" or something that refers to an inventory produced after the fact.

Page 22, paragraph 1, Space heating area sources. Please further explain how the combined survey data best represents 2013 emissions.

Page 23: Add information about how NH₃ was inventoried for this category.

Page 23, 2nd paragraph from bottom. Facilities need to provide direct PM and all precursors, whether directly submitted or calculated from emissions factors.

Page 23, last paragraph.

- Potential typo we believe that 2018 should be 2013.
- Question Does scaling emissions cause any point source to exceed its PTE?

Page 25, bullet 3, Laboratory – Measured Emissions Factors for Fairbanks Heating Devices. The statement "first and most comprehensive systematic" would be more credible if simplified.

Page 27: Clarify how data from the 2014 NEI was modified to reflect emissions in 2013. Were they assumed to be the same between the two years? Or adjusted based on population change, or some other information?

Page 33: Please include information on how the Speciate database was used to develop the modeling inventory (and perhaps elsewhere for the planning inventory, if appropriate).

Precursor Demonstration

Throughout the Serious Area SIP we recommend using the terminology, Precursor Demonstration, to be consistent with the PM_{2.5} Implementation Rule.

General: The overview of the nitrate chemistry is complicated. We suggest you combine the two discussions into one and organize it with the following logic:

- 1. Describe the two chemical environments: (1) daytime and (2) nighttime.
- 2. Describe the information that supports that daytime chemistry is not relevant here.
- 3. Describe the information that supports that nighttime chemistry is limited by excess NO.

- 4. Describe what happens if the entire emission inventory was increasing by a factor of 3.6 to get appropriate concentrations in the North Pole area. How does ammonium nitrate change?
- 5. Describe how increasing the emission inventory and then reducing all source sectors by 75% results in less of a reduction in $P_{M2.5}$ than reducing all source sectors by 75% in the original emission inventory.
- 6. NOTE: We are willing to provide a rough draft of this organization, if provided the original word document.

Title page: remove "com"

Page 2: Recommend using Section 188-190 instead of 7513-7513b.

Page 2: Recommend moving the last three sentences of the first paragraph to the end of the second paragraph.

Page 2: Please add "threshold" after 1.3 in the third paragraph.

Page 2: Please explain concentration-based and sensitivity-based before using the terms.

Page 2: Please add a footnote whether the numbers in the Executive Summary are SANDWICHed or not.

Page 3: Please change "has decided" to "decided."

Page 3: Make sure the concentrations listed for ammonia include ammonium sulfate and ammonium nitrate.

Page 5-7: The figure captions say that concentrations are presented but the images themselves have percentages. Please use concentrations for this analysis.

Page 9: The first paragraph says that the point sources are not responsible for the majority of sulfate at the monitors. Please substantiate that claim, or modify it.

Page 13: Please explain the relevance of referring to the VOC emissions of home heating in this summary of VOCs.

Page 14: Recommend adding "... and adjusted to reflect speciated concentrations for a total PM2.5 equal to the five year 2011-2015 design value" to the sentence that starts "The speciated PM2.5 data [were] analyzed.

Page 14: Please include the results of the concentration based analysis, perhaps as a table.

Page 14: Clarify that the concentration used for NH₃ is the ammonium sulfate and ammonium nitrate. See the draft EPA Precursor Demonstration Guidance.

Page 17: Recommend removing "slightly" and removing the sentence referring to rounding to the nearest tenth of a microgram.

Page 17-18: To help understand what is going on with the bounding run versus the normal run, it would be helpful to have the RRFs for the Modeled 75% scenario.

BACM

Page 9 and throughout: For clarity, please refer to the implementation rule as "PM_{2.5}" not "PM".

Page 14, Table 3. It would be helpful to include filter speciation data.

Page 16, Table 4: Please identify the RACM measures that were technologically and economically feasible but could not be implemented in the RACM timeline or note there were none.

Page 20 and 25, Table 6 and 7: For the final Table identifying the control measures evaluated, it would be helpful to identify the following: measure, cost/ton, BACM determination, MSM determination, and any additional comments.

Page 24: 12 measures were eliminated because they were determined to offer marginal or unquantifiable benefit. However, a measure may offer marginal benefit but may also cost very little. If there is another explanation for why these measures were not considered that follows the BACM steps, please include that in the Serious Area Plan.

Page 28: Stage 1 alerts are referred to multiple times including in Measure 2 on page 28 and Measure 33, pg 47 and pg 48. Please clarify in these analyses whether the measure applies during all stages of alerts and the associated level of control with each stage.

Page 33: Measure 13 identified that no SIPs existed or EPA guidance/requirements for the measure and incorrectly used that rationale as the conclusion for not considering the measure.

Page 34: The discussion of Measure 15 does not clearly state how Alaska and the Borough ensure that devices are taken out at the point of sale. It also does not clearly state the process for ensuring a NOASH application doesn't involve a stove that should have been taken out at the point of sale. It also states that stoves between 2.5 g/hr and 7.5 g/hr can get a NOASH, whereas page 37 implies that a stove must be <2.5 g/hr to be eligible for a NOASH.

Page 47: Measure 33 in Klamath County and Feather River is more stringent than what exists in Fairbanks now. Fairbanks allows open burning without a permit when there is no stage restriction. Alaska DEC prohibits open burning between November 1 and March 31, but the air quality plan makes it clear that the state relies on the Borough to carry out the air quality program in Fairbanks. The fact that the local borough does not require a permit for open burning outside of curtailments makes this measure less stringent in Fairbanks than in other locations. In addition, Fairbanks does not curtail warming fires during a Stage 1.

Page 48: Measure 34 is less stringent in Fairbanks than in Klamath County. Uncertainty in weather forecasting means that Stage 1 alerts are not called correctly all the time, and not

everyone is aware of when an alert is in effect. It is much simpler and less prone to error to prohibit burn barrels and outdoor burning devices entirely.

Page 57: Measure 46 review curtailment exemptions. The current Fairbanks curtailment exemption "These restrictions shall not apply during a power failure." should be reviewed to clarified that it only applies to homes reliant on electricity for heating. As currently written, it appears overly broad.

Page 68: Measure R7, Ban Use of Hydronic Heaters, incorrectly identifies that no other SIPs implemented the measure as rational for not evaluating.

Page 72: Measure R15 is technologically feasible.

Page 78: It may help to make a section break or Section 2 label for "Analysis of Marginal / Unquantifiable Benefit BACM Measures

Page 81-83: The discussion of Measure 6 may need additional documentation. Anecdotal evidence is that damping is common in Fairbanks and is potentially a bigger source of pollution than not having a damper at very cold conditions. If installation by a certified technician addresses this issue, that should be documented.

Page 84: The quote, "did not know if the rule had worked well" needs a reference. It is also not clear of how relevant that is. It could be implemented well in Fairbanks and the fact that it may not have worked well in another location does not make it technologically infeasible for this location.

Page 85-86: While qualitative assessments are helpful to provide context, a quantitative assessment will be necessary to evaluate the measures as BACM and MSM.

Page 88: There are references to Fairbanks in the conclusion for Measure 17, but the analysis refers to AAC code.

Page 89: There appears to be missing text in the Background section related to Method 9.

Page 91: Measure 23 could consider the solution that the decals could be reflective and would be seen by vehicle headlights. Measure 23 could also consider that the decals are used by neighbors to determine who is or is not in compliance. This may be helpful as citizen compliance assistance efforts could supplement the Borough enforcement program.

Page 98-100: Measure 40 needs to include a discussion of all the areas listed on page 22. In addition, if a date certain measure or if Measure 29 were instituted, Measure 40 would essentially be achieved.

Page 114: Measure R5 describes a similar rule in Utah but lists "none" under implementing jurisdictions. Please make consistent.

ULS Heating Oil

Page vii and Page 16: Please check your information on the percentage of households who have a central oil fired furnace. Please consult ADEC's contractor for the emissions inventory and home heating surveys about (1) the percentage of homes that heat only with an oil furnace, and (2) home with a central oil burner and a wood stove. We have seen different numbers than presented here.

Page 13: Please check the labels for Fairbanks HS #2 and Fairbanks HS #1. They may be switched.

Page 14: The statement that there is "a clear explanation" may not be correct, or at minimum is an overstatement. The difference in price between HS#1 and ULSD has varied over time, and the report did not include an explanation for the variations.

Page 14: The third paragraph assumes that the capital costs of shipping ULS would be more than exists today. However, all heating oil is shipped, regardless of sulfur content, and there is no justification for the report for why shipping ULS would be higher than for HS. Additionally, it is possible that the shipping cost per unit could go down marginally if only one product is being supplied to Fairbanks and/or if the quantity supplied increases.

Page 21: The text and Table 7 present inconsistent information. For instance, the text says that the discounted net-present value of scenario 2 is \$10,232 while the table says it is \$5,768.56.

Adopted



November 1, 2018

Alaska Department of Environmental Conservation Division of Air Quality ATTN: Director 410 Wiloughby Avenue, Suite 303 Juneau, Alaska 99811-1800

Subject: Second Request for Additional Information for the Best Available Control Technology Technical Memorandum from Aurora Energy, LLC (Aurora) for the Chena Power Plant.

Dear Ms. Koch,

Thank you for the opportunity to provide additional information to better characterize Aurora's operations for the Best Available Control Technology (BACT) Analysis which will be a part of the Serious Area State Implementation Plan.

The following is being provided in response to the information request letter dated September 13, 2018. The ADEC letter included an enclosure with twelve comments for which additional information was requested. Each comment is summarized below followed by a response from Aurora. The information is being submitted to the ADEC by November 1, 2018 as requested.

 <u>Alternative Fuel Source</u> - Evaluate alternative coal sources as a potential control option for the coal-fired boilers and identify energy, environmental, and economic impacts and other costs that would affect the selection of an alternative source of coal as a technically feasible control option. Evaluate the control efficiency of alternative coal sources based on a comparison of the coal's heat content as well as nitrogen and sulfur content.

<u>Response</u>: There are no other economically viable coal options for Aurora. Usibelli Coal Mine is the state's only operating coal mine.

2. <u>Low Excess Air (LEA) and Overfire Air (OFA)</u> - Evaluate these technically feasible control technologies using EPA's top down approach.

<u>Response:</u> Aurora's BACT analysis dated March of 2017, Section 2.3.2, references the use of combustion controls, including OFA and LEA. The BACT analysis concludes that the Unit 5 (EU 7) is already equipped with OFA, LEA (i.e., oxygen trim system), and air preheaters. It is stated within the BACT that Units 1, 2, and 3 (EU 4-6) have OFA and air preheaters. Although the air preheater ductwork is installed, the preheaters have been removed from operation. The current

configuration of the traveling-grate boilers as installed, includes a 'partial' LEA (i.e., oxygen trim system). The fuel feed rate and oxygen for Boiler Units 1-3 (EU 4-6) are manually adjusted and tuned daily. The traveling-grate boilers have a knife gate which sets the bed thickness and the air-to-fuel ratio is manually adjusted to accommodate the boiler's performance. Once adjusted, the fuel-to-air ratio is maintained automatically.

 <u>Additional SO₂ Control Technologies</u> - The BACT analysis does not include a substantive analysis of spray-dry scrubbing, dry flue gas desulfurization, dry scrubbing, or dry sorbent injection (DSI). All of these technologies have the potential to offer SO2 removal, and therefore must be included in the analysis.

<u>Response:</u> - An addendum to the initial BACT submittal was provided to the State on December 22, 2017. This addendum included a substantive analysis of Spray Dry Absorbers (SDA) and Dry Sorbent Injection (DSI) technologies.

4. <u>BACT Limits</u> - Provide numerical emission limits (and averaging periods) for each proposed BACT selection, or justify why a measurement methodology is technically infeasible and provide the proposed design equipment, or work/operational practices for pollutant for each emission unit included in the analysis. Startup, Shutdown, and Malfunction (SSM) must be addressed in the BACT analysis. In no event shall application of BACT result in emissions of any pollutant which would exceed the emissions allowed by an applicable standard under 40 C.F.R. parts 60 (NSPS) and 61 (NESHAP).

<u>Response</u>: Statements concerning applicable standards under 40 CFR Parts 60 (New Source Performance Standards—NSPS) and 61 (National Emission Standards for Hazardous Air Pollutants—NESHAP) are not relevant to the Chena boilers. The NESHAP do not regulate criteria air pollutants such as SO₂, and therefore, no SO₂ floor can be defined by any NESHAP. Furthermore, the Chena boilers are not subject to NSPS and therefore are not required to achieve the NSPS standard. In any case, the NSPS SO₂ emission limit of 1.2 lb/MM Btu (for units less than 75 MM Btu/hr) is achieved in the small boilers (the percent reduction is not a requirement for units less than 75 MM Btu/hr).

An NSPS or NESHAP standard must be considered as the floor for BACT only when a source is subject to one of the standards. In that case, a source must achieve compliance with the NSPS or NESHAP, and a less stringent emission limit cannot be considered BACT. As noted in a July 28, 1987 memo by Gary McCutchen, then Chief of the New Source Review Section of the US EPA:

"Since an *applicable* NSPS must always be met, it provides a legal "floor" for the BACT, which cannot be less stringent." (emphasis added). This statement implies that a source must first be subject to an NSPS for the standard to be considered the BACT floor.

The Chena plant operates four coal-fired boilers: three at 76.8 MM Btu/hr (22.5 megawatt, MW) heat input and one at 254.7 MM Btu/hr (74.6 MW) heat input. If newly-constructed today, the three smaller units would be subject to an NSPS Subpart Dc limit of 1.2 lb SO₂/MM Btu, and the larger unit would be subject to an NSPS Subpart Da limit of 0.15 lb SO₂/MM Btu. On a Btuweighted average basis, the overall NSPS limit would be 0.64 lb SO₂/MM Btu. The Chena boilers

currently combust low-sulfur coal, with emissions of 0.39 lb SO_2/MM Btu from the combined exhaust. This overall emission rate represents a 39% reduction from NSPS limits if the Chena boilers had been built today.

Regardless of the NSPS applicability to the Chena boilers, the history of rulemaking for small industrial, commercial, and institutional (ICI) boilers provides valuable insight into the definition of BACT for SO₂ from these units. The three smaller units, if constructed today, would be subject to NSPS Subpart Dc for small ICI boilers. As defined in the standard, ICI units smaller than 22 MW (75 MM Btu/hr) heat input are not subject to a percent reduction requirement in NSPS and instead may achieve compliance with NSPS through the use of low-sulfur fuel. The rationale for this "exemption" is provided in the preamble to the proposed rule (54 *Federal Register* (FR) 24806, June 9, 1989) and the Background Information Document for the Promulgated Standards. As discussed in the Background Document:

"Section 111 of the CAA requires standards to reflect application of the best demonstrated technology considering costs, nonair quality health and environmental impacts, and energy requirements. Section 111 also requires that for fossil fuel-fired steam generating units a percent reduction standard be established. Read together, this means that the Administrator is compelled to include a percent reduction standard unless the impacts associated with the requirements would be unreasonable....Imposing these high (capital and annualized) costs for the units (those less than 22 MW) was considered to be unreasonable when compared to the increase in emission reduction achievable be the percent reduction requirement on these units. Therefore, in keeping with the requirements of the CAA, the final standards will not require percent reduction for any units operating at less than a 55 percent annual capacity factor for coal or any unit with a heat input capacity of 22 MW (75 million Btu/hr) or less."

The passage presented above is the basis for the US EPA's definition of BACT for small ICI boilers less than 22 MW. This analysis therefore defines BACT for such units as an emission rate equal to or greater than 1.2 lb SO₂/MM Btu. In the proposed rule, US EPA further states that compliance with this NSPS limit/ BACT emission rate for units smaller than 22 MW (75 MM Btu/hr) can be achieved through use of low-sulfur fuels (see 54 FR 24793). For all practical purposes, the three smaller boilers at the Chena plant fall into this category, and therefore BACT is defined as an emission limit of 1.2 lb SO₂/MM Btu, achieved through combustion of low-sulfur coal. Furthermore, as illustrated above, the four boilers at the Chena plant collectively operate with an actual SO₂ emission level that is 39 percent less than the levels that would be required if all of the units were subject to NSPS.

5. <u>Retrofit Costs</u> - Provide detailed cost analyses and justification for difficult retrofit (1.6 – 1.9 times the capital costs) considerations used in the BACT analysis.

<u>Response</u>: The BACT cost analysis employed a retrofit factor of 2.0. The basis for this factor was the EPA Air Pollution Control Cost Manual, Sixth Edition. As discussed in the Cost Manual:

"To quantify the unanticipated additional costs of installation not directly related to the capital cost of the controls themselves, engineers and cost analysts typically multiply the

> cost of the system by a retrofit factor. The proper application of a retrofit factor is as much an art as it is a science, in that it requires a good deal of insight, experience, and intuition on the part of the analyst....The magnitude of the retrofit factor varies across the kinds of estimates made as well as across the spectrum of control devices. At the study level, analysts do not have sufficient information to fully assess the potential hidden costs of an installation. At this level, a retrofit factor of as much as 50 percent can be justified. Even at detailed cost level (± 5 percent accuracy), vendors will not be able to fully assess the uncertainty associated with a retrofit situation and will include a retrofit factor in their assessments." (see page 2-28 in EPA/452/B-02-001)

As noted in the above citation, US EPA notes that a retrofit factor can be as high as 1.5, this partially supports the value selected for the Chena BACT cost analysis. The cost model employed during the BACT analysis (i.e., CUECost) suggests the following retrofit factors: 1.0 factor for a new facility, a 1.3 factor for a moderately difficult retrofit, and a 1.6 factor for a difficult retrofit. The user is also given the option to input his own retrofit factor based on plant-specific information. As noted by the Northeast States for Coordinated Air Use Management (NESCAUM) in a in a report entitled "Applicability and Feasibility of NOx, SO2, and PM Emissions Control Technologies for industrial, Commercial, and Institutional (ICI) Boilers an independent researcher (Emmel) noted that:

"this range (of CUECost retrofit factors) significantly understated the cost of retrofit for FGD and SCR technologies when applied to EGUs (i.e., electric generating units) less than 100 MW. Emmel also noted that on average, a retrofit factor of 1.45 was more reasonable and that the factor should even be higher when CUECost is applied to ICI boilers."

Two main factors impact selection of the retrofit factor for the Chena plant: space availability and equipment congestion. These two factors will require additional efforts for installation, equipment staging, and maneuverability during construction.

6. <u>Baseline Emissions</u> - Include the baseline emissions for all emission units included in the analysis. Typically, the baseline emission rate represents a realistic scenario of upper bound uncontrolled emissions for the emissions unit (unrestricted potential to emit not actual emissions). The baseline is usually the legal limit that would exist, but for the BACT determination.

<u>Response</u>: The Baseline Emission rate is not a legal limit. As stated in the U.S. EPA 1990 New Source Review Workshop Manual:

"Calculating Baseline Emissions"

The baseline emissions rate represents a realistic scenario of upper boundary uncontrolled emissions for the source. *The NSPS/NESHAP requirements or the application of controls, including other controls necessary to comply with State or local air pollution regulations, are not considered in calculating the baseline emissions.* In other words, baseline emissions are essentially uncontrolled emissions, calculated using realistic upper boundary operating assumptions. (emphasis added)"

Based on this guidance, the Chena baseline emissions were properly calculated and applied to the BACT analysis.

7. <u>Factor of Safety</u> - If warranted, include a factor of safety when setting BACT emission limitations. The safety factor is a legitimate method of deriving a specific emission limitation that may not be exceeded. These limits do not have to reflect the highest possible control efficiencies, but rather, should allow the Permittee to achieve compliance with the numerical emission limit on a consistent basis.

<u>Response</u>: The current BACT analyses included operating as is, therefore a factor of safety was not included.

8. <u>Good Combustion Practices</u> - For each emission unit type (coal boilers, distillate boilers, engines, and material handling) for which good combustion practices was proposed as BACT, describe what constitutes good combustion practices.

<u>Response</u>: Good combustion practices were not proposed. The operation of existing combustion controls (OFA & LEA) were determined to be BACT for NOx.

 Interest Rate - All cost analyses must use the current bank prime interest rate. This can be found online at <u>https://www.federalreserve.gov/releases/h15/</u> (go to bank prime rate in the table). Please revise the cost analyses as appropriate.

<u>Response</u>: Suggest that the State revise interest rate to prime (currently 5.25%) and equipment life to 10 years, not 15, due to corresponding short remaining lifespan of associated boilers.

10. <u>Economic Analysis for Circulating Dry Scrubber (CDS)</u> - Provide in the analysis: the control efficiency associated with CDS, captured emissions (tons per year), emissions reduction (tons per year), capital costs (2017 dollars), operating costs (dollars per year), annualized costs (dollars per year), and cost effectiveness (dollars per ton) using EPA's cost manual.

Response: See attached memo "CDS v SDA Cost Comparison.pdf" for CDS analysis.

11. <u>Review State's Spreadsheets</u> – Review cost effectiveness spreadsheet provided as a part of the preliminary SO₂ BACT determination which was originally developed by Sargent & Lundy (S&L) in 2010.

<u>Response</u>: Aurora has provided a review of the ADEC's cost effectiveness spreadsheets and inputs. Comments are included on the spreadsheets. Please reference documents "chena-so2-economic-analyses-adec--With ERM Comments.xlsm" and "chena-large-boiler-so2-economic-analyses-adec--With ERM Comments.xlsm".

12. <u>Site-Specific Quotes Needed</u> - The cost analyses, particularly for SO2 control technologies, must be based on emission unit-specific quotes for capital equipment purchase and installation costs at each facility. These are retrofit projects which must be considered individually in order to obtain reliable study/budget level (+/- 30%) cost estimates which are appropriate to use as the basis for decision making in determining BACT.

<u>Response</u>: Included as attachments within this response are vendor quotes as well as a cost analysis for Dry Sorbent Injection (DSI). Due to time constraints, the consultant was able to provide a +50/-30 cost estimate. Please reference the enclosed documents, to include: "Aurora Energy Preliminary Opinion of Probable Cost.pdf";

"Aurora_DSI_Opinion_of_Probable_Cost_rev0.pdf"; "BACT Proposal No. 1899-R1.pdf"; and "Aurora_Chena_DSI_General Arrangement.pdf".

Below are a list of documents that are being provided as enclosures which are referenced within the responses given above. If there are any questions pertaining to the information provided, please contact David Fish at <u>dfish@usibelli.com</u> or 907-457-0230.

Sincerely,

David Fish Environmental Manager

Enclosures:

- 1. CDS v SDA Cost Comparison.pdf
- 2. chena-so2-economic-analyses-adec--With ERM Comments.xlsm
- 3. chena-large-boiler-so2-economic-analyses-adec--With ERM Comments.xlsm
- 4. Aurora Energy Preliminary Opinion of Probable Cost.pdf
- 5. Aurora_DSI_Opinion_of_Probable_Cost_rev0.pdf
- 6. BACT Proposal No. 1899-R1.pdf
- 7. Aurora_Chena_DSI_General Arrangement.pdf
- 8. Unified Facilities Criteria (UFC) DoD Facilities Pricing Guide (ufc_3_701_01_c1_2018.pdf)
- 9. ufc_3_701_01_data_tables_may_2018.xlsx
- 10. NSPS ICI SO2 RE.docx
- 11. ICI Boilers 20081118 final_revised-Jan2009.pdf
- 12. EPA Air Pollution Cost Control Manual, sixth edition, January 2002, accessible at https://www3.epa.gov/ttncatc1/dir1/c_allchs.pdf.

Cc:

Larry Hartig, ADEC/Commissioner's Office Alice Edwards, ADEC/ Commissioner's Office Denise Koch, ADEC/ Air Quality Cindy Heil, ADEC/ Air Quality Deanna Huff, ADEC/ Air Quality Jim Plosay, ADEC/ Air Quality Aaron Simpson, ADEC/ Air Quality Buki Wright/ Aurora Energy, LLC Rob Brown/ Usibelli Coal Mine, Inc. Tim Hamlin/ EPA Region 10 Dan Brown/ EPA Region 10 Zach Hedgpeth/ EPA Region 10



STANLEYCONSULTANTS, Inc

8000 South Chester Street > Suite 500 > Centennial, CO 80112 303.799.6806 > stanleyconsultants.com

November 1, 2018

David Fish Environmental Manager Aurora Energy, LLC 100 Cushman St. Suite 210 Fairbanks, AK 99701-4674

RE: Qualitative Cost Comparison of Circulating Dry Scrubber Technology Versus Spray Dryer Absorbers

David:

Per your request Jason Smith and I have developed a comparison between the Circulating Dry Scrubber and Spray Dry Absorption technologies and the expected differences in total installed cost. Jason is an expert in SO₂ scrubbers having participated in the construction, startup, and commissioning of several installations over the course of his career.

The two commercially available semi-dry acid gas scrubbing processes consist of Spray Dryer Absorption (SDA) and Circulating Dry Scrubber (CDS). Both technologies, for industrial coal fired applications, employ an alkaline reagent of calcium hydroxide and fly ash, which is collected from the combustion process. The calcium hydroxide reacts with sulfur dioxide (SO2) and sulfur trioxide (SO3) of the flue gas to form calcium sulfite and calcium sulfate. The calcium sulfite and calcium sulfate, unreacted calcium hydroxide, and fly ash is collected downstream of the acid gas scrubbing process by a baghouse, and a considerable portion is "recycled," back to the scrubber to offset reagent costs by utilizing available unreacted alkalinity of the fly ash. The fly ash particles also serve to increase the available surface area for reactions to occur. Both process also depend on the humidification of the flue gas. In general, the greater the humidification, the lower the alkalinity stoichiometry, which reduced reagent consumption. To prevent corrosion downstream of these scrubbers and promote the longevity of downstream equipment (namely fluework, particulate collection, and stack), the humidification is limited to operating above the saturation temperature, referred to as the approach temperature.

The humidification of the flue gas stream is an area where the SDA and CDS scrubbing processes diverge.

In the SDA process, water for humidification is delivered as a portion of the lime and ash constituents. The water, lime, and ash slurries are pumped through recirculation loops and fed to an atomization feed system. The slurry that is fed to the atomizer is then dispersed in a passing flue gas stream inside an absorber or scrubber vessel. Once dispersed in the flue gas, a chemical reaction occurs, and the gas stream is scrubbed of the SO₂ and SO₃ pollutants. Since the slurry reagent is pumped, the SDA process can sometimes leverage existing infrastructure such as existing particulate collection equipment. The ability to integrate a SDA system into an existing flue gas system serves to limit the capital outlay necessary for a targeted level of compliance. The potential to leverage existing infrastructure is dependent on



numerous factors such as existing equipment layout and condition, site spatial limitations, and original design parameters of the existing particulate collection equipment, just to name a few.

The humidification of the flue gas stream for a CDS scrubbing process is essentially decoupled from the hydrated lime and ash constituents. Water for gas humidification is mechanically atomized into the passing flue gas stream and the dry alkaline products are conveyed to the CDS vessel using air slide conveyors. Air slide conveyors utilize an air permeable fabric, which is stretched across a rectangular enclosure flow path, to aerate particulate material, and allow the force of gravity to covey the material down the sloped surface. The alkaline material and water injection typically occurs after a venturi assembly that increases the velocity of the passing gas stream to establish a fluidized bed of alkaline material. The flue gas then passes through this bed and is scrubbed of the SO_2 and SO_3 . The use of air slides to convey the fly ash from the particulate collection device (typically a baghouse) back to the scrubber necessitates that the collector be placed at higher elevations. This will ensure that the proper slope is maintained between the collector and the injection point on the absorber tower. It is technically challenging to take an existing collector and elevate it, so CDS technologies are typically purchased with an absorber vessel, air slides, particulate collection device, and waste ash systems. This allows the integration of the required elevation differences and the steel and foundations to accommodate the higher elevation construct to be handled under a single contract, thus limiting risk for the owner. Due to the additional equipment, steel, and deep foundations necessary, these factors typically increase the necessary capital outlay for the CDS technology.

Additional information on both SDA and CDS technology can be found in Chapter 34 of *STEAM, Its Generation and Use, 42nd Edition*, Babcock and Wilcox, Inc. Reference Figure 10 on Page 34-15 for an illustration of a typical SDA installation and Figure 17 on Page 34-21 for an illustration of a typical CDS installation.

The information above indicates that CDS and SDA technologies are similar in their nature and operation. However, the installation of a CDS frequently requires the installation of a new particulate collector, where the SDA system does not. The CDS equipment itself, along with the additional equipment needed for proper operation, will result in a significantly larger installation cost when compared to an equivalent SDA system. Given that the ADEC Preliminary BACT Determination for the Chena Plant (Dated March 22, 2018) has already established that a SDA system is not economically feasible (Table 4-3, Page 12), it can therefore be concluded that the CDS system is economically infeasible as well.

Please let me know if you have any questions or comments regarding the information presented in this letter.

Sincerely,

John P Solan

John P. Solan, P.E. Senior Mechanical Engineer Stanley Consultants, Inc.

cc: File



STANLEYCONSULTANTS, Inc

 ∞

8000 South Chester Street > Suite 500 > Centennial, CO 80112 303.799.6806 > stanleyconsultants.com

October 30, 2018

David Fish Environmental Manager Aurora Energy, LLC 100 Cushman St. Suite 210 Fairbanks, AK 99701-4674

RE: Preliminary Opinion of Probable Cost for Addition of Dry Sorbent Injection

David,

This letter serves to document the preliminary results of our opinion of probable cost for the installation of a Dry Sorbent Injection (DSI) System at the Aurora Energy Chena Plant for the control of Sulfur Dioxide (SO₂) emissions.

Background

The US Environmental Protection Agency (EPA) has recently reclassified portions of the Fairbanks North Star Borough as a Serious PM 2.5 Non-Attainment Area. This reclassification triggers a requirement that all major sources within the non-attainment area perform a BACT analysis for particulate emissions and the emissions of any precursor pollutants. In response to this requirement Aurora Energy submitted the required BACT report to the Alaska Department of Environmental Conservation (ADEC) in March of 2017. An addendum to the report was submitted in December of that year.

After reviewing the data and conclusions presented in the BACT report, ADEC conducted their own analysis and presented their results as a Preliminary BACT Determination in March of 2018. The results developed by ADEC as a part of their analysis were significantly different from the results presented in the BACT report submitted by Aurora Energy.

Project Scope

Given the disparity in the results of the analyses, Aurora Energy has hired Stanley Consultants to develop a site-specific, third-party estimate of the costs to install SO₂ emissions control equipment on the four operating boilers at the Chena Combined Heat and Power Plant near downtown Fairbanks. Stanley Consultants will also provide an estimated sorbent consumption rate and a cost for the purchase and delivery of sorbent to site. Once these costs have been developed, Aurora Energy and their environmental consultants, ERM, will incorporate the estimated costs into a calculation to determine the cost effectiveness of the emissions control equipment on a Dollars/Tons of SO₂ removed basis.

This letter serves to document the preliminary Opinion of Probable Cost results so that Aurora Energy can submit a response to the BACT Determination ahead of a November 1, 2018 deadline. The information included herein relates only to the installation of a DSI system on the existing boilers. All performance information, quantities, and costs are preliminary and are



November 19, 2019 David Fish October 30, 2018

subject to revision as the cost estimate is refined and finalized. Additional clarifications as to the basis of the cost estimate and the anticipated performance are included below.

Design Basis

Boiler Performance and Flue Gas

Boiler heat input, flue gas flows, and uncontrolled SO₂ emissions rates from the previous reports were utilized to determine equipment sizes and required sorbent feed rates

Dry Sorbent Unloading, Storage, Preparation, and Injection System

Equipment and piping costs for the Dry Sorbent Injection Systems were developed by BACT Process Systems, Inc. BACT supplied the DSI system that was recently installed at Eielson AFB, and therefore was already familiar with the emissions from burning Healy coal in stoker-type boilers. The BACT proposal includes:

- Sorbent unloading equipment suitable for transporting sodium bicarbonate from a railcar to a bulk storage silo. This equipment includes unloading blowers, coolers, piping and piping components.
- Two bulk storage silos with a total storage capacity that is sufficient for four months of continuous full load operation.
- Sorbent transfer equipment for moving the sorbent from the bulk storage silos to the day bins located in a sorbent preparation building including transport blowers, coolers, and associated piping
- Sorbent mills for optimizing the particle size of the sorbent prior to injection into each boiler flue
- Sorbent injection equipment including filter receivers, airlock feeders, blowers, coolers, and piping up to the wall of the sorbent preparation building.
- Sorbent injection lances
- Dedicated PLC's for the control of all equipment included in the proposal
- Engineering to facilitate the integration of the sorbent control system into the plant control system
- Computational Fluid Dynamics (CFD) of each flue to confirm predicted sorbent effectiveness

Additional equipment or systems that are required for proper operation of the DSI system, but was not included in the BACT proposal have been included separately in the cost estimate. This includes:

- Piping between the sorbent preparation building and the injection lance on each flue
- Additional ductwork on Boiler 5 to increase sorbent resonance time prior to the baghouse
- Electrical feeds and equipment required to support the BACT equipment
- Foundations
- Sorbent preparation building and interior structures
- Miscellaneous steel and supports



November 19, 2019 David Fish October 30, 2018

Equipment Layout

The cost estimate is based on the following approximate equipment locations

- Unloading Equipment Adjacent to the unloading building on the north side of Phillips Field Road
- Bulk Storage and Transfer Equipment Adjacent to the existing coal pile on the south side of Phillips Field Road.
- Sorbent Preparation Building Adjacent to the existing baghouse

See the attached sketch for additional information on the proposed equipment locations and interconnecting piping.

Opinion of Probable Cost

Based on the information above, the current estimate of probable cost is as follows:

Total Installed Cost: \$20.682MM

Sorbent Cost: \$550/Ton, Delivered

Reference the attached spreadsheet for additional information relating to the equipment and construction costs used. Total installed costs include probable costs for engineering, procurement and construction of the DSI system. It also includes mobilization and indirect contractor costs such as bonding, overhead, and profit. Finally, the Total Installed Cost includes an escalation factor to account for inflation and other cost increases over the construction period.

Clarifications

- The estimated accuracy of this Opinion of Probable Costs is +50% and -30%. The accuracy is expected to improve as the cost estimate is refined.
- Sorbent consumption numbers and equipment sizing were developed based on typical performance characteristics. These characteristics are typical of a flue gas system that operates at or near 500 degrees F and has sufficient duct length ahead of a baghouse to ensure at least 2 to 3 seconds of resonance time for the sorbent. The flue gas streams from the Chena boilers operate at significantly lower temperatures (300 to 350 degrees F). The potential reduction in sorbent performance due to the existing flue gas temperatures has not yet been evaluated. Adjustments to the maximum capture rate or sorbent feed rate may be determined to be necessary as the preliminary design develops.
- The costs included in this estimate are based on the best information that we have been able to obtain to-date. The refinement of existing costs or the inclusion of additional direct or indirect costs may be determined to be necessary as the preliminary design develops.
- Sorbent pricing information provided by BACT in their equipment proposal was supplied by the sorbent vendor based on a proposal from the year 2000. Stanley Consultants is aware of sorbent pricing from other operators in the region, but we have not been given explicit permission to identify the price or the plant in question. The price identified above is our best estimate for current pricing based on the information that we have available today.



November 19, 2019 David Fish October 30, 2018

Conclusion

The preliminary Opinion of Probable Cost presented in this letter is our current best estimate for the costs associated with the procurement and installation of a DSI system at the Chena Combined Heat and Power Plant. The estimate attempts to account for many of the site-specific factors that may negatively impact the actual capital costs including, plant configuration, site layout, seismic considerations, existing infrastructure, and local construction cost factors.

We hope the information presented in this letter meets your immediate needs and we look forward to providing you with a final Opinion of Probable Costs along with supporting documentation in the near future.

Thank you for the opportunity to assist Aurora Energy in this matter.

Sincerely, John Solan

Senior Mechanical Engineer Stanley Consultants, Inc.

cc: File

Attachments: DSI Equipment Layout Sketch

Opinion of Probable Cost Tabulation

Adopted

			Rev. 0	Job No.	2870	9.01.00	Page No.	1
	J Smith / S Worcester/ D Bacon	Date	10/29/2018	Subject	Aurora	Energy	Chena - Dry Sorben able Cost	t Injection
Checked by	J. Solan	Date	10/29/2018	Shoot No.		4	of	1
Approved by	C. Spooner	Date	10/30/2018	Sheet No.	antity	1	61	1
	Item Description			No. of Unit	U	IOM	Unit Cost	Total Cost
Engineering Services								
Engineering services provided throughout the project to assist with BOP design, technical specifications, procurement, bid evaluation, and construction observation.				1	I EA		\$1,880,200.00	\$1,880,200
Dry Sorbent Injection System Supply								
DSI	Includes Railcar offloading, long term storage silos, day storage							
DSI Installation DSI Equipment Freight	silos, milling, metering and feed. Field Installation FOB jobsite			1 1 1	EA EA EA		\$4,900,000.00 \$6,370,000.00 \$200,000.00	\$4,900,000 \$6,370,000 \$200,000
Structural								
Solio Foundation Sorbent Building Substructure Sorbent Building Superstructure Sorbent Building Exterior Closure Roofing Railcar Unloading Skid Foundation Transfer Skid Enclosure Foundation MCC Foundation				2 1 1 1 1 5 5 5 4	EA EA EA EA CY CY CY		\$244,304.00 \$247,047.00 \$160,334.00 \$161,334.00 \$12,149.00 \$650.00 \$650.00	\$488,608 \$247,047 \$183,067 \$160,334 \$12,149 \$3,250 \$3,250 \$2,600
Pipe Bridge by Silos - Steel	coal yard front end loader drive under.			4	TONS		\$9.000.00	\$36.000
Pipe Bridge by Silos - Foundations Outside Pipe Supports - Steel Outside Pipe Supports - Foundations Inside Pipe Supports - Steel				6 10.0 40 3.00	CY TONS CY TONS		\$650.00 \$9,000.00 \$650.00 \$9,000.00	\$3,900 \$90,000 \$26,000 \$27,000
Ductwork	100' Feet of Ductwork for Residence Time prior to PJFF			12.50	TONS		\$10,300.00	\$128,750
Mechanical								
Unit 1 Aggregate Piping Cost: 6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				300) LF		\$238.00	\$71,400
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				310	LF		\$239.00	\$74,090
6" Sch 80 Pipe/Fittings/Flanges/Supports - Sorbent Prep to Injection Location				280	LF		\$239.00	\$66,920
Unit 5 Aggregate Piping Cost: 6" Sch 80 Pipe/Flanges/Supports - Sorbent Prep to Injection Location				200	LF		\$239.00	\$47,800
Electrical				~			¢05 477 00	¢400.054
480V MCC 480V Panelboard and Xfmr	Mtl & Labor			2	2 EA		\$10,200.00	\$20,400
Cable - 480V - MCC, Loads Conduit - RGS	Mtl & Labor Mtl & Labor			9000 6800) LF) LF		\$14.83 \$20.26	\$133,436 \$137,748
Cable Terminations (Mat'l)	480V Material & Labor			496	6 EA		\$26.11	\$12,950
Light Fixtures Interior/Exterior	fixtures (Mtl & Labor)			20) EA		\$1,561.00	\$31,220
Ground Grid extension	Mtl & Labor			1050) LF		\$13.43	\$14,100
Instrumentation & Controls BOP DCS Aspects				1	EA		\$76,428.00	\$76,428
All Terrain Forklift	45' lift, 35' reach 9000 lb canacity						\$6 455 00	\$77 460
Hydraulic Crane	80-ton			12 90	WK DY		\$4,365.00	\$392,850
					Fi	urnish an	d Erection Subtotal	\$14.169.111
					Mobili-	ation & C	emobilization 5%	\$700 /50
					WODIIZ	Contracto Con	Bond - 2.5% or Overhead - 10% tractor Profit - 10%	\$708,430 \$354,228 \$1,416,911 \$1,416,911
	Escalation Percent	4.00%	Periods	14 Es	calation	Total (Nov 20	Construction Cost 18 - January 2020)	\$18,065,617 \$736,199
				PROBABLE EQUI	PMENT	& CONS	TRUCTION COST	\$18,802,000
Note: All costs presented in this document	t are Stanley Consultants' opinions of	PR probab	OBABLE EN	struction, and/or on	PMENT beration	& CONS and main	TRUCTION COST itenance costs. This	\$20,682,000 s estimate of probable
construction cost is based on our experien competitive bidding or market conditions. construction, and/or operation and mainter Construction Cost Index, and/or vendor qu	ce and represent our best judgment. Therefore, we do not guarantee that p nance costs presented. The costs ide otes.	We ha roposa ntified	ve no control o Ils, bids, or act are based on l	ver cost of labor, n ual construction cos Means Building Con	naterials sts will n structio	, equipm lot vary fr n Cost Da	ent, contractor's met rom estimates of pro ata, Engineering Net	thods, or over ject costs, ws Record



3345 N. ARLINGTON HEIGHTS RD. SUITE B ARLINGTON HEIGHTS, IL 60004-1900 (847) 577-0950 FAX: (847) 577-6355 E-MAIL: bact_process@sbcglobal.net

November 1, 2018

Mr. John Solan, P.E. Senior Mechanical Engineer Stanley Consultants 8000 S. Chester Street, Suite 500 Centennial, CO 80112

RE: DSI for Aurora Energy / BACT Proposal No. 1899-R1

Dear John,

We are revising our proposal in the light of your comments. The Emissions and sorbent usage from the boiler is based on recent information from you: on 0.39 lbs. of SO2/MBTU these calculations are based on using a weight ratio of 2.6 lbs. of sodium bicarbonate to 1 lb. of sulfur and a NSR of 1.3; Sulphur at .28%; Heating Volume of 7,600; 80% removal of SO2.

BOILER	MBTU/HR	S02 <u>РРН</u>	SODIUM BICARBONATE PPH
1	76	29.64	100
2	76	29.64	100
3	76	29.64	100
4	269	<u>139.88</u>	<u>400</u>
	ТОТА	AL 228 PPH	700 PPH
			0.35 Tons/Hr.
	Per Month:	8.4 Tons/Day	252 Tons

Bicarbonate Storage

For four months; we need 756 Tons of sorbent (2) Silos: 518 Tons capacity each TOTAL CAPACITY = 1,036 Tons Silo Size: Same as Eielsen

Cost of Sodium Bicarbonate = \$123,480 per month; this is based on estimate by Solvay for year 2000 delivery: \$250 plus, \$240 freight.

Scope of Supply

- 1. (2) Bolted Storage Silos 22' DIA x 100' tall with bin-vent level control and bin vibrators; capacity = 1,036 tons; storage silo complete.
- (1) Rail car unloading and diverters to fill silos located 500' away; rate = 33,000 PPH, blower = 200 HP; installed spare; backup blower.
- 3. (3) Day bins with pneumatic conveying from storage silos. Conveying distance 1,000', 6,000 PPH capacity, blower = 200 HP; blowers are spared.
- 4. (3) Classifier mills; 1,000 PPH capacity, 75 HP total, connected HP (for 2). The 75 HP is the sum of the grinding motor, classifier motor, brakes, and VFD.
- 5.&6. (3) Filter receivers with conveying blowers. Milled material conveying material from mill to filter receivers. (2) Blowers 75 HP total; total connected.
- 7. (4) Injector sets to be installed on duct work.
- 8. (1) Dedicated compressor.
- 9. (1) NEMA 6 control panel with microprocessor.
- 10. Integration to the boiler control panel.
- 11. CFD modeling and programing.
- 12. All pneumatic piping up to the reagent building. All piping within the sorbent prep building by BACT. Pipe from the building wall for the 4 pipes leading to each stack by customer. Air coolers are provided to minimize puffing of the reagent.
- 13. Sorbent building and foundation by customer.

Budget Sell Price: <u>\$4,900,000</u> Freight: \$200,000 F.O.B. Shipping Point Taxes Extra

If you have any questions, please let me know.

Best regards,

BACT PROCESS SYSTEMS, INC.

N.S. ("Bala") Balakrishnan

President



November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

UNIFIED FACILITIES CRITERIA (UFC)

DoD FACILITIES PRICING GUIDE



APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED

Appendix III.D.7.7-4709

UNIFIED FACILITIES CRITERIA (UFC)

DoD FACILITIES PRICING GUIDE

Any copyrighted material included in this UFC is identified at its point of use. Use of the copyrighted material apart from this UFC must have the permission of the copyright holder.

Indicate the preparing activity beside the Service responsible for preparing the document.

U.S. ARMY CORPS OF ENGINEERS

NAVAL FACILITIES ENGINEERING COMMAND (Preparing Activity)

AIR FORCE CIVIL ENGINEER CENTER

Record of Changes (changes are indicated by $1 \dots /1$)

Change No.	Date	Location
1	6-25-18	Update Table 3 with RUC. Text update 3-2.

FOREWORD

The Unified Facilities Criteria (UFC) system is prescribed by MIL-STD 3007 and provides planning, design, construction, sustainment, restoration, and modernization criteria, and applies to the Military Departments, the Defense Agencies, and the DoD Field Activities in accordance with <u>USD (AT&L) Memorandum</u> dated 29 May 2002. UFC will be used for all DoD projects and work for other customers where appropriate. All construction outside of the United States is also governed by Status of Forces Agreements (SOFA), Host Nation Funded Construction Agreements (HNFA), and in some instances, Bilateral Infrastructure Agreements (BIA.) Therefore, the acquisition team must ensure compliance with the most stringent of the UFC, the SOFA, the HNFA, and the BIA, as applicable.

UFC are living documents and will be periodically reviewed, updated, and made available to users as part of the Services' responsibility for providing technical criteria for military construction. Headquarters, U.S. Army Corps of Engineers (HQUSACE), Naval Facilities Engineering Command (NAVFAC), and Air Force Civil Engineer Center (AFCEC) are responsible for administration of the UFC system. Defense agencies should contact the preparing service for document interpretation and improvements. Technical content of UFC is the responsibility of the cognizant DoD working group. Recommended changes with supporting rationale should be sent to the respective service proponent office by the following electronic form: <u>Criteria Change Request</u>. The form is also accessible from the Internet sites listed below.

UFC are effective upon issuance and are distributed only in electronic media from the following source:

• Whole Building Design Guide web site http://dod.wbdg.org/.

Refer to UFC 1-200-01, *DoD Building Code (General Building Requirements)*, for implementation of new issuances on projects.

AUTHORIZED BY:

an & M Willt

LARRY D. McCALLISTER, PhD, PE, PMP, SES Chief, Engineering and Construction Directorate of Civil Works U.S. Army Corps of Engineers

EDWIN H. OSHIBA, SES, DAF Deputy Director of Civil Engineers DCS/Logistics, Engineering & Force Protection

123

JOSEPH E. GOTT, P.E. Chief Engineer Naval Facilities Engineering Command

Mules M. and

MICHAEL McANDREW Deputy Assistant Secretary of Defense (Facilities Investment and Management) Office of the Assistant Secretary of Defense (Energy, Installations, and Environment)

UNIFIED FACILITIES CRITERIA (UFC) [REVISION] SUMMARY SHEET

Document: UFC 3-701-01, DoD Facilities Pricing Guide

Superseding: UFC 3-701-01, dated March 2011

Description: The document provides updated cost and pricing data in support of facility planning, investment and analysis needs.

Reasons for Document:

 This UFC provides updated cost and pricing data intended to support preparation of the DoD budget.

Impact:

• Provides consistency across the DoD for the development of budgets for military construction projects.

Unification Issues

None

TABLE OF CONTENTS

CHAPTER 1	INTRODUCTION	1
1-1	PURPOSE AND SCOPE	1
1-1.1	Chapter 2: Unit Costs for Military Construction Projects.	1
1-1.2	Chapter 3: Unit Costs for DoD Facilities Cost Models.	1
1-1.3	Chapter 4: Cost Adjustment Factors	1
1-2	APPLICABILITY	1
1-3	DATA TABLES	1
1-4	PROPONENT	1
CHAPTER 2	UNIT COSTS FOR MILITARY CONSTRUCTION PROJECTS	3
2-1	OVERVIEW	3
2-2	FACILITY UNIT COST TABLE	3
2-3	GUIDANCE UNIT COST (GUC) DEVELOPMENT METHODOLOGY	3
2-3.1	Data Source	3
2-3.2	Business Rules	3
2-3.3	Data Normalization.	4
2-3.4	Primary Facility Included Costs	4
2-3.5	Primary Facility Excluded Costs.	5
2-3.6	Primary Facility Cost Considerations.	6
CHAPTER 3	UNIT COSTS FOR DOD FACILITIES COST MODELS	7
3-1	OVERVIEW	7
3-2	REPLACEMENT UNIT COSTS (RUC)	7
3-2.1	Definition	7
3-2.2	Use of Replacement Unit Costs	7
3-3	SUSTAINMENT UNIT COSTS (SUC).	8
3-3.1	Definition	8
3-3.2	Use of Sustainment Unit Costs	9
3-4	UNIT COST SOURCES1	0
3-4.1	Source 1 Published Data1	0
3-4.2	Source 2 Similar Data1	0
3-4.3	Source 3 Derived Data1	0
3-5	REVISING UNIT COSTS	1
CHAPTER 4	COST ADJUSTMENT FACTORS	3

4-1

4-1.1

4-1.2

4-1.3

4-1.4

4-1.5

4-2 4-2.1

4-2.2 4-2.3

LOCATION ADJUSTMENTS.	November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018 13
Application	
Data Source	
Survey	
Force Majeure	14
User Requested Revisions	

ESCALATION.14

Military Construction.14Plant Replacement Value Escalation Rates.14

CHAPTER 1 INTRODUCTION

1-1 PURPOSE AND SCOPE.

The DoD Facilities Pricing Guide supports a spectrum of facility planning, investment, and analysis needs. This version of the Guide reflects updated cost and pricing data for <u>FY 2018</u> intended to support preparation of the DoD budget for <u>FY 2020</u>. It includes reference information organized into three chapters, as follows:

1-1.1 Chapter 2: Unit Costs for Military Construction Projects.

Chapter 2 describes the usage of facility unit cost data for selected DoD facility types in support of preparing Military Construction (MILCON) project documentation (DD Forms 1391) and other program-level estimates in accordance with UFC 3-730-01, "Programming Cost Estimates for Military Construction."

1-1.2 Chapter 3: Unit Costs for DoD Facilities Cost Models.

Chapter 3 describes the usage of unit costs in support of DoD facilities cost models. These unit costs are based upon the reported average DoD facility size or an established benchmark size, as annotated for each Facility Analysis Category (FAC) in the DoD Real Property Classification System (published separately). These unit costs are intended for macro-level analysis and planning rather than individual facilities or projects.

1-1.3 Chapter 4: Cost Adjustment Factors.

Chapter 4 describes the usage of cost adjustment factors for location and price escalation that are applicable to the base unit costs in both Chapters 2 and 3.

1-2 APPLICABILITY.

This UFC applies to all projects in both the continental US (CONUS) and outside the continental US (OCONUS).

1-3 DATA TABLES.

All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

1-4 PROPONENT.

The Office of the Assistant Secretary of Defense for Energy, Installations, and Environment is the proponent for the Facilities Pricing Guide. Recommendations from users toward improving the usefulness of this reference are welcome. Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

Adopted

CHAPTER 2 UNIT COSTS FOR MILITARY CONSTRUCTION PROJECTS

2-1 OVERVIEW.

The facility unit costs in this chapter apply to preparation of programming-level cost estimates for constructing military facilities in accordance with the methodology described in UFC 3-730-01.

All data tables in this UFC are found under "Related Materials" in a combined file accompanying this UFC on the (WBDG) Web site: <u>https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.</u>

2-2 FACILITY UNIT COST TABLE.

Table 2 provides facility unit costs for various DoD facility types in dollars per square meter (\$/SM) and equivalent English unit cost data in dollars per square foot (\$/SF) as of <u>October 2017</u>. The listed facility types represent only those facilities most frequently constructed by the Military Services, and the application of a facility unit cost may not be directly applicable for those facilities with unique requirements. See UFC 3-730-01 for additional guidance on facility unit costs and their application.

The unit costs in Table 2 are average unit costs for new construction based on no less than three project awards per building type occurring since September 2014 for Army, Navy, Air Force, Defense Education Activities (for school projects) and Defense Health Agency (for medical projects) facilities as entered into the Historical Analysis Generator (HII) unit cost database prior to 1 Nov 2017. Facility additions which are less than 25% of the Reference Size of the listed facility type, and projects outside of the continental United States (OCONUS), are included only for Family Housing and DoD Schools. For additional information regarding how the facility unit costs are determined, refer to paragraph 2-3, Guidance Unit Cost Development.

2-3 GUIDANCE UNIT COST (GUC) DEVELOPMENT METHODOLOGY.

2-3.1 Data Source.

The data source for the facility unit costs is all reliable HII project records, after excluding records for reasons stated in paragraph 2-2. In general, all project records for the CONUS and projects from Alaska and Hawaii are included.

Facility level information from all three Services projects is entered into HII database for comparable service category codes (CATCODEs). Normalized project unit costs are statistically analyzed to eliminate outliers before calculating the guidance unit cost (GUC).

2-3.2 Business Rules.

The business rules are reviewed annually prior to updating Table 2 Facility Unit Costs for Military Construction. The business rules include the following components.

- The Tri-Service CATCODEs Cross-walk table groups like service CATCODEs to a common Office of the Secretary of Defense (OSD) Code. OSD Codes are not published and are only utilized for this task of segregating data. A minimum of three projects are required within those defined years to create a dataset. If there is insufficient data available within the above three-year period, the dataset search is extended to the last four years.
- Projects are new construction only.
- Projects are located within the CONUS, plus Hawaii and Alaska, except where noted otherwise in Table 2.
- Projects with extreme variation from the mean (50%) are excluded., and
- Exclusion of inappropriate data for cause.

2-3.3 Data Normalization.

Each facility-specific data set is normalized to the National Average Area Cost Factor (ACF=1) and number of bidders, and escalated to October of the year of interest, before unit costs are averaged.

- Escalation: The DoD Selling Price Index (DoD-SPI), which is an average of three commonly accepted national construction price escalation indices, is utilized to escalate actual project award cost data to October of 2017 for this UFC,
- Number of Bidders: Based on actual bid data for the data set,
- Location: Normalize each project award by the appropriate ACF to the national average of 1.0, and
- Facility Size: Normalize each facility award amount in the dataset for facility size, using a normalization process that looks at the facility size as compared to the average facility size of the selected dataset by OSD code.

2-3.4 Primary Facility Included Costs.

The facility unit costs include the following:

- Minimum antiterrorism design features (reference UFC 4-010-01, "DoD Minimum Antiterrorism Standards for Buildings") inside the building meeting Table B-1 standoff distance requirements,
- Sales tax on building materials,

- Building information system costs (e.g., conduits, racks, trays, telecommunication rooms) without any specialized communications requirements,
- Installed (built-in) building equipment and furnishings normally funded with MILCON funds,
- Energy Management Control System (EMCS) connections,
- Intrusion Detection System (IDS) infrastructure, including conduits, racks, and trays,
- Sustainable design and construction features energy consumption reduction requirements mandated before 6 November 2016; and all other sustainable design features for criteria in effect from September 2014 thru September 2017 with the exception of renewable energy generation elements,
- Progressive Collapse premiums for the following specific facility types: Inpatient Hospital/Medical Center, Primary Care Clinic (Attached), Major Command Headquarters Building, Barracks/Dormitory, and Recruit Open Bay (Barracks), and
- Standard foundation systems (e.g. strip/spread footings, thickened edge slab for slab on grade).

2-3.5 Primary Facility Excluded Costs.

The unit costs do not include the following:

- Gross receipt taxes or gross taxes, gross excise taxes, or state commerce taxes,
- "Acts of God" or unusual market conditions,
- Supporting facility costs,
- Equipment acquired with other fund sources, including pre-wired workstations or furnishing systems, intrusion detection systems,
- Sustainable design and construction features renewable energy generation elements; energy consumption reduction requirements mandated on or after 6 November 2016; and all other features mandated since September 2017; these will be estimated separately in accordance with component guidelines and documented on DD Form 1391 per DoD Instruction 4170.11, Installation Energy Management,
- Special foundations (e.g. pre-stressed concrete piles, caissons), intrusion detection system installation, base exterior architectural preservation guidelines,
- Enhanced Anti-Terrorism (AT) standards (exceeding the minimum in UFC 4-010-01, or when minimum standoff distances [Table B-1] are not achieved) construction contingency allowances,
- Cybersecurity costs,
- Supervision, inspection, and overhead (SIOH),
- Design costs (design-build contracts), and Construction cost growth resulting from user changes, unforeseen site conditions, or contract document errors and omissions.

2-3.6 Primary Facility Cost Considerations.

The following are cost considerations for primary facilities:

- <u>Medical facilities</u>: Unit costs <u>include</u> category A and category B equipment and building infrastructure for category C equipment,
- <u>Housing for Unaccompanied Military Personnel</u>: Unit costs for barracks, dormitories, and Unaccompanied Officers Quarters do not include freestanding kitchen equipment. In addition to using the size adjustment factors, use the project size adjustment factors in UFC 3-730-01,
- <u>Child Development Centers</u>: Unit costs <u>do not include</u> free-standing food service equipment or playground area and equipment,
- <u>Family housing</u>: Unit costs are based upon gross area and <u>include</u> sprinkler systems or fire-rated construction. Unit costs <u>include</u> post-award design costs,
- <u>Reserve facilities other than reserve centers</u>: Use the unit cost of the appropriate facility type, and
- Costs are independent of the acquisition strategy and are not specific to any single construction type.

Adopted

3-1 OVERVIEW.

This chapter describes the unit costs and related factors used in support of DoD facilities cost models. These unit costs are intended for macro-level analysis and planning and are not reliable for individual facilities or project estimates.

Unit costs and related factors are associated with FACs represented by a 4-digit code in the DoD Real Property Classification System (RPCS), which is a hierarchical scheme of real property types and functions that serves as the framework for identifying, categorizing, and modeling the DoD's inventory of land and facilities. FACs are common across the department and suitable for department-wide applications. For each FAC, Table 3 identifies the associated unit cost to be used in DoD facilities cost models and metrics.

Whenever possible, unit costs and factors have been based upon approved government or commercial benchmarks. Detailed supporting data for unit costs is available, and accompanies this UFC on the WBDG Web site. All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: <u>https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.</u>

3-2 REPLACEMENT UNIT COSTS (RUC).

3-2.1 \1\ Definition and Use of Replacement Unit Costs. /1/

\1\ Replacement unit costs form the basis of calculating Plant Replacement Value (PRV) in a consistent manner across DoD, representing a complete and useable facility built to current DoD design standards. Replacement unit costs can also support largescale program-level estimates for re-stationing plans with the addition of allowance for site preparation, earthwork, landscaping, and related factors. Replacement unit costs should not be used for individual project estimates. /1/

Replacement \1\ unit /1/ costs include construction of standard foundations, all interior and exterior walls and doors, the roof, utilities out to the 5-foot line, all built-in plumbing and lighting fixtures, security and fire protection systems, electrical distribution, wall and floor coverings, heating and air conditioning systems, and elevators. Replacement \1\ unit /1/ costs do not include project costs such as design, supporting facility costs, special foundations, equipment acquired with other funding sources (e.g. missionfunded components), contingency costs, or supervision, inspection, and overhead (SIOH). \1\ unit /1/ costs also do not include items that are generally considered personal property such as computer systems, and furniture. See paragraph 3-5, Revising Unit Costs, for guidance on requesting changes \1\ to replacement unit costs /1/in Table 3.

3-2.2 \1\ Plant Replacement Value (PRV). /1/

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

DoDI 4165.14 defines PRV as the cost to design and construct a notional facility to current standards to replace an existing facility on the same site. The factor values are provided in the "Report of the Plant Replacement Value (PRV) Panel, August 2001-May 2003" published by the Office of the Deputy Under Secretary of Defense (Installations and Environment). The standard DoD formula for calculating PRV is:

Equation 3-2 Calculating PRV

PRV = Q x RUC x ACF x HF x PD x SIOH x CF

Where:

PRV is plant replacement value

Q is facility quantity, in the same unit of measure as the RUC

RUC is replacement unit cost found in Table 3 of this UFC

ACF is area cost factor found in Table 4 of this UFC, to account for geographical differences in the costs of labor, materials and equipment

HF is an adjustment of 1.05 to account for increased costs for replacement of historical facilities or for construction in a historic district. The factor is 1.0, should the facility not qualify as "historical".

PD is a factor to account for the planning and design of a facility; the current value of this factor is 1.09 for all but medical facilities, and 1.13 for medical facilities.

SIOH is the factor to account for the supervision, inspection, and overhead activities associated with the management of a construction project. The current value of the factor is 1.057 for facilities in the (CONUS), and 1.065 (USACE) or 1.062 (NAVFAC) for facilities in the (OCONUS).

CF is a factor of 1.05 to account for construction contingencies

3-3 SUSTAINMENT UNIT COSTS (SUC).

3-3.1 Definition.

Sustainment provides for maintenance and repair activities necessary to keep a typical inventory of facilities in good working order over its expected service life. It includes the following:

- Regularly scheduled adjustments and inspections, including maintenance inspections (e.g., fire sprinkler heads, HVAC systems) and regulatory inspections (e.g., elevators, bridges),
- Preventive maintenance tasks,
- Emergency response and service calls for minor repairs, and
- Major repair or replacement of facility components (usually accomplished by contract) that are expected to occur periodically throughout the facility service life.

Sustainment includes regular roof replacement, refinishing wall surfaces, repairing and replacing electrical, heating, and cooling systems, replacing tile and carpeting and similar types of work as well as overhead costs which include architectural and engineering services. It does not include repairing or replacing non-attached equipment or furniture, or building components that typically last more than 50 years (such as foundations and structural members). Sustainment does not include restoration, modernization, environmental compliance, facility leases, specialized historical preservation, general facility condition inspections and assessments, planning and design (other than shop drawings), or costs related to Acts of God, which are funded elsewhere. Other tasks associated with facilities operations (such as custodial services, grass cutting, landscaping, waste disposal, and the provision of central utilities) are also not included.

3-3.2 Use of Sustainment Unit Costs.

Sustainment unit costs represent the annual average sustainment cost for each FAC, and serve as the basis for calculating annual facilities sustainment requirements for DoD using the following formula:

Equation 3-3 Calculating Sustainment Requirement

$$SR = Q \times SUC \times SACF \times I$$

Where:

SR is sustainment requirement

Q is facility quantity, in the same unit of measure as the SUC

SUC is sustainment unit cost found in Table 3

SACF is sustainment area cost factor found in Table 4

I is the value(s) representing future-year escalation for operation and maintenance accounts, published in Table 4-4.

The Sustainment Requirement for each qualifying asset in the DoD inventory is aggregated by sustaining organization and sustainment fund type in the Facilities Sustainment Model (FSM), published annually.

3-4 UNIT COST SOURCES.

Unit costs for DoD cost models are developed using a variety of sources. These sources fall into the three categories described below, listed in order of preference of use. The source description and source group for each unit cost are identified in Table 3. Supporting documentation for each unit cost calculation is available in the "Supporting documentation" file download accompanying this UFC document on the WBDG website: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

3-4.1 Source 1 Published Data

Standard, easily-accessible published data that is highly applicable to the FAC. Source 1 is the most desirable due to ease of access, general applicability, and lack of bias. Examples include the DoD Tri-Service Committee on Cost Engineering, Service-specific cost guidance (USACE), commercial cost-estimating guidelines or models, or other Government-published cost guidance from federal, state, or local government agencies (e.g. Fairfax County (Virginia) Park Authority). Non-DoD source 1 data may require refinement for application in DoD, but is still considered source 1 if it closely matches the design attributes of the FAC.

3-4.2 Source 2 Similar Data

Data that is applied to facilities with similar but not identical characteristics (e.g., sewage waste treatment facilities and industrial waste treatment facilities). Source 2 also includes unpublished government or trade association cost data, and Component-validated costs for non-standard facilities that have no commercial counterparts (e.g. missile launch facilities or military ranges).

3-4.3 Source 3 Derived Data

Unpublished project-specific data derived from Component project documents (e.g. DD Forms 1391) or from calculating costs from reported Plant Replacement Value and inventory, or derived from using a ratio of sustainment to construction from a similar source 1 Facilities Analysis Category (e.g. FAC 2115, Aircraft Maintenance Hangar, Depot derived from FAC 2111, Aircraft Maintenance Hangar).

3-5 REVISING UNIT COSTS.

Users of this UFC are encouraged to suggest revisions to the published cost factors, particularly for facilities unique to their mission. Submit proposed changes to the proponent office in accordance with the following guidelines:

- Revised costs should come from an equivalent or superior source,
- Revised costs should be easily audited,
- Revised costs should be consistent with the functional definitions,
- Revised costs should be consistent with the FAC scope and
- Revised costs should be suitable for application throughout DoD.

Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

CHAPTER 4 COST ADJUSTMENT FACTORS

4-1 LOCATION ADJUSTMENTS.

Table 4-1 provides area cost factors (ACFs) to be used for adjusting "bare" unit costs to location-specific costs for the most common locations.

All data tables in this UFC are found in a combined file under "Related Materials" accompanying this UFC on the (WBDG) Web site: https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01.

4-1.1 Application

For military construction projects, use the MILCON ACFs with the primary facility unit costs from Chapter 2 or approved Air Force, Army, or Navy MILCON Pricing Guide. For calculating Plant Replacement Value, use the MILCON ACFs with the appropriate RUCs from Chapter 3. For calculating sustainment costs, use the sustainment ACFs with the appropriate SUCs from Chapter 3.

Do not use the MILCON ACFs to modify parametric cost estimates, detailed quantitytake-offs, unit price book (UPB) line items, commercial cost data, or user-generated unit costs. These cost estimating methods and databases have their own processes and factors for adjusting costs to different locations. MILCON ACFs or any component(s) that make up MILCON ACFs are only applicable to construction costs and should not be applied or utilized for any other purpose.

4-1.2 Data Source

In general, the Tri-Service Cost Engineering ACF software program evaluates the local costs for a United States market basket of eight labor crafts, 18 construction materials, and four equipment items. These labor, materials, and equipment (LME) items are representative of the types of products, services, and methods used to construct most military facilities in the United States. Each of the LME costs is normalized and weighted to represent its contribution to the total cost of a typical facility. The normalized LME is then modified by seven matrix factors that cover local conditions affecting construction costs. These matrix factors include weather, seismic, climatic (frost zone, wind loads, and HVAC systems), labor availability, contractor overhead and profit, logistics, and labor productivity and are relative to the U.S. standard. The resultant ACF for each location is normalized again by dividing by the 96-Base-City average to provide a final ACF that reflects the relative relationship of construction costs between that location and the 96-Base-City average as 1.00.

MILCON ACFs are calculated using a LME ratio of 35/63/2. Sustainment ACFs are calculated using a LME ratio of 53/46/1.

4-1.3 Survey

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

Both CONUS and OCONUS construction market surveys were conducted in 2017. The CONUS survey covered 300 locations that included 96 Base Cities (two per state in the continental U.S.). The OCONUS survey included 75 locations, and was based on a market basket of goods for typical U.S. labor, material, equipment, and construction methods.

CONUS and OCONUS surveys are performed annually. When local materials and construction methods differ from those represented by the published ACF, specific adjustments may need to be added to the project estimate to account for any differences. There is no easy correlation between the current MILCON ACFs and previous MILCON ACFs for specific locations. No common benchmarks exist because both the Base City average and the relationships between cities change with each survey. It is possible, however, to compare differences between several locations in this database with differences between the same locations in previous databases.

4-1.4 Force Majeure

The ACF is not intended to, or capable of, responding to rapid changes in the market place. Examples include Acts of God, accelerated construction schedules, changes in the demand and supply for construction materials, labor, and equipment. An increased demand for labor beyond what the local market can supply may require the enticement of premium pay, overtime hours, temporary living expenses, and travel expenses.

4-1.5 User Requested Revisions

Users may request revisions to published ACFs when market conditions unexpectedly change. Each request must be initiated by the USACE District senior cost engineer through HQUSACE or by the NAVFAC regional cost engineer to their corresponding NAVFAC Atlantic or Pacific Tri-Service Cost Engineering committee member. The local cost engineer shall provide updated market basket ACF software input factors with adequate backup documentation to HQUSACE or NAVFAC for them to update the Tri-Service Cost Engineering ACF software.

4-2 ESCALATION.

Tables 4-2, 4-3, and 4-4 provide escalation (inflation) factors used to adjust unit costs in Tables 2 and 3 (expressed in base-year dollars) to the desired year, as follows:

4-2.1 Military Construction.

Military construction project estimates that use unit costs from Table 2 should use the military construction escalation factor from table 4-2 for the expected midpoint of construction as described in UFC 3-730-01.

4-2.2 Plant Replacement Value Escalation Rates.

Plant Replacement Value (PRV) calculations that use replacement unit costs from Table 3 should use the escalation factor from Table 4-3 for the desired program year.

14

4-2.3 Facilities Sustainment.

Modeled facilities sustainment cost estimates that use unit costs from Table 3 should use the O&M escalation factor from Table 4-4 for the desired program year.

Adopted

November 19, 2019 UFC 3-701-01 23 May 2018 Change 1, 25 June 2018

This Page Intentionally Left Blank

APPENDIX A REFERENCES

UNIFIED FACILITIES CRITERIA

http://www.wbdg.org/ccb/browse_cat.php?o=29&c=4

UFC 3-730-01, Programming Cost Estimates for Military Construction

PLANT REPLACEMENT VALUE

https://www.wbdg.org/ffc/dod/unified-facilities-criteria-ufc/ufc-3-701-01

Report of the Plant Replacement Value (PRV) Panel, August 2001 – May 2003, R&K Engineering, Inc. for the Office of the Deputy Under Secretary of Defense (Installations and Environment) .

+

	United States Environmental Protection Agency	Office of Air Quality Planning and Standards Research Triangle Park NC 27711	EPA-450/3-90-016 August 1990
	Air		
EPA	Small Industrial-		
	Comme	rcial-	
	Institutional		
	Steam (Generating	10
	Units		
	Backgro	ound	
	Information for Promulgated Standards		

EPA-450/3-90-016

Small Industrial-Commercial-Institutional Steam Generating Units --Background Information for Promulgated Standards

Emission Standards Division

U.S. ENVIRONMENTAL PROTECTION AGENCY Office of Air and Radiation Office of Air Quality Planning and Standards Research Triangle Park, North Carolina 27711

August 1990

Appendix III.D.7.7-4733

2.3.3 Percent Reduction Standard

1. <u>Comment</u>: Two commenters (IV-D-08, IV-D-28) requested that the 90 percent SO₂ reduction requirement be eliminated and replaced with an emission limit of 520 ng/J (1.2 lb/million Btu) heat input. One commenter (IV-D-08) objected to applying the 90 percent SO₂ reduction requirement to all coal regardless of sulfur content. This commenter stated that the EPA's conclusion that no units will be built in the size range between 22 and 29 MW (75 and 100 million Btu/hr) heat input capacity and operating at greater than 55 percent capacity factor is flawed. This commenter stated that the SO₂ standard of 520 ng/J (1.2 lb/million Btu) heat input for coal-fired plants should apply to all steam generating units in this source category, regardless of size. This commenter further recommended that the full 90 percent SO₂ removal be required only when the 520 ng/J (1.2 lb/million Btu) limit could not be met by using low sulfur coals or by pretreating the coals.

Another commenter (IV-D-28) stated that the 90 percent SO_2 reduction requirement should be removed and that coal-fired steam generating units in the 8.7 to 29 MW (30 to 100 million Btu/hr) range should be required only to meet the 520 ng/J (1.2 lb/million Btu) SO_2 limit. The commenter stated that the percent reduction requirement would place an unjustified cost and performance burden on units in this range that either already meet or are close to meeting the 520 ng/J (1.2 lb/million Btu) SO_2 limit.

<u>Response</u>: Section 111 of the CAA requires standards to reflect application of the best demonstrated technology considering costs, nonair quality health and environmental impacts, and energy requirements. Section 111 also requires that for fossil fuel-fired steam generating units a percent reduction standard be established. Read together, this means that the

2-22

Administrator is compelled to include a percent reduction standard unless the impacts associated with the requirements would be unreasonable. As discussed in the background document, "Model Boiler Cost Analysis for Controlling Sulfur Dioxide (SO₂) Emissions from Small Steam Generating Units" (EPA-450/3-89-14), a small coal-fired steam generating unit of 22 MW (75 million Btu/hr) size and operating at a 55 percent capacity factor has an incremental cost-effectiveness value of about \$3,600/Mg (\$3,300/ton) relative to an emission limit standard of 520 ng/J (1.2 lb/million Btu). Capital and annualized costs are projected to increase by approximately 20 percent over the regulatory baseline for the percent reductions standard. However, these values increase significantly for units less than 22 MW (75 million Btu/hr) heat input capacity and for any unit less than 29 MW (100 million Btu/hr) operating at an annual capacity factor for coal of less than 55 percent. Imposing these high costs for these units was considered to be unreasonable when compared to the increase in emission reductions achievable by the percent reduction requirement on these units. Therefore, in keeping with the requirements of the CAA, the final standards will not require percent reduction for any units operating at less than a 55 percent annual capacity factor for coal or any unit with a heat input capacity of 22 MW (75 million Btu/hr) or less.

Finally, no conclusion was made that coal-fired steam generating units greater than 22 MW (75 million Btu/hr) heat input and greater than 55 percent capacity factor would not be built. Rather, this was a projection of sales over the next five years based on sales trends over the past several years. The sales projections for coal-fired units had no influence on the conclusion of the reasonableness of the percent reduction requirement. (The assumption was used in generating national impacts of the standards.) The model steam generating unit analysis examined the potential impacts of the percent reduction requirement on a coal-fired unit greater than 22 MW (75 million Btu/hr) and greater than 55 percent capacity factor. Therefore, should a unit be built, requiring 90 percent reduction of emissions would be reasonable.

2-23

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Northeast States for Coordinated Air Use Management (NESCAUM)

November 2008

(revised January 2009)

Appendix III.D.7.7-4736

Members of Northeast States for Coordinated Air Use Management

Arthur Marin, Executive Director Northeast States for Coordinated Air Use Management

Anne Gobin, Bureau Chief Connecticut Department of Environmental Protection, Bureau of Air Management

James P. Brooks, Bureau Director Maine Department of Environmental Protection, Bureau of Air Quality

Barbara Kwetz, Director Massachusetts Department of Environmental Protection, Bureau of Waste Prevention

Robert Scott, Director New Hampshire Department of Environmental Services, Air Resources Division

William O'Sullivan, Director New Jersey Department of Environmental Protection, Office of Air Quality Management

David Shaw, Director New York Department of Environmental Conservation, Division of Air Resources

Douglas L. McVay, Acting Chief Rhode Island Department of Environmental Management, Office of Air Resources

Richard A. Valentinetti, Director Vermont Department of Environmental Conservation, Air Pollution Control Division

UNITS, SPECIES, ACRONYMS

Acronyms

- APCD Air Pollution Control Device
- BACT -Best Available Control Technology
- BART Best Available Retrofit Technology
- BOOS Burners Out of Service
- CAA Clean Air Act
- CAAA Clean Air Act Amendments (of 1990)
- CFBA Circulating Fluidized-Bed Absorption
- CFR Code of Federal Regulations
- DI Dry Injection
- DSI Dry Sorbent Injection
- EGU Electricity Generating Unit
- ESP Electrostatic Precipitators
- FBC Fluidized Bed Combustion
- FF Fabric Filter (also known as baghouse)
- FGD Flue Gas Desulfurization (also known as SO₂ scrubber)
- FGR Flue Gas Recirculation
- FOM Fixed Operating and Maintenance Costs
- FSI Furnace Sorbent Injection
- GR Gas Reburn
- HHV Higher Heating Value
- ICI Industrial, Commercial, and Institutional (boilers)
- LAER Lowest Achievable Emission Rate
- LNB Low-NOx Burner
- LSDI Lime Slurry Duct Injection
- LSFO Limestone Forced Oxidation
- LSC Low-Sulfur Coal (also known as compliance coal)
- MACT Maximum Achievable Control Technology
- MANE-VU Mid-Atlantic-Northeast Visibility Union
- MC Mechanical Collector
- NAAQS National Ambient Air Quality Standard
- NCG Non-Condensable Gases
- NESCAUM Northeast States for Coordinated Air Use Management
- NSPS New Source Performance Standards
- NSR Normalized Stoichiometric Ratio
- OFA Overfire Air
- PC Pulverized Coal
- PRB Powder River Basin (coal)
- RACT Reasonably Available Control Technology
- RPO Regional Planning Organization
- SCA Specific Collection Area
- SCR Selective Catalytic Reduction

SD – Spray Dryer
SIP – State Implementation Plan
SNCR – Selective Non-Catalytic Reduction
TCR – Total Capital Requirement
TR – Transformer Rectifier
UBC – Unburned Carbon
US EIA – United States Energy Information Administration
US EPA – United States Environmental Protection Agency
ULNB – Ultra Low-NOx Burner
VOM – Variable Operating and Maintenance (costs)
WESP – Wet Electrostatic Precipitator
WFGD – Wet Flue Gas Desulfurization (also known as wet SO₂ scrubber)

Chemical Species

HCl – Hydrochloric Acid HF – Hydrofluoric Acid H₂SO₄ – Sulfuric Acid NOx – Oxides of Nitrogen (NO₂ and NO) NO – Nitric Oxide NO₂ – Nitrogen Dioxide NH₃ – Ammonia PM_{2.5} – Particulate Matter up to 2.5 μ m diameter in size PM₁₀ – Particulate Matter up to 10 μ m diameter in size S – Sulfur SO₂ – Sulfur Dioxide SO₄ – Sulfate VOC – Volatile Organic Compound

Units

<u>Length</u> m – meter μ m – micrometer or micron (0.000001 m; 10⁻⁶ m) km – kilometer (1000 m; 10³ m) Mm – Megameter (1,000,000 m; 10⁶ m)

<u>Flow Rate</u> acfm – actual cubic feet per minute

 $\frac{Volume}{L - liter}$ m³ - cubic meter

<u>Mass</u> lb – pound g – gram μ g – micrograms (0.000001 g; 10⁻⁶ g) Adopted

kg – kilograms (1000 g; 10^3 g)

<u>Force</u> psi – pounds per square inch

 $\label{eq:wer} \begin{array}{l} \underline{Power} \\ \overline{W} - watt \mbox{ (Joules/sec)} \\ kW - kilowatt \mbox{ (1000 W; $10^3 W)} \\ MW - megawatt \mbox{ (1,000,000 W; $10^6 W)} \end{array}$

Energy Btu – British thermal unit (= 1055 Joules) MMBtu – million Btu MWhr – megawatt-hour kWhr – kilowatt-hour

 $\frac{Concentration}{\mu g/m^3 - micrograms per cubic meter}$

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Northeast States for Coordinated Air Use Management (NESCAUM)

November 2008

(revised January 2009)

iv

Appendix III.D.7.7-4741

Applicability and Feasibility of NOx, SO₂, and PM Emissions Control Technologies for Industrial, Commercial, and Institutional (ICI) Boilers

Project Director

Praveen Amar, Ph.D., P.E., Director, Science and Policy, NESCAUM

Principal Contributors

Constance L. Senior, Ph.D., Reaction Engineering International Rui Afonso, Energy and Environmental Strategies

Acknowledgments

NESCAUM gratefully acknowledges the funding support provided by the United States Environmental Protection Agency (Clean Air Markets Division (CAMD) and Office of Air Quality Planning and Standards (OAQPS)). Mr. Sikander Khan (CAMD) and Mr. Tim Smith (OAQPS) acted as the Project Managers and Mr. Gene Sun was the Grant Manager.

This report was managed and directed by NESCAUM (Dr. Praveen Amar). NESCAUM was very ably supported by its contractors, Reaction Engineering International (Dr. Constance L. Senior) and Energy and Environmental Strategies (Mr. Rui Afonso). Additionally, Mr. Addison Faler, a student intern at NESCAUM, did extensive data analysis of emission estimates from industrial, commercial, and institutional boilers in the Northeast and the US. Ms. Wendy Roy, Administrative Assistant, NESCAUM, was extremely helpful in final formatting of the report.

NESCAUM thanks the members of the NESCAUM Stationary Sources and Permitting Committee, who guided the design of this report in early stages and provided access to the operating permits data, included in this report. The following individuals provided strong technical support and comments on various draft versions of this report:

Andrew Bodnarik, New Hampshire Department of Environmental Services

Sunila Agrawal, New Jersey Department of Environmental Protection

NESCAUM is an association of the eight northeast state air pollution control programs and provides technical guidance and policy advice to its member states.

TABLE OF CONTENTS

U	NITS,	SPEC	CIES, ACRONYMS	i
A	cknow	ledgn	nents	vi
E	EXECUTIVE SUMMARYxii			
1	IN	INTRODUCTION1-1		
	1.1 Objectives		1-1	
	1.2 Regulatory Drivers		1-1	
	1.3 Characterization of Combustion Sources		1-1	
	1.3.1 Description of Combustion Sources		1-1	
	1.3.2 Emissions by Size, Fuel, and Industry Sector		Emissions by Size, Fuel, and Industry Sector	1-2
	1.3	.3	Differences between EGU and ICI boilers	1-7
	1.3	.4	Control Technology Overview	1-10
	1.4	Cha	pter 1 References	1-10
2	NC	Ox CO	NTROL TECHNOLOGIES	2-1
	2.1	Intro	oduction	2-1
	2.1	.1	ICI versus EGU Boilers	2-1
	2.1	.2	Control Technologies' Impact on Efficiency and CO ₂ Emissions	2-2
	2.2	Disc	cussion of NOx Control Technologies	2-3
	2.2	.1	NOx Formation	2-3
	2.2	.2	NOx Reduction	2-3
	2.2	.3	Other Benefits of NOx Control Technologies	2-3
	2.3	Sum	mary of NOx Control Technologies	2-3
	2.3	.1	Combustion Modifications	2-3
	2.3	.2	Low-NOx Burners and Overfire Air	2-4
2.3.3		.3	Reburn	
	2.3	.4	Post-Combustion Controls	2-6
	2.3	.5	Technology Combinations	2-11
	2.4	App	licability to ICI Boilers	2-12
	2.5	Effic	ciency Impacts	
	2.6	NOx	x Control Costs	2-13
	2.7	Cha	pter 2 References	
3	SO	$_2$ COI	NTROL TECHNOLOGIES	
	3.1	SO_2	Formation	
	3.2	SO_2	Reduction	

	3.3	Othe	er FGD Benefits	
	3.4	Sum	mary of FGD Technologies	
	3.4	4.1	Wet Processes	
	3.4	4.2	Dry Processes	
	3.4	4.3	Other SO ₂ Scrubbing Technologies	
	3.5	Use	of Fuel Oils with Lower Sulfur Content	
	3.6	Арр	licability of SO ₂ Control Technologies to ICI Boilers	
	3.7	Effi	ciency Impacts	
	3.8	SO_2	Control Costs	
	3.9	Cha	pter 3 References	
4	PN	A CON	NTROL TECHNOLOGIES	4-1
	4.1	PM	Formation in Combustion Systems	4-1
	4.2	PM	Control Technologies	
	4.3	Des	cription of Control Technologies	
	4.3	3.1	Fabric Filters	
	4.3	3.2	Electrostatic Precipitators	4-4
	4.3	3.3	Venturi Scrubbers	
	4.3	3.4	Cyclones	
	4.3	3.5	Core Separator	
	4.4	App	licability of PM Control Technologies to ICI Boilers	
	4.5	Effi	ciency Impacts	
	4.6	PM	Control Costs	
	4.7	Cha	pter 4 References	
5	Al	PPLIC	ATION OF A COST MODEL TO ICI BOILERS	5-1
	5.1	Cos	t Model Inputs and Assumptions	5-1
	5.2	Con	parison of the Cost Model Results with Literature	
	5.3	Sum	imary	5-11
	5.4	Cha	pter 5 References	
6	SU	JMMA	NRY	6-1
	6.1	NO	c Controls	6-1
	6.2	SO_2	Controls	
	6.3	PM	Controls	
A	APPENDIX A : Survey of Title V Permits in NESCAUM Region			
A	PPEN	IDIX I	3: CUECost-ICI Inputs	B-1

LIST OF FIGURES

FIGURE 1-1.	TOTAL CAPACITY OF INDUSTRIAL BOILERS AS A FUNCTION OF SIZE [EEA, 2005]1-3
FIGURE 1-2.	TOTAL AND AVERAGE BOILER CAPACITY OF U.S. INDUSTRIAL BOILERS AS A FUNCTION
OF FUE	L FIRED [EAA, 2005]
FIGURE 1-3	TOTAL ANNUAL EMISSIONS OF NOX, SO ₂ , AND $PM_{2.5}$ from ICI boilers in the U.S.
AND IN	THE EIGHT-STATE REGION FROM EPA AIRDATA DATABASE
FIGURE 1-4.	Emissions of NOx, SO ₂ , and $PM_{2.5}$ from ICI boilers in the NESCAUM region
FROM N	MANEVU DATABASE AS A FUNCTION OF FUEL FIRED
FIGURE 1-5.	SOLID-FUEL BOILER INFORMATION FROM FOUR NORTHEAST STATES, BASED ON TITLE
V PERM	IIT INFORMATION 1-8
FIGURE 2-1.	LOW-NOX BURNER [TODD DYNASWIRL-LN ^{IM}]
FIGURE 2-2.	GAS REBURN APPLIED TO A STOKER BOILER [WWW.GASTECHNOLOGY.ORG]2-6
FIGURE 2-3.	SNCR SYSTEM SCHEMATIC [FUELTECH]
FIGURE 2-4.	3-D SCHEMATIC OF AN SCR SYSTEM [ALSTOM POWER]
FIGURE 2-5.	SCHEMATIC AND ACTUAL RSCR [TOUPIN, 2007]2-9
FIGURE 2-6.	BLOCK OF MONOLITH CERAMIC HEAT EXCHANGER [TOUPIN, 2007]2-10
FIGURE 2-7.	CAPITAL COST FOR NOX CONTROL FOR COMBUSTION MODIFICATION APPLIED TO ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 2-8.	CAPITAL COST FOR NOX CONTROL FOR SNCR APPLIED TO ICI BOILERS AS A
FUNCTI	ON OF BOILER CAPACITY
FIGURE 2-9.	CAPITAL COST FOR NOX CONTROL FOR SCR APPLIED TO ICI BOILERS AS A FUNCTION
OF BOII	LER CAPACITY
FIGURE 3-1.	SCHEMATIC OF A WFGD SCRUBBER [BOZZUTO, 2007]
FIGURE 3-2.	SCHEMATIC OF A SPRAY DRYER
[HTTP:/	//www.epa.gov/eogapti1/module6/sulfur/control/control.htm]
FIGURE 3-3.	DRY SORBENT INJECTION (DSI) SYSTEM DIAGRAM
[HTTP:/	//www.epa.gov/eogapti1/module6/sulfur/control/control.htm]
FIGURE 3-4.	FLOW DIAGRAM FOR TRONA DSI SYSTEM [DAY, 2006]
FIGURE 3-5.	SO ₂ REMOVAL TEST DATA [DAY, 2007]
FIGURE 3-6.	INDUSTRIAL ENERGY PRICES FOR NO. 6 OIL GREATER THAN 1 PERCENT S, NO. 6 OIL
LESS TH	HAN 1 PERCENT S, AND NO. 2 OIL [SOURCE: US EIA, 2008]
FIGURE 3-7.	INDUSTRIAL ENERGY PRICES FOR NO. 2 (DISTILLATE) OIL [SOURCE: US EIA, 2008]. 3-
10	
FIGURE 3-8.	CAPITAL COST FOR SO_2 control for dry sorbent injection applied to ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 3-9.	CAPITAL COST FOR SO_2 CONTROL FOR SPRAY DRYER ABSORBER APPLIED TO ICI
BOILER	S AS A FUNCTION OF BOILER CAPACITY
FIGURE 3-10). CAPITAL COST FOR SO_2 CONTROL FOR WET FGD APPLIED TO ICI BOILERS AS A
FUNCTI	ON OF BOILER CAPACITY
FIGURE 4-1.	PHOTOGRAPH OF FABRIC FILTER COMPARTMENT WITH FILTER BAGS [SOURCE:
WWW.H	IAMON-RESEARCHCOTTRELL.COM]
FIGURE 4-2.	SIDE VIEW OF DRY ESP SCHEMATIC DIAGRAM [SOURCE: POWERSPAN]4-4
FIGURE 4-3.	WET ESP [CROLL REYNOLDS]
FIGURE 4-4.	VENTURI SCRUBBER [CROLL REYNOLDS]

8
9
8
9
9
0
1

LIST OF TABLES

TABLE ES-1. ICI BOILER CONTROL TECHNOLOGIES xvii
TABLE 1-1. CAPACITY OF INDUSTRIAL BOILERS [EEA, 2005] 1-3
TABLE 2-1. CO AND NOX REDUCTION USING RSCR [SOURCE: BPEI 2006]2-10
TABLE 2-2. RSCR COST EFFICIENCY [BPEI, 2008]2-11
TABLE 2-3. SUMMARY OF NOX CONTROL TECHNOLOGIES 2-13
TABLE 2-4. NOX CONTROL COSTS FOR COMBUSTION MODIFICATIONS APPLIED TO ICI BOILERS 2-14
TABLE 2-5. NOX CONTROL COSTS FOR SNCR APPLIED TO ICI BOILERS
TABLE 2-6. NOX CONTROL COSTS FOR SCR APPLIED TO ICI BOILERS 2-18
TABLE 3-1. COMPARISON OF PRICE FOR FSI AND LSDI SYSTEMS FOR A 100 MW COAL-FIRED
BOILER [DICKERMAN, 2006]
TABLE 3-2. COMPARISON OF ALTERNATIVE FGD TECHNOLOGIES [BOZZUTO, 2007]3-8
TABLE 3-3. COST ESTIMATES FOR ALTERNATIVE FGD TECHNOLOGIES [BOZZUTO, 2007]3-8
TABLE 3-4. DISTILLATE AND RESIDUAL OIL STOCKS IN 2006 (X1000 BARRELS) [US EIA, 2006]. 3-9
TABLE 3-5. EXAMPLE OF COSTS OF SWITCHING TO LOW-SULFUR FUEL OIL [FUEL PRICES FROM US
EIA, 2008]
TABLE 3-6. Summary of energy impacts for SO_2 control technologies
TABLE 3-7. SO ₂ control costs applied to ICI boilers
TABLE 4-1. AVAILABLE PM CONTROL OPTIONS FOR ICI BOILERS
TABLE 4-2. CORE SEPARATOR COLLECTION EFFICIENCY [USEPA, 2008; RESOURCE SYSTEMS
GROUP, 2001]
TABLE 4-3. CORE SEPARATOR COST ANALYSIS [B. H. EASON TO P. AMAR, 2008]4-9
TABLE 4-4. Summary of energy impacts for control technologies
TABLE 4-5. PM control costs applied to ICI boilers
TABLE 5-1. CUECOST GENERAL PLANT INPUTS 5-2
TABLE 5-2. FUEL CHARACTERISTICS AND ASSUMPTIONS FOR CUECOST CALCULATION OF HEAT
RATE AND FLUE GAS FLOW RATES
TABLE 5-3. EQUIVALENT HEAT INPUT RATE AND FLUE GAS FLOW RATES FOR 250 and 100
MMBTU/HR HEAT INPUT RATES
TABLE 5-4. CAPITAL AND OPERATING COSTS FOR NOX CONTROL TECHNOLOGIES (ASSUMING
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-5. CAPITAL AND OPERATING COSTS FOR SO_2 control technologies (assuming
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-6. CAPITAL AND OPERATING COSTS FOR PM CONTROL TECHNOLOGIES (ASSUMING
7.5 PERCENT INTEREST AND 15-YEAR PROJECT LIFE)
TABLE 5-7. CAPITAL AND OPERATING COSTS FOR SNCR ON WOOD-FIRED BOILERS, COMPARISON
OF COST CALCULATIONS FROM AF&PA AND CUECOST

EXECUTIVE SUMMARY

ES-1 Objectives

The main objective of this study is to evaluate the viability of technologies for controlling emissions of nitrogen oxides (NOx), sulfur dioxide (SO₂), and particulate matter (PM) from industrial, commercial, and institutional (ICI) boilers. These pollutants contribute to the formation of ozone, fine particles, and regional haze, and to ecosystem acidification. This source sector is coming under increased scrutiny by air quality regulators needing emission reductions to meet Clean Air Act requirements.

This study also includes a literature review of emission control costs and develops methods for estimating the costs and cost effectiveness of air pollution controls for ICI boilers. The study concludes that ICI boilers are a significant source of emissions, are relatively uncontrolled compared to electricity-generating units (EGUs), and offer the potential to achieve cost effective reductions for all three pollutants. The results of this technical and economic evaluation are intended as a resource in assessing regulatory and compliance strategies for ICI boilers.

Most of the technologies considered in this report have been successfully applied to the larger EGU boilers. This study investigates both the feasibility of down-scaling such control technologies for ICI boiler applications and of certain technologies that have not been applied to EGUs, but show promise for the ICI boilers.

ES-2 Report Organization

Chapter One provides an overview of the ICI boiler fleet in terms of boiler size, applications, fuel type and associated emissions. Chapters Two, Three, and Four discuss control technology options for NOx, SO₂ and PM, respectively. Each chapter provides: (1) descriptions of available control technologies; (2) a discussion of the applicability of these technologies to ICI boilers; (3) published cost estimates; and (4) an assessment of the impact of control technologies on overall facility efficiency. Chapter Five summarizes information about air pollution control equipment costs for ICI boilers calculated with the Coal Utility Environmental Cost (CUECost) model.

ES-3 Differences between ICI and EGU Boilers

ICI and EGU boilers differ in size, application, design, and emissions. Most commercial and institutional boilers are relatively small, with an average capacity of 17 MMBtu/hour. Industrial boilers can be as large as 1,000 MMBtu/hr or as small as 0.5 MMBtu/hr. By contrast, the average size of a coal-fired EGU boiler in the U.S. is greater than 2,000 MMBtu/hr.

All coal-fired EGUs in the United States are equipped with PM control devices and many have SO_2 and NOx emission controls. ICI boilers are significantly less likely to have air pollution control devices.

As part of this study, NESCAUM conducted a preliminary survey of the use of emission controls on ICI boilers in the Northeast. Survey results revealed that more than half of the units surveyed in the region had no controls; about one-third had PM controls, while very few units

had NOx controls. None of the surveyed units had SO_2 controls, although some have wet venturi scrubbers for PM control, which minimally reduce SO_2 emissions.

Technical, operational, economic and regulatory factors impose different opportunities and constraints on the applicability of air pollution control devices (APCDs) for EGU and ICI boilers. The following technical and operational characteristics must be evaluated in determining the potential applicability of emission controls for specific ICI boilers.

- Fuel type and quality SO₂, PM, and NOx emissions from coal-fired boilers are typically higher than from those burning natural gas, oil, or wood waste. Some APCD technologies are not particularly sensitive to such variations. For example, an electrostatic precipitator (ESP) or a fabric filter (FF) can accommodate different PM concentrations, although the type and size of PM and gas temperatures will have an impact. Other controls that utilize reagents, such as SO₂ scrubbers and selective catalytic reduction or selective non-catalytic reduction (SCR/SNCR) technologies for NOx, are directly affected by fuel type and quality.
- Duty cycle APCD controls must be capable of accommodating significant variation or cycling of boiler loads. These variations affect flue gas flow rates and temperatures, which in turn may require different control capability. For example, an SCR or SNCR system must operate within a temperature window that may or may not exist across the load range for a particular ICI boiler.
- Design differences The presence of equipment such as economizers or air preheaters has a direct impact on flue gas temperatures. Temperature-sensitive technologies such as ESPs, SO₂ scrubbers, and SCR/SNCR that are widely used in EGUs may or may not be applicable to ICI boilers in certain cases.

ES-4 NOx Control Technologies

Emission control strategies for NOx can be divided into two basic categories: combustion modifications and post-combustion technologies. Control efficiency ranges and cost effectiveness (\$/ton of NOx removed) for various technologies are provided in Table ES-1. Combustion modification technologies, which minimize the formation of NOx during the combustion process, include: combustion tuning; low-NOx burners and overfire air (LNBs and OFA); and gas, oil, or coal reburn.

LNBs have minimal effect on overall operating costs, but may introduce higher carbon monoxide and/or carbon levels in the fly ash, which reflect lower plant efficiency. In the case of gas reburn, operating costs are primarily a function of the fuel cost differential; for coal or oil reburn, fuel preparation costs (pulverization and atomization, respectively) represent the primary operating and maintenance costs. While gas reburn is easier to implement, the fuel differential costs are often prohibitive. The overall cost of low-NOx combustion technology installation depends on the firing system, and this is reflected in the lack of a clear relationship between capital cost and boiler capacity.

Post-combustion technologies reduce the amount of NOx exiting the stack that was formed during combustion. This group includes SNCR, SCR, and regenerative SCR (RSCR) technologies. Because the reaction occurs without the need for catalysts, SNCR systems have

lower capital costs, but achieve lower NOx reduction. SCR, on the other hand, is capitalintensive, but offers the opportunity for significantly greater NOx reductions because a dedicated reactor and a reaction-promoting catalyst ensure a highly controlled, efficient reaction. RSCR combines a regenerative thermal oxidizer with SCR technology, making it suitable for facilities with lower gas temperatures, such as those found in some ICI boilers. RSCRs can also reduce carbon monoxide emissions by half.

ES-5 SO₂ Control Technologies

SO₂ emission control technologies are post-combustion devices that utilize a process involving SO₂ reacting in the exhaust gas with a reagent (usually calcium- or sodium-based) and removal of the resulting product (a sulfate/sulfite) for disposal or commercial use. SO₂ control technologies are commonly referred to as flue gas desulfurization (FGD) and/or "scrubbers" and are usually characterized in terms of the process conditions (wet vs. dry), byproduct utilization (throwaway vs. saleable), and reagent utilization (once-through vs. regenerable). Wet scrubbers provide much greater levels of SO₂ control. Conventional dry processes include spray dryers (SDs) and dry sorbent injection (DSI). The capital costs of wet scrubbers are higher than those of dry scrubbers, although the cost effectiveness values (in dollars per ton of SO₂ removed) of wet and dry processes are similar. DSI technology has a significantly lower capital cost than wet or dry scrubbers and should therefore be more attractive for ICI boilers than conventional scrubbers.

In the eight-state NESCAUM region, residual oil is a common fuel for ICI boilers. Switching to a lower sulfur residual oil (for example, from 3 percent to 1 percent sulfur residual oil) can provide cost-effective SO_2 reductions. The cost of switching to lower sulfur distillate oil is much higher than switching to low sulfur residual oil, because the cost of distillate oil has been about twice that of residual oil in recent years. The cost effectiveness (in dollars per ton of SO_2 removed) from switching from residual fuel oil to distillate fuel oil is not as attractive and falls in the range of the cost effectiveness of installing a FGD scrubber.

ES-6 PM Control Technologies

Combustion processes emit both primary and secondary particulate matter. Primary emissions consist mostly of fly ash (e.g., non-combustible inorganic matter and unburned solid carbon). Secondary emissions are the result of condensable particles such as nitrates and sulfates that typically make up the smaller fraction of the particulate matter. PM control technologies include: fabric filters or "baghouses," wet and dry ESPs, venturi scrubbers, cyclones, and core separators. While PM controls are not currently widely used on ICI boilers, there are no technical reasons why PM controls cannot be applied to solid-fueled and oil-fired ICI boilers.

ES-7 Impact of Control Technologies on Operational Efficiency and Carbon Dioxide Emissions

Air pollution control technologies and strategies (e.g., fuel switching) can have varying impacts on the overall efficiency of the host plant. This impact can be either positive or negative depending on technology and fuel choices.

Carbon dioxide (CO₂) emissions are primarily a function of the carbon content of fuels. However, the application of conventional pollutant control technologies can affect CO_2 emissions. This impact can vary widely among technologies within the same pollutant (e.g., LNB vs. SCR for NOx), as well as across different pollutants (e.g., fabric filter for PM vs. scrubbers for SO₂).

Combustion modification technologies for NOx have essentially no impact on the CO_2 emissions of the host boilers – with the noted exception of reburn when displacing coal or oil with natural gas – because the technologies do not impose any significant parasitic energy consumption (auxiliary power) requirements. With respect to the post-combustion technologies, both SNCR and SCR impose some degree of energy demand on the host boiler. These impacts include pressure, compressor, vaporization, and steam losses, and can range from 1–2 kW/1000 actual cubic feet per minute (acfm) for SNCR and up to about 4 kW/1000 acfm for SCR.

The major components affecting energy consumption for SO_2 systems include electrical power associated with material preparation (e.g., grinding) and handling (pumps/blowers), flue gas pressure loss across the scrubber vessel, and steam requirements. The power consumption of the SO_2 control technologies is further affected by the SO_2 control efficiency of the technology itself. SO_2 controls have a range of potential parasitic losses, from duct injection representing about 1–2 kW/1000 acfm to wet FGD at as high as 8 kW/1000 acfm.

PM control technologies will result in some parasitic energy loss due to pressure loss, power consumption, and ash handling. Dry ESPs and fabric filters have the lowest associated parasitic power consumption (<2 kW/1000 acfm), while high-energy venturi scrubbers can be up to 10 kW/1000 acfm or higher.

ES-8 Cost Analysis

Cost is an important factor in evaluating the viability of air pollution control technologies. Information on capital and operating costs is more readily available for EGU than ICI boilers. Operating costs may be different for ICI boilers than utility boilers because of their size and the fact that they are typically located on smaller sites. Operating costs also include waste disposal and reagent use. ICI boiler sites typically have higher contingency, general facility, engineering, and maintenance costs, as a percentage of total capital cost, than those for utility boilers.

Cost estimates for ICI boilers with capacities ranging from 100 to 250 MMBtu/hr were generated by the CUECost model. This model, created by Raytheon Engineers for US EPA, was originally developed for large coal-fired EGUs and calculates capital and operating costs for certain pre-defined air pollution control devices for NOx, SO₂, and PM. The CUECost model produces approximate estimates (\pm 30 percent accuracy) of installed capital and annualized operating costs. The CUECost model was adapted in this study for ICI boilers burning a variety of fuels by changing the fuel composition and heating value to simulate different fuels. This study represents the first attempt to utilize a comprehensive cost model specific to ICI boilers.

Chapter Two contains a detailed discussion of the literature values for NOx control costs for ICI boilers. The NOx control costs for ICI boilers computed with CUECost were largely consistent with values reported in the literature. In terms of NOx removal, reported values were in the range of \$1,000 to \$3,000 per ton for LNBs or SNCR, and \$2,000 to \$14,000 per ton for SCR. The SCR costs for coal-fired ICI boilers appear to be consistent with the literature, although the CUECost capital cost values for residual oil were higher than the literature values. The capital costs for SNCR calculated from the CUECost models were in good agreement with literature values, particularly their sensitivity to boiler capacity. The capital costs for LNBs

calculated from CUECost for coal-fired boilers were consistent with the literature values, although the costs for residual oil-fired boilers were higher in CUECost than the literature values.

Chapter Three contains a detailed discussion of the literature values for SO_2 control costs for ICI boilers. In terms of the cost per ton of SO_2 removed, reported values were in the range of \$1,600 to \$5,000 for spray dryers (SDs) and \$1,900 to \$5,200, for wet FGDs. The SO_2 capital costs computed with CUECost for SDs were in the range of the literature values at 250 MMBtu/hr. However, the capital costs computed by CUECost for wet FGDs were high compared to values reported in the literature.

Chapter Four contains a detailed discussion of the literature values for PM control costs. Literature values for capital costs for PM control were evaluated from EPA reports on PM controls applied to industrial boilers. The cost effectiveness of ESPs was in the range of \$50 to \$500 per ton of PM for coal, and up to \$20,000 per ton of PM for oil. The cost effectiveness of baghouses was in the range of \$50 to \$1,000 per ton of PM for coal and up to \$15,000 per ton of PM for oil.

The dry-ESP control costs computed with CUECost were consistent with the literature values, although the CUECost predicted slightly higher values than reported by EPA for dry, wire-plate ESPs. The baghouse/fabric filter costs computed with CUECost were higher than the literature values for pulse-jet fabric filters.

This adaptation of CUECost model from EGUs to ICI boilers was intended to investigate the feasibility of estimating costs of controlling emissions of NOx, SO_2 , and PM from ICI boilers. Further detailed work would be needed to validate this approach, but initial results included in this report are promising.

ES-9 Conclusion

ICI boilers are a significant source of NOx, SO₂, and PM emissions, which contribute to the formation of ozone, fine particles, and regional haze, and to ecosystem acidification. These boilers are relatively uncontrolled compared to EGUs and offer the potential to achieve cost-effective reductions for all three pollutants. A host of proven emission control technologies for EGUs can be scaled-down and deployed in industrial, commercial, and institutional settings to cost-effectively reduce emissions of concern. Other technologies that have not been applied to EGUs show promise for ICI boiler applications. Careful analysis will be needed to match the appropriate emission control technology for specific applications given: boiler size, fuel type/quality, duty-cycle, and design characteristics. Further, regulators will need to determine the level of emission reductions needed from this sector in order to inform the appropriate choice of controls.

Pollutant	Technology	Control Efficiency	Cost Effectiveness \$ per ton
NOx			
Combustion Modifications	Tuning	5-15%	current data not available
	LNB	25-55%	\$750-\$7,500
	Reburn	35-60%	current data not available
Post- Combustion	SNCR	30-70%	\$1,300-\$3,700
	SCR	70-90%	\$2,200-\$14,400
	RSCR	60-75%	\$4,500
SO ₂	Wet Scrubbers	95+%	\$1,900-\$5,200
	Spray Dryers	90-95%	\$1,600-\$5,200
	Dry Sorbent Injection	40-90%	current data not available
PM			
	Fabric Filters/Baghouses	99+%	\$400-\$1,000 – coal \$6,900-\$16,500- oil
	Wet/Dry ESPs	99+%	\$160-\$2,600 – coal
			\$2,300 to \$43,000 - oil
	Venturi Scrubbers	50-90%	current data not available
	Cyclones	70-90%	current data not available
	Core Separators	60-75%	current data not available

Table ES-1. ICI Boiler Control Technologies

1 INTRODUCTION

1.1 Objectives

The main objective of this study is to evaluate various available control technologies and their cost effectiveness in reducing emissions of three pollutants: oxides of nitrogen (NOx), sulfur dioxide (SO₂), and primary fine particulate matter ($PM_{2.5}$) from industrial, commercial, and institutional (ICI) boilers. The study results should provide a strong technical and economic basis for developing cost-effective regulations and strategies to reduce emissions of these three major pollutants from ICI boilers.

1.2 Regulatory Drivers

Federal, state and local governments regulate all major criteria air pollutants under the authority of the Clean Air Act (CAA). The CAA mandates control of pollutants such as NOx, SO₂, and PM_{2.5} to attain and maintain National Ambient Air Quality Standards (NAAQSs) for ozone and PM_{2.5}, reduce acidic deposition, and improve visibility under regional haze regulations. Emission standards for specific source categories, including ICI boilers, are also set by federal, state, and local governments to attain and maintain a NAAQS. Examples of these emission standards include New Source Performance Standards (NSPS), Best Available Control Technology (BACT), Lowest Achievable Emission Rate (LAER), Reasonably Available Control Technology (RACT), and Best Available Retrofit Technology (BART).

States must formulate State Implementation Plans (SIPs) that provide a framework for limiting air emissions from major sources as part of a strategy for demonstrating attainment and maintenance of NAAQS. Some individual SIPs (if allowed by the state law) may set more stringent limits on emissions of NOx, SO₂, and PM_{2.5} than required by the federal rules. However, states cannot set less stringent limits than required by federal rules and regulations. Generally, federal, state, and local permitting authorities rely upon available information on the latest advanced technologies for emission control when setting emission limits. Where applicable, permitting authorities require BACT and RACT in order to reduce air emissions from stationary sources. In areas that have not achieved a NAAQS (i.e., non-attainment areas), the CAA requires air pollution limits established by LAER for new major stationary sources and major modifications to existing stationary sources. BACT and RACT analyses consider the cost of controls. LAER control technologies, applicable to new major sources located in non-attainment areas, must be installed, operated and maintained without consideration of costs.

1.3 Characterization of Combustion Sources

1.3.1 Description of Combustion Sources

Boilers utilize the combustion of fuel to produce steam. The hot steam is then employed for space and water heating purposes or for power generation via steam-powered turbines.
Boiler size is typically represented in four ways: fuel input in units of MMBtu/hr, output of steam in lb steam/hr at a specified temperature and pressure, boiler horsepower (1 boiler hp = 33,475 MMBtu/hr), or electrical output in MWhr or MW (if electricity is generated).

The three main types of boilers are described below:

- *Firetube boilers*. Hot gases produced by the combustion of fuel are used to heat water. The hot gases are contained within metal tubes that run through a water bath. Heat transfer through thermal conduction heats the water bath and produces steam. Typically, firetube boilers are small, with capacity below 100 MMBtu/hr.
- *Watertube boilers*. Hot gases produced by fuel combustion heat the metal tubes containing water. Typically, there are several tubes configured as a "wall." Watertube boilers vary in size from less than 10 MMBtu/hr to10,000 MMBtu/hr.
- *Fuel-firing*. Fuel is fed into a furnace and the high gas temperatures generated are used to heat water. Fuel-firing boilers include stoker, cyclone, pulverized coal, and fluidized beds. Stokers burn solid fuel and generate heat either as flame or as hot gas. Pulverized coal (PC) enters the burner as fine particles. The combustion in the furnace produces hot gases. The ash (the unburned fraction) exits in molten or solid form. Fluidized beds utilize an inert material to "suspend" the fuel. The suspension allows for better mixing of the fuel and subsequently better combustion and heat transfer to tubes.

Boilers are also classified by the fuel they use – chiefly coal, oil, natural gas, wood, and waste byproducts.

1.3.2 Emissions by Size, Fuel, and Industry Sector

In 2005, Energy & Environmental Analysis, Inc. [EEA, 2005] estimated that there were 162,805 industrial and commercial boilers in the U.S., which had a total fuel input capacity of 2.7 million MMBtu/hr as summarized in Figure 1-1 and Table 1-1. This estimate included 43,015 industrial boilers with a total capacity of 1.6 million MMBtu/hr and 119,790 commercial boilers with a total capacity of 1.1 million MMBtu/hr. In addition, EEA estimated that there were approximately 16,000 industrial boilers in the non-manufacturing sector with a total capacity of 260,000 MMBtu/hr, but details on size distribution of these boilers were not provided because these units were not well characterized.

The EEA report divided boilers into two major categories (industrial and commercial) instead of the more common characterization as industrial, commercial, and institutional boilers. One segment of the ICI boiler population, identified as non-manufacturing industrial boilers, is not included in the EEA analyses due to a lack of sufficient data. The non-manufacturing segment accounted for only 11 percent of energy consumption in the industrial boiler population. The manufacturing and non-manufacturing segment of the population appear (from EEA's description) to correspond to what would be called industrial boilers. The commercial segment of the population includes what are designated in this report as commercial and institutional boilers. For example, there are several large boilers located at major institutions such as universities (e.g., Notre Dame, Cornell, etc.) and also several large boilers located at major hospitals (e.g., Massachusetts General Hospital) that belong in the institutional category instead

of the commercial sector. Thus, EEA's analysis appears to apply to most of the ICI boiler population, representing 89 percent of energy use by ICI boilers.

Industrial boilers were generally larger than commercial units. Sixty percent of the boilers in the manufacturing sector were greater than 100 MMBtu/hr in capacity, whereas 60 percent of the boilers in the commercial sector were in the range of 10 to 100 MMBtu/hr. The average capacity of the commercial boilers was 10 MMBtu/hr, with most less than 10 MMBtu/hr; the capacity of the average industrial boiler was 36 MMBtu/hr. Non-manufacturing boilers fell in between, at an average capacity of 16 MMBtu/hr. For industrial boilers, the average capacity factor was 47 percent (capacity factor is defined as the ratio of actual heat input in MMBtu to the maximum heat input based on nameplate capacity of the unit, calculated for a period of one year).

	Manufacturing	Non-Mfg	Commercial	
Unit Capacity	Boilers	Boilers*	Boilers	Total
<10 MMBtu/hr	102,306		301,202	403,508
10-50 MMBtu/hr	277,810		463,685	741,495
50-100 MMBtu/hr	243,128		208,980	452,108
100-250 MMBtu/hr	327,327		140,110	467,437
>250 MMBtu/hr	616,209		33,639	649,848
Total Capacity, MMBtu/hr	1,566,780	260,000	1,147,617	2,714,397
Total Capacity >10 MMBtu/hr	1,464,474		846,415	2,310,889**
Total number of units	43,015	16,000	119,790	162,805
Average Capacity, MMBtu/hr	36	16	10	17

*No details provided on range of capacities

**Total does not include non-manufacturing boilers



Figure 1-1. Total capacity of industrial boilers as a function of size [EEA, 2005]

1-3 Appendix III.D.7.7-4757 Five major steam-intensive industries accounted for more than 70 percent of the boiler units and more than 80 percent of the boiler capacity of the manufacturing segment of industrial boilers: food, paper, chemicals, petroleum refining, and primary metals. The non-manufacturing segment of the industrial sector included agriculture, mining and construction. The largest categories in the commercial sector, by capacity, were schools, hospitals, lodgings, and office buildings.

Industrial boilers in the manufacturing sector are used to generate process steam and electricity. The fuels used in manufacturing boilers are related to the size of the boilers and, in some cases, the byproducts generated in the particular manufacturing process.

In the food production subsector, the average boiler capacity was 20 MMBtu/hr. The relatively small average capacity was reflected in the higher percentage (58 percent) of natural gas-fired boilers in the food industry than in any other major subsector, since very small boilers tend to burn natural gas.

The paper industry included some of the largest industrial boilers, with an average boiler size of 109 MMBtu/hr. The paper industry represented more than half (230,000 MMBtu/hr) of the total capacity of the manufacturing sector. More than 60 percent of the fuel used in paper industry boilers was wood (bark, wood chips, etc.) or black liquor, a waste product from the chemical pulping process.

The chemical industry employed both large and small boilers, with about seven percent of the units with capacities smaller than 10 MMBtu/hr, and a significant number (about 350 or 37 percent of total capacity) larger than 250 MMBtu/hr. The primary fuels for chemical industry boilers were natural gas (43 percent), process off-gas (39 percent), and coke (15 percent).

The refining industry had an average boiler size of 143 MMBtu/hr, the largest of any of the major industries, with over 200 boilers with capacities above 250 MMBtu/hr. By-product fuels (refinery gas or carbon monoxide) were the most common fuel source for boilers (58 percent), followed by natural gas (29 percent) and residual oil (11 percent).

About half of the total boiler capacity in the primary metals industry was from boilers larger than 100 MMBtu/hr. By-product fuels, like coke oven gas and blast furnace gas, provided the largest share (63 percent) of boiler fuel in the primary metals industry.

The remaining industries accounted for about 29 percent of manufacturing boilers (12,000 units) or about 18 percent of industrial boiler capacity. The average capacity for the rest of the manufacturing subsector was 23 MMBtu/hr. Approximately 100 boilers at other manufacturing facilities had capacities larger than 250 MMBtu/hr.

Unlike industrial boilers, which serve production processes, commercial boilers provide space heating and hot water for buildings. Natural gas fired the vast majority of commercial boilers, including 85 percent of commercial boiler units and 87 percent of the total commercial boiler capacity. About 10 percent of the commercial boilers were fired by oil. Coal was fired at about one percent of the commercial boilers, but represented five percent of the capacity, reflecting the larger size of commercial coal-fired boilers.

Figure 1-2 summarizes the total US boiler capacity in the manufacturing and commercial sectors as a function of fuel fired (left side of figure) and shows the average capacity per boiler (right side of figure) by fuel type. Coal-fired boilers were the largest in size on average. As discussed above, natural gas accounted for 70 percent of the total industrial boiler capacity in the

EEA survey. Coal and byproduct fuels accounted for about 10 percent each, with lesser capacity in oil- and wood-fired boilers.

In the manufacturing sector, the average coal-fired boiler capacity was about 180 MMBtu/hr, but the average capacity in both sectors combined was about 125 MMBtu/hr. Wood- and byproduct-fired boilers in the manufacturing sector were also large on average (120 and 110 MMBtu/hr, respectively). On the other hand, oil- and natural gas-fired boilers were small, on the order of 20 MMBtu/hr in the manufacturing sector and less than 10 MMBtu/hr in the commercial sector.





From EEA's 2005 study, the following general conclusions about boiler size for the entire U.S. ICI boiler population can be drawn:

- natural gas is the fuel fired at most ICI boilers;
- natural gas- and oil-fired boilers tend to be small, less than 20 MMBtu/hr in capacity;
- boilers fired with coal, wood, or process byproducts are larger in size, greater than 100 MMBtu/hr on average;
- although natural gas fired most of the ICI boilers in the U.S., coal, oil, and wood contribute substantially more to the emissions of SO₂ and PM; and
- all fuels are sources of NOx emissions.

One needs to be careful drawing conclusions for the eight-state NESCAUM region based on the national data in the EEA 2005 study because there are large region-to-region and state-tostate differences in boiler populations. For example, fuel oil is an important fuel in the Northeast, especially in rural areas where natural gas may not be available, while natural gas is predominant in other areas of the country. A preliminary assessment of emissions from ICI boilers by pollutant in the U.S. and in the eight-state NESCAUM region was carried out using data from the AirData database via the EPA website (www.epa.gov/air/data). In this database, stationary sources, such as electric generating plants and factories, are identified individually by name and location. Figure 1-3 compares the annual emission of NOx, SO₂, and PM_{2.5} in the U.S. with the eight-state NESCAUM region for 2002. Emissions in the NESCAUM region are about 5 percent of the US total emissions.



Figure 1-3 Total annual emissions of NOx, SO₂, and PM_{2.5} from ICI boilers in the U.S. and in the eight-state region from EPA AirData database

Another set of data from the eight-state region was extracted from the MANEVU 2002 non-road inventory (<u>www.manevu.org</u>). In this data set, oil-fired boilers were divided into distillate oil and residual oil-fired boilers (Figure 1-4).

NOx emissions in the eight-state NESCAUM region are mostly from oil- and gas-fired boilers. Because these are generally small boilers, combustion controls are good candidates for NOx control. For larger, coal- or wood-fired boilers, SNCR or SCR might also be applicable.

PM emissions are relatively low from coal-fired sources in the eight-state region, which suggests that most of the coal-fired sources already have particulate control devices. Oil- and wood-fired units have higher PM emissions, and PM emissions attributed to natural gas are quite small.

As might be expected, most of the SO_2 emissions from oil-fired boilers come from residual oil-fired boilers because of residual oil's higher sulfur content.



Figure 1-4. Emissions of NOx, SO₂, and PM_{2.5} from ICI boilers in the NESCAUM region from MANEVU database as a function of fuel fired

1.3.3 Differences between EGU and ICI boilers

EGU boilers produce steam in order to generate power. While ICI boilers do in some cases generate steam for electricity production, ICI boilers differ from EGUs in size, steam application, design, and emissions. Most commercial and institutional boilers are small, with an average capacity of 17 MMBtu/hour (Table 1-1). Industrial boilers can be as large as 1,000 MMBtu/hr or as small as 0.5 MMBtu/hr. The average size of a coal-fired EGU boiler in the U.S. is over 200 MW or over 2,000 MMBtu/hr.

All coal-fired EGUs in the United States use control devices to reduce PM emissions. Additionally, many of the EGU boilers are required to use controls for SO_2 and NOx emissions, depending on site-specific factors such as the properties of the fuel burned, when the power plant was built, and the area where the power plant is located.

According to 1999 EPA Information Collection Request (ICR) responses from coal-fired EGUs, 77.4 percent of EGUs had PM post-combustion control only, 18.6 percent had both PM and SO₂ controls, 2.5 percent had PM and NOx controls, and 1.3 percent had all three post-combustion control devices [Kilgroe *et al.*, 2001]. Information from 2004 indicated that the fractions of total capacity of large coal-fired EGUs that have flue gas desulfurization (FGD) to control SO₂ and selective catalytic reduction (SCR) to reduce NOx controls were 38 percent and 37 percent, respectively [NESCAUM, 2005]. Since the 1999 ICR survey, additional NOx and SO₂ controls have been added at a rapid pace to coal-fired EGUs. It is presently not clear how

the implementation of NOx and SO_2 control technologies for EGUs would evolve as a consequence of the recent vacatur of Clean Air Interstate Rule (CAIR) by the U.S. D.C. Circuit.

In contrast to EGUs, ICI boilers are substantially less likely to have air pollution control devices. A study of industrial boilers and process heaters [USEPA, 2004] that looked at 22,117 industrial boilers and process heaters, which burned natural gas, distillate oil, residual oil, and coal, found that 88 percent had no air pollution control equipment.

A preliminary survey was undertaken as part of this study to evaluate the extent to which various emission controls were currently being applied to ICI boilers in the Northeast. These data were acquired from State Title V permits for solid-fueled (coal and wood) boilers as well as additional information from state personnel. The survey collected data in four states: Massachusetts, Vermont, New Hampshire, and New York. The data set was composed of 64 boilers – 47 wood-fired and 17 coal-fired. *Figure 1-5* illustrates the distribution of boiler capacity (by size) and the air pollution control devices (APCDs) in this data set. The full data set is summarized in Appendix A. As can be seen in *Figure 1-5(b)*, more than half of the units had no controls, about one-third had controls only for PM, and very few units had controls for NOx. There were no units with SO₂ controls, although some of the PM controls were wet venturi scrubbers, which might have a limited impact on SO₂ emissions.





There are several factors that directly or indirectly affect the reasons for the discrepancy in APCD deployment between EGU and ICI boilers. Technical and operational as well as business, economic, and regulatory factors impose different constraints and provide different opportunities for the applicability of APCDs for these two categories of boilers. The following discussion summarizes some of the important technical and operational issues.

Large, base-loaded EGUs operate mainly near maximum capacity or steam production. Industrial boilers typically do not run at maximum capacity, although this varies from one industry to another [EEA, 2005]. EGUs produce steam for electricity generation, while ICIs may produce steam for a variety of applications. The type of manufacturing is often more important in determining boiler operation, or duty cycle (load vs. time) than manufacturing demand in general.

ICI boilers generate steam for processing operations for paper, chemical, refinery, and primary metals industries. Commercial boilers produce steam for a variety of processes, while institutional boilers are normally used to produce steam and hot water for space heating in office buildings, hotels, apartment buildings, hospitals, universities, and similar facilities.

Another difference between EGU and ICI boilers is fuel diversity. EGU boilers are mostly single-fuel (coal, No. 6 oil, natural gas), while ICI boilers tend to be designed for and use a more diverse mix of fuels (e.g., fuel by-products, waste, wood) in addition to the three conventional fuels above.

These differences in operational and fuel usage not only affect a boiler's duty cycle, but its design, which is equally important from the perspective of APCD applicability. Examples that directly affect APCD choice and applicability include equipment such as economizers or air preheaters, which affect the temperature of the flue gas at the stack. The differentiation in fuel usage also leads to different design parameters for emissions controls. For example, the iron and steel industry generates blast furnace gas or coke-oven gas, which is used in boilers, resulting in sulfur emissions. Pulp and paper boilers may use wood waste as a fuel, resulting in high PM emissions. Units with short duty cycles may utilize oil or natural gas as a fuel. The use of a wide variety of fuels is an important characteristic of the ICI boiler category.

These factors relate directly to APCD equipment choices and applicability. The following examples should help explain some of these impacts.

- Fuel quality different fuels have different emission characteristics. SO₂, PM, and NOx emissions from coal fired boilers are different from those burning natural gas, oil, or wood waste. Some APCD technologies are not very sensitive to fuel quality variations (e.g., an electrostatic precipitator (ESP) may accommodate different levels of PM concentration, although the type and size of particles and gas temperatures will have an impact). However, others can be directly affected by changes in fuel quality and the resulting changes in pollutant concentrations in the flue gas to be treated (e.g., SO₂ and NOx controls that utilize reagents such as scrubbers for SO₂ and SCR/SNCR for NOx).
- Duty cycle significant variation or cycling of boiler load requires APCD controls capable of accommodating such variations. These variations affect flue gas flow rates and temperatures, which in turn may require different control capability. For example, an SCR or SNCR system must operate within a temperature window that may or may not exist across the load range for a particular ICI boiler.
- Design differences the use of equipment such as economizers or air preheaters has direct impact on the resulting flue gas temperature. Temperature-sensitive technologies such as ESPs, SO₂ scrubbers (wet and dry), and SCR /SNCR that are widely used in EGUs may or may not be applicable for some ICI boilers in such cases.

1.3.4 Control Technology Overview

A variety of emission control technologies are employed to reduce emissions of NOx, SO₂, and primary PM emissions. Technical details of control technologies for NOx, SO₂, and PM are discussed in Chapters Two, Three, and Four, respectively. Pollutant emission controls are generally divided into three major types given in the following list.

- *Pre-combustion Controls*. Control measures in which fuel substitutions are made or fuel pre-processing is performed to reduce pollutant formation in the combustion unit.
- *Combustion Controls.* Control measures in which operating and equipment modifications are made to reduce the amount of pollutants formed during the combustion process; or in which a material is introduced into the combustion unit along with the fuel to capture the pollutants formed before the combustion gases exit the unit.
- *Post-combustion Controls*: Control measures in which one or more air pollution control devices are used at a point downstream of the furnace combustion zone to remove the pollutants from the post-combustion gases.

Data on costs of pollution control equipment taken from the literature are reviewed in the individual technology chapters. In Chapter Five, an existing model for the estimation of air pollution control equipment costs for coal-fired EGUs (CUECost) is applied to ICI boilers burning different fuels (coal, oil, wood) with appropriate caveats and assumptions to provide reasonable and approximate control costs for ICI boilers.

1.4 Chapter 1 References

Energy & Environmental Analysis, Inc. (EEA). *Characterization of the U.S. Industrial Commercial Boiler Population*. May 2005.

Kilgroe, J.D. et al. Control of Mercury Emissions from Coal-Fired Electric Utility Boilers: Interim Report, EPA-600/R-01-109, December 2001.

MACTEC. Assessing Reasonable Progress for Regional Haze in the Mid-Atlantic North Eastern Class I Area - Revised Final Draft; MACTEC Federal Programs: Research Triangle Park, NC, March 8, 2007.

NESCAUM. Assessment of Control Technology Options for BART-Eligible Sources; 2005.

Ozone Transport Commission (OTC). *Identification and Evaluation of Candidate Control Measures – Technical Support Document*. February 28, 2007.

Sabo, E.; Toothman, D. *Identification and Evaluation of Candidate Control Measures Final Technical Support Document*; MACTEC Federal Programs, Inc.: Herndon, VA, February 28, 2007.

Sliwinski, R. "ICI Boiler Control Recommendations," Ozone Transport Commission Fall Meeting, November 15, 2006.

State and Territorial Air Pollution Program Administrators/Association of Local Air Pollution Control Officials (STAPPA/ALAPCO), now known as National Association of Clean Air

Agencies (NACAA). Controlling Fine Particulate Matter under the Clean Air Act: A Menu of Options, March 2006.

US EPA. Alternative Control Techniques Document--NO Emissions from Industrial/Commercial/Institutional (ICI) Boilers; EPA-453/R-94-022; 1994.

US EPA. Regulatory Impact Analysis for the Industrial Boilers and Process Heaters NESHAP, EPA EPA-452/R-04-002, February, 2004.

2 NOx CONTROL TECHNOLOGIES

2.1 Introduction

This brief introduction applies to chapters Two, Three, and Four, which discuss control technology options for ICI boilers for NOx, SO₂, and PM, respectively. However, these chapters are not intended to provide detailed descriptions of the many available technologies for each pollutant. Significant literature is available for that purpose; in the context of this report, these chapters are intended to provide the reader with a general understanding of concepts, performance, applicability, and costs of the main technologies available. Further, in recognition of the concern with climate change, a brief discussion of energy consumption (parasitic power) associated with major technologies is included.

Specifically with respect to the deployment and applicability of air pollution controls, comparisons between ICI boilers and EGUs are relevant because of the more widespread application of pollution control equipment in the EGU sector. This was discussed in some detail in Chapter One. In addition, a few considerations specific to certain technologies and strategies are discussed, as appropriate.

2.1.1 ICI versus EGU Boilers

In general, the greater proliferation of air pollution control technologies in the EGU sector, as opposed to the industrial sector, seems to be driven by three dominant, differentiating factors.

- Size difference and associated emissions between the two: Because EGUs are much larger than ICI boilers, they have been targeted for environmental regulatory controls more heavily over the years.
- Technology costs: While not universally true, ICI boilers often have constraints due to their smaller sizes, diversity of plant layouts, and urban settings, all of which can have a negative impact on the costs of applying some of the control technologies. Conversely, and equally important, opportunities for lower-cost applications to ICI boilers do exist as a result of the smaller sizes, such as in the ability to have systems pre-fabricated and ready to erect onsite, as opposed to on-site construction requirements often needed with larger systems for EGUs.
- Cost recovery: The two sectors are significantly different from a fundamental business view, with EGUs being regulated entities, as opposed to openly competitive markets that exist within the ICI boiler population. This is important in that it affects how business decisions are made in the two sectors, how capital equipment purchases are funded, and also how ICI plants are designed and operated.

2.1.2 Control Technologies' Impact on Efficiency and CO₂ Emissions

Air pollution control technologies and strategies can have varying impacts on the overall efficiency of the host plant. This impact can be either positive or negative and it is a function of the type of technology, as well as fuel choices.

An extreme example of this is the control of SO_2 from a coal-fired unit by two significantly different approaches: in one case, the use of an energy–intensive FGD "scrubber" penalizes the efficiency of such unit by up to 2 percent, resulting in a corresponding increase in CO_2 emissions; a very different and contrasting case, in which the unit chooses to reduce its SO_2 generation by switching from coal to natural gas, yields a corresponding and substantial decrease in its CO_2 emissions. Similarly, an efficient Low-NOx Burner (LNB) may replace an older burner and increase unit efficiency, while reducing NOx emissions, whereas a SNCR or SCR also reduces NOx, but will have some inherent parasitic power requirement that will have a negative impact on overall efficiency (and emissions of CO_2).

These chapters primarily address control technology options, as opposed to fuel switching strategies, except for SO₂. Switching from high-sulfur oil to low-sulfur oil is also discussed in Chapter 3. CO_2 impacts are well established as a function of the carbon content of fuels. The same applies in the case of renewable, carbon-based fuels (biomass). However, with control technologies, the impacts can vary widely among technologies for the same pollutant (e.g., LNB vs. SCR for NOx), as well as across different pollutants (e.g., fabric filter for PM vs. wet and dry scrubbers for SO₂).

In general, efficiency impacts from application of air pollution control technologies can be divided into two major general areas:

- Direct impact (positive or negative) on the combustion process itself (e.g., changes in concentrations of O₂ or CO and in the amount of unburned carbon (UBC) in ash)
- Parasitic power associated with the particular technology or its components (e.g., increased gas pressure loss, power requirements for pumps/fans)

This parasitic power is given here in terms of electric power (kW) per flue gas flow rate (acfm) or kW/1000 acfm. These units are appropriate for several reasons:

- Most ICI boilers do not produce electricity, hence, size is more universally characterized by a parameter other than electrical generation (e.g., flow rate);
- Most control technology suppliers rank their equipment size in terms of gas flow rate as this is the dominant parameter for gas handling equipment sizing;
- If the objective is to "correlate" this parasitic power loss to an equivalent CO₂ impact, it can be done simply by knowing the size (acfm) of the technology application and the CO₂ emission profile of the equivalent kW generation (or savings) to offset the parasitic power loss.

2.2 Discussion of NOx Control Technologies

2.2.1 NOx Formation

The formation of NOx is a byproduct of the combustion of fossil fuels. Nitrogen contained in fuels such as coal and oil, as well as the harmless nitrogen in the air, will react with oxygen during combustion to form NOx. The degree to which this formation evolves depends on many factors including both the combustion process itself and the properties of the particular fuel being burned. This is why similar boilers firing different fuels or similar fuels burned in different boilers can yield different NOx emissions.

2.2.2 NOx Reduction

As a result of complex interactions in the formation of NOx, a variety of approaches to minimize or reduce its emissions into the atmosphere have been and continue to be developed. A relatively simple way of understanding the many technologies available for NOx emission control is to divide them into two major categories: (1) those that minimize the formation of NOx itself during the combustion process (e.g., smaller quantities of NOx are formed); and (2) those that reduce the amount of NOx after it is formed during combustion, but prior to exiting the stack into the atmosphere. It is common to refer to the first approach under the "umbrella" of combustion modifications whereas technologies in the second category are termed post-combustion controls. Within each of these two categories, several technologies and variations of the same technology exist. Finally, combinations of some of these technologies are not only possible, but also often desirable as they may produce more effective NOx control than the application of a stand-alone technology.

2.2.3 Other Benefits of NOx Control Technologies

Some NOx control technologies have shown the potential to promote the capture of mercury (Hg) from the flue gas. Examples include combustion modification technologies (e.g., Low-NOx Burners and Overfire Air – though potentially with higher levels of unburned carbon) and post-combustion technologies (SCR – through the oxidation of mercury, making it more soluble and amenable to capture in a downstream process such as a scrubber for SO₂). This suggests that strategic and economic analyses for NOx controls need to also consider the potential impacts on mercury removal.

2.3 Summary of NOx Control Technologies

2.3.1 Combustion Modifications

Combustion modifications can vary from simple "tuning" or optimization efforts to the deployment of dedicated technologies such as LNBs, Overfire Air (OFA) or reburn (most often done with natural gas and called Gas Reburn - GR).

Boiler Tuning or Optimization

Combustion optimization efforts can lead to reductions in NOx emissions of 5 to 15 percent or even higher in cases where a unit was originally badly "de-tuned." It is important to remember that optimization results are truly a function of the "pre-optimization" condition of the power plant or unit (just as the improvement in an automobile from a tune-up depends on how badly it was running prior to it), and as such have limited opportunity for substantial emission reductions.

Development of "intelligent controls" – software-based systems that "learn" to operate a unit and then maintain its performance during normal operation, can also go a long way towards keeping plants well tuned, as they gain acceptance and become common features in combustion control systems.

2.3.2 Low-NOx Burners and Overfire Air

LNBs and OFA represent practical approaches to minimizing the formation of NOx during combustion. Simply, this is accomplished by controlling the quantities and the way in which fuel and air are introduced and mixed in the boiler (usually referred to as "fuel or air staging").



Figure 2-1. Low-NOx burner [TODD Dynaswirl-LNTM]

Figure 2-1 shows a gas/oil Low-NOx burner. These technologies are prevalent in the electric power industry as well as in ICI boilers at present and increasingly used by ICIs, even at small sizes (less than 10 MMBtu/hr). Competing manufacturers have proprietary designs, geared towards application for different fuels and boiler types, as well as reflecting their own design philosophies. LNBs and OFA, which can be used separately or as a system, are capable of NOx reductions of 30 to 65 percent from uncontrolled baseline levels. Again, the type of boiler and the type of fuel will influence the actual emission reduction achieved.

Particularly for gas-fired applications, as in the majority of ICI boilers, advanced Low-NOx Burners, often referred to as ultra Low-NOx Burners (ULNBs), are commercially offered by several companies. Ultra Low-NOx Burners are capable of achieving NOx emission levels on the order of single digits in ppm. As with all technologies, "pushing the envelope" on emission levels requires increasingly more careful suitability analyses as well as a good understanding of operational constraints. Conversely, the advent of these very low-emission burners (less than 10 ppm NOx), allows units to achieve very low emission rates at costs well below post-combustion alternatives like SCR.

All combustion modification approaches face a common challenge of striking a balance between NOx reduction and decrease in fuel efficiency. The concern is exemplified by typically higher CO and/or carbon levels in the fly ash, which reflect lower efficiency and also the contamination of the fly ash itself, possibly making it unsuitable for reutilization such as in concrete manufacturing. This is a bigger concern for large EGUs than for ICI boilers due to the much larger quantities of ash produced and the associated costs of disposal.

LNBs/OFA have little or no impact on operating costs (other than by the potential for the above-mentioned efficiency loss). Low-NOx Burners are applicable to most ICI boiler types, excluding stoker types and Fluidized Bed Combustion units (FBCs).

2.3.3 Reburn

Reburn, while generically included in the "Combustion Modification" category, is different from the other technologies in this group (LNBs/OFA) in that it "destroys" (or chemically reduces) NOx shortly after it is formed rather than minimizing its formation as discussed previously. From a practical standpoint, this is accomplished by introducing the reburn fuel (theoretically any fossil fuel can be used, however, natural gas is the most common) into the boiler above the main burner region. A portion of the heat input from the primary fuel is replaced by the reburn fuel. Subsequently, this "fuel-rich" environment reacts with and destroys the NOx formed in the main burners. This technology has been implemented in the U.S. and overseas, and while not as popular as LNB/OFA, it is commercial at this time. Owing to stricter compatibility criteria, reburn is not as universal as LNB/OFA in its applicability to the overall boiler population. *Figure 2-2* shows a typical reburn system applied to a stoker boiler.



Figure 2-2. Gas reburn applied to a stoker boiler [www.gastechnology.org]

Specific criteria such as boiler size, availability of natural gas, type and quality of the main fuel, are all important in determining the suitability of a unit for this technology. One important feature of reburn is its compatibility with a particular type of boiler – "Cyclone," – for which the previously mentioned technologies are not particularly well suited. However, this technology has been used only in large EGUs and is not a typical option for ICI boilers. Cyclone boilers are inherently high NOx emitters and are not an attractive option for new or retrofit units with increasingly lower NOx emission limits requirements.

Reburn performance has been shown to range from 30 to 60 percent reduction in NOx emissions, depending on such factors as reburn fuel type and quantity, initial NOx levels, boiler design, etc. Similar to the other combustion modification options, reburn can affect efficiency and fly-ash quality. As such, it requires the same optimum balance between NOx reduction and avoidance of negative impacts. On the other hand, reburn can be thought of as a "dial-in" NOx technology in that NOx reductions are, to a degree, a function of the amount of reburn fuel.

Operating costs are primarily driven by the fuel cost differential in the case of gas reburn, while for coal or oil reburn fuel preparation costs (pulverization and atomization, respectively) represent the dominating O&M costs. Reburn using coal or oil as the reburn fuel does not seem like a very attractive option for ICI boilers for technical reasons (boiler size, residence times), as well as the wider availability of similar performance options simpler to implement, such as LNBs. Gas reburn, while easier to implement, often has a prohibitive operating cost if, for example, natural gas is partially substituted for a less expensive primary fuel. Reburn is therefore an option for larger watertube-type boilers, including stokers, but require appropriate technical and economic analyses to determine suitability. Gas reburn has an impact on CO_2 emissions that is proportional to the type and quantity of fuels displaced (gas vs. coal or oil).

2.3.4 Post-Combustion Controls

Conventional, commercial post-combustion NOx controls include Selective Non-Catalytic Reduction (SNCR) and Selective Catalytic Reduction (SCR). They are fundamentally similar, in that they use an ammonia-containing reagent to react with the NOx produced in the boiler to convert the NOx to harmless nitrogen and water. SNCR accomplishes this at higher temperatures (1700°F-2000°F) in the upper furnace region of the boiler, while SCR operates at lower temperatures (about 700°F) and hence, needs a catalyst to produce the desired reaction between ammonia and NOx. As noted below, SCR technology is capable of achieving much larger reductions in NOx emissions, higher than 90 percent, compared to the 30 to 60 percent reductions achievable by SNCR. *Figure 2-3* and *Figure 2-4* depict views of these two systems.



Figure 2-3. SNCR system schematic [FuelTech]



Figure 2-4. 3-D schematic of an SCR system [Alstom Power]

While the difference between the SNCR and SCR may seem minor, it yields significant differences in performance and costs. In the case of SNCR, the reaction occurs in a somewhat uncontrolled fashion (e.g., the existing upper furnace becomes the reaction vessel, which is not what it was originally designed to be), while in the SCR case, a dedicated reactor and the reaction-promoting catalyst ensure a highly controlled, efficient reaction. In practice, this means that SNCR has lower capital costs (no need for a reactor/catalyst); higher operating costs (lower efficiency means that more reagent is needed to accomplish a given reduction in NOx); and finally, has lower NOx reduction capability (typically 30 to 50 percent, with some units achieving reductions in the 60 percent range). SCR, on the other hand, is capital intensive, but offers lower reagent costs and the opportunity for very high NOx reductions (90 percent or higher).

Costs are driven primarily by the consumption of the chemical reagent – usually (but not necessarily) urea for SNCR and ammonia for SCR, which in turn is dependent upon the efficiency of the process (usually referred to in terms of reagent utilization) as well as the initial NOx level and the desired percent reduction. It is also important to consider possible contamination of fly ash (in the case of coal firing) by ammonia making it potentially unable to be sold. This is, again, a bigger issue for larger EGU plants than for ICI boilers due to the size and quantities involved; as already stated, ICIs burning solid fuel do not typically sell their fly ash.

2.3.4.1 RSCR

Commonly, EGU boilers utilize SCR systems to reduce NOx emissions. However, a conventional SCR may not be cost-effective to retrofit into smaller units like ICI boilers because of the extensive modifications required to accommodate the unit. For some applications, the SCR may be located downstream of the particulate control equipment, where the flue gas temperature is much lower than the range of 650-750°F required for a conventional SCR (Toupin, 2007). These conditions are encountered in some ICI boilers firing a variety of fuels, including biomass.

If it is necessary to compensate for the reduction of flue gas temperatures, a regenerative selective catalytic reduction ($RSCR^{TM}$) system allows the efficient use of an SCR downstream of a particulate control device. The primary application of an RSCR system is the reduction of NOx emissions where the flue gas is typically at 300-400°F (Toupin, 2007). *Figure 2-5* illustrates the schematic and the actual RSCR system. *Figure 2-6* shows a block of ceramic heat exchanger.



Figure 2-5. Schematic and actual RSCR [Toupin, 2007]

A direct-contact regenerative heater technology (i.e., burner), coupled with cycling beds of ceramic heat exchangers, is used to transfer heat to the flue gas. Additionally, some oxidation of CO to CO_2 in the flue gas occurs. The NOx reduction portion of the RSCR takes place on a conventional SCR catalyst. Either anhydrous or aqueous ammonia can be used.

Figure 2-5 (left side) shows the working principles of the RSCR. Essentially, the flue gas in the space between the two canisters (called the retention chamber) is heated by the burner to make up for heat loss through the walls of the canisters and inefficiency in the ceramic heat transfer modules. This raises the temperature in the retention chamber by about 10-15°F. The gas flows into the second canister, through the catalyst, and passes through the second ceramic module, which absorbs heat from the hot flue gas. Once this cycle is completed, the flow reverses, so that the second canister (which was just heated) becomes the inlet canister and the first canister becomes the outlet canister. The cycling between canisters accomplishes a similar function to the continuously rotating heating elements of a conventional regenerative air/gas heater.

Other components of the RSCR include the ductwork, fans, and the ammonia delivery system. Ductwork must be adequately sized to provide sufficient distance for ammonia mixing

and to minimize pressure drop. For the ceramic heat exchanger, factors that need to be taken into consideration during the design process are gas-side pressure drop, thermal efficiency, and cost. A large bed face area reduces the pressure drop and operating cost but increases capital cost. The ammonia delivery system consists of ammonia pumps, storage tanks, interconnecting piping, and a control system. The pump typically does not exceed one horsepower and often a redundant pump is provided to assure continuity in system operation [Toupin, 2007].



Figure 2-6. Block of monolith ceramic heat exchanger [Toupin, 2007]

The RSCR combines a regenerative thermal oxidizer (RTO) (e.g., retention chamber burner) with SCR technology. This ability to control flue gas temperatures allows for high NOx reduction under varying temperature conditions. *Table 2-1* shows the expected reduction in NOx and CO emissions [BPEI, 2006]. This study indicated that the RSCR is able to reduce NOx by 60 to 75 percent and CO by about 50 percent.

	Typical Stoker Design	CO and NOx Reductions from Baseline
Steam Flow lbs/hr x 10 ³	100 - 500	
Steam Press, psi	600 - 900	
Steam Temp., °F	955 - 1000	
Unburned Combustibles Boiler	1.0 - 1.5	
Efficiency Loss (%)		
Furnace Retention sec. ⁽¹⁾	3.0	
Grate Heat Release Btu/hr-ft	850,000 maximum	
Emissions:		
CO lbs/10 ⁶ Btu @ 3.0% O ₂ (ppm)	0.10 - 0.30	Base
	(122 – 370)	
CO w/RSCR lbs/ 10^6 Btu @ 3.0% O ₂	0.05 - 0.15	(-50%)
(ppm)	(61 - 185)	
NOx lbs/10 ⁶ Btu @ 3.0% O ₂ (ppm)	0.15 - 0.25	Base
	(112 – 186)	
NOx w/SNCR lbs/10 ⁶ Btu @ 3.0%	0.10 - 0.17	(-30 to 40%)
O ₂ (ppm)	(75 - 130)	
NOx w/RSCR lbs/10 ⁶ Btu @ 3.0%	0.06 - 0.075	(-60 to 75%)
O ₂ (ppm)	(45 – 56)	

Table 2-1.	CO and NOx	reduction	using RSCR	[Source:	BPEI 2006]
------------	------------	-----------	------------	----------	------------

Additionally, the heat exchanger part of the RSCR has a thermal efficiency of about 95 percent, which translates to fuel savings. Traditional technologies that utilize Ljungstrom or plate type heat exchangers for heat recovery and duct burners to reach the catalyst operating temperature are typically in the range of 70 to 75 percent thermal efficiency.

An analysis performed by BPEI on a typical 25 MW plant with a 75 percent reduction in NOx shows a cost effectiveness of \$4,514 per ton of NOx removed. The cost breakdown is tabulated below in *Table 2-2*.

Plant Overview:	
Plant Gross MW	25
GROSS HEAT INPUT, MMBTU/HR	321
TYPICAL UNCONTROLLED NOx, LB/MMBTU	0.25
TYPICAL CONTROLLED NOx, LB/MMBTU	0.065
NOx REMOVED, TONS/YEAR	249.4
RSCR Cost:	
AMMONIA COST, \$/TON NOx	\$ 419
NATURAL GAS, \$/ton NOx	\$ 404
POWER COST, \$/TON NOx	\$ 589
CATALYST COST, \$/TON	\$ 555
CAPITAL COST, \$/TON	\$ 2,546
TOTAL COST PER TON NOx REMOVED	\$ 4,514

Table 2-2.	RSCR	cost efficiency	[BPEI, 2008]
------------	------	-----------------	--------------

Two RSCR installations (15 and 50MW) are currently in operation in the Northeast. The 15 MW plant uses whole tree chips as fuel; the 50 MW plant uses whole tree chips, waste wood, and construction and demolition wood as fuel for the boilers. The goal of the two installations was to qualify for the Massachusetts Renewable Energy Credits (RECs). The state requirement for qualifying for RECs imposed a NOx level of 0.075 lb/MMBtu or less on a quarterly average basis.

2.3.5 Technology Combinations

In theory, most of the technologies described above can be used together. However, NOx reductions are not necessarily additive, and more importantly, the economics of the combined technologies may or may not be cost-effective. Such analyses are highly specific to the site and strategy. However, several such technology combinations are considered attractive and have gained acceptance. For example, the combination of LNB/OFA with either SCR or SNCR is more prevalent than the application of the post-combustion technologies alone. The economics of this approach are justified by the reduced chemical (SNCR) and capital costs (SCR – smaller reactor/catalyst) due to lower NOx levels entering the SCR/SNCR system. Another combination offered commercially is the hybrid SNCR/SCR concept, which uses the excess ammonia (ammonia "slip") of the SNCR to promote additional NOx reduction in a downstream SCR catalyst.

2.4 Applicability to ICI Boilers

The NOx control technologies previously described are commercially available and are used extensively in EGUs, but most are also applicable to ICI boilers. Because conventional fuels (e.g., coal, oil, gas) as well as alternative fuels (e.g., wood, petroleum coke, process offgases) emit NOx, these technologies are applicable to most boilers using various fuels. With the exception of FBC and Stoker boilers, LNBs are available and widely used for most combinations of boiler types and fuels. OFA and reburn as well as SNCR and SCR technologies require sitespecific suitability analyses, as several important parameters can have substantial impact on their performance or even retrofit feasibility. As already stated, these include available space, residence times and gas temperatures. Conversely, other than firetube type boilers, these technologies are potential candidates for the other boiler types including stokers and FBCs. Finally, the RSCR may offer advantages for applications where low flue gas temperatures are present and a conventional SCR may be more costly to implement.

2.5 Efficiency Impacts

The NOx control technologies involving combustion modification have essentially no impact on the CO_2 emissions of the host boilers, with the noted exception for reburn when displacing coal or oil with natural gas. This is because combustion modification technologies do not impose any significant parasitic energy consumption (auxiliary power). Note that combustion modification technologies can affect the resulting combustion conditions in addition to the desired reduction in NOx emissions. These impacts are reflected in varying temperatures, oxygen levels, and CO/UBC, all of which affect combustion efficiency as discussed previously. However, we do not attempt to quantify these impacts. The overriding assumption is that these NOx control technologies, once deployed, are optimized such that the resulting NOx emissions are achieved without compromising the above parameters (or at least their combined effects).

With respect to the post-combustion technologies, both SNCR and SCR impose some degree of energy impact on the host boiler. The losses attributable to these technologies include the following:

- For SNCR
 - o compressor power (air atomization/mixing)
 - o steam (if steam atomization/mixing)
 - o dry gas loss (air injection into furnace)
 - o water evaporation loss
- For SCR
 - o compressor
 - reactor pressure loss
 - o steam (sootblowing)

Table 2-3 summarizes the key parameters for major NOx control technologies.

Technology	Applicability	Performance (% Reduction)	Energy Impacts (kW/1000 acfm)	Comments
LNB	All except Stokers, FBC	30 – 60 (<10ppm possible on gas)	NA	Assumed not to have negative impact on CO/UBC/O ₂
OFA	All except firetube/FBC	30 - 60	NA	Assumed not to have negative impact on CO/UBC/O ₂
Reburn	All except firetube/FBC	30 - 60	NA	Assumed not to have negative impact on CO/UBC/O ₂
SNCR	All except firetube (Must have adequate temperature window)	30 - 70	1 - 2	Compressor/va porization losses
SCR	All (Most likely for larger coal units where LNBs cannot reach very low NOx levels)	60 - 90	0.5 – 1 (gas) 2 - 4 (oil/coal)	Pressure loss/steam

Table 2-3.	Summary	of NOx	control	technologies
------------	---------	--------	---------	--------------

2.6 NOx Control Costs

The following tables summarize published NOx control costs for ICI boilers reported in the literature [US EPA, 1996; NESCAUM, 2000; Khan, 2003; US EPA, 2003; MACTEC, 2005; Whiteman, 2006]. Literature values of capital cost have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness in dollars per ton of NOx removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs. Reagents or consumables can make up a large portion of some operating costs. Costs of reagents and fuels (e.g., ammonia, natural gas) and consumables (e.g., SCR catalyst) change with time, but not always at the general rate of inflation. Some of these costs have increased at rates higher than the general rate of inflation. Thus, cost effectiveness values (or operating costs) from before 2005 have not been reported.

Table 2-4 summarizes the published NOx control costs for combustion modification technologies. The cost of the installation of low-NOx combustion technology depends on the firing system, and this is reflected in the lack of a clear relationship between capital cost and boiler capacity (*Figure 2-7*). Smaller boilers (10 to 50 MMBtu/hr) are often firetube or packaged watertube, whereas larger oil and gas boilers are more likely to be field-erected watertube boilers. Coal-fired boilers can be stokers, pulverized coal (PC), or cyclones. Combustion modification technologies therefore need to be evaluated on a case-by-case basis, taking into account both the fuel and the design of the combustion system. For the substantial majority of the estimates for ICI boilers, capital costs are in the range of \$1,000 to \$6,000 per MMBtu/hr. Cost effectiveness values, where available, are generally in the range of \$1,000 to \$7,000 per ton of NOx removed.

	NOx		Size of	Capital Costs	Base yr.	Cost (\$/ton	
Tashasalasan	Reduction	E	Boiler	@2006\$	for or	NOx @ base	D.f
Technology	Range	Fuel Type	(MMBtu/hr)	(\$/MMBtu/hr)	Ref. yr	year)	Ker
Overfire Air	15-30	Coal	500	\$2,682	1996		1
Fuel-Lean	35%	Coal	350	\$1 302	1000		2
Cos Poburn	55%	Coal	500	\$1,502	1999		2
	25%	Coal	250	\$2,004	1999		2
	25%	Coal	350	\$0,578 \$6,278	1999		2
	50.0%	Coal	500	\$0,378 \$9,464	1999		2
	50%	Coal	500	\$8,404 \$0,297	1996		
	51%	Coal	100	\$9,287 #7.055	1999		6
	51%	Coal	250	\$7,055	1999		6
LNB	51%	Coal	1000	\$4,654	1999	#2.202	6
LNB	42.6%	Coal (Tangent.)	250	\$5,088	2005	\$3,383	3
LNB	42.6%	Coal (Tangent.)	250	\$5,088	2005	\$3,988	3
LNB	49%	Coal (Wall)	250	\$5,088	2005	\$2,636	3
LNB	49%	Coal (Wall)	250	\$5,088	2005	\$3,101	3
LNB	40%	Pulv. Coal	250	\$346-\$3,610	2005	\$749-\$3,393	3
LNB	45.0%	Resid. Oil	250-FT	\$5,088	2005	\$6,361-\$7,483	3
LNB	50%	Resid. Oil	250-WT	\$5,088	2005	\$4,691-\$5,519	3
LNB	40%	Resid. Oil	250	\$346-\$5,088	2005?	\$1,505-\$6,813	3
LNB	45%	Resid. Oil	10	\$7,617	1996		1
LNB	45%	Resid. Oil	50	\$3,021	1996		1
LNB	45%	Resid. Oil	150	\$1,563	1996		1
LNB	45%	Dist. Oil	10	\$7,617	1996		1
LNB	45%	Dist. Oil	50	\$3,021	1996		1
LNB	45%	Dist. Oil	150	\$1,563	1996		1
LNB	25%	Gas	350	\$6,378	1999		2
LNB	40%-55%	Gas	10	\$7,617	1996		1
LNB	40%-55%	Gas	50	\$3,021	1996		1
LNB	40%-55%	Gas	150	\$1,563	1996		1
LNB+FGR	50%	Pulv. Coal	250	\$930-6,629	2005	\$1,482-\$3,582	3
LNB+FGR	72%	Pulv. Coal	250	\$930-6,629	2005	\$1,029-\$2,488	3
LNB+FGR	50%	Resid. Oil	250	\$930-6,629	2005	\$2,977-\$7,197	3
LNB+FGR	72%	Resid. Oil	250	\$930-6,629	2005	\$2,068-\$4,998	3
LNB+OFA	51%-65%	Coal	100	\$9,287	1999		6
LNB+OFA	51%-65%	Coal	250	\$7,055	1999		6
LNB+OFA	51%-65%	Coal	1000	\$4,654	1999		6
LNB+OFA	30%-50%	Oil	100	\$3,258	1999		6
LNB+OFA	30%-50%	Oil	250	\$2,474	1999		6
LNB+OFA	30%-60%	Oil	1000	\$1,633	1999		6
LNB+OFA	60%	Gas	100	\$3,258	1999		6
LNB+OFA	60%	Gas	250	\$2,474	1999		6
LNB+OFA	60%	Gas	1000	\$1,633	1999		6

Table 2-4. NOx control costs for combustion modifications applied to ICI boiler

Technology	NOx Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs @2006\$ (\$/MMBtu/hr)	Base yr. for or Ref. yr	Cost (\$/ton NOx @ base year)	Ref
ULNB	46%	Pulv. Coal	250	\$1,364	2005	\$1,876	3
ULNB	63%	Pulv. Coal	250	\$1,364	2005	\$933	3
ULNB	72%	Pulv. Coal	250	\$1,364	2005	\$619	3
ULNB	75%	Pulv. Coal	250	\$1,364	2005	\$784	3
ULNB	85%	Pulv. Coal	250	\$1,364	2005	\$692	3
ULNB	75%	Resid. Oil	250	\$1,364	2005	1575	3
ULNB	85%	Resid. Oil	250	\$1,364	2005	1390	3
ULNB	80%	Dist. Oil	24.5	\$8,619	2005	17954	3
ULNB	80%	Dist. Oil	70	\$2,280	2005	5756	3
ULNB	94%	Dist. Oil	68	\$1,987	2005	4751	3
ULNB	94%	Dist. Oil	68	\$1,987	2005	4564	3

Table 2-4 [continued]

References:

1. US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/

2. NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.





	NOx Reduction		Size of Boiler	Capital Costs @2006\$	Base yr. for	Cost (\$/ton NOx @ base	
Technology	Range	Fuel Type	(MMBtu/hr)	(\$/MMBtu/hr)	or Ref. yr	year)	Ref.
SNCR	30%-70%	Coal	500	\$2,044	1996		1
SNCR	40%	Coal	100	\$6,717	1999		6
SNCR	40%	Coal	250	\$5,102	1999		6
SNCR	40%	Coal	1000	\$3,366	1999		6
SNCR	30%-70%	Resid. Oil	50	\$4,297	1996		1
SNCR	30%-70%	Resid. Oil	150	\$4,297	1996		1
SNCR	35%		350	\$2,862	1999		2
SNCR			21	\$17,101	2006	\$3,718	4
SNCR			120	\$6,377	2006	\$2,231	4
SNCR			240	\$4,493	2006	\$1,821	4
SNCR			387	\$2,899	2006	\$1,564	4
SNCR			543	\$2,319	2006	\$1,538	4
SNCR			844	\$1,449	2006	\$1,346	4
SNCR	40%	Oil	100	\$5,205	1999		6
SNCR	40%	Oil	250	\$3,954	1999		6
SNCR	40%	Oil	1000	\$2,608	1999		6
SNCR	30%-70%	Dist. Oil	50	\$4,297	1996		1
SNCR	30%-60%	Natural Gas	50	\$4,297	1996		1
SNCR	40%	Gas	100	\$5,372	1999		6
SNCR	40%	Gas	250	\$4,082	1999		6
SNCR	40%	Gas	1000	\$2,693	1999		6
LNB+SNCR	50%-89%	Pulv. Coal	250	\$2,064-6,829	2005	\$1,409-\$4,473	3
LNB+SNCR	50%-89%	Resid. Oil	250	\$2,064-6,829	2005	\$2,229-\$7,909	3

Table 2.5	NOv control costs	for SNCD	applied to	ICI boilore
1 able 2-5.	NOX CONTROL COSTS	IOF SINCK	appned to	ICI Doners

References:

US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/
NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost

Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

Table 2-5 summarizes the published NOx control costs for SNCR applied to ICI boilers. As with combustion modifications, the capital cost of SNCR systems is sensitive to the type of combustion system. As long as the boiler has sufficient space for installation of injection lances and mixing of reagent and flue gas (at the appropriate temperature), the capital costs should not depend on the fuel burned. The relationship between capital cost and boiler capacity is shown in *Figure 2-8*. Except for the 1996 EPA estimates for gas and oil boilers, there is a pronounced effect of boiler capacity on capital cost. The graph shows that fuel type is probably secondary to boiler capacity, although there will be an indirect effect of fuel, because fuel type influences the design of the combustion system. The cost effectiveness for SNCR was given by ICAC [Whiteman, 2006] without regard to fuel type and by MACTEC [2005] for coal and residual oil.



Figure 2-8. Capital cost for NOx control for SNCR applied to ICI boilers as a function of boiler capacity

Table 2-6 summarizes the published NOx control costs for SCR. The relationship between capital cost and boiler capacity is shown in *Figure 2-9*. The capital cost of SCR systems is sensitive to the type of fuel and to the level of NOx reduction desired, but not to the combustion system. The volume of catalyst required for an SCR installation depends on the level of desired NOx reduction and on the fuel. Coal-fired power plant applications are the most expensive, since the flue gas entering the SCR contains fly ash, which affects the design of the catalyst. The capital cost for a given fuel and boiler size can vary (see, for example, the variation in capital costs reported for coal application). When an SCR must be retrofit, the cost of the installation depends on the configuration of the specific system. Because the amount of

ductwork required, significant variation in installed capital cost can occur for a given boiler size. Upgrades like rebuilding the air preheater also affect the installed capital cost. MACTEC [2005] gave the cost effectiveness (in dollars per ton of NOx removed) for SCR for coal and residual oil; these costs showed a wide range, because of the wide range in assumed capital costs.

	NOx			Capital Costs			
	Reduction		Size of Boiler	@2006\$	Base yr. for	Cost (\$/ton NOx	
Technology	Range	Fuel Type	(MMBtu/hr)	(\$/MMBtu/hr)	or Ref. yr	@ base year)	Ref.
SCR	80%	Coal	350	\$12,755-19,133	1999		2
SCR	80%-90%	Coal	500	\$15,365-16,145	1996		1
SCR	70%-90%	Pulv. Coal	250	\$1,666-13,881	2005	\$2,233-\$7,280	3
SCR	80%	Coal	100	\$18,574	1999		6
SCR	80%	Coal	250	\$14,110	1999		6
SCR	80%	Coal	1000	\$9,309	1999		6
SCR	80%	Oil	100	\$14,116	1999		6
SCR	80%	Oil	250	\$10,723	1999		6
SCR	80%	Oil	1000	\$7,075	1999		6
SCR		Oil		\$5,102-7,653	1999		5
SCR	70%-90%	Resid. Oil	250	\$1,666-13,881	2005	\$4,363-\$14,431	3
SCR	80%-90%	Resid. Oil	50	\$8,359	1996		1
SCR	80%-90%	Resid. Oil	150	\$4,909	1996		1
SCR	80%-90%	Dist.	50	\$8,359	1996		1
SCR	80%-90%	Dist.	150	\$4,909	1996		1
SCR	80%	Gas	100	\$10,216	1999		6
SCR	80%	Gas	250	\$7,760	1999		6
SCR	80%	Gas	1000	\$5,120	1999		6
SCR	80%	Gas	100	\$9,566	1999		2
SCR	80%	Gas	350	\$7,015	1999		2
SCR	80%-90%	Natural Gas	50	\$8,359	1996		1
SCR	80%-90%	Natural Gas	150	\$4,909	1996		1
SCR	80%	Wood	350	\$6,378-7,653	1999		2
SCR	74%	Wood	321	\$1,978	2006	\$4,514	7

Table 2-6. NOx control costs for SCR applied to ICI boilers

References:

1. US EPA, OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/

2. NESCAUM, Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

3. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

4. Whiteman, C., ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

5. US EPA Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fscr.pdf

6. Khan, S. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

7. BPEI. (2008, February). RSCR Cost Effective Analysis.



Figure 2-9. Capital cost for NOx control for SCR applied to ICI boilers as a function of boiler capacity

2.7 Chapter 2 References

Albanese, Vince (2006). "Applications, Issues, & Answer for SNCR." NACAA Fall Meeting in San Antonio, TX.

Babcock Power Environmental Inc. (2006). Regenerative SCR. Worcester: Babcock Power Environmental Inc.

Bodnarik, Andrew M. New Hampshire Department of Environmental Services, "ICI Boiler NOx Control Cost Estimates from the OTC Methodology," presented at the OTC Control Strategy/SAS Committee Meeting, November 2, 2006.

Babcock Power Environmental Inc. (2008). RSCR Cost Effective Analysis.

Khan, Sikander. Methodology, Assumptions, and References Preliminary NOx Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

MACTEC. Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness, (Praveen Amar, Project Director), December 2000.

STAPPA/ALAPCO (2006). "Controlling Fine Particulate Matter under the Clean Air Act: A Menu of Options."

Toupin, R. F. (2007). Efficient and Low Emission Stoker Fired Biomass Boiler Technology in Today's Marketplace. Worcester: Babcock Power Environmental Inc.

US EPA. Air Pollution Control Technology Fact Sheet: Selective Catalytic Reduction (SCR); EPA-452/F-03-032, July 15, 2003. <u>http://www.epa.gov/ttn/catc/dir1/fscr.pdf</u>.

US EPA. OTAG Technical Supporting Document, Chapter 5, Appendix C, 1996. <u>http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/</u>.

Whiteman, C. ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

3 SO₂ CONTROL TECHNOLOGIES

3.1 SO₂ Formation

 SO_2 is an undesirable byproduct of the combustion of sulfur-containing fossil fuels. SO_2 , like NOx, is a precursor to ambient fine particles: Thirty to 50 percent of ambient fine PM mass in the eastern U.S. is attributable to sulfate derived from SO_2 . SO_2 is a significant contributor to wet and dry acid deposition on various ecosystems (lakes, streams, soils, and forests). Various coals in the U.S. can have 1 to 3 percent (by mass) sulfur; residual oil (No. 6 oil) can have sulfur contents of 2 percent and higher. Distillate oils are generally lower in sulfur content (less than 0.5 percent by mass). Natural gas has essentially zero sulfur content. However, unlike nitrogen in coal or oil, essentially all of the sulfur in the fuel is oxidized to form SO_2 (a very small percentage is further oxidized to SO_3 depending on fuel and boiler characteristics). This means that the relationship between sulfur content in the fuel and SO_2 emissions is much more direct and linear than that between fuel nitrogen and NOx emissions, and as such, the emission reduction benefits of fuel switching (for example from higher- to lower-sulfur coal or from higher-sulfur oils to lower-sulfur oils) are directly proportional to the difference in sulfur contents of fuels.

Another important difference is that this relationship is, for all practical purposes, independent of the type of boiler technology. Two exceptions to this include the high–alkaline nature of ash in some sub bituminous coals, which causes a portion of the sulfur in the coal to react and form various sulfate salts (mostly calcium sulfate); another is the combustion of coal in fluidized bed combustion (FBC) boilers where the lower temperatures of combustion and the use of alkaline material (e.g., limestone) in the "bed" promote the reaction of SO₂ with calcium to form sulfate, thereby reducing the net emissions of SO₂. In practical terms, this means that most solid- and liquid-fuel-fired systems produce SO₂ emissions proportional to their sulfur content, whereas natural gas combustion produces essentially no SO₂.

Additionally, despite the much smaller quantities of SO_3 formed in comparison to SO_2 , as noted above, SO_3 presents both operational and environmental challenges. Operationally, SO_3 is a concern because if the temperature of the back-end flue gas handling equipment (e.g., ducts, particulate control devices, scrubbers) falls below the acid dew point, corrosion and material deterioration can result. From an environmental perspective, nucleation and condensation of ultra-fine sulfuric acid particles formed from the SO_3 present in the flue gas can contribute to the primary emissions of fine PM from the stack into the atmosphere.

3.2 SO₂ Reduction

As a result of the relationship between fuel sulfur content and SO_2 , SO_2 emission control technologies fall in the category of reducing SO_2 after its formation, as opposed to minimizing its formation during combustion. This is accomplished by reacting the SO_2 in the flue gas with a reagent (usually calcium- or sodium-based) and removing the resulting product (a sulfate/sulfite) for disposal or commercial use, depending on the technology used. SO_2 reduction technologies are commonly referred to as Flue Gas Desulfurization (FGD) or SO_2 "scrubbers" and are usually

described in terms of the process conditions (wet vs. dry), methods for gas-sorbent contact (e.g., absorber vessel vs. duct for dry sorbent injection), byproduct utilization (throwaway vs. saleable), and reagent utilization (once-through vs. regenerable).

Within each technology category, multiple variations are possible and typically involve the type and preparation of the reagent, the temperature of the reaction, and the use of enhancing additives. Because these variations mostly involve complex process chemistry, but are fundamentally similar, this summary focuses on the major categories of SO_2 control technologies, their applicability to ICI boilers, and data on performance and cost. For a more detailed description of FGD technologies, see Srivastava [2000].

As noted earlier, SO_2 control strategies can also include fuel switching (from high-sulfur coal to low-sulfur coal or from high-sulfur oil to low-sulfur oil/natural gas). While not considered a "technology," switching from a higher-sulfur fuel to a lower-sulfur one requires considerable cost and operational analysis. Major issues include price, availability, transportation, and suitability of the boiler or plant to accommodate the new fuel.

3.3 Other FGD Benefits

Significant attention has been given recently to the issue of mercury emissions from EGUs and ICI boilers. It is relevant to note that some FGD technologies have been shown to capture mercury from the flue gas [Jones and Feeley, 2008] by absorbing the water-soluble oxidized forms of mercury from the flue gas. Both wet and dry SO_2 control processes have been and are being tested to determine their mercury capture potential. This suggests that strategic and economic analyses for SO_2 control technologies need to consider the potential side-benefit of mercury removal as well.

3.4 Summary of FGD Technologies

A brief overview of FGD technologies is provided here to give the reader a broad perspective on SO_2 controls.

3.4.1 Wet Processes

Wet FGD (WFGD) or "wet scrubbers" date back to the 1960s with commercial applications in Japan and the U.S. in the early 1970s [NESCAUM 2000]. They represent the predominant SO_2 control technology in use today with over 80 percent of the controlled EGUs capacity in the world and the U.S. [EPA 2000].

In a wet scrubber, the SO₂-containing flue gas passes through a vessel or tower where it contacts an alkaline slurry, usually in a counterflow arrangement. The intensive contact between the gas and the liquid droplets ensures rapid and effective reactions that can yield >90 percent SO₂ capture. Currently, advanced scrubber designs for EGUs have eliminated not only many of the early operational problems, primarily related to reliability, but have also demonstrated very high SO₂ reduction capabilities with the technology being capable of well over 95 percent SO₂ control [Dene *et al.*, 2008]. *Figure 3-1* provides a schematic view of a wet scrubber.



Figure 3-1. Schematic of a WFGD scrubber [Bozzuto, 2007]

Variations of the basic technology, in addition to equipment improvements made over the years, include reagent and byproduct differences. Limestone, lime, sodium carbonate, ammonia, and even seawater-based processes are all commercially available. Limestone is by far the most widely used with commercial-grade gypsum (wallboard quality) being produced in the so-called Limestone Forced Oxidation (LSFO) process. The use of other reagents, as mentioned, is driven by site-specific criteria, such as local reagent availability, economics, and efficiency targets.

Technology costs have changed over time, as expected, reflecting changes in market conditions, labor and raw material costs, local, state, regional, and federal regulatory drivers, and site-specific considerations. Recently, capital costs have trended upward after a downward trend in the mid-late 1990s. These fluctuations have in large part, been driven by labor and material costs, the global nature of technology markets, and regulatory changes within the electric power sector [Sharp, 2007; Cichanowicz, 2007].

3.4.2 Dry Processes

Conventional dry processes include spray dryers (SDs) or "dry scrubbers" and Dry Sorbent Injection (DSI) technologies, and are shown in *Figure 3-2* and *Figure 3-3*, respectively. The technologies are referred to as "dry" because the SO₂ sorbent, while it may be injected as a slurry or a dry powder, is finally dried and collected in a conventional particulate control device, a fabric filter, or an ESP.

SD refers to a configuration where the reaction between SO_2 and the sorbent takes place in a dedicated reactor or scrubber vessel. DSI technology does not require a dedicated reactor and instead uses the existing boiler and duct system as the "reactor," and several configurations are possible based on the temperature window desired. This can occur at the furnace (1800-2200°F), economizer (800-900°F), or in a low-temperature duct (250-300°F). In addition, another common feature of dry scrubbing systems is the need for the particulate control equipment downstream of the sorbent injection. Usually this is accomplished through the use of fabric filters (although, depending on the application, ESPs may be used) that are not only efficient collectors of fine particulates, but can also provide some additional SO₂ removal as the flue gas passes through unreacted sorbent collected on the bags. Dry processes are more compatible with low- to medium-sulfur coals because of the need to limit solid concentrations in the slurry below a threshold for adequate atomization and the need to limit the amount of solids collected in an existing particulate control device. This requirement precludes higher sulfur fuel applications where the required amount of reagent would be above that threshold. Therefore, high-sulfur applications are more typically associated with wet FGDs.



Figure 3-2. Schematic of a spray dryer [http://www.epa.gov/eogapti1/module6/sulfur/control.htm]

It is relevant to note that DSI technology did not gain any meaningful market penetration as part of the EGU compliance options to meet the requirements of the 1990 CAAA (Title IV) "acid rain" legislation for reducing emissions of SO₂. The large number of wet FGD installations in response to the Clean Air Act of 1970, and creation of "emission allowances," combined with the trend to switch fuels (mostly to low-sulfur Powder River Basin or PRB coal) in response to the 1990 CAAA, help explain this situation. However, more recently, interest in DSI technology applications for ICI boilers has been renewed and companies are "revamping" the knowledge base for DSI.



Figure 3-3. Dry Sorbent Injection (DSI) system diagram [http://www.epa.gov/eogapti1/module6/sulfur/control/control.htm]

DSI technologies include calcium (lime) and sodium (trona) reagents and are currently being tested or demonstrated within the ICI boiler sector. Companies such as O'Brien and Gere [Day, 2006; Day, 2007] and Siemens Environmental [Siemens, 2007] are marketing and deploying duct injection systems, and Nalco Mobotec [Haddad *et al.*, 2003] offers furnace sorbent injection (FSI) systems for ICI boilers. O'Brien and Gere, for example, have conducted over 5,000 hours of demonstrations at 15 different boilers since January 2005 to evaluate the viability, performance, and economics of DSI [Day, 2007]. These processes require relatively little new equipment and are thus suitable candidates for ICI boiler retrofit applications, where site constraints (e.g., space) are often critical.

Two examples of DSI systems are Furnace Sorbent Injection (FSI) in which hydrated lime is injected into the upper furnace of the boiler, and Lime Slurry Duct injection (LSDI) where atomized lime slurry is sprayed into the gas stream in the duct. FSI systems were first demonstrated in the 1980s on EGU boilers and are currently operating at ICI boilers [Dickerman, 2006].

FSI systems are capable of removing between 20 to 60 percent of the SO_2 and have shown removal percentages of as high as 90 to 99 percent for HCl and SO_3 [Haddad *et al.*, 2003]. The FSI systems also offer a low capital cost option and the attractiveness of quick cost recovery for ICI boiler sector [Dickerman, 2006].

The LSDI utilizes an atomized spray of lime slurry. The particles are subsequently captured in the downstream particulate collector. Sorbent particle size distribution is important for maximizing SO_2 capture while minimizing operational problems such as duct fallout and deposition.

LSDI systems have been utilized to mitigate plume generation from cement plants, and are capable of SO₂ reductions of up to 90 percent for industrial applications and ICI boilers, as well as HCl and HF reductions of greater than 95 percent [Dickerman, 2006].

In either case, both dry sorbent injection technologies offer an economical method for reducing emissions of SO₂. *Table 3-1* compares the FSI and LSDI systems for a 100 MW boiler, burning coal with one percent sulfur.

Parameter	FSI (Hydrated Lime)	LSDI
SO ₂ Removal	35%	50%
Reagent Cost (\$10 ³ /yr)	\$1,400	\$370
Parasitic Power (\$10 ³ /yr)	\$182	\$182
Disposal Cost (\$10 ³ /yr)	\$168	\$93
Subtotal (\$10 ³ /yr)	\$1,750	\$645
Capital Cost (\$/kW)	\$1,000,000 (10 \$/kW)	\$2,500,000 (25 \$/kW)
Annual Capital Charge (\$10 ³ /yr)	\$100	\$250
Total Operating Cost (\$10 ³ /yr)	\$1,850	\$895
\$/ton SO ₂ Removed	\$1,070	\$311

Table 3-1.	Comparison of	price for FSI	and LSDI s	vstems for a	100 MW	coal-fired boiler	[Dickerman.	20061
I ubic o Ii	Comparison of	price for 1 br		jotenno ioi u	100 101 00	cour mea boner	[Dicker many	=0000j

Trona (sodium sesquicarbonate) is another reagent that has shown potential to reduce SO_2 emissions. A typical flow diagram is shown in *Figure 3-4* for injection of trona into a duct.



Figure 3-4. Flow diagram for trona DSI system [Day, 2006]

Trona's higher reactivity compared to lime helps it to offset the reaction stoichiometry advantage of lime. More importantly, due to the ability of trona to capture SO_2 when injected at higher temperatures [Cremer *et al.*, 2008], it is potentially applicable to many ICI boilers where flue gas temperatures may be higher that the desired ~300°F required for lime. *Figure 3-5* gives
some test data showing percent SO_2 reduction, [Day, 2006], averaged over several applications for units with ESPs.



Figure 3-5. SO₂ removal test data [Day, 2007]

Figure 3-5 presents results for SO₂ reduction as a function of normalized stoichiometric ratio (NSR), which is the ratio of the reagent (trona in this case) to SO₂ in the flue gas. The two lines depict SO₂ reduction potential for two different sizes of trona at the same flue gas temperature of 700°F. Larger particles (unmilled) result in lower SO₂ reductions, as expected, relative to the milled condition (smaller particle size).

3.4.3 Other SO₂ Scrubbing Technologies

A number of other scrubber technologies have been developed for control of SO₂, but have not to date received significant market share. Among them are sodium- and ammonia-based wet scrubbing technologies. Some of these technologies, like the activated coke process [Dene, 2008], are regenerable (meaning the reagent can be regenerated and used repeatedly) and may produce useful byproducts, such as sulfuric acid, elemental sulfur, and ammonium sulfate. *Table 3-2* and *Table 3-3* present a comparison of the key performance characteristics and attributes for several alternative scrubbing technologies compared with conventional wet and dry scrubbers [Bozzuto, 2007].

	Limestone WFGD	Spray Dryer	Ammonia WFGD	Sodium WFGD
Features	 High Efficiency 	• Low	 High value 	• Low investment cost
	 Low cost reagent 	investment cost	byproduct	 Operational
	 Byproduct 	 Dry byproduct 	 Economics 	simplicity
	flexibility	Small footprint	improved at high	
		 No liquid 	sulfur levels	
		waste	 Low operating cost 	
Pros	 Small flue gas 	 Low/medium 	 High sulfur fuel 	 High sulfur fuel
	flow	sulfur fuel	 Larger flue gas 	 Larger flue gas flow
	 Operational 	 Smaller flue 	flow	 Fertilizer market
	simplicity required	gas flow	 Gypsum market 	
	 Acute capital cost 	Short	 Medium cost 	
	 Short evaluation 	evaluation period	evaluation period	
	period			
Cons	 Effluent discharge 	 Limited 	 Acute capital cost 	 Acute capital cost
	issue	landfill area	sensitivity	sensitivity
		 High 	 Ultra-low PM 	
		lime/limestone	emission	
		cost ratio	requirements	
Reagent	Limestone	Lime	Ammonia	Caustic, soda ash
Byproduct	Marketable gypsum	Landfill	Fertilizer	Sodium sulfate
	or landfill			
SO ₂ inlet	High	Low/medium	High	High
Removal	>98%	90 - 95%	>98%	>98%
Efficiency				

Table 3-2. Comparison of alternative FGD technologies [Bozzuto, 2007]

 Table 3-3. Cost estimates for alternative FGD technologies [Bozzuto, 2007]

	Limestone WFGD	Spray Dryer	Ammonia WFGD	Sodium WFGD
Capital Cost	25 - 45	15-25	35 - 60	10 - 20
(\$/acfm)				
Power	3-6	2	3-6	2-3
Consumption				
(kW/acfm)				
Reagent Cost	\$15 – 25/ton	\$60 – 75/ton	\$80 - 105/ton	\$100-130/ton
(\$/ton SO ₂				
removed.)				
Byproduct Cost	\$12 - 20/ton -	\$12 - 20/ton	\$150 - 250/ton	??
(\$/ton SO ₂	disposal (\$15/ton)			
removed.)	- sale			

3.5 Use of Fuel Oils with Lower Sulfur Content

Distillate fuel (No. 2 oil) is used in combustion systems in which an atomizer sprays droplets of oil into a combustion chamber and the droplets burn in suspension. Residual fuel oil (No. 6 oil) is also atomized and burned in ICI boilers. No. 6 oil is more viscous and has a higher boiling point range than distillate oil. Preheating is required for metering and atomization of No. 6 oil in industrial combustion systems. A wide range of sulfur contents are available, from less than 0.3 wt% to greater than 3 wt%.

For oil-fired ICI boilers, switching to lower-sulfur oil can provide significant reductions in emissions of SO₂. There is also an additional and important benefit of reduced emissions of $PM_{2.5}$. There are generally costs associated with switching to lower-sulfur fuels, which will undoubtedly vary from region to region.

Table 3-4 shows an example of the stocks of the fuel oils available on the East Coast and in the U.S. in 2006, taken from the Energy Information Administration (EIA) Petroleum Supply Annual [US EIA, 2006]. Substantial stocks of low-sulfur No. 6 fuel oil (less than 0.3 percent sulfur) and of ultra-low-sulfur No. 2 fuel oil (less than 0.0015 percent sulfur) were available both in the U.S. and on the East Coast.

	East	Coast	U. S.	Total
Distillate Fuel Oil	4,174		31,318	
0.0015% sulfur and under	1,856	(44%)	16,531	(53%)
Greater than 0.0015% to 0.05% sulfur	560	(13%)	6,223	(20%)
Greater than 0.05% sulfur	1,758	(42%)	8,564	(27%)
Residual Fuel Oil	2,486		11,936	
Less than 0.31% sulfur	869	(35%)	1,291	(11%)
0.31 to 1% sulfur	975	(39%)	2,544	(21%)
Greater than 1% sulfur	642	(26%)	8,101	(68%)

Table 3-4. Distillate and residual oil stocks in 2006 (x1000 barrels) [US EIA, 2006]

Figure 3-6 shows the prices for residual oil and distillate oil from 1983 through 2007. The differential between low (less than 1 percent sulfur) and high (greater than 1 percent sulfur) sulfur residual oil has been narrowing in recent years. The price of distillate oil in recent years, however, has been at times twice as much as the price of residual oil. The EIA prices for residual oil do not include a breakdown for very low sulfur residual oil (less than 0.31 percent sulfur). However, the prices for No. 2 (distillate) oil are broken out by ultra-low (<15 ppm S), low-sulfur (15-500 ppm S), and high-sulfur (>500 ppm S). These prices, shown in *Figure 3-7*, do not show much difference in price as a function of sulfur content of No. 2 oil.



Figure 3-6. Industrial energy prices for No. 6 oil greater than 1 percent S, No. 6 oil less than 1 percent S, and No. 2 oil [Source: US EIA, 2008]



Figure 3-7. Industrial energy prices for No. 2 (distillate) oil [Source: US EIA, 2008]

3-10 Appendix III.D.7.7-4795 The potential increased costs (in fuel only) for switching to lower-sulfur fuel oil can be estimated as shown in the following example, in which December 2007 fuel prices are used. If the high-sulfur residual oil is assumed to be 3 percent S, the low-sulfur residual oil is assumed to be 1 percent S, and the distillate oil is assumed to be 0.2 percent S, then the cost for fuel switching is shown in *Table 3-5*. These costs are only fuel costs, and do not include any equipment costs needed to switch fuels (for example, burner changes when switching from residual to distillate oil).

The cost estimates in *Table 3-5* suggest that switching from a 3 percent sulfur residual fuel oil to a low-sulfur residual oil (1 percent S) would provide a cost-effective sulfur removal strategy at about \$771 per ton of SO₂ removed. The cost of switching to distillate oil is estimated to be much higher than switching to low-sulfur residual oil, because the cost of distillate oil has been as much as twice that of residual oil in recent years. The cost effectiveness of a wet FGD for 90 to 99 percent SO₂ removal is in the range of \$2,000 to \$5,200/ton SO₂ (see Section 3.8). Thus, a switch to lower-sulfur fuel represents a cost-effective sulfur-compliance strategy for residual oil-fired boilers. The cost effectiveness (in dollars per ton of SO₂ removed) of switching from residual fuel oil to distillate fuel oil is not as attractive and is in the range of the cost effectiveness of installing a FGD or scrubber.

Fuel Switch	SO ₂ reduction	\$/ton SO ₂ removed (2007\$)
From 3% S to 1% Residual Oil*	66.7%	\$771
From 3% S Residual to 0.2% Distillate**	93.6%	\$5,335

 Table 3-5. Example of costs of switching to low-sulfur fuel oil [Fuel Prices from US EIA, 2008]

*Assuming December 2007 prices for <1%S and >1%S residual oil **Assuming December 2007 prices for >1%S and distillate oil

3.6 Applicability of SO₂ Control Technologies to ICI Boilers

The technologies described above are commercially available and are used extensively throughout the electric utility industry for coal-firing applications. The EGUs have deployed SO₂ controls (mostly wet and dry scrubbers) since the 1970s. ICI boilers firing coal are good candidates for the application of SO₂ control technologies. At least one oil-fired installation of a wet FGD has been noted in the literature [Caine and Shah, 2008]. Economics, however, will dictate preferred options on a case-by-case basis. It is likely that the higher capital-cost intensive technologies (e.g., wet and dry scrubbers) will be most attractive to larger ICI boilers, whereas the injection technologies (such as DSI) would likely be favored at smaller ICI boilers. The annualized cost of a wet FGD scrubber using wet sodium or alkaline waste can be lower relative to lime and limestone FGD, especially if low-cost waste disposal is available and the amount of SO₂ to be removed is small [Emmel, 2006]. This would suggest that smaller ICI boilers may not be good candidates for high capital-cost FGD systems. However, they should be good candidates for application of lower capital cost technologies such as DSI.

In terms of applicability, it is also important to recognize the impact of sulfur content of coal. Dry scrubbing has been typically restricted to low and medium sulfur coals (less than 2 wt% S) due to economic and technical considerations, including constraints associated with sorbent slurry concentration and adequate atomization performance. Lastly, while theoretically feasible, fluidized bed combustion (FBC) boilers are low emitters of SO_2 due to their inherent combustion process (bed temperature and composition), and are not likely candidates for SO_2 scrubber systems.

3.7 Efficiency Impacts

From the brief descriptions above, it should be clear that the common thread among the major SO_2 control technologies involves the reaction of SO_2 in the flue gas with a sorbent or reagent. The chemical reaction occurs either in a dedicated vessel (scrubber), or in the existing flue gas duct system. The major components affecting energy consumption for these systems include electrical power associated with material preparation (e.g., grinding) and handling (pumps/blowers), flue gas pressure loss across the scrubber vessel, and steam requirements. As expected, the energy penalties associated with a highly efficient (99 percent SO_2 reduction) wet scrubber are higher than for a less energy-intensive technology such as DSI.

The power consumption of SO_2 control technologies is further affected by the SO_2 control efficiency of the technology itself. In other words, SO_2 control performance is related to reagent utilization, commonly referred to as liquid-to-gas (L/G) ratio for wet systems and normalized stoichiometric ratio or reagent (Ca or Na) to-sulfur ratio for dry technologies. This can be explained based on the fact that for a given SO_2 reduction level, lower quantities of reagent not only translate to lower reagent costs, but also to lower energy costs.

Table 3-6 summarizes performance and energy efficiency impacts for the three general SO_2 technologies discussed. It is important to note the values shown in the table, specifically in the "Energy Impact" column, represent nominal ranges based on generic combustion calculations and parasitic energy consumption for each technology. They are not site- or fuel-specific calculations, which are generally dependent on many variables, such as fuel composition, combustion and steam efficiencies, and operating conditions (e.g., excess air). However, these values represent broad, industry-wide averages for impacts of SO_2 control technologies on efficiency.

Technology	Applicability	Performance (% Reduction)	Energy Impact (kW/1000 acfm)
WFGD	Larger coal units, high sulfur coals, excluding FBC	90 - 95+	4 – 8+
Dry Scrubbers (SDs)	Larger units w/ low/medium sulfur coals, excluding FBC	70 – 90+	2 - 4
Duct Injection	Larger units w/ low/medium sulfur coals (FBC applications possible for additional "SO ₂ trim")	30 – 60+	1 - 2

Table 3-6	Summary	of energy	impacts	for SO.	control	technologies
1 able 3-0.	Summary	or energy	impacts	101° 50_{2}	control	technologies

3.8 SO₂ Control Costs

Table 3-7 summarizes published SO₂ control costs for ICI boilers, as reported in the literature [Khan, 2003; US EPA, 2003; Whiteman, 2003; MACTEC, 2005]. Literature values of capital costs have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness in dollars/ton of SO₂ removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs, and reagents or consumables can make up a large portion of some of the operating costs. Costs of reagents and fuels (e.g., limestone, trona) change with time, but not always at the general rate of inflation. Thus, cost effectiveness values (or operating costs) from years before 2005 are not shown in the table. *Table 3-7* summarizes the published SO₂ control costs for a number of SO₂ control technologies.

A range of capital costs has been reported for sorbent injection technologies. *Figure 3-8* shows costs for dry duct injection (e.g., trona injection), wet duct injection (e.g., LSDI), and furnace sorbent injection (FSI). There was a large range of capital costs reported for dry sorbent injection. Wet sorbent injection (e.g., injection of hydrated lime slurry) was reported to have a significantly lower capital cost than dry sorbent injection. FSI capital costs were between dry and wet duct injection. The cost effectiveness (cost in dollars per ton of SO₂ removed) depends on the specific sorbent used and the stoichiometric ratio of sorbent to SO₂.

						Cost	
	SO_2		G' 6D 1	Capital Costs,	Base	Effectiveness	
Technology	Reductio	Evol Type	Size of Boiler	\$2006 per	year for	(\$/ton	Dof
Technology	II Kalige	Fuel Type				(Base 11)	Kei
In-Duct Dry Sorbent Inj.	40%	High-S Coal	100	\$34,228	1999		1
In-Duct Dry Sorbent Inj.	40%	High-S Coal	250	\$24,028	1999		1
In-Duct Dry Sorbent Inj.	40%	High-S Coal	1000	\$15,954	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	100	\$22,953	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	250	\$16,565	1999		1
In-Duct Dry Sorbent Inj.	40%	Low-S Coal	1000	\$11,031	1999		1
In-Duct Dry Sorbent Inj.	50 - 90%	Coal	100	\$17,327	2003		3
In-Duct Dry Sorbent Inj.	50 - 90%	Coal	250	\$12,624	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	100	\$8,663	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	250	\$4,703	2003		3
In-Duct Wet Sorbent Inj.	50 - 70%	Coal	1000	\$4,641	2003		3
Furnace Sorbent Inj.	70%	Coal	100	\$26,609	2003		3
Furnace Sorbent Inj.	70%	Coal	250	\$14,851	2003		3
Furnace Sorbent Inj.	70%	Coal	1000	\$7,054	2003		3
Spray Dryer	90%	Coal	100	\$69,744	1999		1
Spray Dryer	90%	Coal	250	\$46,209	1999		1
Spray Dryer	90%	Coal	1000	\$25,861	1999		1
Spray Dryer	90%	Coal	250	\$13,300-188,820	2005	\$1,712-3,578	4
Spray Dryer	95%	Coal	250	\$13,300-188,820	2005	\$1,622-3,390	4
Spray Dryer	90%	Oil	250	\$13,300-188,820	2005	\$1,944-5,219	4
Spray Dryer	95%	Oil	250	\$13,300-188,820	2005	\$1,841-4,945	4

 Table 3-7. SO₂ control costs applied to ICI boilers

Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Wet FGD	90%	High-S Coal	100	\$81,939	1999		1
Wet FGD	90%	High-S Coal	250	\$62,318	1999		1
Wet FGD	90%	High-S Coal	1000	\$41,216	1999		1
Wet FGD	90%	Low-S Coal	100	\$76,018	1999		1
Wet FGD	90%	Low-S Coal	250	\$57,759	1999		1
Wet FGD	90%	Low-S Coal	1000	\$38,122	1999		1
Wet FGD	90%	Coal	250	\$11,507-172,672	2005	\$2,089-3,822	4
Wet FGD	99%	Coal	250	\$11,507-172,672	2005	\$1,881-3,440	4
Wet FGD	90%	Oil	100	\$69,848	1999		1
Wet FGD	90%	Oil	250	\$53,066	1999		1
Wet FGD	90%	Oil	1000	\$35,019	1999		1
Wet FGD	90%	Oil	250	\$11,507-172,672	2005	\$2,173-5,215	4
Wet FGD	99%	Oil	250	\$11,507-172,672	2005	\$1,956-4,694	4

Table 3-7 [continued]

References

Khan, S. Methodology, Assumptions, and References Preliminary SO₂ Controls Cost Estimates for Industrial Boilers; US EPA: 2003.
 US EPA, Air Pollution Control Technology Fact Sheet: Flue Gas Desulfurization (FGD - Wet, Spray Dry, and Dry Scrubbers; EPA-452/F-03-034, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ffdg.pdf

3. Whiteman, C., ICAC, "SO₂ Control Technology Cost Estimates for Industrial Boilers" memo to John Robbins, US EPA, December 12, 2003.

4. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.





3-14 Appendix III.D.7.7-4799 Spray dryer (SD) technology has been widely applied to coal-fired EGUs. Estimates in the literature for SD technology for ICI boilers give the same capital costs for coal- and oil-fired boilers [ICAC, 2003; MACTEC, 2005]. *Figure 3-9* summarizes these capital costs for ICI boilers. Note that the MACTEC estimates at 250 MMBtu/hr boiler size assumed high and low equipment cost, but a detailed cost breakdown was not given.



Figure 3-9. Capital cost for SO₂ control for Spray Dryer Absorber applied to ICI boilers as a function of boiler capacity

Wet FGD technology has been widely applied to coal-fired EGU boilers but rarely to ICI boilers, although at least one oil-fired installation has been noted in the literature [Caine and Shah, 2008]. The relationship between FGD capital cost and boiler capacity is shown in *Figure 3-10*. Estimates in the literature give the same capital costs for coal- and oil-fired boilers [ICAC, 2003; MACTEC, 2005], although these estimates are not always based on actual field installation data because installations of wet FGD technology on ICI boilers are few at present.



Figure 3-10. Capital cost for SO₂ control for wet FGD applied to ICI boilers as a function of boiler capacity

3.9 Chapter 3 References

Bozzuto, C. "SO₂ Scrubber Systems," CIBO Industrial Emissions Conference, Portland, ME 2007.

Caine, John, Shah, Hardik. "Next Generation Wet Electrostatic Precipitators," presented at 101st Air & Waste Management Association Annual Meeting, Portland, OR, June 24-26, 2008.

Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emission Control Systems," prepared for UARG, 2007.

Cremer, Marc, Wang, David H., Senior, Connie L. "Testing and Model Based Optimization of SO₂ Removal with Trona in Coal Fired Utility Boilers," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Day, Keith. "Use of Dry Sorbent Injection Systems for Controlling Hg, HCL, SO₂/SO₃, NOx," CIBO 2007.

Day, Keith. *Duct Injection for Controlling SO*₂, *SO*₃, *Hg*, and *HCl*; O'Brien and Gere: Jan. 3, 2006.

Dene, Chuck, Baker, Lesley A., Keeth, Robert J. "FGD Performance Capability," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Dene, Chuck. "ReACT Process Demonstration at Valmy Generating Station," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 28-31, 2008.

Dickerman, Jim (2006). "SO₂ Emission Controls for Older and Smaller Boilers," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Baltimore, MD, August 25-28, 2006.

Emmel, T. "Use of CUECost Model for Developing Cost Estimates for Industrial Size Boilers," memorandum to CIBO, March 2006.

Haddad, E., Ralston, J., Freen, G., Castagnero, S. "Full-Scale Evaluation of a Multi-Pollutant Reduction Technology: SO₂, Hg, and NOx," presented at the DOE-EPRI-US EPA-A&WMA Combined Power Plant Air Pollutant Control Symposium - The Mega Symposium, Washington, DC, May 19-22, 2003.

Jones, Andrew P., Feeley, Thomas J. (2008) *Preliminary Economic Analysis of Wet FGD Co-Benefit Enhancement Technologies*. National Energy Technology Laboratory, Pittsburgh, PA, May 2008, http://www.netl.doe.gov/energy-analyses/pubs/Enhanced FGD Hg Capture Economics FINAL May2008.pdf.

Khan, Sikander. *Methodology, Assumptions, and References Preliminary SO*₂ Controls Cost Estimates for Industrial Boilers; US EPA: 2003.

MACTEC. *Boiler Best Available Retrofit Technology (BART) Engineering Analysis*; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Environmental Regulation and Technology Innovation: Controlling Mercury Emissions from Coal-Fired Boilers (Praveen Amar, Project Director), September 2000.

NJ DEP. Workgroup Recommendations and Other Potential Control Measures, Stationary Combustion Sources Workgroup, SCS003 – ICI Boilers, May 2, 2006. www.nj.gov/dep/airworkgroups/docs/wps/scs003_fin.pdf.

Nichols, B. "Air Pollution Control Systems at Virginia Tech's Power Plant," CIBO 2007.

Siemens Environmental Systems and Services. "Dry Scrubbing for Industrial Facilities," CIBO2007.

Sharp, G. Power Magazine, 2007.

Srivistava, R. "Controlling SO₂ Emissions – A Review of Technologies," EPA/600/R-00/093, November 2000.

US EIA. *Petroleum Price Data and Analysis*, accessed March 20, 2008. <u>http://tonto.eia.doe.gov/dnav/pet/pet_pri_top.asp</u>.

US EIA. *Petroleum Supply Annual 2006*, Volume 1, 2006. <u>http://www.eia.doe.gov/oil_gas/petroleum/data_publications/petroleum_supply_annual/psa_volume1/psa_volume1.html</u>.

US EPA. *Integrated Planning Model*, Documentation for EPA Base Case 2006 (v3.0), Section 8, Fuel Assumptions. <u>http://www.epa.gov/airmarkt/progsregs/epa-ipm/docs/Section-8.pdf</u>.

US EPA. *Integrated Planning Model*, Documentations for EPA Base Case 2006 (v3.0), Attachment O. <u>http://www.epa.gov/airmarkt/progsregs/epa-ipm/docs/attachment-o.pdf</u>.

US EPA. Air Pollution Control Technology Fact Sheet: Flue Gas Desulfurization (FGD - Wet, Spray Dry, and Dry Scrubbers; EPA-452/F-03-034, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ffdg.pdf. Whiteman, C. ICAC, "SO₂ Control Technology Cost Estimates for Industrial Boilers," memo to John Robbins, US EPA, December 12, 2003.

4 PM CONTROL TECHNOLOGIES

4.1 PM Formation in Combustion Systems

PM emissions from combustion processes include primary and secondary emissions. Primary emissions consist mostly of fly ash. Secondary emissions are the result of condensable particles such as nitrates and sulfates that typically make up the smaller fraction of the particulate matter (PM_{10} and $PM_{2.5}$). Fly ash refers to the mineral matter of the fuel, which typically includes some level of unburned carbon. ICI boilers burn a variety of fuels that contain ash and, as such, have PM emissions. Therefore, ICI boilers are candidates for PM controls.

Coal and oil contain non-combustible ash material. Other liquid or solid fuels (e.g., petroleum coke, wood) also contain ash. The quantity of ash in the flue gas depends on many factors, such as fuel properties, boiler design, and operating conditions. In dry-bottom, pulverized-coal-fired boilers, approximately 80 percent of the total ash in the as-fired coal exits the boiler as fly ash, and the remaining ash is collected as bottom ash. However, in wet-bottom, pulverized-coal-fired boilers, about 50 percent of the total ash exits the boiler as fly ash. In cyclone boilers (common in the EGU sector but not in the ICI population), most of the ash is retained as liquid slag, and the fly ash is only about 20 percent of the total ash. Fluidized-bed combustors (FBC) emit high levels of fly ash because the coal is fired in suspension and the ash is present in dry form. Stoker-fired boilers can also emit high levels of fly ash. However, overfeed and underfeed stokers emit less fly ash than spreader stokers because combustion takes place in a relatively quiescent fuel bed.

In addition to the nitrates and sulfates mentioned as secondary PM, NOx control technologies that inject ammonia or amine-based reagents (SNCR and SCR) yield a certain amount of ammonia "slip," which can also form fine particulate (ammonium sulfate) as the flue gas temperatures decrease towards the stack.

This section presents a brief description of the major primary PM technologies.

4.2 PM Control Technologies

PM control technologies have been commercially available and widely used in ICI and EGU boilers for many years. *Table 4-1* summarizes the main types of commercially available technologies.

Technology	Description	Applicability	Performance
Fabric filters (Baghouse)	"Baghouses" made of close-knit fabrics remove particulates through filtration.	Primarily used in coal/wood fired industrial/utility boilers. Not used with oil boilers due to clogging.	>99% total and PM _{2.5} removal
ESPs (Dry/Wet)	Charged particles attracted to oppositely charged plates. Collection method either wet/dry.	Widely used in coal applications. Suitable for oil, pet coke and waste solid fuels. Wet ESPs suitable for saturated flue gas.	Effectiveness depends on resistivity of particulates. Low sulfur can reduce performance of dry ESP. >99% reduction of total PM (dry/wet) and sulfuric acid mist and PM _{2.5} (wet)
Venturi Scrubbers	Scrubbers work on the principle of rapid mixing and impingement of the particulate with the liquid droplets and subsequent removal with the liquid waste.	High pressure required for significant removal. Applicable to a wide range of fuels.	50% removal for fine particulates, 99% removal for large (>5 micron) particulates
Cyclones	Cyclones use aerodynamic forces to separate particles from the gas stream.	Widely applicable to all fuels.	70%-90% total PM potential

Table 4-1.	Available	РМ	control	options	for	ICI boilers
1 abic 4-1.	11 vanabic	T TAT	control	options	101	ICI boncis

4.3 Description of Control Technologies

4.3.1 Fabric Filters

Fabric filters (also called baghouses) are essentially giant vacuum cleaners and very effective devices for collecting dry PM from flue gas. They are used in ICI and EGU applications, although less widely than ESPs. Separation occurs when the ash-laden flue gas passes through a porous layer of filter material. As the individual particles accumulate on the surface of the filter, they gradually form a layer of ash known as the "dust cake." Once formed, the dust cake provides most of the filtration. However, they are not particularly well suited for wet gas applications due to the negative impact of wet gas on the bag filters. *Figure 4-1* shows a photograph of the internal components of a fabric filter compartment with several individual bags and mounting mechanisms.



Figure 4-1. Photograph of fabric filter compartment with filter bags [Source: <u>www.hamon-researchcottrell.com</u>]

As shown in *Figure 4-1*, multiple bags are assembled in compartments to provide a large surface area for filtration. The large surface area is required to maintain acceptable pressure loss across the fabric. Groups of bags are placed in compartments, which can be isolated from one another to allow cleaning of the bags (see below), or to allow replacement of some of the bags without shutting down the entire baghouse.

Baghouse size is typically defined in terms of "air-to-cloth" ratio, expressed in the units of velocity in feet per minute (cubic feet per minute of flow divided by square feet of fabric area). The size of the baghouse depends on the particulate loading and characteristics, and the cleaning method used.

The type of bag cleaning method employed characterizes baghouses. Cleaning intensity and frequency are important because the dust cake provides a significant fraction of the fine particulate removal capability of a fabric. Hence, too frequent or too intense a cleaning method may lower the removal efficiency. Conversely, if removal of this dust cake happens infrequently or inefficiently, the pressure drop will increase to unacceptable levels. The major cleaning methods are as follows.

- Reverse-air baghouse In this case, the flue gas flows upward through the vertical bags, which open downward. The fly ash thus collects on the insides of the bags, and the gas flow keeps the bags inflated. To clean the bags, a compartment of the baghouse is taken off-line, and the gas flow in this compartment reversed. This causes the bags to collapse, and collected dust to fall from the bags into hoppers.
- Pulse-jet baghouse In this case, the dust is collected on the outside of the bags, which are mounted on cages to keep them from collapsing. Dust is removed by a reverse pulse of high-pressure air. This cleaning does not require isolation of the bags from the flue gas flow, allowing it to be done on-line. Because pulse-jet cleaning is more intensive than in reverse-air baghouses, the bags in a pulse-jet baghouse remain relatively clean, resulting in the ability to use a higher air-to-cloth ratio or a smaller baghouse compared to the reverse-air type.

Additionally, fabric filters can also be used in applications where fly-ash resistivity makes it difficult for collection with ESPs. Further, baghouses are capable of 99.9 percent removal efficiencies, as well as being able to remove the smaller size PM fraction ($PM_{2.5}$) more efficiently.

4.3.2 Electrostatic Precipitators

ESP's operate on the principle of electrophoresis by imparting a charge to the particulates and collecting them on opposed charged surfaces. Dry vs. wet ESPs refer to whether the gas is water-cooled and saturated prior to entering the charged collection area or is dry. *Figure 4-2* and *Figure 4-3* show schematic views of dry and wet ESPs, respectively. Older ESPs are often of the wire-pipe design, in which the collecting surface consists of one or more tubes (operated wet or dry). The wire-plate design is the other commonly used ESP design, as illustrated in the schematic in *Figure 4-2*.

In gases with high moisture content, dry ESPs are not suitable because the wet gas would severely limit the ability to collect the "sticky" particulates from the plates. The wet ESP technology is capable of very high removal efficiencies and is well suited for the wet gas environments. Both types of ESPs are capable of greater than 99 percent removal of particle sizes above 1 μ m on a mass basis with wet ESPs being capable of such reductions well into the sub-micron level (0.01 μ m) [Altman, 2001].



Figure 4-2. Side view of dry ESP schematic diagram [Source: Powerspan]



Figure 4-3. Wet ESP [Croll Reynolds]

Compared to fabric filters, ESPs affect the flue gas flow minimally, resulting in much lower pressure drops then an equivalent baghouse (typically less than two inches H_2O vs. greater than six inches H_2O for the fabric filter).

An electric field between high-voltage discharge electrodes and grounded collecting electrodes produces a corona discharge from the discharge electrodes, which ionizes the gas passing through the precipitator, and gas ions subsequently ionize fly ash (or other) particles. The negatively charged particles are attracted to the collecting electrodes. To remove the collected fly ash, the collecting electrodes are rapped mechanically, causing the fly ash to fall into hoppers for removal.

A balance generally needs to be struck between higher voltages for higher particulate removal efficiency and excessive sparking which will have the opposite effect. Larger ESPs are sectionalized (see *Figure 4-2*) such that higher voltages can be used in the first sections of the precipitator, where there is more particulate to be removed. Lower voltages are then used in the last, cleaner precipitator sections to avoid excessive sparking between the discharge and collecting electrodes. This has the added advantage that particles re-entrained in the flue gas stream by rapping (striking the electrode to dislodge the dust) may be collected in the downstream sections of the ESP.

Precipitator size is a major variable affecting overall performance or collection efficiency. Size determines residence time (the time a particle spends in the precipitator). Precipitator size also is typically defined in terms of the specific collection area (SCA), the ratio of the surface area of the collection electrodes to the gas flow. Higher SCA leads to higher removal efficiencies. Collection areas can range from as low as 200 to as high as 800 ft²/1000 acfm. In order to achieve collection efficiencies of 99.5 percent, SCA of 350-400 ft²/1000 acfm is typically used. The overall (mass) collection efficiencies of ESPs can exceed 99.9 percent, and efficiencies in excess of 99.5 percent are common. Precipitators with high overall collection efficiencies can achieve high efficiencies across a range of particle sizes so that good control of PM_{10} and $PM_{2.5}$ is possible with well designed and operated electrostatic precipitators.

Unlike dry ESPs, which use rapping to remove particulates from the collecting electrodes, wet ESPs use a water spray to remove the particulates. By continually wetting the collection surface, the collecting walls never build up a layer of particulate matter. This means that there is little or no deterioration of the electrical field due to resistivity, and power levels within a wet ESP can therefore be higher than in a dry ESP. The ability to inject greater electrical power within the wet ESP and elimination of secondary re-entrainment are the main reasons a wet ESP can collect sub-micron particulate more efficiently.

Overall, ESPs have historically been the collection device of choice for many applications in the ICI boiler and EGU boiler sectors. High removal efficiencies are possible and the units are rugged and relatively insensitive to operating upsets. Wet ESPs offer performance characteristics for capturing $PM_{2.5}$ similar to fabric filters and are well suited for applications such as oil firing, for which fabric filters are less attractive, because the sticky ash particles produced from oil combustion can blind the bags.

4.3.3 Venturi Scrubbers

Venturi scrubbers for PM control operate on the principle of rapid mixing and impingement of PM with liquid droplets and subsequent removal with the liquid waste. For particulate controls, the venturi scrubber is an effective technology whose performance is directly related to the pressure loss across the venturi section of the scrubber. However, for higher collecting efficiencies and a wider range of particulate sizes, higher pressure drops are required. High-energy scrubbers operate at pressure losses of 50 to 70 inches of water. Higher pressure drop translates to higher energy consumption. Performance of scrubbers varies significantly across particle size range with as little as 50 percent capture for small (<2 microns) sizes to 99 percent for larger (>5 microns) sizes, on a mass basis. However, venturi scrubbers are seldom used as the primary PM collection device because of excessive pressure drop and associated energy penalties. *Figure 4-4* depicts a venturi scrubber.



Figure 4-4. Venturi scrubber [Croll Reynolds]

4.3.4 Cyclones

Cyclones are devices that separate particulates from the gas stream through inertial forces. As ash-laden gas enters the cyclone near the top, a high-velocity vortex is created inside the device. Heavy particles move outward due to centrifugal force and begin accumulating on the wall of the cyclone. Gravity continuously forces these particles to move downward where they collect in the lower, hopper region of the cyclone. The collected particles eventually discharge through an opening in the bottom of the hopper into a system that transports the particles to a storage area. Smaller and lighter particles that remain suspended in the flue gas move toward the center of the vortex before being discharged through the clean-gas outlet located near the top of the cyclone (see *Figure 4-5*).

Cyclones are comparatively simple devices in design and construction, with no moving parts. Cyclones can operate over a wide range of temperatures, which makes them attractive for smaller ICI boilers that do not have economizers and/or air preheaters (and thus higher stack temperatures than in EGU boilers). Pressure drops across cyclones are typically in the range of 2 to 8 inches of water for a single cyclone. Cyclones can be arranged in arrays (multi-cyclones) and have overall mass removal efficiencies of 70 to 90 percent with the corresponding increase in pressure drop. However, cyclone collection efficiencies are very sensitive to particle size, and control efficiency for fine particulate ($PM_{2.5}$) is poor [Licht, 1988].

Cyclones are most effective at high boiler loads, where flue gas flow rates are highest. From an operational perspective, cyclones have no moving parts, are not sensitive to fuel quality or gas temperature, and require only regular cleaning to avoid plugging. These characteristics have made them good options in the past, particularly in the absence of regulatory PM $_{2.5}$ requirements.



Figure 4-5. Schematic of a cyclone collector [www.dustcollectorexperts.com/cyclone]

Due to the limited potential for $PM_{2.5}$ capture, use of cyclones in new combustion applications is primarily limited to fluidized-bed boilers where they are used to re-circulate the bed material – and not as primary PM control devices.

4.3.5 Core Separator

The core separator is a mechanical device that operates based on aerodynamic separation (like cyclones), but also utilizes a "core separator." The separator portion of the device consists of multiple cylindrical tubes with one inlet and two outlets. One outlet allows for a clean gas stream to exit, while the other outlet is used for recirculating the concentrated stream. This recirculation stream then passes through the cyclone unit (see *Figure 4-6* [Resource Systems Group, 2001]), where it is further cleaned and returned to the separator. This sequential process enhances its overall control efficiency as compared to single or multiple cyclones.



Figure 4-6. Schematic (left) and actual (right) core separator system [EPA, 2003]

The core separator capability for PM removal falls between that of an ESP and a cyclone. Several systems are currently installed on coal- and wood-fired boilers. The core separator unit is capable of overall PM reductions of up to the 90 percent range. Its collection efficiency, however, diminishes to about 50 percent for $PM_{2.5}$. *Table 4-2* displays inlet and outlet PM concentrations and removal efficiency of a core separator at two different plants. *Table 4-3* presents estimated costs for the core separator for two different sizes and gas flow conditions.

Core Separator Inlet Loading (lb/million Btu)	Core Separator Outlet Loading (lb/million Btu)	Removal Efficiency	Boiler Type
0.17	0.07	59%	Wood Fired
0.846	0.214	75%	Stoker – Coal

Table 4-2. Core separator collection efficiency [USEPA, 2008; Resource Systems Group, 2001]

Boiler Size	MMBtu/hr	8	10
	Estimated gas temperature (°F)	500	500
	Estimated gas flow rate (acfm)	4979	5996
Core Separator Size and	Gas Flow per 12" module	660	660
Estimated Price (uninstalled)			
	Number of 12" Modules	7	9
	Estimated price	\$110,000	\$130,000
	Gas Flow per 24" Module	2640	2640
	Number of 24" Modules	1	2
	Estimated Price	\$55,000	\$83,000

Table 4-3. Core separator cost analysis [B. H. Eason to P. Amar, 2008]

4.4 Applicability of PM Control Technologies to ICI Boilers

The PM control technologies described in this section are widely available and are used in both ICI and EGU applications. Because all these PM controls are based on the collection of particulates from the flue gas, they are applicable to a variety of boiler types and ash-containing fuels, including coal, oil, wood, petroleum coke, and other waste fuels. Determining the most attractive option for individual applications is a case-by-case decision that needs to account for technical, economic, and regulatory considerations. One exception, as mentioned, is that fabric filters are not suitable for fuel oil applications due to the "stickiness" and composition of the ash.

4.5 Efficiency Impacts

PM control technologies do result in some parasitic energy loss as can be deduced from the brief descriptions of technologies above (see *Table 4-1*). The inherent energy losses associated with each technology are given below and summarized in *Table 4-4*.

- For Fabric Filters
 - o compressor (bag cleaning)
 - o flue gas pressure loss
 - electric power (heaters, ash handling)
- For ESPs
 - o transformer-rectifier (TR) power
 - o flue gas pressure loss
 - o electric power (heaters, ash handling)
- For Venturi Scrubber and Cyclone
 - o flue gas pressure loss

10	ibie 4-4. Summary	of energy impacts it	n control technologie	
Technology	Applicability	Performance (% Reduction)	Energy Impact (kW/1000 acfm)	Comments
Fabric Filter	Coal, Wood	99+	1 – 2	Pressure loss / compressor / ash handling
Dry ESP	Coal, Oil, Wood	99	0.5 – 1.5	Pressure loss / TR power / ash handling
Wet ESP	Coal, Oil, Wood	99+	3 - 6	Pressure loss / TR power / ash handling
Venturi Scrubber	Coal, Oil, Wood	70-90 (Not efficient for PM _{2.5})	5 - 11	Pressure loss
Cyclone	Coal, Wood	70-90 (Not efficient for PM _{2.5})	0.5 – 1.5	Pressure loss

Table 4-4. Summary of energy impacts for control technologies

4.6 PM Control Costs

The following tables summarize published PM control costs for ICI boilers reported in the literature [US EPA, 2003a; US EPA, 2003b; US EPA, 2003c; US EPA, 2003d; US EPA, 2003e; US EPA, 2003f; MACTEC, 2005]. Literature values of capital cost have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using the Chemical Engineering Plant Cost Index values. Cost effectiveness

in dollars per ton of PM removed is only quoted for the literature references from 2005 or 2006 (and in those year's dollars). Cost effectiveness depends on the operating costs. Reagents or consumables can make up a large portion of some of the operating costs, but these items do not always increase with the rate of inflation for chemical plant equipment. Thus, cost effectiveness values (or operating costs) from years before 2005 have not been reported.

Table 4-5 summarizes the published PM control costs for several different PM control technologies. In the EPA references, the capital costs were given in terms of dollars/scfm (2002 dollars). These costs were converted to dollars per MMBtu/hr using the flow rates given in Chapter Five and then converted to 2006 dollars, using the Chemical Engineering Plant Cost Index values.

The MACTEC capital costs [MACTEC, 2005] span a large range, because high and low estimates for capital equipment were used in the calculation. The EPA capital costs are much higher for the wire-pipe ESP (also known as a tubular ESP) than the wire-plate ESP. Note that a size was not given in the EPA cost estimate, so a range is shown. The capital cost comparison is similar for wet ESPs although the capital costs themselves (in dollars/MMBtu/hr) are higher for wet ESPs as compared to dry ESPs.

For fabric filters, pulse-jet and reverse-air fabric filters were considered. These types of equipment have similar collection efficiencies, but the capital costs and effectiveness of pulse-jet fabric filters are lower than that of reverse-air fabric filters.

	Table -	-3. 1 MI COIR	l ul custs ap	pheu to ICI bollers			
Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu /hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Dry ESP	90%	Coal	250	\$12,365-\$160,754	2005	\$171-\$1,300	7
Dry ESP	99%	Coal	250	\$12,365-\$160,754	2005	\$156-\$1,172	7
Dry ESP	90%	Oil	250	\$6,713-\$87,275	2005	\$2,584-\$21,009	7
Dry ESP	99%	Oil	250	\$6,713-\$87,275	2005	\$2,328-\$18,912	7
Dry ESP (Wire-Pipe)		Coal		\$6,571-\$41,070	2002		1
Dry ESP (Wire-Plate)	90%-99%	Coal		\$3,286-\$10,843	2002		2
Dry ESP (Wire-Pipe)		Resid.Oil		\$5,198-\$32,486	2002		1
Dry ESP (Wire-Plate)	90%-99%	Resid.Oil		\$2,599-\$8,576	2002		2
Dry ESP (Wire-Pipe)		Dist.Oil		\$5,117-\$31,983	2002		1
Dry ESP (Wire-Plate)	90%-99%	Dist.Oil		\$2,559-\$8,443	2002		2
Dry ESP (Wire-Pipe)		Wood		\$7,560-\$47,249	2002		1
Dry ESP (Wire-Plate)	90%-99%	Wood		\$3,780-\$12,474	2002		2
ESP	99.50%	Wood	Small		2005	\$594	8
ESP	99.50%	Wood	Medium		2005	\$203-\$292	8
ESP	99.50%	Wood	Large		2005	\$114-130	8
Fabric Filter	90%	Coal	250	\$7,453-\$93,158	2005	\$444-\$1,006	7
Fabric Filter	99%	Coal	250	\$7,453-\$93,158	2005	\$423-\$957	7
Pulse-Jet Fabric Filter	95%-99.9%	Coal		\$1,971-\$8,543	2002		5
Reverse-Air FF	95%-99.9%	Coal		\$3,286-\$28,585	2002		6
Fabric Filter	90%	Oil	250	\$4,046-\$50,577	2005	\$7,277-\$16,464	7
Fabric Filter	99%	Oil	250	\$4,046-\$50,577	2005	\$6,915-\$15,643	7
Pulse-Jet Fabric Filter	95%-99.9%	Resid.Oil		\$1,559-\$6,757	2002		5
Reverse-Air FF	95%-99.9%	Resid.Oil		\$2,559-\$22,260	2002		6
Pulse-Jet Fabric Filter	95%-99.9%	Dist.Oil		\$1,535-\$6,652	2002		5
Reverse-Air FF	95%-99.9%	Dist.Oil		\$2,599-\$22,610	2002		6
Fabric Filter	99.50%	Wood	Small		2005	\$958	8
Fabric Filter	99.50%	Wood	Medium		2005	\$147-249	8
Fabric Filter	99.50%	Wood	Large		2005	\$91-\$107	8
Pulse-Jet Fabric Filter	95%-99.9%	Wood		\$2,268-\$9,829	2002		5
Reverse-Air FF	95%-99.9%	Wood		\$3,780-\$32,886	2002		6

Table 4-5.	PM control costs ap	olied to ICI boilers

Technology	Reduction Range	Fuel Type	Size of Boiler (MMBtu/hr)	Capital Costs, \$2006 per MMBTU/hr	Base year for Costs	Cost Effectiveness (\$/ton @Base Yr)	Ref
Wet ESP	90%	Coal	250	\$25,968-\$252,260	2005	\$906-\$2,627	7
Wet ESP	99.9%	Coal	250	\$25,968-\$252,260	2005	\$815-2,365	7
Wet ESP (Wire-							
Pipe)	90%-99.9%	Coal		\$13,142-\$65,712	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Coal		\$6,571-\$13,142	2002		4
Wet ESP	90%	Oil	250	\$14,098-\$136,955	2005	\$14,938-\$43,036	7
Wet ESP	99.9%	Oil	250	\$14,098-\$136,955	2005	\$13,446-\$38,736	7
Wet ESP (Wire-							
Pipe)	90%-99.9%	Resid.Oil		\$10,395-\$51,977	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Resid.Oil		\$5,198-\$10,395	2002		4
Wet ESP (Wire-							
Pipe)	90%-99.9%	Dist.Oil		\$10,235-\$51,172	2002		3
Wet ESP (Wire-							
Plate)	90%-99.9%	Dist.Oil		\$5,117-\$10,234	2002		4
Wet ESP (Wire-	000/ 00 00/	XX7 1		#15 100 #75 500	2002		
Pipe)	90%-99.9%	Wood		\$15,120-\$75,599	2002		3
Wet ESP (Wire-	0.00/ 00.00/	X V 1		Φ 7.5 (0, Φ15, 100	2002		4
Plate)	90%-99.9%	Wood		\$7,560-\$15,120	2002		4

Table 4-5 [continued]

References

1. US EPA, Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) - Wire-Pipe Type; EPA-452/F-03-027, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fdespwpi.pdf

2. US EPA, Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) - Wire-Plate Type; EPA-452/F-03-028, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf

3. US EPA, Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) - Wire-Pipe Type; EPA-452/F-03-029, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fwespwpi.pdf

 4. US EPA, Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) - Wire-Plate Type; EPA-452/F-03-030, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/fwespwpl.pdf

5. US EPA, Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type; EPA-452/F-03-025, July 15, 2003.

http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf

6. US EPA, Air Pollution Control Technology Fact Sheet: Fabric Filter - Reverse-Air Cleaned Type; EPA-452/F-03-026, July 15, 2003. http://www.epa.gov/ttn/catc/dir1/ff-revar.pdf

7. MACTEC, Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

8. STAPPA. Controlling PM2.5 Under the Clean Air Act: A Menu of Options; STAPPA/ALAPCO: March 2006.

4.7 Chapter 4 References

Caine, John, Shah, Hardik. "Next Generation Wet Electrostatic Precipitators," presented at 101st Air & Waste Management Association Annual Meeting, Portland, OR, June 24-26, 2008.

Licht, William (1988). *Air Pollution Control Engineering*, 2nd Edition. New York: Marcel Dekker.

Eason, B. "Core Separator Field Performance Data Summary 080118," personal communication to P. Amar, NESCAUM, September 2008.

MACTEC. Boiler Best Available Retrofit Technology (BART) Engineering Analysis; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

Resource Systems Group (2001). "An Evaluation of Air Pollution Control Technologies for Small Wood-Fired Boilers." Prepared for Vermont Department of Public Service, Vermont Department of Environmental Conservation (Air Pollution Control Division), New Hampshire Governor's Office of Energy Resources and Community Services, and Massachusetts Division of Energy Resources.

STAPPA. Controlling PM2.5 under the Clean Air Act: A Menu of Options; STAPPA/ALAPCO: March 2006.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) – Wire-Pipe Type; EPA-452/F-03-027, July 15, 2003a. http://www.epa.gov/ttn/catc/dir1/fdespwpi.pdf.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) – Wire-Plate Type; EPA-452/F-03-028, July 15, 2003b. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) – Wire-Pipe Type*; EPA-452/F-03-029, July 15, 2003c. http://www.epa.gov/ttn/catc/dir1/fwespwpi.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Wet Electrostatic Precipitator (ESP) – Wire-Plate Type*; EPA-452/F-03-030, July 15, 2003d. http://www.epa.gov/ttn/catc/dir1/fwespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003e. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter – Reverse-Air Cleaned Type*; EPA-452/F-03-026, July 15, 2003f. <u>http://www.epa.gov/ttn/catc/dir1/ff-revar.pdf</u>.

US EPA. *LSR Success Stories*; Acton, MA, December 16, 2003. http://es.epa.gov/ncer/sbir/success/pdf/lsr_success.pdf.

5 APPLICATION OF A COST MODEL TO ICI BOILERS

When evaluating the applicability of pollution control equipment to a specific ICI boiler, cost and performance capability need to be considered. A number of cost estimation models have been created for estimation of capital and operating costs of retrofit technology for air pollutants. However, most of the cost models have been developed for and applied to EGUs burning coal. Much less work has been carried out on cost estimation models for ICI boilers. In this Chapter, a cost modeling approach currently used for estimating control costs for coal-burning EGUs is modified and then investigated for its applicability to ICI boilers burning coal as well as other fuels. The purpose of this Chapter is to present this modified cost model (CUECost-ICI) and resulting cost calculations. The strengths and weaknesses of this approach are also discussed. However, the purpose of this effort is not to carry out an exhaustive calculation of costs, but to generate a set of reasonable cost estimates for ICI boilers burning different fuels and compare them with published cost information.

5.1 Cost Model Inputs and Assumptions

The Coal Utility Environmental Cost (CUECost) model was developed by Raytheon Engineers for EPA; version 3, and is available on EPA's website at <u>http://www.epa.gov/ttn/catc/products.html</u>. The model calculates capital and operating costs for certain predefined air pollution control devices for control of NOx, SO₂, and PM as applied to coal-fired power plants. The CUECost model produces approximate cost estimates (±30 percent accuracy) of the installed capital and annualized operating costs. The CUECost model was originally designed for and is intended for use on coal-fired boilers greater in size than 100 MW (about 1,000 MMBtu/hr heat input).

Table 5-1 gives the general plant inputs that are needed to set up the model; more inputs are needed for specific air pollution control devices (see Appendix B).

Input Parameter	Comment
Location - State	
	This was designed for EGUs, but can be scaled to
MW Equivalent of Flue Gas to Control System	generate the appropriate gas flow for ICIs
Net Plant Heat Rate	Function of the efficiency of the plant
Plant Capacity Factor	Use averages from EEA study, parametric variations
Percent Excess Air in Boiler	Assume $3\% O_2$ for NG and oil, $7\% O_2$ for coal, wood
	Determines the flow rate for downstream devices such as
Air Heater In-leakage	scrubbers and particulate control devices
Air Heater Outlet Gas Temperature	
Inlet Air Temperature	
Ambient Absolute Pressure	
Pressure After Air Heater	
Moisture in Air	
Ash Split:	Depends on firing system
Fly Ash	
Bottom Ash	
Seismic Zone	
Retrofit Factor	Moderate effect on total capital requirement (TCR)
(1.0 = new, 1.3 = medium, 1.6 = difficult)	
Select Fuel	User can define "coal" with respect to HHV, %S, %ash

Table 5 1	CUECost	gonorol	nlant	innuta
1 able 5-1.	CUECOSI	general	plant	inputs

The EPA version of CUECost contains the following modules for specific air pollution control devices:

- Limestone forced-oxidation, wet FGD scrubber
- Lime spray dryer
- FF
- ESP
- SCR
- SNCR
- LNB
- Natural Gas Reburn

CUECost bases the costs of equipment and operation on the generating capacity (in MW of electricity generated) of a given boiler. Industrial boilers are usually rated by the heat input (in MMBtu/hr); the boiler heat rate is used to convert from heat input to the equivalent size in MW. In order to use CUECost in its present form for ICI boilers, an equivalent size in MW needs to be estimated, although this could be modified in a dedicated ICI boiler version of CUECost (which was not developed in this effort).

Industrial boilers are operated differently from utility boilers, and the inputs for CUECost-ICI must be adjusted accordingly, including:

- Heat rate
- Excess air level

- Flue gas temperatures
- Capacity factor

The default values in the current version of CUECost for EGUs generally do not describe ICI boilers well. Fuel compositions vary widely for ICI boilers, while the EGU version of CUECost includes coal as the only fuel option (with different compositions). However, the user can define other fuels, as described below.

An important factor in determining total installed capital cost is the choice of appropriate retrofit factor, which expresses the difficulty of installing a control technology in an existing plant. In CUECost a retrofit factor of 1.0 denotes a new plant (corresponding to the lowest capital cost), and retrofit factors of 1.3 and 1.6 denote medium and difficult retrofits, respectively. Emmel [2006] noted that this range of retrofit factors significantly understated the cost of retrofit for FGD and SCR technologies when applied to EGUs less than 100 MW. Emmel also noted that on average a retrofit factor of 1.45 was more reasonable and that the factor should be even higher when CUECost is applied to ICI boilers.

The technology options in CUECost are also fixed, and the user cannot create a new technology option without supplying formulae for calculating the capital equipment cost. The technology options for SO_2 control in CUECost, in particular, have been noted to be more appropriate for larger utility boilers than for ICI boilers. Wet FGD and spray dryer technology – the SO_2 scrubbing options in CUECost – are based on lime or limestone reagents and have high capital and operating costs compared to alkaline scrubbers or duct injection. The latter scrubbing options might be more attractive for ICI boilers, but would have to be added to the current version of CUECost.

Finally, Emmel [2006] notes that most ICI boiler sites will have higher contingency, general facility, engineering, and maintenance costs (on a percentage of capital cost basis) than those identified for EGUs in CUECost in order to take into account necessary upgrades or demolition of existing facilities that are less likely to be needed at sites.

In this effort, the CUECost model was adapted for ICI boilers burning a variety of fuels by changing the fuel composition and heating value to simulate different fuels. Capital and operating costs in the model were based on correlations derived from coal-fired power plant experience since no reliable field data were available for the ICI boilers. It is not clear how robust the correlations for capital equipment are for small (≤ 25 MW equivalent) boilers.

The CUECost model is based on the electrical generating capacity. A combustion calculation was used to relate heat input rate to equivalent MW for five different fuels.

Table 5-2 gives the properties of these fuels. Boiler efficiency was specified, and heat rate was calculated from boiler efficiency. The uncontrolled or baseline emissions were based on fuel composition (in the case of SO_2 and PM) or on industry operating experience (in the case of NOx).

Table 5-3 shows the results (in terms of calculated flue gas flow rates) of the combustion calculations for a fixed heat input rate of 250 MMBtu/hr or 100 MMBtu/hr. Flue gas flow rate is an important parameter or input to the cost model, because the size of capital equipment is often related to the flue gas flow rate.

	Bituminous	Wood	No.2 Oil	No.6 Oil	Gas
C, wt%	76.2	27.6	86.4	85.8	75
S, wt%	2.5	0.04	0.6	2.5	0
H wt%	4.6	3.3	12.7	10.6	25
Moisture, wt%	1.4	45	0.02	0.02	0
N _, wt%	1.4	0.3	0.1	0.5	0
O, wt%	7	22.86	0.1	0.5	0
Ash, wt%	6.9	0.9	0.08	0.08	0
Fuel heating value, BTU/lb	13,630	4,633	19,563	18,273	20,800
Unburned carbon, wt% in ash	5	1	75	75	0
Boiler efficiency*	34%	30%	39%	39%	45%
Stack O ₂ , vol% dry	7%	7%	3%	3%	3%
Boiler heat rate, Btu/kWh	10,000	11,370	8,750	8,750	7,600
Uncontrolled or Baseline					
emissions					
NOx, lb NO ₂ /MMBtu	0.60	0.26	0.20	0.40	0.40
SO ₂ , lb/MMBtu	3.67	0.17	0.61	2.74	0.00
PM, lb/MMBtu	5.06	1.94	0.04	0.04	0.00

Table 5-2. Fuel characteristics and assumptions for CUECost calculation of heat rate and flue gas flow rates

*Fuel to MW

Table 5-3.	Equivalent	heat input ra	te and flue gas	flow rates t	for 250 and	100 MMBtu/hr	· heat input rates
1 4010 0 01	Equivalence	meat input i u	te una mae gus	no n naves i	tor aco una		near mpar races

	MW	MMBtu/hr	Flue gas, scfm
Bituminous coal (34% efficiency, 7% O_2)	25.0	250	65,305
Wood (30% efficiency, 7% O ₂)	22.0	250	81,184
No.2 oil (39% efficiency, 3% O ₂)	28.6	250	50,622
No.6 oil (39% efficiency, 3% O ₂)	28.6	250	51,117
Natural gas (45% efficiency, 3% O ₂)	32.9	250	59,336
Bituminous coal (34% efficiency, 7% O ₂)	10.0	100	26,122
Wood (30% efficiency, 7% O ₂)	8.8	100	32,474
No.2 oil (39% efficiency, 3% O ₂)	11.4	100	20,178
No.6 oil (39% efficiency, 3% O ₂)	11.4	100	20,375
Natural gas (45% efficiency, 3% O ₂)	13.2	100	23,806

5.2 Comparison of the Cost Model Results with Literature

A comparison was made of the CUECost-ICI model with other published information for a selection of fuels and air pollution control devices applied to ICI boilers. Where possible, the inputs for the model were set to be the same as information cited in the literature.

Using the appropriate fuel composition and boiler heat rates, the modified ICI version of the original CUECost (CUECost-ICI) model was run for a number of ICI boiler cases. *Table 5-4*, *Table 5-5*, and *Table 5-6* show the installed capital costs, first-year annual operating costs, and cost per ton of pollutant removed for NOx, SO₂, and PM, respectively. Capital and operating costs were calculated on 2006 dollars basis in the CUECost-ICI model. A complete

list of inputs to CUECost-ICI is included in Appendix B. For the NOx and SO_2 control technologies, percentage reduction of the pollutant was used as an input, so that the CUECost-ICI results could be easily compared to published literature results. For PM controls, a specific emission limit (in lb/MMBtu) was used as an input and the percentage PM reduction was calculated from the fuel ash content.

	Dollutont				Installed		
	removal				Capital	Annual	
MMBtu/hr	efficiency	Fuel	Technology	Reagent	Cost, \$M	Cost, \$M	Cost/ton
250	80.0%	Coal	SCR	Ammonia	\$4.394	\$1.253	\$4,763
100	80.0%	Coal	SCR	Ammonia	\$2.585	\$0.702	\$6,668
250	80.0%	No.6 Oil	SCR	Ammonia	\$2.923	\$0.790	\$3,972
100	80.0%	No.6 Oil	SCR	Ammonia	\$1.760	\$0.460	\$5,805
250	80.0%	Nat.Gas	SCR	Ammonia	\$3.005	\$0.811	\$4,673
100	80.0%	Nat.Gas	SCR	Ammonia	\$1.805	\$0.472	\$6,777
250	50.0%	Coal	SNCR	Ammonia	\$1.142	\$0.398	\$2,422
100	50.0%	Coal	SNCR	Ammonia	\$0.969	\$0.317	\$4,817
250	50.0%	No.6 Oil	SNCR	Ammonia	\$0.724	\$0.338	\$2,722
100	50.0%	No.6 Oil	SNCR	Ammonia	\$0.407	\$0.196	\$3,961
250	50.0%	Nat.Gas	SNCR	Ammonia	\$0.785	\$0.362	\$3,335
100	50.0%	Nat.Gas	SNCR	Ammonia	\$0.443	\$0.209	\$4,798
250	40.0%	Coal	LNB		\$1.227	\$0.301	\$2,290
100	40.0%	Coal	LNB		\$0.677	\$0.166	\$3,155
250	40.0%	No.6 Oil	LNB		\$1.339	\$0.329	\$3,305
100	40.0%	No.6 Oil	LNB		\$0.737	\$0.181	\$4,559
250	40.0%	Nat.Gas	LNB		\$1.467	\$0.360	\$4,151
100	40.0%	Nat.Gas	LNB		\$0.810	\$0.199	\$5,715

 Table 5-4. Capital and operating costs for NOx control technologies (assuming 7.5 percent interest and 15-year project life)

							Cost
	Pollutant				Installed		Effectiveness
	removal				Capital	Annual	(dollars per
MMBtu/hr	efficiency	Fuel	Technology	Reagent	Cost, \$M	Cost, \$M	ton)
250	95%	Coal	wFGD	Limestone	\$38.096	\$11.137	\$4,427
100	95%	Coal	wFGD	Limestone	\$33.680	\$9.608	\$9,547
250	95%	No.6 Oil	wFGD	Limestone	\$36.642	\$10.733	\$5,713
100	95%	No.6 Oil	wFGD	Limestone	\$32.805	\$9.368	\$12,510
250	90%	Coal	SD	Lime	\$29.598	\$8.806	\$3,694
100	90%	Coal	SD	Lime	\$26.263	\$7.540	\$7,909
250	90%	No.6 Oil	SD	Lime	\$28.463	\$8.371	\$4,704
100	90%	No.6 Oil	SD	Lime	\$25.723	\$7.344	\$10,352

Table 5-5. Capital and operating costs for SO₂ control technologies (assuming 7.5 percent interest and 15-year project life)

 Table 5-6. Capital and operating costs for PM control technologies (assuming 7.5 percent interest and 15-year project life)

									Cost
									Effective
	Pollutant			PM	Installed	Capital	Capital	Annua	ness (
	removal			Emission,	Capital	cost,	cost,	l Cost,	dollars
MMBtu/hr	efficiency	Fuel	Technology	lb/MMBtu	Cost, \$M	\$/scfm	\$/acfm	\$M	per ton)
250	99.3%	Coal	ESP	0.03	\$4.05	\$62.00	\$43.00	\$1.11	\$342
100	99.3%	Coal	ESP	0.03	\$2.31	\$88.50	\$61.50	\$0.63	\$485
250	99.3%	Coal	FF	0.03	\$4.77	\$73.00	\$50.70	\$1.32	\$406
100	99.3%	Coal	FF	0.03	\$2.88	\$110.20	\$76.60	\$0.78	\$592
250	95.8%	No.6 Oil	ESP	0.01	\$3.40	\$66.60	\$46.30	\$0.93	\$5,689
100	95.8%	No.6 Oil	ESP	0.01	\$2.02	\$99.00	\$68.80	\$0.55	\$8,410
250	95.8%	No.6 Oil	FF	0.01	\$4.09	\$80.00	\$55.60	\$1.14	\$6,940
100	95.8%	No.6 Oil	FF	0.01	\$2.50	\$122.80	\$85.30	\$0.68	\$10,354

For comparison, the American Forest & Paper Association (AF&PA) calculated SNCR control costs in 2006 for wood-fired boilers ranging in size from 88 to 265 MMBtu/hr [Hunt, 2006]. *Table 5-7* below compares the AF&PA costs with the CUECost-ICI costs for wood-fired boilers. The installed capital cost values agree well between CUECost-ICI and the AF&PA estimates, although the CUECost-ICI values for cost effectiveness (dollars per ton of NOx removed) are 20 to 25 percent lower than the AF&PA estimates.

MMBtu/hr	Pollutant removal efficiency	Fuel	Technology	Reagent	Installed Capital Cost, \$M	Annual Cost, \$M	Cost, \$/ton
AF&PA							
88.5	70.0%	Wood	SNCR	Urea	\$0.924	\$0.250	\$11,283
176.9	70.0%	Wood	SNCR	Urea	\$1.400	\$0.384	\$8,574
285.4	70.0%	Wood	SNCR	Urea	\$1.786	\$0.502	\$7,480
CUECost							
88.5	70.0%	Wood	SNCR	Urea	\$0.923	\$0.289	\$9,239
176.9	70.0%	Wood	SNCR	Urea	\$1.025	\$0.324	\$5,174
285.4	70.0%	Wood	SNCR	Urea	\$1.130	\$0.361	\$5,011

Table 5-7.	Capital and operating costs for SNCR on wood-fired boilers, comparison of cost calculations from
AF&PA ar	nd CUECost

Finally, the CUECost-ICI model results for capital cost were compared with some of the values reported in the literature [US EPA, 1996; NESCAUM, 2000; US EPA, 2003a; US EPA, 2003b; Whiteman, 2006], where available. Literature values of capital costs have been reported for different base years. The calculated capital cost values from the literature were normalized to a base year of 2006 using Chemical Engineering Plant Cost Index values.

The NOx capital costs computed with CUECost-ICI were largely consistent with the literature values. (Chapter Two contains a detailed discussion of the literature values for NOx control costs.)

Figure 5-1 compares capital costs for SCR for boilers burning coal, residual (No. 6) oil, and natural gas. The SCR costs appear to be consistent with the literature values. The literature value for SCR as reported by the Ozone Transport Assessment Group (OTAG) [US EPA, 1996] did not describe its basis in any detail, so it is difficult to determine if the OTAG cost estimates assumed a significantly different space velocity or different equipment than assumed in the CUECost-ICI model.



Figure 5-1. Comparison of CUECost-ICI model and reported literature values for capital cost of SCR for NOx control

The capital costs for SNCR (*Figure 5-2*) calculated from the CUECost-ICI model are in good agreement with literature values, particularly the sensitivity of capital cost to boiler capacity, which was also noted by ICAC [Whiteman, 2006].

The capital costs for LNB (*Figure 5-3*) calculated from the CUECost-ICI model for coalfired boilers were consistent with the literature values, although the capital costs for residual oilfired boilers were higher in the CUECost-ICI model than the literature values. Again, no details were provided in the literature references.



Figure 5-2. Comparison of CUECost-ICI model and reported literature values for capital cost of SNCR for NOx control





5-9 Appendix III.D.7.7-4826 Chapter Three contains a detailed discussion of the literature values for SO_2 control costs. The SO_2 capital costs computed with CUECost-ICI for spray dryers (SDs) were in the range of the literature values at boiler size of 250 MMBtu/hr (*Figure 5-4*). No literature data were available for residual oil-fired boilers and spray dryers. However, the capital costs calculated by CUECost –ICI for wet FGDs (*Figure 5-5*) were high when compared to the literature values.



Figure 5-4. Comparison of CUECost-ICI model and reported literature values for capital cost of Spray Dryer for SO₂ control


Figure 5-5. Comparison of CUECost-ICI model and reported literature values for capital cost of wet FGD for SO₂ control

Literature values for capital costs for PM control were evaluated from EPA reports on PM controls applied to ICI boilers [US EPA, 2003a; US EPA, 2003b]. In these references, the capital costs were given in terms of dollars/scfm (2002\$). These costs were converted to dollars per MMBtu/hr using the flow rates in *Table 5-3* and then converted to 2006 dollars, using the Chemical Engineering Plant Cost Index values. Chapter Four contains a detailed discussion of the literature values for PM control costs.

The dry ESP control costs computed with CUECost-ICI were consistent with the literature values, although the CUECost-ICI predicted slightly higher values than reported by EPA for dry, wire-plate ESPs [US EPA, 2003a]. Note that a size was not given in the EPA cost-estimate. The FF costs computed with CUECost-ICI were higher than the literature values for pulse-jet fabric filters [US EPA 2003b].

5.3 Summary

An existing EPA model for estimating costs of selected control technology for NOx, SO₂, and PM for coal-fired EGU boilers greater than 1,000 MMBtu/hr was adapted for ICI boilers. Inputs were modified to allow a wider variety of fuels and to express boiler capacity in MMBtu/hr instead of MW. Modification of the correlations used for the coal-fired EGU model to calculate capital and operating costs for ICI boilers was outside the scope of this work. The new model, CUECost-ICI provided good agreement with published values of capital cost of APCD equipment for small boiler sizes for coal-, oil- and natural gas-fueled boilers. The resulting model provided a quick and flexible means to estimate capital and operating costs of

specific control technologies as applied to ICI boilers. Further detailed and extensive work will be needed to validate and refine the model's calculation framework for ICI boilers, and to add other APCD technologies to the model.

5.4 Chapter 5 References

Emmel, Thomas. RTP Environmental Associates, "Use of CUECost Model for Developing Cost Estimates for Industrial Size Boilers," memorandum to Pat Dennis, Archer Daniels Midland Company, Robert Bessett, Council of Industrial Boiler Owners, March 22, 2006.

Hunt, T. American Forest & Paper Association, "AF&PA Comments on Draft NOx Model Rule and Related 6.7.06 OTC Resolution," letter to Christopher Recchia, Executive Director, Ozone Transport Commission, November 1, 2006.

MACTEC. *Boiler Best Available Retrofit Technology (BART) Engineering Analysis*; Lake Michigan Air Directors Consortium (LADCO): March 30, 2005.

NESCAUM. Status Report on NOx Controls for Gas Turbines, Cement Kilns, Industrial Boilers, and I.C. Engines - Technologies & Cost Effectiveness (Praveen Amar, Project Director), December 2000.

US EPA. Air Pollution Control Technology Fact Sheet: Dry Electrostatic Precipitator (ESP) -Wire-Plate Type; EPA-452/F-03-028, July 15, 2003a. http://www.epa.gov/ttn/catc/dir1/fdespwpl.pdf.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003b. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

US EPA. *OTAG Technical Supporting Document*, Chapter 5, Appendix C, 1996. <u>http://www.epa.gov/ttn/naaqs/ozone/rto/otag/finalrpt/</u>.

US EPA. *Air Pollution Control Technology Fact Sheet: Fabric Filter - Pulse-Jet Cleaned Type*; EPA-452/F-03-025, July 15, 2003b. <u>http://www.epa.gov/ttn/catc/dir1/ff-pulse.pdf</u>.

Whiteman, C. ICAC, "Selective Non-Catalytic Reduction Technology Costs for Industrial Sources," memo to Christopher Recchia, Executive Director, Ozone Transport Commission, October 6, 2006.

6 SUMMARY

ICI boilers are a significant source of NO_x , SO_2 , and PM emissions, and are relatively uncontrolled, compared to EGUs. More than half of the surveyed ICI boilers in the Northeast have no controls, approximately one-third have PM controls, very few units have NOx controls, and no units have SO_2 controls.

There are a range of technology options for cost-effectively reducing emissions of NOx, SO₂, and PM emissions from ICI boilers in the U.S. Operating costs may differ for ICI boilers than utility boilers, primarily because of their size and location. ICI boiler sites typically have higher contingency, general facility, engineering, and maintenance costs as a percentage of total capital cost than do utility boilers. While ICI boilers often have cost constraints due to their sizes and diversity of plant layout and settings, these factors also provide opportunities for low-cost applications. It is critical to conduct site-specific suitability analyses to assess performance potential or retrofit feasibility, and match the appropriate emission control technology for specific applications given boiler size, fuel type/quality, duty-cycle, and design characteristics.

This study adapted the CUECost model -- initially developed by EPA to estimate costs of selected control technology for NOx, SO₂, and PM for large coal-fired EGU boilers -- to assess ICI boiler control costs. The modeling results were consistent with published values of capital cost of APCD equipment for small boiler sizes for coal-, oil- and natural gas-fueled boilers.

6.1 NOx Controls

Most of the commercially available NOx control technologies used extensively in EGUs may also apply to ICI boilers. Some technologies have potential to capture mercury from the flue gas. Employing a combination of technologies can be more effective in reducing emissions than a stand-alone technology. While most of these technologies can be used together, some combinations may be more cost-effective. This should be assessed on a site- and strategy-specific basis. Options include:

- Boiler Tuning or Optimization, which can yield reductions of five to 15 percent or more;
- *Low-NOx Burner (LNB) and Overfire Air (OFA)*, which can be used separately or as a system, and can reduce NOx emissions by 40 to 60 percent. LNBs are applicable to most ICI boiler types, and are being increasingly used at ICI boilers less than 10 MMBtu/hr. These technologies require site-specific suitability analyses, as several important parameters can have substantial impact on their performance or even retrofit feasibility.
- *Ultra Low-NOx Burners (ULNB)*, which can achieve NOx emission levels on the order of single digits in ppm.
- *Reburn*, which has been used only in large EGU applications, but is an option for larger watertube-type boilers, including stokers. It requires appropriate technical and economic analyses to determine suitability. Reburn may yield 35 to 60 percent reductions in NOx emissions.
- *Selective Catalytic Reduction (SCR)*, which can achieve reductions higher than 90 percent.

- *Selective Non-Catalytic Reduction (SNCR)*, which can achieve between a 30 to 60 percent reduction in NOx.
- *Regenerative Selective Catalytic Reduction (RSCRTM)*, which is able to reduce NOx by 60 to 75 percent and CO by about 50 percent. These systems allow efficient use of an SCR downstream of a particulate control device, where the flue gas typically has a lower temperature than what is required for a conventional SCR. Such conditions are encountered in some ICI boilers firing a variety of fuels, including biomass.

NOx control technologies involving combustion modification have essentially no impact on the CO₂ emissions of the host boilers, with the exception of reburn. SNCR and SCR impose some degree of energy demand on the host boiler, including pressure, compressor, vaporization, and steam losses.

Most estimates for ICI boilers indicate capital costs in the range of \$1,000 to \$6,000 per MMBtu/hr and \$1,000 to \$7,000 per ton of NOx removed. LNBs and SNCR costs range from \$1,000 to \$3,000 per ton. For SCR, costs are between \$2,000 and \$14,000 per ton. SCR and SNCR costs are driven primarily by the consumption of the chemical reagent.

6.2 SO₂ Controls

ICI boilers firing coal are good candidates for employing SO_2 control technologies. Options include:

- Flue Gas Desulfurization (FGD) or Scrubbers. These technologies are commercially • available, and have been used extensively on EGUs since the 1970s. Wet scrubbers (Wet FGD) are the predominant SO₂ control technology currently in use for EGUs, and are typically associated with high-sulfur applications. Dry scrubbers include Spray Dryers (SD) and Dry Sorbent Injection (DSI) technologies, and are more compatible with lowto medium-sulfur coals. Some dry scrubber systems can remove 20 to 60 percent of the SO₂, and in some cases up to 90 to 99 percent for HCl and SO₃. DSI technologies are currently being demonstrated on ICI boilers. Furnace Sorbent Injection systems used on cement plants are capable of SO₂ reductions of up to 90 percent for industrial applications and ICI boilers, as well as HCl and HF reductions of greater than 95 percent. For SDs, cost per ton of SO₂ removed was in the range of \$1,600 to \$5,000. Costs were between \$1,900 and \$3,800 per ton of SO₂ for wet FGDs. While the SO₂ capital costs computed with CUECost for SDs were consistent with the literature at 250 MMBtu/hr, the capital costs computed for wet FGDs were high compared to values reported in the literature.
- *Fuel switching*. While not a control technology *per se*, the emission reduction benefits of fuel switching are directly proportional to the difference in sulfur contents of the fuels. Fuel switching requires considerable cost and operational analyses. In the NESCAUM region, residual oil is commonly used in ICI boilers. Switching from a 3 to a 1 percent sulfur residual oil can provide cost-effective SO₂ reductions at about \$771 per ton of SO₂ removed. For oil-fired ICI boilers, switching to lower-sulfur oil can provide significant reductions in emissions of SO₂, as well as in PM_{2.5}. The cost of switching to distillate oil is estimated to be much higher than for residual oil, because the higher cost of distillate oil.

6.3 PM Controls

ICI boilers burn a variety of fuels that contain fly ash and thus emit PM. PM control technologies have been commercially available and widely used in EGU boilers for many years. While PM controls are not currently widely used on ICI boilers, there are no technical reasons why PM controls cannot be applied to solid-fueled and oil-fired boilers. They are very effective in removing total PM and $PM_{2.5}$, with most options removing greater than 99 percent. The options include: (1) fabric filters or baghouses; (2) wet and dry electrostatic precipitators (ESPs); (3) venturi scrubbers; (4) cyclones; and (5) core separators. Control technology decisions should be made on a case-by-case basis that accounts for technical, economic, and regulatory considerations. Fabric filters are not suitable for fuel oil applications due to the "stickiness" and composition of the ash. The cost effectiveness of baghouses was in the range of \$50 to \$1,000 per ton of PM removed for coal and up to \$15,000 per ton of PM removed for oil. The cost effectiveness of ESPs was in the range of \$50 to \$500 per ton of PM for coal, and up to \$20,000 per ton of PM for oil. PM control technologies will result in some parasitic energy loss due to pressure loss, power consumption, and ash handling. Dry ESPs and fabric filters have the lowest associated parasitic power consumption (<2 kW/1000 acfm), while high-energy venturi scrubbers can have a larger parasitic consumption – up to 10 kW/1000 acfm or higher.

APPENDIX A: Survey of Title V Permits in NESCAUM Region

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,N	IJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Solutia Incorporated	MA	Foster Wheeler	249	Coal (Bit. 0.7%S)	-	0.027	baghouse (Carborundum Environmental Systems)	1.2	-	0.525	OFA (Foster wheeler)	-
St. Gobain Abrasives	MA	Riley	230	Coal (Subbit. 0.63%S)	-	0.1	Dust Collector	1.1	-	0.45	LNB	-
UMASS Amherst	МА	Union Iron Works	80	Coal	-	0.12	baghouse	1.1	-	0.43	-	Convert to CHP No. 2 (9/07)
Cooley Dickinson Hospital	МА	Early 1980s	-	Wood	-	-	-	0.008	-	0.16	-	-
Cooley Dickinson Hospital	MA	2006/ AFS Energy Systems	29.88	Wood	-	0.01	Cyclone, Baghouse	0.025	-	0.15	FGR	-
Seaman Paper	МА	2006/ Hurst Boiler	29.88	Wood	-	0.01	Baghouse	0.025	-	0.15	FGR	-

ICI Coal and W	ood Fire	d in NESCAUM	Region (CT,M	A,ME,NH,N	J,NY,RI,VT)	F	M	s	02	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Cornell University	NY	-	248	Coal	-	0.3	Fabric Filter	Coal 1% S by weight	-	0.4	-	
Cornell University	NY	-	117	Coal	-	0.35	Fabric Filter	Coal 1% S by weight	-	0.4	-	-
Commonwealth Plywood	NY	-	16	Wood	-	-	Multi- Cyclone w/o Fly ash injection	-	-	-	-	-
Crawford Furniture	NY	-	6	Wood	-	-	Single Cyclone	-	-	-	-	-
Deferiet Paper Company	NY	1945/ Combustion Engineering	190	Coal	-	0.46	Multi- Cyclone w/o Fly ash injection, and wet Venturi scrubber	2.5	-	0.5	-	-
Eastman Kodak	NY	-	265	Coal (Bit.)	-	0.26	ESP	2.5 (coal)	-	0.53	-	Boiler # 13

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Eastman Kodak	NY	-	265	Coal (Bit.)	-	0.26	ESP	2.5 (coal)	-	0.53	-	Boiler # 14
Eastman Kodak	NY	-	478	Coal (Bit.)	#2 Oil	0.26	ESP	-	-	-	-	Boiler # 15
Eastman Kodak	NY	-	500	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 41
Eastman Kodak	NY	-	500	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 42
Eastman Kodak	NY	-	640	Coal (Bit.)	#2 Oil	-	ESP	-	-	0.6	-	Boiler # 43
Eastman Kodak	NY	-	705	Coal (Bit.)	#2 Oil	0.035	ESP	.6 (coal)	-	0.42	-	Boiler # 44

ICI Coal and	Wood Fi	red in NESC/	AUM Region (C	ſ,MA,ME,NH,	NJ,NY,RI,VT)	F	PM	s	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Gunlocke Co.	NY	E. Keeler	18	Wood	Oil #2	0.53	Fly Ash Cyclone	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	14.6	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	41.54	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Harden Furniture	NY	Industrial Boiler Co.	27.6	Wood	-	-	Multi- Cyclone w/ Fly ash injection	-	-	-	-	
Lyonsdale Biomass	NY	Zurn	290	Wood	-	0.1	-	-	-	0.2	-	
Morton International	NY	-	138	Coal	-	0.34	Fabric Filter, ESP	1.7	-	0.5	-	

ICI Coal	and Woo	d Fired in NES	CAUM Region	(CT,MA,ME,NH,NJ,N	IY,RI,VT)	F	PM	S	D ₂	N	Ox	l l
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
SUNY at Binghamton	NY	International Boiler Works	100	Coal	Coal/Wood Mix	0.6	Multi- Cyclone w/o Fly ash injection	1.7	-	-	-	Х3
SUNY at Binghamton	NY	International Boiler Works	50	Coal	Coal/Wood Mix	0.6	Multi- Cyclone w/o Fly ash injection	1.7	-	-	-	
US Salt - Watkins Glen Refinery	NY	2000?	160	Coal and/or Wood	NG and/or Coal, Wood	0.051	Fabric Filter	1.2	-	0.18	SNCR	
Dirigo Paper	VT	1977	180	Wood	-	0.20 gr/dscf	multiclone	-	-	0.3	none	-
Ethan Allen	VT	1950	59.5	Wood	-	0.45 gr/dscf	multiclone	-	-	1.94lb/ton wet wood 7.45lb/ton dry wood	none	-
Fraser	NH	1981, Zurn	324	Wood/Bark/Paper	# 6 Oil	0.1	Multi-cyclone + Venturi scrubber	0.8	-	0.25	-	

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Tillotson Rubber	NH	1978	41	Wood	-	0.43	Multi-cyclone	-	-	-	-	
Allen Rogers Limited	NH		5	Wood								
Allen Rogers Limited	NH		5	Wood								
Forest Products Processing Center	NH		47	Wood								
Madison Lumber Mill	NH		13	Wood								
Chick Packaging	NH		10	Wood								

ICI Coal and	l Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Ossipee Mountain Land Company	NH		4	Wood								
Ossipee Mountain Land Company	NH		4	Wood								
Tommila Brothers	NH		11	Wood								
Monadnock Forest Products	NH		30	Wood								
Whitney Brothers Company	NH		2	Wood								
HG Wood Industries	NH		9	Wood								

ICI Coal and W	ood Fire	d in NESCA	UM Region (CT	,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Design Contempo	NH		19	Wood								
Design Contempo	NH		13	Wood								
Solon Manufacturing	NH		9	Wood								
Rochester Shoe Tree/Ashland	NH		4	Wood								
Precision Lumber	NH		9	Wood								
King Forest Industries - Wentworth	NH		29	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Peterboro Basket Company	NH		3	Wood								
Souhegan Wood Products	NH		8	Wood								
Souhegan Wood Products	NH		1	Wood								
Souhegan Wood Products	NH		1	Wood								
Concord Steam Corporation	NH		40	Wood								
Concord Steam Corporation	NH		40	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	T,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	s	O ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Boyce Highlands	NH		4	Wood								
Herrick Millwork	NH		5	Wood								
Northland Forest Products	NH		5	Wood								
Anthony Galluzzo Corporation	NH		4	Wood								
Cousineau Wood Products	NH		14	Wood								
Newport Mills Inc	NH		6	Wood								

ICI Coal and	Wood Fi	red in NESC	AUM Region (C	Γ,MA,ME,NH,I	NJ,NY,RI,VT)	F	PM	S	0 ₂	N	Ox	
Facility	State	Year/ Manuf.	Heat Input (MMBtu/hr)	primary fuel	secondary fuel	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	limit (Ib/MMBtu)	control device	Comments
Newport Mills Inc	NH		6	Wood								
Catamount Pellet Corporation	NH		40	Wood								
Durgin & Crowell Lumber Company	NH		10	Wood								
GH Evarts & Company	NH		7	Wood								
References:	State Title	V Permits, C	coal SO ₂ Databas	e, ICI Coal Da	atabase, MA IC	100-250 Boiler	Database, VT IC	I Boiler Databas	e	·	·	

APPENDIX B: CUECost-ICI Inputs

INPUTS

Description	Units	Input 1	Input 2	Input 3	Input 4	Input 5
<u>^</u>		•	•	•	•	•
General Plant Technical Inputs						
Location - State	Abbrev.	PA	PA	PA	PA	PA
Combustion Configuration	Abbrev.	PC	PC	PC	PC	PC
MW Equivalent of Flue Gas to Control System	MW	25	25.1	28.6	28.6	32.9
Net Plant Heat Rate	Btu/kWhr	10,000	11,370	8,750	8,750	7,600
Plant Capacity Factor	%	66%	66%	66%	66%	66%
Total Air Downstream of Economizer	%	154%	169%	118%	118%	119%
Air Heater Leakage	%	12%	12%	12%	12%	12%
Air Heater Outlet Gas Temperature	°F	350	350	350	350	350
Inlet Air Temperature	°F	80	80	80	80	80
Ambient Absolute Pressure	In. of Hg	29.4	29.4	29.4	29.4	29.4
Pressure After Air Heater	In. of H2O	-12	-12	-12	-12	-12
Moisture in Air	lb/lb dry air	0.013	0.013	0.013	0.013	0.013
Ash Split:						
Fly Ash	%	85%	85%	85%	85%	85%
Bottom Ash	%	15%	15%	15%	15%	15%
Seismic Zone	Integer	1.0	1.0	1.0	1.0	1.0
Retrofit Factor	Integer	1.0	1.0	1.0	1.0	1.0
(1.0 = new, 1.3 = medium, 1.6 = difficult)						
Select Coal	Integer	2	3	4	5	6
s Selected Coal a Powder River Basin Coal?	Yes / No	No	No	No	No	No
Economic Inputs						
Cost Basis - Year Dollars	Year	2006	2006	2006	2006	2006
Service Life (levelization period)	Years	15	15	15	15	15
Inflation Rate	%	3%	3%	3%	3%	3%
After Tax Discount Rate (current \$'s)	%	8%	8%	8%	8%	8%
AFDC Rate (current \$'s)	%	8%	8%	8%	8%	8%
First-year Carrying Charge (current \$'s)	%	22%	22%	22%	22%	22%
Levelized Carrying Charge (current \$'s)	%	17%	17%	17%	17%	17%
First-year Carrying Charge (constant \$'s)	%	16%	16%	16%	16%	16%
Levelized Carrying Charge (constant \$'s)	%	12%	12%	12%	12%	12%
Sales Tax	%	6%	6%	6%	6%	6%
Escalation Rates:						
Consumables (O&M)	%	3%	3%	3%	3%	3%
Capital Costs:						
Is Chem. Eng. Cost Index available? If "Yes" input cost basis CE Plant	Yes / No	Yes	Yes	Yes	Yes	Yes
ndex.	Integer	478.7	478.7	478.7	478.7	478.7
If "No" input escalation rate.	%	3%	3%	3%	3%	3%
Construction Labor Rate	\$/hr	\$35	\$35	\$35	\$35	\$35
Prime Contractor's Markup	%	3%	3%	3%	3%	3%

Operating Labor Rate	\$/hr	\$25	\$25	\$25	\$25	\$25
Power Cost	Mills/kWh	47	47	47	47	47
Steam Cost	\$/1000 lbs	3.5	3.5	3.5	3.5	3.5
Limestone Forced Oxidation (LSFO) Inputs						
	<i></i>	0.504	050	0.504	050/	0.544
SO ₂ Removal Required	%	95%	95%	95%	95%	95%
L/G Ratio	gal / 1000 act	125	125	125	125	125
Design Scrubber with Dibasic Acid Addition? $(1 - y_{22}, 2 - p_{2})$	Integer	2	2	2	2	2
(1 = yes, 2 = no)	٩E	107	127	127	127	107
Adiabatic Saturation Temperature	Г Factor	127	127	1.05	127	127
(Mole CoCO3 / Mole SO, removed)	Factor	1.05	1.05	1.05	1.05	1.05
(Mole CaCOS / Mole SO ₂ femoved)	W/t 0/2	15%	15%	15%	15%	15%
Stacking Landfill Wallboard	Wt. 70	1370	1370	1370	1370	1570
(1 - stacking, 2 - landfill, 3 - wallboard)	Integer	1	1	1	1	1
(1 - stacking, 2 - faithin, 5 - wantboard)	Integer	1	1	1	1	1
(May, Capacity = 700 MW per absorber)	Integer	1	1	1	1	1
Absorber Material	Integer	1	1	1	1	1
(1 - allow 2 - RLCS)	integer	1	1	1	1	1
Absorber Pressure Drop	in H2O	6	6	6	6	6
Reheat Required ?	Integer	1	1	1	1	1
(1 = ves, 2 = no)	integer		•	-		-
Amount of Reheat	°F	25	25	25	25	25
Reagent Bulk Storage	Days	60	60	60	60	60
Reagent Cost (delivered)	\$/ton	\$15	\$15	\$15	\$15	\$15
Landfill Disposal Cost	\$/ton	\$25	\$25	\$25	\$25	\$25
Stacking Disposal Cost	\$/ton	\$6	\$6	\$6	\$6	\$6
Credit for Gypsum Byproduct	\$/ton	\$2	\$2	\$2	\$2	\$2
Maintenance Factors by Area (% of Installed Co	st)					
Reagent Feed	%	5%	5%	5%	5%	5%
SO ₂ Removal	%	5%	5%	5%	5%	5%
Flue Gas Handling	%	5%	5%	5%	5%	5%
Waste / Byproduct	%	5%	5%	5%	5%	5%
Support Equipment	%	5%	5%	5%	5%	5%
Contingency by Area (% of Installed Cost)						
Reagent Feed	%	20%	20%	20%	20%	20%
SO ₂ Removal	%	20%	20%	20%	20%	20%
Flue Gas Handling	%	20%	20%	20%	20%	20%
Waste / Byproduct	%	20%	20%	20%	20%	20%
Support Equipment	%	20%	20%	20%	20%	20%
General Facilities by Area (% of Installed Cost)						
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Engineering Fees by Area (% of Installed Cost)						
Reagent Feed	%	10%	10%	10%	10%	10%
SO ₂ Removal	%	10%	10%	10%	10%	10%

Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Lime Spray Dryer (LSD) Inputs						
SO ₂ Removal Required	%	90%	90%	90%	90%	90%
Adiabatic Saturation Temperature	°F	127	127	127	127	127
Flue Gas Approach to Saturation	°F	20	20	20	20	20
Spray Dryer Outlet Temperature	°F	147	147	147	147	147
Reagent Feed Ratio	Factor	0.90	0.90	0.90	0.90	0.90
(Mole CaO / Mole Inlet SO ₂)						
Recycle Rate	Factor	30	30	30	30	30
(lb recycle / lb lime feed)						
Recycle Slurry Solids Concentration	Wt. %	35%	35%	35%	35%	35%
Number of Absorbers	Integer	2	2	2	2	2
(Max. Capacity = 300 MW per spray drye	r)					
Absorber Material	Integer	1	1	1	1	1
(1 = alloy, 2 = RLCS)						
Spray Dryer Pressure Drop	in. H2O	5	5	5	5	5
Reagent Bulk Storage	Days	60	60	60	60	60
Reagent Cost (delivered)	\$/ton	\$60	\$60	\$60	\$60	\$60
Dry Waste Disposal Cost	\$/ton	\$25	\$25	\$25	\$25	\$25
Maintenance Factors by Area (% of Installed	Cost)					
Reagent Feed	%	5%	5%	5%	5%	5%
SO ₂ Removal	%	5%	5%	5%	5%	5%
Flue Gas Handling	%	5%	5%	5%	5%	5%
Waste / Byproduct	%	5%	5%	5%	5%	5%
Support Equipment	%	5%	5%	5%	5%	5%
Contingency by Area (% of Installed Cost)						
Reagent Feed	%	20%	20%	20%	20%	20%
SO ₂ Removal	%	20%	20%	20%	20%	20%
Flue Gas Handling	%	20%	20%	20%	20%	20%
Waste / Byproduct	%	20%	20%	20%	20%	20%
Support Equipment	%	20%	20%	20%	20%	20%
General Facilities by Area (% of Installed Cos	st)					
Reagent Feed	%	10%	10%	10%	10%	10%
SO_2 Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%
Engineering Fees by Area (% of Installed Cos	t)					
Reagent Feed	%	10%	10%	10%	10%	10%
SO_2 Removal	%	10%	10%	10%	10%	10%
Flue Gas Handling	%	10%	10%	10%	10%	10%
Waste / Byproduct	%	10%	10%	10%	10%	10%
Support Equipment	%	10%	10%	10%	10%	10%

Particulate Control Inputs

Number of Air Preheaters

Outlet Particulate Emission Limit	lbs/MMBtu	0.03	0.03	0.01	0.01	0
Fabric Filter:						
Pressure Drop	in. H2O	6	6	6	6	6
Type (1 = Reverse Gas, 2 = Pulse Jet)	Integer	2	2	2	2	2
Gas-to-Cloth Ratio	acfm/ft ²	5.5	5.5	5.5	5.5	5.5
Bag Material (RGFF fiberglass only)	Integer	1	1	1	1	1
(1 = Fiberglass, 2 = Nomex, 3 = Ryton)						
Bag Diameter	inches	6	6	6	6	6
Bag Length	feet	20	20	20	20	20
Bag Reach		3	3	3	3	3
Compartments Out of Service	%	10%	10%	10%	10%	10%
Bag Life	Years	2	2	2	2	2
Maintenance (% of installed cost)	%	5%	5%	5%	5%	5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	10%	10%	10%	10%	10%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
ESP:						
Strength of the electric field in the $ESP = E$	kV/cm	10.0	10.0	10.0	10.0	10.0
Plate Spacing	in.	12	12	12	12	12
Plate Height	ft.	36	36	36	36	36
Pressure Drop	in. H2O	3	3	3	3	3
Maintenance (% of installed cost)	%	5%	5%	5%	5%	5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	10%	10%	10%	10%	10%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
NOx Control Inputs						
Selective Catalytic Reduction (SCR) Inputs						
NH3/NOx Stoichiometric Ratio	NH3/NOx	0.9	0.9	0.9	0.9	0.9
NOx Reduction Efficiency	Fraction	0.70	0.70	0.70	0.70	0.70
Inlet NOx	lbs/MMBtu	0.6	0.26	0.2	0.4	0.4
Space Velocity (Calculated if zero)	1/hr	3000	3000	11800	11800	16800
Overall Catalyst Life	years	4	4	4	4	4
Ammonia Cost	\$/ton	411.17	411.17	411.17	411.17	411.17
Catalyst Cost	\$/ft3	356.34	356.34	356.34	356.34	356.34
Solid Waste Disposal Cost	\$/ton	25.38	25.38	25.38	25.38	25.38
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	5%	5%	5%	5%	5%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
Number of Reactors	integer	1	1	1	1	1

1

integer

1

1

1

1

Adopted

Selective NonCatalytic Reduction (SNCR) Inputs

Leagent 1:Urea 2:Ammonia		1	1	1	1	1
Number of Injector Levels	integer	3	3	3	3	3
Number of Injectors	integer	18	18	18	18	18
Number of Lance Levels	integer	0	0	0	0	0
Number of Lances	integer	0	0	0	0	0
Steam or Air Injection for Ammonia	integer	1	1	1	1	1
NOx Reduction Efficiency	Fraction	0.50	0.50	0.50	0.50	0.50
Inlet NOx	lbs/MMBtu	0.6	0.26	0.2	0.4	0.2
NH3/NOx Stoichiometric Ratio	NH3/NOx	1.2	1.2	1.2	1.2	1.2
Urea/NOx Stoichiometric Ratio	Urea/NOx	1.2	1.2	1.2	1.2	1.2
Urea Cost	\$/ton	200	200	200	200	200
Ammonia Cost	\$/ton	411.17	411.17	411.17	411.17	411.17
Water Cost	\$/1,000 gal	0.22	0.22	0.22	0.22	0.22
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	5%	5%	5%	5%	5%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%
Low-NOx Burner Technology Inputs						
NOx Reduction Efficiency	fraction	0.40	0.40	0.40	0.40	0.40
Boiler Type	T:T-fired, W:Wall	W	W	W	W	W
Retrofit Difficulty	L:Low, A:Average, H:High	А	А	А	А	А
Maintenance Labor (% of installed cost)	%	0.8%	0.8%	0.8%	0.8%	0.8%
Maintenance Materials (% of installed cost)	%	1.2%	1.2%	1.2%	1.2%	1.2%
Natural Gas Reburning Inputs						
NOx Reduction Efficiency	fraction	0.61	0.61	0.61	0.61	0.61
Gas Reburn Fraction	fraction	0.15	0.15	0.15	0.15	0.15
Waste Disposal Cost	\$/ton	11.48	11.48	11.48	11.48	11.48
Natural Gas Cost	\$/MMBtu	4.24	4.24	4.24	4.24	4.24
Maintenance (% of installed cost)	%	1.5%	1.5%	1.5%	1.5%	1.5%
Contingency (% of installed cost)	%	20%	20%	20%	20%	20%
General Facilities (% of installed cost)	%	2%	2%	2%	2%	2%
Engineering Fees (% of installed cost)	%	10%	10%	10%	10%	10%



Proposed BACT Alternative

November 19, 2018

Submitted by David Fish Environmental Manager, Aurora Energy <u>dfish@usibelli.com</u> (907) 457-0230

Appendix III.D.7.7-4851

TABLE OF CONTENTS

1.0 Introduction 1.1 ADEC BACT Analysis 1.2 Aurora BACT Analysis 2.0 Economic Infeasibility 3.0 Proposed Alternative BACT – District Heating 3.1 District Heating 3.2 District Heating Expansion 3.3 District Heating Economics 3.4 Output Based Emission 4.0 Proposed Alternative BACT - Firewood Drying Kiln 4.1 Equivalent Emissions 4.2 Firewood Kiln Economics 5.0 Proposed Alternative BACT - Biomass Co-Firing 5.1 Biomass Economics 6.0 Proposed Alternative BACT – Reduction in Potential to Emit 7.0 Precursor Demonstration 8.0 Conclusion Appendix A (Economic Analysis Spreadsheets – V1) Appendix B (Economic Analysis Spreadsheets – V2)

Appendix C (Coal Analyses Summary)

Appendix D (Professional Memos)

1.0 Introduction

The Fairbanks North Star Borough (FNSB) has levels of fine particulate matter (PM_{2.5}) that are above the health based National Ambient Air Quality Standard (NAAQS). In November 2009 the area was designated as a Moderate Nonattainment Area (NAA) based on monitoring data indicating the area did not meet the 2006 24-hour PM_{2.5} standard. On April 28, 2017, the area was re-designated as a "Serious" NAA as a result of not attaining the PM_{2.5} standard within 5-years from designation. As a result, the state is required to propose additional measures to bring the area into compliance within 10-years from designation (i.e., December 2019).

Once EPA re-classified the FNSB $PM_{2.5}$ nonattainment area to Serious, it triggered the requirement for stationary sources with over 70 tons per year (tpy) potential to emit (PTE) for $PM_{2.5}$ or its precursors (SO₂, NO_x, VOC, & NH₃) to conduct a Best Available Control Technology (BACT) analysis. Based on the Alaska Department of Environmental Conservation (ADEC) preliminary evaluations, sulfur dioxides are being evaluated for point source control measures under BACT. At this time, ADEC is considering one control measure per major stationary source to meet BACT and Most Stringent Measures (MSM) for sulfur dioxide (SO2) control. Preliminary Determinations by ADEC suggest a capital cost to Aurora Energy, LLC (Aurora) for BACT compliance of \$12,332,076 for an 80% removal efficiency using dry sorbent injection.

Aurora asserts that the proposed Best Available Control Technologies for sulfur dioxide emissions are not economically feasible. Confronted with this fact, ADEC and the EPA have asked Aurora to suggest an alternative to the ADEC proposed BACT. Within the context of this document Aurora is providing a proposal for alternative BACTs, all of which mitigate Aurora's impact to the nonattainment area problem.

The alternative BACTs proposed by Aurora provide meaningful solutions in offsetting the largest contributing factor to the PM_{2.5} problem in Fairbanks: home heating. The alternative BACTs being proposed by Aurora are more efficient from a dollar per ton of pollutant removed than the ADEC proposed BACT. Aurora strongly believes that these alternatives can have a more positive impact to the air quality issue than the ADEC proposed BACT. Before implementing these alternative BACTs, Aurora needs ADEC and EPA to agree that these alternative BACTs satisfy Aurora's obligations for compliance with the NAA issue and that future controls to address PM_{2.5} in the NAA will not be required.

Additionally, Aurora is making this alternative proposal based on the premise that ADEC and EPA will consider a precursor demonstration to determine the actual contribution of PM_{2.5} by the point sources in the NAA. It has been stated repeatedly that the point sources are not the primary cause of the PM_{2.5} problem. However there has never been a thorough analysis done to understand to what extent the point sources are or are not contributing to the problem. Should a precursor demonstration show that the point sources within the NAA are not major contributors to the PM_{2.5} problem, all PM_{2.5} compliance requirements imposed on the point sources shall be vacated. If however the precursor demonstration shows that the point sources are above the insignificance threshold, the alternative BACTs proposed by Aurora would satisfy the requirements for compliance within the NAA.

In closing, Aurora desires to be a part of the solution to reduce the $PM_{2.5}$ levels within the NAA. Aurora remains convinced that the ADEC proposed BACT is cost prohibitive and an inefficient use of funds. Instead Aurora is proposing alternative BACTs that directly help solve the PM2.5 problem. In proposing these alternatives, Aurora needs ADEC and the EPA to agree to continue to study the source of PM2.5

pollution as well as confirm that these alternative BACTs meet Aurora's compliance with the Clean Air Act for purposes of NAA attainment.

1.1 ADEC BACT Analysis

ADEC provided its review of a BACT analysis for Aurora which included an evaluation of technologies to mitigate emissions of oxides of nitrogen (NOx) and sulfur dioxide (SO₂) emissions, which are precursor pollutants that can form PM_{2.5} in the atmosphere post combustion. The BACT analysis evaluated all available control options for equipment emitting the triggered pollutants and followed a process for selecting the best option based on feasibility, economics, energy, and other impacts. The results of the BACT analysis are reflected in Table 1.

Technology	Pollutant	Capital Cost	Annualized Cost	Cost Effectiveness
		(\$)	(\$/year)	(\$/ton)
Selective Non-Catalytic Reduction (SNCR) ¹	NOx	\$ 3,930,809.00	\$ 957,728.00	\$ 2,226.00
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 17,331,770.00	\$ 2,787,995.00	\$ 3,240.00
Dry Sorbent Injection (DSI) ²	SO ₂	\$ 12,332,076.00	\$ 4,284,104.00	\$ 6,308.00
Spray Dry Absorber (SDA) ²	SO ₂	\$ 60,270,115.00	\$ 11,862,577.00	\$ 15,525.00
Wet Scrubber (WS) ²	SO ₂	\$ 65,957,875.00	\$ 12,160,961.00	\$ 14,469.00

Table 1: Department Economic Analysis for Technically Feasible NOx and SO₂ controls.

1 - Capital Recovery Factor = 0.094 (7% interest rate for a 20 year equipment life)

2 - Capital Recovery Factor = 0.1098 (7% interest rate for a 15 year equipment life)

1.2 Aurora BACT Analysis

The ADEC requested additional information concerning Aurora's BACT analysis in a letter dated September 13, 2018. One of the ADEC's request were that Aurora comment on the cost analysis spreadsheets developed by ADEC and provided with the Preliminary Draft SIP. Comments were made on the spreadsheets and submitted to the ADEC on November 1, 2018. Below (Table 2) are the results of Aurora's inputs considering EPA and ADEC's comments. Spreadsheets are included along with this proposal for review by the agencies. Several changes to the inputs are documented in the summary for the spreadsheet inputs (See Appendix A & B). In conjunction with the changes made to the spreadsheets, sitespecific quote for SO₂ controls, namely Dry Sorbent Injection (DSI), was provided to the ADEC as requested and included as a parameter within the cost analysis spreadsheets for the referenced control technologies. The EPA is requiring that the cost analyses include a 30 year equipment life for the control technologies except SNCR which is evaluated for 20 year equipment life.

Table 2: Adjustment of ADEC Economic Analysis for Technically Feasible NOx and SO₂ Controls – V.1

Technology	Pollutant	Capital Cost (\$)	Annualized Cost (\$/year)	Cost Effectiveness (\$/ton)
Selective Non-Catalytic Reduction (SNCR) ²	NOx	\$ 6,208,948.00	\$ 989,197.00	\$ 3,107.00
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 25,758,941.00	\$ 2,921,054.00	\$ 4,587.00
Dry Sorbent Injection (DSI) ¹	SO_2	\$ 20,682,000.00	\$ 4,601,940.00	\$ 8,423.00
Spray Dry Absorber (SDA) ¹	SO_2	\$ 51,115,267.00	\$ 8,716,232.00	\$ 12,408.00
Wet Scrubber (WS) ^{1,3}	SO ₂	\$ 56,318,290.00	\$ 8,839,892.00	\$ 11,440.00

1 - Capital Recovery Factor = 0.0669 (5.25% interest rate for a 30 year equipment life) [EPA requirement per comments]

2 - Capital Recovery Factor = 0.0820 (5.25% interest rate for a 20 year equipment life) [EPA requirement per comments]

3 - Does not include costs associated with building and maintaining a wastewater treatment facility. [Notation from ADEC spreadsheet]

Table 3 reflects another iteration (V.2) of Aurora's changes to the ADEC's spreadsheets. The results in Table 3 consider a lower emission rate for both SO₂ and NO_x based on 2011 source testing information and/or additional information. The SO_2 emission rate assumed by the state and Aurora has been 0.39 lbs/MMBtu. The coal analysis for feed coal during the test showed elevated sulfur content (0.18%) in comparison to the 5-year weighted average sulfur content from 2013-2017 (0.14 %). Using a conservative conversion from sulfur content (0.14%) to sulfur dioxide, the 5-year weighted average SO_2 emission rate would be 0.36 lbs/MMBtu. This conservative emission rate was used in the calculations to derive the cost effectiveness values in Table 2. The sulfur content during the source test conducted in 2011 (0.18%) when converted to a heat input emission rate considering total conversion of sulfur to SO₂ yields an emission factor of 0.48 lbs/MMBtu. The actual tested emission rate was 0.40 lbs/MMBtu. The emission rate for SO_2 was 83% of the maximum potential. This suggests there is 17% capture of sulfur compounds in the ash. As such, the emission rate derived and used in Table 3, considers a 17% capture of sulfur in the ash. The conversion of sulfur to SO₂ based on the 5-year weighted average sulfur content in coal and a 17% capture rate yields 0.30 lbs/MMBtu (0.36 lbs/MMBtu X 0.834 = 0.30 lbs/MMBtu). The results in Table 3 account for the current sulfur content in coal and the rate adjustment for sulfur capture fraction from the process based on a source test conducted in 2011.

Also accounted for in Table 3 is a more realistic equipment life expectancy for the facility and control equipment. It is not reasonable to consider a 30 year and 20 year life expectancy for the control equipment and the boilers. Considering the age of the Chena Power Plant, Units 1-3 are 50,000 lb/hr boilers that were installed in the early 1950s, and Unit 5 is a 200,000 lb/hr boiler which was installed in 1970. Units 1-3 are already +65 years and Unit 5 is +45 years old. A 30 year horizon should not be applicable to the Chena Power Plant. A 15 year equipment life is considered in the following cost effectiveness analysis (Table 3).

		····//		-2
Technology	Pollutant	Capital Cost (\$)	Annualized Cost (\$/year)	Cost Effectiveness (\$/ton)
Selective Non-Catalytic Reduction (SNCR) ¹	NOx	\$ 6,208,948.00	\$ 1,088,694.00	\$ 3,419.00
Selective Catalytic Reduction (SCR) ¹	NOx	\$ 25,758,941.00	\$ 3,721,132.00	\$ 5,844.00
Dry Sorbent Injection (DSI) ¹	SO ₂	\$ 20,682,000.00	\$ 4,914,480.00	\$ 10,785.00
Spray Dry Absorber (SDA) ¹	SO ₂	\$ 50,880,540.00	\$ 10,084,456.00	\$ 17,213.00
Wet Scrubber (WS) ^{1,2}	SO_2	\$ 56,318,290.00	\$ 10,314,589.00	\$ 16,005.00

Table 3: Adjustment of ADEC Economic Analysis for Technically Feasible NOx and SO₂ Controls - V.2

1 – Capital Recovery Factor = 0.0980 (5.25% interest rate for a 15 year equipment life)

2 - Does not include costs associated with building and maintaining a wastewater treatment facility. [Notation from ADEC spreadsheet]

2.0 Economic Infeasibility

The BACT review process as outlined by EPA includes five-step approach to determine the best control option. The economic feasibility of potential measures are addressed under Step 4 of the review process. Since there is no cost threshold for economic feasibility for controls within a serious nonattainment area, a source has to make the assertion to the regulatory agencies in order for economic infeasibility to be considered. Aurora's BACT results, as illustrated in Table 3, show that the least expensive SO₂ control technology is a \$20 million dollar investment and the cost effectiveness value is above \$10,000/ton of SO₂ removed.

Therefore, per the fine particulate implementation guidance, if a source contends that a source-specific control level should not be established because the source cannot afford the control measure or technology demonstrated to be economically feasible, the source should make its claim known to the state and support the claim with information regarding the impact of imposing the identified control measure or technology on the following financial indicators to the extent applicable:¹

- 1. Fixed and variable production costs;
- 2. Product supply and demand elasticity;
- 3. Product prices (cost absorption vs. cost pass-through);
- 4. Expected costs incurred by competitors;
- 5. Company Profits;
- 6. Employment costs;
- 7. Other costs (e.g., for BACM implemented by public sector entities).

At this time, ADEC is considering one control measure per major stationary source to meet BACT and Most Stringent Measures (MSM) for sulfur dioxide (SO₂) control. ADEC's preliminary determination suggests Aurora invest \$12,332,076 for DSI technology to remove 80% of the SO₂ emissions from the Chena Power Plant. ADEC estimates that annualized costs for the application would be \$4,284,104. ADEC's projected capital cost for retrofit SO₂ control technology is just above half of the costs of a +50/-30 design (e.g., capital cost \$20,682,000) which was recently submitted to the ADEC. Even if the lower cost for controls estimated by the ADEC were valid, it is not economically feasible and therefore should not be required. Further, ADEC does not know whether the installation of DSI or any control technology on stationary sources will have a significant impact on the overall air quality in the non-attainment area.

Aurora has one electric customer and approximately 200 district heating customers. Income from power production is from wholesale electric sales to the local electrical cooperative, Golden Valley Electrical Association (GVEA). Aurora has a long term contract with GVEA which would be difficult to renegotiate for necessary price increases to accommodate additional control technologies. Pass-through cost opportunities for Aurora's district heating are not viable. The necessary product price increases to cover additional costs of the proposed control technology would price Aurora out of the market for both heat and power. The result would be higher electric and heat costs, coupled with an increase in PM_{2.5} pollution due to the introduction of ground-level emissions from oil and/or gas fired furnaces and boilers that would be installed to replace uneconomic district heat. As Aurora customers switch to less expensive fossil fuels – or yet even less expensive wood – the resulting burden on Aurora's remaining customers will increase, causing more and more of them to switch, resulting in a continuous increase in particulate emissions in the Fairbanks core, and in a death spiral for Aurora as an economically viable business. Within this section, Aurora will address the financial indicators applicable to demonstrate the economic infeasibility of installing and operating ADEC's proposed control technology.

1. Production Costs

Aurora's five year operating costs for electric and district heating (RCA) are provided below in Table 4. Operating costs consist of operations expense, maintenance expense, administrative expenses, and depreciation expense. The net operating costs for power generation was \$0.08/kW in 2017 (Table 4). The

¹ Federal Register, Vol. 81, No.164, Wednesday August 24, 2016. pg. 58085.

margin for income is small as reflected in Table 6. District heating operating costs exceed income generated resulting in a net loss over the past 5 years (Table 6).²

Year	Electrical Total	Net kWh	\$/kWh	District heating Total	Net MMBtu	\$/MMBtu
2017	\$13,795,480	181,113,600	\$0.08	\$4,658,655	262,189	\$17.77
2016	\$13,707,259	189,093,610	\$0.07	\$5,285,399	249,151	\$21.21
2015	\$12,582,952	194,083,220	\$0.06	\$5,395,212	267,686	\$20.16
2014	\$12,250,548	184,058,400	\$0.07	\$5,648,209	273,089	\$20.68
2013	\$10,833,349	181,569,600	\$0.06	\$5,387,853	274,139	\$19.65
Average	\$12,633,918	185,983,686	\$0.07	\$5,275,066	265,251	\$19.89

Table 4:	Aurora	Energy	Operating	Costs

2. Supply and Demand Elasticity

The issue of supply and demand elasticity is addressed in more detail within the context of the following sections. The cost of control technologies cannot be absorbed by Aurora under the current pricing to consumers for district heating and power. Aurora has no alternative but to pass those costs to its customers. Those customers, in turn, would have no choice but to go elsewhere for their heat and power, as Aurora would no longer be competitive with other options. This would be the beginning of a death spiral for Aurora as a business, and the beginning of an increase in lower level emissions in the Fairbanks core as more and more buildings switch to oil or gas for heat.

3. Product prices (cost absorption vs cost pass-through)

Aurora's current product prices are competitive with other power suppliers and heating sources. Aurora's heat business is generally regulated by the Regulatory Commission of Alaska (RCA). District heating prices are set based on Aurora's cost to produce the heat. At the same time, many district heat customers are able to switch to alternative sources of heat, such as oil, gas or wood; therefore, Aurora has a powerful incentive to maintain district heating prices competitive with other heating options. Likewise, GVEA maintains several contracts with various power producers including Aurora. GVEA's portfolio includes power generated with natural gas, hydroelectric gradient, wind, solar, coal, and oil. Aurora's contract with GVEA ensures Aurora's power pricing is competitive and marketable.

District Heating

District heating prices cannot absorb the pass through costs of control technology. Aurora's district heating customer base is approximately 200 including mostly commercial and some residential customers. District steam heating rates are set with oversight by the RCA and do not vary. Hot water district heating prices differ depending on consumers' annual heating needs. The hot water district heating rates are adjusted throughout the year to be competitive with other sources of heat.

Absorbing full or partial costs for upgrades or control technologies is not feasible through district heating rate adjustments. The price adjustment necessary to compensate for the current average annual net loss from district heating (Table 6) would be an increase of \$3.71/MMBtu representing a 20% increase in heating costs. A 20% increase in district heat prices per unit energy (MMBtu) is not marketable. The potential is a loss of revenue from customers switching to alternative forms of heat which would make

² Based on RCA annual filing from 2013-2017.

district heating even less sustainable and exacerbate air quality due to an increase in ground level emissions.

Electric Generation

Aurora's power pricing cannot absorb the pass through cost of control technologies without revising the current contract and becoming less marketable. Aurora sells its power at wholesale price to GVEA, its sole electric customer. Aurora has averaged 186,000 MWh in net sales annually. Pass through of any additional incurred cost would have to be negotiated with GVEA, and would cause an increase in power costs to all customers in GVEA's service area.

Product Pricing for GVEA including Control Technology Costs

ADEC indicates that SO₂ controls are being considered for BACT or Most Stringent Measures (MSM) at this time.³ ADEC's estimate of the capital investment of the preferred control technology for Aurora is estimated to be \$12,332,076 and the annualized cost is estimated to be \$4,284,104. The requirement is that BACT must be installed within 4 years of reclassification of an area from a moderate to a serious nonattainment area.⁴ The Fairbanks North Star Borough nonattainment area designation change from "Moderate" to "Serious" was effective June 9, 2017.⁵ Since the area is now identified as serious, BACT control would have to be in place by June of 2021. Funds for the capital investment would need to be arranged by 2019 to allow for construction and installation of the control equipment. The power purchase agreement with GVEA would need to be renegotiated prior to committing to construction.

Assuming electrical sales would correspond to the 5-year average (185,984 MWh), the weighted average price per MWh at the Chena Power Plant (CPP) would be \$85.51.⁶ When the annualized cost of operating the preferred control technology is included, the price of power from the CPP increases to \$108.55/MWh; a 27% increase in price of power. The average total electric power consumption of sulfur control on Healy Unit #2 is 550.5 kW.⁷ Assuming a comparable station service use, SO₂ control on the Chena Power Plant could require an additional 2.6% for station service load.

The SO₂ control technologies being considered (DSI) require the addition of lime, limestone, or sodium bicarbonate to the gas path prior to the baghouse. The amount of unreacted sorbent added to the process could alter the leaching characteristics of metals from coal ash. Recent testing of coal ash from coal blended with 2% by weight limestone, demonstrated elevated metals leaching from coal ash at various pH. Metals leaching in excess of water quality standards could require Aurora to incur additional disposal costs for coal ash. Aurora would either have to build a coal ash landfill, or take the coal ash to the municipal landfill at a cost to Aurora of \$90/ton.⁸ If additional costs were incurred by Aurora for disposing 20,000 tons of coal ash, then the price per MWh would need to increase to \$118.60; which represents a 39% increase in the price of power.

³ ADEC. 2018. Preliminary Draft, Possible Concepts and Potential Approaches for the development of the FNSB NAA Serious SIP.

⁴ Federal Register, Vol. 81, No.164, Wednesday August 24, 2016.

⁵ Federal Register, Vol. 82, No.89, Wednesday May 10, 2017.

⁶ 2013 Contract Pricing for 2020: \$79.37/MWh (<150,000 MWh) + \$112.12/MWh (>150,000 MWh).

⁷ Alaska Industrial Development and Export Authority. 1999. Spray Dryer Absorber System Performance Test Report, Healy Clean Coal Project. Healy, AK.

⁸ FNSB. 2014. Interior AK Coal Ash. Pg. 42

8				Ū.					
	Average kWh/year (2013-2017)	No Cor	ntrols	SO2	- DSI	SO2	- SDA	SO2	- WS
Annual BACT									
Operating Cost		\$	-	\$4,	284,104	\$11	,862,577	\$12	2,160,961
2020 (\$/kWh)	185,983,686	\$	0.09	\$	0.11	\$	0.15	\$	0.15
2020 (\$/kWh) -2.5%									
station load (BACT)	181,334,094	\$	0.08	\$	0.11	\$	0.15	\$	0.15
Coal Ash Disposal -									
Borough Landfill ¹		\$	-	\$	0.12	\$	0.16	\$	0.16

				~	. ~
$T_{a}hle 5 \cdot S/kW/h$	Wholesale Pricing	for GVEA	including (Control Techno	LOGV COSte
$1 a O C J. \phi K W H$	wholesale i fieling	IOI OVLA	menuumg v	control reenno	logy Costs

1 - Borough Landfill disposal cost based on 20,000 tons of ash; \$90/ton (FNSB. 2014). Interior AK Coal Ash. Pg 42.

Aurora's price of power is in competition with other power producers. If the price of power exceeds that of the competition, Aurora would not be as competitive in the energy market. Currently, GVEA will take as much power as Aurora can produce; however, it is likely that GVEA would reduce the amount of power accepted from Aurora if product prices increase above those of the competition.

4. Expected costs incurred by competitors

The FNSB nonattainment area impacts stationary sources within the area. Aurora's main competitors are power producers outside of the nonattainment area. Aurora's competition will not be required to consider BACT or MSM as a new requirement of a nonattainment area. This puts Aurora at a serious economic disadvantage. It is the only private for-profit power producer in the state being subjected to the $PM_{2.5}$ nonattainment area BACT requirements. Table 5 illustrates the price of wholesale power in $\/kWh$ from Aurora. The price of power with controls is 0.11/kWh. When additional disposal requirements are considered as a result of the use of the control technology, the price of Aurora's wholesale power to GVEA is 0.12/kWh.

Aurora's competition for power sales is primarily natural gas generated power; including Anchorage Municipal Light and Power (AMLP), Matanuska Electric Association, Inc. (MEA), and Chugach Electric Association (CEA). Aurora is also in competition with GVEA's fleet including the coal facilities (Healy #1 and Healy #2). The expected increase in price of Aurora's power due to BACT will make its power less marketable. At \$0.12/kWh, the price of Aurora's power to GVEA would exceed AMLP (\$0.09/kWh), Healy #1 (\$0.10/kWh), MEA (\$0.10/kWh), and CEA (\$0.11/kWh) based on GVEA's cost of power report in 2017⁹. Aurora currently provides 14% of GVEA's power requirements. At current prices, Aurora's power is competitive. An increase in the price of power to \$0.11/kWh or \$0.12/kWh would likely change that perspective.

5. Company Profits

Net income (loss) for Aurora over the past five years are not sufficient to absorb annual control technology costs for any of the control technologies proposed. Table 6 below includes the net income (loss) from district heating, electrical generation and the combined company income (loss) for years 2013

⁹ 2017 GVEA Annual Report to the RCA.

through 2017. Net income (loss) include income generated from district heat and power sales minus the operating costs as presented in Table 2 and include nonutility income, interest income, miscellaneous amortizations, and interest expenses.

			/
Year	Electric	District Heating	Net Income (loss)
2017	\$ 801,037.00	\$ (377,585.00)	\$ 423,452.00
2016	\$ 419,092.50	\$ (1,808,914.00)	\$ (1,389,821.50)
2015	\$ 1,094,599.25	\$ (1,059,348.00)	\$ 35,251.25
2014	\$ 321,876.05	\$ (892,950.00)	\$ (571,073.95)
2013	\$ 420,072.77	\$ (775,432.00)	\$ (355,359.23)
Average	\$ 611,335.51	\$ (982,845.80)	\$ (371,510.29)

Table 6: Aurora Energy, LLC – 5 Year Net Income (Losses)

The annual cost to operate the preferred technology is \$4,284,104 (Table 1 & 4); the average 5-year net income (loss) for Aurora is (\$371,510) [Table 6]. Conclusively, Aurora is not able to absorb the cost of additional control technologies.

The only alternative for Aurora to address annual operating expenses for any proposed control technologies would be to attempt to renegotiate the power contract to raise the price of power to GVEA. However, the rate adjustment would increase the price of Aurora's power to the extent that it would be less competitive.

6. Employment Cost

The state's calculations for annual operation costs of the proposed technologies include labor cost increases. The increases vary depending on the type of control technology. As a part of the state's analysis for SO_2 controls, annualized cost increases include the projection of additional labor for operation, maintenance, and administration.

7. Other Costs

No additional costs were considered.

ADEC has not shown that Aurora's, nor other stationary source's, SO₂ emissions are a significant contributor to the nonattainment area problem. ADEC does not know whether installation of BACT or MSM on stationary sources will significantly mitigate the impact of SO₂ on particulate concentration. Aurora cannot afford the control measure or technology that has been selected by the ADEC in the preliminary BACT analyses. The basis for this determination is that Aurora has consistently shown insufficient income to absorb the cost of the control technologies. Alternatively, increasing the price of power or heat to accommodate the cost of control technology will price Aurora's products out of the market. Any increase in district heating prices would make alternative sources of heat more attractive to consumers. The result would be a loss in business from customers switching to alternate sources of heat. This change in heating source could exacerbate pollution emissions at the ground level due to customers' use of distributed home heating alternatives. Aurora's district heating displaces the emissions from the equivalent of 2 - 2.5 million gallons of heating oil. The current power purchase agreement with GVEA allows Aurora's power to be competitive with other power sellers. The cost of additional control technology would have to be negotiated with Aurora's one customer based on its power purchase agreement and make Aurora's power prices less competitive; and subsequently, less sustainable.

3.0 Proposed Alternative BACT – District Heating

Aurora is sympathetic to the requirements of the Serious Nonattainment Area and believe that a reasonable alternative exists within the framework of what is economically feasible. As previously discussed, Aurora asserts that imposing retrofit controls, as proposed by ADEC, on its older boilers in the next four years is economically infeasible and could have negative impacts on the goals of the community to achieve attainment with the PM_{2.5} standard. As such, Aurora has developed a list of mitigating measures that are more economically sustainable and will have a direct impact on the community with respect to achieving attainment with the PM_{2.5} standard. Included as alternatives are the expansion of district heating, a wood drying kiln, and the potential use of biomass.

3.1 District Heating

Aurora is proposing that past district heat expansions as well as future district heating projects be considered as BACT for the Chena Power Plant. As it stands, Aurora's district heating displaces about 42 tons of SO₂ and 2 tons of particulates annually. District heating is referenced in both the Moderate Area State Implementation Plan (SIP)¹⁰ and the Preliminary Serious Area SIP¹¹ as a Pollution Control Measure for the FNSB NAA. As stated in the Moderate Area SIP, "An increase in the coverage of the district heating systems would therefore result in a decrease in measured PM_{2.5} concentrations". Based on modeling results, the PM_{2.5} concentration attributed to Aurora during an episode in 2008 was $0.02 \,\mu g/m^3$ and the SO₂ concentration at ground level from Aurora represents $0.75 \,\mu g/m^3$ (See Table 7).¹² The

Table 7: Summary of Six Major Fairbanks Point Source Plumes from CALPUFF for the Episode (Jan.23rd to Feb. 9th, 2008) Average Surface Concentrations at the State Office Building of PM2.5 and SO2 in ug/m3.

Power Plant	Episode	Episode	
	average	average	
	SO ₂ (μg/m ³)	PM _{2.5} (μg/m ³)	
UAF- 316	2.75	0.16	
Aurora- 315	0.75	0.02	
Zehnder-109	0.48	0.19	
Flint Hills-071	0.016	0.38	
GVEA NP-110	3.8	1.45	
Ft. WW- 1121	14	1.6	
Total surface concentration	21.8	3.8	

implication of the small pollutant contribution from Aurora at ground level is that taller stacks decrease the impact from emissions at ground level. The amount of pollutant loading at ground level within the nonattainment area is mitigated by district heating through the removal of ground level source emissions and vertically displacing them. An added benefit to increasing district heat coverage is an increase in efficiency at the plant. The plant is generally base loaded and driven to operate at a maximum capacity; there is moderate room for growth, but realistically, the plant is nearing its maximum capacity. The plant could accommodate, roughly, an additional 100 MMBtu/hour of heating capacity while still being able to provide a modest amount of electricity.

In order to quantify the impact district heating has on the nonattainment area, Aurora evaluates the potential use of fuel oil based on

¹⁰ ADEC. 2014. *Moderate Area State Implementation Plan. Appendix III.D.5.7.* pg 42.

¹¹ ADEC. 2018. Preliminary Draft, Possible Concepts and Potential Approaches for the development of the FNSB NAA Serious SIP.

¹² ADEC. 2014. Moderate Area State Implementation Plan. Section III.D.5.8-11.

a conversion from the heating load compensated by the plant for district heating. A fuel oil heating value of 137,000 btu/gal and an assumed efficiency of 85% for heating appliances are used to determine the quantity of heating oil equivalent to the district heating load. Since SO₂ and PM_{2.5} are the pollutants of most concern, Aurora is using emission rates for fuel oil using EPA's emission inventory warehouse, AP-42. Using the value of 2566 ppm sulfur in heating oil¹³, an emission rate of 36.92 lbs/10³ gallons (2.64×10^{-1} lbs/MMBtu) for SO₂ emissions and 0.4 lbs/10³ gallons (2.86×10^{-3} lbs/MMBtu) for filterable or direct PM_{2.5} and 1.3 lbs/10³ gallons (9.29×10^{-3} lbs/MMBtu) for condensable PM_{2.5} are derived. Using these emission rates, Aurora can evaluate the impact of district heating on the removal of SO₂ and PM_{2.5} from the nonattainment area.

As part of a further analysis, the SO₂ is converted to PM_{2.5} by using an ADEC derived method for comparing direct emissions of pollutants to PM_{2.5} concentration from various sources. Using this methodology, point source SO₂ emissions, wood smoke emissions, and heating oil SO₂ can be correlated to PM_{2.5} concentration. Through the use of a dispersion model, CALPUFF, ADEC determined that 22% of modeled SO₂ concentration are from point sources at ground level, 78% are from central oil, and <1% from mobile sources. Using this information and the ADEC's methodology (based on 'scenario 2'), a ratio of 5.5 tons SO2 emissions from major sources is estimated to form 1 μ g/m³ of PM_{2.5} as ammonium sulfate [8.38 TPD/(1.1 μ g/m³ x 132g/mol of ammonium sulfate/96 g/mol sulfate)]. Likewise, a ratio of 0.3 tons of wood smoke emissions is estimated to form 1 μ g/m³ of PM_{2.5}.¹⁴ Based on the same methodology, the ratio of SO₂ from fuel oil (78% of modeled concentration) to particulates is 0.8 tons of fuel oil SO₂ emissions to 1 μ g/m³ of PM_{2.5} as ammonium sulfate [4.12 TPD¹⁵/(3.9 μ g/m³ x 132g/mol of ammonium sulfate [4.12 TPD¹⁵/(3.9 μ g/m³ x 132g/mol of ammonium sulfate [4.12 trpation and that in Table 8, wood smoke produces 18 times more PM_{2.5} than the SO₂ from point sources and 2.6 times more PM_{2.5} than fuel oil.

Pollutant	Point Sources (SO ₂)	Fuel Oil (SO ₂)	Wood Smoke
Emissions (tons)	5.5	0.8	0.3
$PM_{2.5}$ Equivalent Concentration (μ g/m ³)	1	1	1

Table 8: Source pollutant emission and equivalent contribution in $\mu g/m^3$ of PM_{2.5}.

3.2 District Heat Expansion

District heating from Aurora mitigates emissions from ground level sources. The 5-year average (2013-2017) heating value of Aurora's district heat supply is 265,251 mmbtu/year. That is equivalent to about 2.3 million gallons of heating oil per year; assuming a heating value of 137,000 btu/gal and an 85% efficiency for an oil fired furnace. Using these values, district heat displaces about 42 tons of SO₂ from ground level emissions per year and 2 tons of PM_{2.5} in the down town area. Since 2008, Aurora has added district heating equivalent to 243,000 gallons of fuel oil per year. The impact of the addition is equivalent to the removal of 3510 lbs of wood smoke per year based on SO₂ reduction from fuel oil [4.5 TPY SO₂ fuel oil/0.77 tons SO2 fuel oil/1 μ g/m³ x 0.3 tons wood smoke/1 μ g/m³ x 2000 lbs/ton]. District heating records show that 67% of heating use is between November – March (151 days). The loading that

¹³ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.6. pg 102.

¹⁴ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

¹⁵ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.6. pg 27.

was mitigated since 2008 is approximately 16 lbs/day of wood smoke equivalence during the winter months.

Aurora has the mechanical potential to expand district heating another 100 mmbtu/hr of additional heating. The equivalent SO_2 removal potential would be about 24 tons per year based on the displacement of 1.3 million gallons of heating oil No.2 (fuel oil S% = 0.26).

3.3 District Heating Economics

Installation of district heating can be costly. The evaluation of DH as a control technology for the plant is difficult to assess a cost/ton comparison. Ideally, the expansion cost would be mitigated by revenue generated from the use of district heating. The business model for district heating would justify the expansion; the added benefit would be the reduction in pollutants emissions from ground level sources, and a decrease in the output based emission rate. In general, efficiency gains at the plant is a sustainable practice with the benefit of reducing pollutant emissions at ground level.

3.4 Output Based Emission

District heat expansion has the added benefit of making the plant more efficient. A method of illustrating efficiency gains with respect to pollutant emissions is in the derivation of an output based emission rate. The output based emission rate for SO_2 at the plant is approximately 4.6 lbs/MW of energy output. The emission rate is based on a conservative calculation using the 5-year weighted average coal sulfur content and converting all of it to SO_2 . The denominator consists of net power and net district heat sales in MW. When the maximum output of district heating is added to the denominator, the emission rate is reduced to 3.4 lbs/MW. This represents a 27% reduction in the emission rate per energy output.

The output based emission rate can be used to show efficiency gains with respect to pollutant emissions. Efficiency gains through the use of central heat and power facilities clearly demonstrate the advantages of minimize emission increases while maximizing energy output.

4.0 Proposed Alternative BACT - Firewood Drying Kiln

Couched within the benefits of district heating, Aurora is proposing an alternative to address its potential formation of fine particulate matter ($PM_{2.5}$) from sulfur dioxide. According to a 2008 report by the Northeast States for Coordinated Air Use Management (NESCAUM), for every 10 percentage point increase in the moisture content of wood, the $PM_{2.5}$ emissions increase by 65% to 167%. The increase in emissions is due to increased amount of wood needed to evaporate the extra moisture and poor combustion conditions leading to reduced heat transfer efficiency. Wood fuel use may double if wet wood were burned as opposed to dry wood.¹⁶ Aurora is proposing to develop and operate a firewood drying kiln using district heat from the Aurora plant to help mitigate the use of wet wood. The general idea is that, along with district heat conversions, Aurora would offset its potential $PM_{2.5}$ formation by providing dry wood to the community from a kiln. The kiln would require 3.5 mmbtu/hour of thermal loading from district heating. The initial moisture content in the wood is assumed to be around 50%; the kiln would evaporate 35% of the moisture to a wood moisture content of 15% or less. By conditioning solid fuel (fire wood) to be used in homes, district heating is effectively expanded without the cost of installation.

¹⁶ ADEC. 2014. *Moderate Area State Implementation Plan. Appendix III.D.5.7.* pg 22.
4.1 Equivalent Emissions

The state has derived a method for comparing direct emissions of pollutants to $PM_{2.5}$ concentration. Using this methodology, point source SO₂ emissions, wood smoke emissions, and heating oil SO₂ can be correlated to $PM_{2.5}$ concentration. Based on 22% of modeled SO₂ concentration from point sources at ground level, a ratio of 5.5 tons SO₂ emissions is estimated to form 1 µg/m³ of $PM_{2.5}$ as ammonium sulfate. Likewise, a ratio of 0.3 tons of wood smoke emissions is estimated to form 1 µg/m³ of $PM_{2.5}$.¹⁷ Using the fore mentioned conversions, Aurora estimated the power plants SO₂ emissions equivalent to wood smoke emission rate at Aurora of 608.3 tons/year of SO₂ (1.67 tpd), the wood smoke emission equivalent is 181 lbs/day [1.67 TPD/ (5.5 tons SO₂ from major sources/1 µg/m³) x 0.3 tons of wood smoke/1 µg/m³ x 2000 lbs/ton]. The equivalent annual wood smoke emission to 608.3 tons of SO₂ emission is proposed to be mitigated through drying wood by reducing 35% moisture from cord wood.

Source of Emissions	SO ₂ Emissions (tpd)	SO ₂ /PM _{2.5} (tpd)/(µg/m ³)	Wood Smoke/PM _{2.5} (tpd)/(µg/m ³)	Wood Smoke Equivalent (lbs/day)
Aurora Energy	1.67	5.5	0.3	181
Displaced Heating Oil Use - DH	0.01	0.8	0.3	10

Table 9: SO2 Conversion to Wood Smoke Equivalent Emission

The emission reduction for $PM_{2.5}$ in lbs/MMBtu was derived using the ADEC's referenced information within the Appendices of the Moderate Area State Implementation Plan (See Tables 10 & 11). The average emission rate for wood burning devices at 50% moisture (1.14 lbs/MMBtu) was subtracted from the average emission rate for wood burning devices at 15% moisture (0.67 lbs/MMBtu). The equivalent amount of cords needed to account for 100% of Aurora's annual SO₂ emissions is 8,495 cords per year.

Table 10. Emission raciors based on wood moisture content	Table	10:	Emission	Factors	based	on	wood	moisture	content
---	-------	-----	----------	---------	-------	----	------	----------	---------

Wood Burning Devices	EF PM2.5 lbs/ton ¹	Btu/lb ²	lbs/MMBtu	Btu/lb ²	lbs/MMBtu	Btu/lb ²	lbs/MMBtu
Moisture content (%)		0		15		50	
non-EPA certified Wood Stoves	11.6	8,119	7.14E-01	6,901	8.40E-01	4,060	1.43E+00
EPA Wood stove non-catalytic	7.57	8,119	4.66E-01	6,901	5.48E-01	4,060	9.32E-01
EPA Wood stove catalytic	8.4	8,119	5.17E-01	6,901	6.09E-01	4,060	1.03E+00
Hydronic Heater weighted 80/20 (OWB unqualified/OWB-Ph2)	9.43	8,119	5.81E-01	6,901	6.83E-01	4,060	1.16E+00
Average emission factor	9.25	8,119	5.70E-01	6,901	6.70E-01	4,060	1.14E+00
Note: 1 - Appendix III.D.5.6-105, Table 5.6-40; 2 - Appendix III.D.5	.6-86, Table 5.6-31						

¹⁷ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

Table 11: Calculation to determine how much kiln dried wood is necessary to mitigate AE's SO_2 emissions.

PM 2.5 Daily Emissions Reduction [Scenario 2] (lbs/day)	181
PM 2.5 Annual Emissions Reduction (lbs/year)	66,003
Spruce weight at 20% moisture	2,550
Dry Wood (%) moisture	15
Wet Wood (%) moisture	50
Emission Diff. wet vs. dry (lbs/MMBtu)	4.69E-01
Daily Wood processing minimum (MMBtu/year)	140,695
Cords per year	8,495
cords/load	42
Loads per year	202

4.2 Firewood Kiln Economics

The capital cost and annualized cost of the kiln is much less than that of the other BACT alternatives. The cost effectiveness is determined by a % cost ratio based on drying wood at a maximum potential of 8,495 cords of wood to reduce, effectively, 608.3 tons per year of SO₂-equivalent emission. The annualized cost is used to derive the cost effectiveness ratio of \$980 per ton of pollutant removed.

Table 12: Cost Effectiveness of Kiln

Control Technology	PM 2.5 Reduction (tpy)	Equivalent SO2 Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annual Cost (\$/year)	Cost Effectiveness (\$/ton SO ₂)
Wood Kiln	32.5	608.3	\$ 1,500,000	\$ 736,078	\$ 980

Unlike a traditional BACT approach, the effective emission reduction is hinged on the marketability of dry wood. Aurora plans to market the kiln dried wood as a benefit from a performance and air quality standpoint. The Fairbanks Northstar Borough, ADEC and EPA all have an important role in enforcing the use of dry wood for home heating the NAA.

5.0 Proposed Alternative BACT - Biomass Co-Firing

Aurora's boilers are subject to 40 CFR 63 subpart JJJJJJ. Under the rule, the Chena Power Plant (CPP) boiler units are classified as coal-fired boilers. The definition of coal-fired boiler subcategory extends to coal boilers that burn up to 15% biomass on a total fuel annual heat input basis. This flexibility in definition would allow Aurora to burn up to 15% biomass and still retain its classification as a coal-fired boiler. Aurora has been involved in a projects with Alaska Center for Energy and Power (ACEP) and the US Forestry Service using biomass (wood chips and refuse) as a substitute for coal. The projects did not demonstrate much of a change to the current operations; however, the material used had a significant amount of moisture (40%) and was not uniform. Sizing of the material was an issue and created problems. Biomass refuse and chips were not appropriately sized and created issues with material feeding through the auxiliary coal feed system. Also, due to density differences, material segregation within the bunkers occurred; wood chips tended to be pushed to the top of the coal. Ultimately, the lessons learned from the project were that with the right material sizing and processing, biomass could be used in the boilers to

help increase efficiency. As noted by operators during the project, the biomass burned off quickly leaving holes within the coal bed which allowed for air pockets which qualitatively made coal combustion more effective. The theory is that air voids left after the biomass was burned off facilitated greater air-to-fuel contact. Also, the rapid burning of the biomass may have increased the heat of the coal bed which helped coal combustion. Although this theory has not been vetted though rigorous research, the potential benefits of using biomass within the process may be substantial. At the very least, biomass has very little sulfur and could be a measure to mitigate the emissions of SO_2 from the plant.

The material used during the biomass project at Aurora was unprocessed and, consequently, not uniform. If the biomass material was processed and met some consistency standards there could be a significant measurable gain in efficiency. As such, processed biomass in the form of industrial grade pellets can provide a consistent sizing which would be compatible with the sizing of the stoker coal used at the Chena Power Plant (CPP). The benefit of using an industrial grade pellet is that the anticipated heat content of the pellets are assumed to be upwards of 8300 btu/lb, the moisture content is near 0%, and there is very little sulfur in the fuel. The cons of using an industrial grade biomass pellet is the cost of the fuel which could be as high as \$295/ton. At this cost, the use of biomass is not economical. Furthermore, Aurora has not determined whether or not enough raw timber supply is available around the Fairbanks area to accommodate a consistent 15% blend rate. However, if waste biomass material, such as sawdust or bark, from local wood sellers were processed into pellets the raw material could be acquired at a low cost.

5.1 Biomass Economics

Biomass pellets, due to their lack of sulfur, could be used as mitigation for SO₂ emissions. As stated above, the negative aspect of pellets is in the cost and potential lack of access to raw material supply. In order to derive a price point for pellets that would be acceptable as a control technology, a cost

Table 13: Biomass and Coal Fuel Revenue/MMBtu					
hhv pellets btu/lb	8,300				
hhv pellets mmbtu/ton	16.6				
hhv coal btu/lb	7,613.05				
coal moisture	29%				
heat of vaporization of water @ 77F btu/lb	1,049.70				
coal btu/lb -vaporized free water	7,304				
coal mmbtu/ton -vaporized free water	14.6				
pellet coal equivalent	1.14				
revenue/ton of coal	\$ 79.09				
revenue/mmbtu of coal	\$ 5.41				
revenue/mmbtu of pellets	\$ 4.76				

effectiveness value of 3.125/ton SO₂ removed is used as a reference. This is a conservative estimate derived by the state in the moderate area SIP.¹⁸ If the 5-year average revenue generated by the plant is divided by the 5year average coal use we get a value of \$79.09 revenue/ton of coal. Pellets have a higher btu/lb content than the coal and pellets have no moisture. To account for this discrepancy, coal heating value is

considered after the evaporation of moisture. The energy needed to vaporize free moisture ($h_{vap} = 1049$ btu/lb @ 77F) is multiplied by the moisture fraction of coal to derive the heat content of the coal at 0% moisture. When comparing the wood pellets to coal, the 5-year average heat content (7623 btu/lb) and moisture (29%) is considered. The heating value of coal without moisture is 7304 btu/lb (7623 btu/lb –

¹⁸ ADEC. 2014. Moderate Area State Implementation Plan. Appendix III.D.5.7. pg 132.

1049.7*29/100). Pellets would	Table 14: Biomass Cost Effectiveness Calcul	ation
have a heating content of 8300 btu/lb and no moisture. If the price of the pellets were	capital investment (hopper modification to auxillary coal feed system)	\$300,000.00
\$84/ton, the cost effectiveness	loan period (years)	\$5.00
value would be \$3,093.04/ton	interest rate (%)	8%
SO ₂ removed.	monthly loan amount	\$6,082.92
The emission reduction	Annual loan amount	\$72,995.04
potential using pellets at 15%	Burden for 0.5 man equivalent (2016)	\$65,520
total fuel loading is 91.24 tons	5-year avg Annual Coal (tons)	221,758.29
of SO_2 per year. Aurora is	5-year avg coal sulfur (%)	0.14%
actively pursuing this concept;	potential max SO2 (tons/yr)	608.24
however, running the boiler	Annual pellets (%)	15%
with 15% biomass has not	Annual pellets (tons)	29,272.22
been tested and a supply of industrial wood pellets at the	emission reduction (tons/yr)	91.24
preferred price has not been	Cost pellets (\$/ton)	\$84.00
identified nor has the	Annual cost	\$2,597,381.16
availability of the raw material	Annual revenue	\$2,315,186.17
supply been verified.	annual burden of pellets	\$282,194.99
	cost/ton removed	3,093.04

6.0 Proposed Alternative BACT – Reduction in Potential to Emit

Aurora proposes to monitor the stack gas emissions out of the common stack. The purpose of the monitoring would be to ensure compliance with an SO_2 emission rate of 190 ppm. Instead of taking a reduction in the sulfur content of the coal or PTE for SO_2 emissions, monitoring the stack gas emissions and maintaining a rolling 30-day average at or under 190 ppm ensures that the plant is not exceeding a certain loading rate equal to 0.25% coal sulfur content. Using the SO_2 emission calculation in the Air Quality Operating permit AQ0315TVP03 Rev. 1, Condition 22.1.c; a stack gas concentration of 7.5% O_2 ; and adjusting the S% to 0.25 (in this ultimate analysis the S% is 0.26), the SO_2 concentration is 188 ppm as illustrated below:

Figure 1: SO ₂	emission	calculation
---------------------------	----------	-------------

SO2 Concentration P	PPM = (1.00X 10^6 xmol ₅₀₂)/(mo	l _{so2} +mol _{co2} +mol _{o2} +mol _N	2)			
SO2 PPM =						
Where:						
mol SO2 =	[wt% Sfuel,%]/32.06					
mol CO2 =	[wt%Cfuel,%]/12.01					
mol O2 =	MF x [(wt%Nfuel,%]/28.01)+	(4.76xmolCO2)+(4.76xmc	ISO2)+(1.88xmoIH2O)-(3.76x[wt%Ofuel,%]/3	32.00)]		
MF =	[vol%O2,exhaust,%]/(100%-	4.76x[vol%O2, exhaust, %	6])			
mol H2O =	[wt%Hfuel,%]/2.016					
mol N2 =	([wt%Nfuel,%]/28.01)+(3.76	xmolSO2)+(3.76xmolCO2)	+(1.88xmolH2O)+(3.76xmolO2)-([wt% Ofuel	,%]/8.51)		
Constituent	mols in flue gas		Ultimate/proximate analysis (AE08162018)	%weight (dry)	Atomic Mass	Atomic Mass
mol _{so2}	0.007796663		wt% Sulfur _{fuel} , %	0.25	Sulphur	32.065
mol _{co2}	5.219382233		wt% Carbon _{fuel} , %	62.69	Carbon	12.011
mol _{H20}	2.277011608		wt% Hydrogen _{fuel} , %	4.59	Hydrogen	1.0079
moloz	3.098516312		wt% Nitrogenfuel, %	0.93	Nitrogen	14.007
mol _{N2}	33.05690137		wt% Oxygen _{fuel} , %	21.8	Oxygen	15.999
MF	0.116640747			%vol		
			Oxygen exhaust %	7.5		
SO ₂ Concentration	188.404394		Source Test Required if exhaust SO ₂ Concer	tration is greate	er than 500 pp	m m

As mentioned, 190 ppm of SO2 emissions on a 30-day rolling average represents an overall PTE reduction from 0.4% sulfur content to 0.25% while still allowing flexibility with respect to coal quality exceeding 0.25% sulfur.

7.0 Precursor Demonstration

As part of the Serious SIP development, states are required to develop Best Available Control Measures for all source sectors that emit PM_{2.5} and the four major precursor gases (e.g., NOx, SO₂, NH₄, and VOC). The analysis specific to the major stationary source is a Best Available Control Technology analysis. Within the rule, if the state determines through a precursor demonstration that controls for a precursor gas are not needed for attaining the standard, then the controls for a precursor gas are not required to be implemented.¹⁹ The regulations provide for three kinds of precursor analyses, comprehensive (which consider precursor emissions from all sources in the nonattainment area), Major stationary source (which consider precursor emissions from major sources), and Nonattainment New Source Review (which considers potential precursor emissions from new sources).²⁰ For each of the first two analyses, there are two varieties available to the state: a concentration-based analysis (compares the precursor contributions to a numerical threshold) and a sensitivity-based analysis which consider other factors to evaluate if reductions in the precursor emissions would significantly reduce PM_{2.5} levels in a nonattainment area.

The ADEC has successfully demonstrated that oxides of nitrogen NOx and VOC are not a significant precursors to the area. The NOx precursor demonstrations included a comprehensive demonstration with a sensitivity based analysis for the community and a Major Stationary Source – concentration based analysis which demonstrated that major sources are not a significant contributor to the nitrate-based particulate formation.²¹ The state also conducted a comprehensive, concentration-based analysis for SO₂ and concluded that SO₂ emissions in the NAA contribute 5.4 µg/m³ in the Fairbanks area and 4.9 µg/m³ of PM_{2.5} in the North Pole area. Since these concentrations exceed the significance threshold of 1.3 µg/m³ (now 1.5 µg/m³)²², the ADEC proposes not to conduct a sensitivity-based precursor demonstration nor are they considering a major source precursor demonstration.

EPA's draft precursor guidance recognizes that the significance of a precursors contribution is determined based on the facts and circumstances of the area which include source characteristics such as source type, stack height, and location.²³ The rationale for doing a precursor demonstration fits with the site-specific factors listed in the EPA guidance, namely tall stacks. However, the ADEC and EPA have been resistant to performing or further considering a Major Source precursor demonstration.

Aurora sought a third party opinion (Ramboll Environmental) regarding the possibility of a successful SO_2 precursor demonstration that could demonstrate that major stationary sources are an insignificant part of the contribution to the nonattainment area. According with the EPA's precursor demonstration guidelines, a successful major stationary source precursor demonstration must show that SO_2 emissions do not contribute significantly to violations of the PM_{2.5} standard (1.5 µg/m³). If the 'contribution-based'

¹⁹ ADEC. 2018. Preliminary Draft Precursor Demonstration.

²⁰ See 40 C.F.R. § 51.1006

²¹ ADEC. 2018. Preliminary Draft Precursor Demonstration.

²² Draft EPA (2016b) guidance recommended 1.3 μ g/m³ for the PM_{2.5} 24-hour NAAQS as the appropriate threshold to identify insignificant contributions to PM_{2.5} concentrations. A more recent updated technical basis document, EPA (2018) now recommends a threshold for identifying significance of 1.5 μ g/m³.

²³ EPA's 2016 Draft PM_{2.5} Precursor Demonstration Guidance.

analysis indicates that the impact exceeds $1.5 \ \mu g/m^3$, then a 'sensitivity-based' analysis may be conducted to show that a reduction of SO₂ emissions in the range of 30-70% would have only an insignificant impact on lowering PM_{2.5}.

Two main hurdles exist to conducting a credible SO_2 precursor demonstration; 1) the large contribution of sulfate by major and minor source contribution to the nonattainment area; and 2) the large under prediction of sulfate mass through the model (CMAQ). In essence, while the SO_2 sources are observed to contribute significantly to the $PM_{2.5}$ nonattainment area, current modeling systems are not sufficiently accurate to provide a reliable estimate of the impacts of emission reductions from SO_2 .

Utilizing the ADEC's information within the Moderate Area SIP, Aurora's third party consult suggests that there is relevant data to suggest major sources are potentially insignificant contributors to the NAA.

"...data analyses and modeling conducted for the Fairbanks moderate area SIP provide some significant information which suggests that in fact major source SO_2 emissions may not contribute significantly to $PM_{2.5}$ nonattainment."²⁴

As such, a Major Source SO₂ precursor demonstration must be pursued by the ADEC. It is an undue burden for Aurora and other major sources within the NAA subject to the requirements of control measures (BACT, and more likely MSM) considering that there is data to suggest that major sources could be insignificant. Even though updating models and research into the chemistry of sulfate particulate formation is costly and time consuming, it is due diligence on the agencies part to further elucidate the impact of major sources. Ultimately, Aurora will continue to pursue alternative control measures as proposed within this document under the assumption that the agencies (ADEC and EPA) will continue to vet the sulfate contribution disparity between model and observed values with the perspective of major stationary source contribution.

8.0 Conclusion

The proposed BACT alternatives in this document and accompanying information demonstrate that the ADEC proposed BACT are economically infeasible and do very little to solve the air quality problem in the nonattainment area. EPA, the State of Alaska, as well as the local community understand and agree that the majority of the PM_{2.5} problem in the area is from home heating sources. Aurora contends that requiring the implementation of the ADEC proposed BACT controls would cause the pollution problem to worsen due to our district heat customer's refusal to accept a higher cost heating product and instead switching to fuel oil, or wood burning.

Aurora does not believe ADEC has demonstrated that the point sources, or more specifically Aurora, are contributing to the $PM_{2.5}$ problem in a significant enough way to warrant the need for additional control measures. Aurora believes that a precursor demonstration would prove this assertion one way or another. Aurora believes a precursor demonstration is possible and requests that ADEC and the EPA move forward with conducting a precursor demonstration in parallel with the implementation of the SIP. Should a precursor demonstration show that the point sources do not cross over the significance threshold, all point sources should be released from further compliance with the $PM_{2.5}$ requirements.

Even though Aurora is not convinced that major source emissions exceed the significance threshold for $PM_{2.5}$ within the NAA, Aurora is interested in being a part of the solution to reduce $PM_{2.5}$. Aurora's

²⁴ Memo. Ramboll. "Summary of issues related to SO₂ precursor demonstration for Fairbanks".2018.

proposed alternative BACT controls are more effective from an environmental perspective and cost substantially less than the ADEC proposed BACT controls. The table below shows the potential amount of SO_2 and $PM_{2.5}$ removed from the NAA by Aurora's proposed alternative BACT.

Emissions	SO2 (tpy)	PM 2.5 (tpy)	Qualifying Parameters
District Heating	42 tpy at	2 tons at	250,000 - 300,000
(Current Operating Conditions)	ground level	ground level	mmbtu per year
District Heating	24 tpy at	1 ton at	100 mmbtu/hr expansion
(Potential Expansion)	ground level	ground level	potential
Wood Kiln	608.3tpy	33 tons at ground level	8495 cords/yr
Biomass Co-Firing	91.2 tpy		15% by fuel heat input from industrial pellets
Potential to emit reduction	38% reduction in PTE (854 tpy)		State upper limit of 500 ppm over 3 hours. Proposed 190 ppm as a new PTE
Total Potential Reduction	1,619.5 tpy	36 tpy	

Table 15: Summary of BACT Alternatives and Potential Emission Reduction

As clearly shown in this table, the environmental benefits from Aurora's proposed alternative BACTs will positively impact the current NAA. Aurora is prepared to move forward with implementing these alternative BACTs as soon as ADEC is able to provide Aurora with the assurance that additional control measures or fees will not be required in order to demonstrate compliance with the PM2.5 regulations for the NAA.

Aurora is committed to continuing to work with ADEC, EPA and the local community in working toward meaningful solutions to the air quality problem in Interior Alaska.

Appendix A (Economic Analysis Spreadsheets – V1)

Air Pollution Control Cost Estimation Spreadsheet

For Selective Catalytic Reduction (SCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Catalytic Reduction (SCR) control device. SCR is a post-combustion control technology for reducing NO_x emissions that employs a metal-based catalyst and an ammonia-based reducing reagent (urea or ammonia). The reagent reacts selectively with the flue gas NO_x within a specific temperature range to produce N₂ and water vapor.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SCR control technology and the cost methodologies, see Section 4, Chapter 2 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM) (version 5.13). The size and costs of the SCR are based primarily on five parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, reagent consumption rate, and catalyst costs. The equations for utility boilers are identical to those used in the IPM. However, the equations for industrial boilers were developed based on the IPM equations for utility boilers. This approach provides study-level estimates (±30%) of SCR capital and annual costs. Default data in the spreadsheet is taken from the SCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/powersector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will clear many of the input cells and reset others to default values.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SCR is for new construction or retofit of an existing boiler. If the SCR will be installed on an existing boiler, enter a retrofit factor between 0.8 and 1.5. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you select fuel oil or natural gas, the HHV and NPHR fields will be prepopulated with default values. If you select coal, then you must complete the coal input box by first selecting the type of coal burned from the drop down menu. The weight percent sulfur content, HHV, and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided. Method 1 is pre-selected as the default method for calculating the catalyst replacement cost. For coal-fired units, you choose either method 1 or method 2 for calculating the catalyst replacement cost.

Step 4: Complete all of the cells highlighted in yellow. If you do not know the catalyst volume (Vol catalyst) or flue gas flow rate (Q_{flue gas}), please enter "UNK" and these values will be calculated for you. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.005 and 0.03, respectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SCR.

Adopted

November 19, 2019

		Data Ir	nputs			
Enter the following data for your combustion unit:						
Is the combustion unit a utility or industrial boiler?	al 🔻		What type of fu	el does the unit burn?	Coal 💌	
Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit	•					
Please enter a retrofit factor between 0.8 and 1.5 based on the level of diffic projects of average retrofit difficulty.	ulty. Enter 1 for	1.5	Simpson, Aaron: No basis was provided ap for installation of select	to justify a retrofit factor r tive catalytic reduction on	eflecting greater than average the boilers.	difficulty
Complete all of the highlighted data fields:			High retrofit cost facto unique ductwork and additional engineering	rs may be justified in unus piping, site preparation, tig , and asbestos abatement)	ual circumstances (e.g., long an ht fits, helicopter or crane insta	nd Ilation,
What is the rating at full load capacity (MMBtu/hr)?	497 M	IMBtu/hr	Aurora: Location of th 500-800F, would be t It's a titght fit, limited	ne catalyst, if it has to be in he top of the boilers just be space, asbestos abatemen	nstalled within a temperature ra efore the economizer and air pr t necessary, duct work is compl	nge of eheater. ex and
What is the higher heating value (HHV) of the fuel?	7,560 Bi	tu/lb	Enter the sulfur	content (%S) =	0.20 percent by weigh	nt
What is the estimated actual annual fuel consumption?	569 114 000 lb	pical Gross As Received. http: //www.sci.com/com/com/com/com/com/com/com/com/com/	://www.usibelli.com/coal/c	data-sheet	Simpson, Aaron Typical Gross As	n: Received. http://www.usibelli.com/coal/data-sheet
			For units burnin Note: T for thes the def	g coal blends: he table below is pre-po e parameters in the tabl ault values provided.	pulated with default values le below. If the actual value	for HHV and %S. Please enter the actual values for any parameter is not known, you may use
Enter the net plant neat input rate (NPHK)	18 M	IMBtu/MW	J	Fr	action in	11107 (Dec. (Ib)
If the NPHR is not known, use the default NPHR value:	Fuel Type Di Coal 10 Fuel Oil 11 Natural Gas 8.	efault NPHR D MMBtu/MW 1 MMBtu/MW 2 MMBtu/MW	SL Please of values t	Bituminous Jb-Bituminous Lignite	0 2.35 1 0.2 0 0.91 n to calculate weighted table above	11,844 7,560 6,534
Plant Elevation	450 Fe	eet above sea level	For coal-fired t the catalyst re rows 85 and 86 method:	poilers, you may use ei placement cost. The e 5 on the Cost Estimate	ther Method 1 or Method quations for both method tab. Please select your pr	2 to calculate s are shown on eferred OMethod 1 OMethod 2 ONot applicable
Enter the following design parameters for the proposed SCR		/a: •	1		- chamber (r.)	
Number of days the balles operates (t_{SCR})	365 da	Assuming baselin New Source Performance	n: ie of 0.5 lb/MMBtu from ormance Standards,	Number of satalyst la	r chambers (n _{scr})	1
Inlet NO. Emissions (NOx.) to SCR	365 d	Subpart Da – Teo Proposed Revisio	chnical Support for ns to NOx Standard, U.S.	Number of empty cata	alust lavers (R)	3
NOx Removal Efficiency (EF) provided by vendor	0.37 lb	/MMBtu Standards, EPA-4	53/R-94-012, June 1997.	Ammonia Slip (Slip) pr	ovided by vendor	10 ppm
Stoichiometric Ratio Factor (SRF)	80 pe	Aurora: Emission 2011 source testi	n Inventory rate based or	Volume of the catalyst	layers (Vol _{catalyst})	Simpson, Aaron:
*The SRF value of 0.525 is a default value. User should enter actual value, if known.	0.525			(Enter "UNK" if value i Flue gas flow rate (Q _{flu}	s not known) _{iegas})	UNK Carbic feet Aurora: Source Test dsc
E E C	PA's Air Pollution Control T pontrol. https://www3.epa.g	echnology Fact Sheet indicati gov/ttncatc1/dir1/fscr.pdf	ng 70 - 90 percent	(Enter "UNK" if value i	s not known)	179,783.2 acfm = 162098.5. 162098.5 dscf/(1-Bws) = acfm; Bws = 0.0984.
Estimated operating life of the catalyst $({\rm H}_{\rm catalyst})$	24,000 ho	Durs				Simpson, Aaron:
Estimated SCR equipment life * For industrial boilers, the twical equipment life is between 20 and 25 years	30 Ye	ears*	J	Gas temperature at th	e SCR inlet (T) umetric flow rate factor	310 °F April 7, 2016 Source Test
, on synthesis equipment are to between 20 and 23 years.			1	(Q _{fuel})		516 ft ³ /min-MMBtu/hour
Concentration of reagent as stored (C _{stored}) Density of reagent as stored (0,)	50 pe	ercent*	*The reagent concentration default values for urea read	n of 50% and density of 71 lbs gent. User should enter actual	/cft are values for	
Number of days reagent is stored (t _{avora})	71 lb 30 da	ycubic feet*	reagent, if different from th	e default values provided.	Densities of typic	cal SCR reagents:
r zitu siter		,-	1		50% urea solutio 29.4% aqueous N	n 71 lbs/ft ³ H ₃ 56 lbs/ft ³
Select the reagent used Urea	•				19% aqueous NH	1 ₃ 58 lbs/ft°
Enter the cost data for the proposed SCR:						
Desired dollar-year	2016]		
CEPCI for 2016	536.4 Er	nter the CEPCI value for 20	16 584.6 2012 CE	EPCI CEP	CI = Chemical Engineering P	ant Cost Index
Annual Interest Rate (i)	5.25 Pe	ercent			5 6.	
Reagent (Cost _{reag})	1.62 \$/	gallon for a 50 percent sol	ution of urea			
Electricity (Cost _{elect})	0.210 \$/	/kWh GVEA rates. http://	www.gvea.com/rates/rate	s		
Catalyst cost (CC _{replace})	160.00 ca	atalyst and installation of n	ew catalyst*	* \$1	60/cf is a default value for the cat	alyst cost. User should enter actual value, if known.
Operator Labor Rate	63.00 \$/	/hour (including benefits)				

Adopted

November 19, 2019

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Operator Hours/Day

4.00 hours/day*

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:	
Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

Data Sources for Default Values Used in Calculations

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source
Reagent Cost (\$/gallon)	1.62	Based on the average of vendor quotes from 2011 - 2013.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for utilities is based on 2014 electricity production cost data for fossil-fuel plants compiled by the U.S. Energy Information (EIA). Available at http://www.eia.gov/tools/faqs/faq.cfm?id=19&t=3.	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Percent sulfur content for Coal (% weight)	0.31	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Higher Heating Value (HHV) (Btu/lb)	8,730	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Catalyst Cost (\$/cubic foot)	160	Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emissions Control Technologies", July 2013.	

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q _B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour]
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tscr/tplant) =	0.99	fraction	
Total operating time for the SCR (t_{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(NOxin- NOxout)/NOxin =	80.0	percent	
NOx removed per hour =	$NOx_{in} x EF x Q_B =$	147.11	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	636.77	tons/year	
NOx removal factor (NRF) =	EF/80	1.00		
Volumetric flue gas flow rate (q _{flue gas}) =	Q _{fuel} x QB x (460 + T)/(460 + 700)n _{scr}	179,783	acfm	
Space velocity (V _{space}) =	q _{flue gas} /Vol _{catalyst}	30.03	/hour	
Residence Time	1/V _{space}	0.03	hour	
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not applicable;
Atmospheric pressure at sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	does not apply to plants located at
Retrofit Factor (RF)	Retrofit to existing boiler	1.50		elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Adopted

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)(1/((1+ interest rate) ^Y -1), where Y =	0.245	Franklar
	H _{catalyts} /(t _{SCR} x 24 hours) rounded to the hearest integer	0.316	Fraction
Catalyst volume (Vol _{catalyst}) =	2.81 x Q _B x EF _{adj} x Slipadj x Noxadj x Sadj x (Tadj/Nscr)	5,986.26	Cubic feet
Cross sectional area of the catalyst (A _{catalyst}) =	q _{flue gas} /(16ft/sec x 60 sec/min)	187	ft²
Height of each catalyst layer (H _{layer}) =	$(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$	12	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A _{SCR}) =	1.15 x A _{catalyst}	215	ft ²
Reactor length and width dimentions for a square	()0.5	14.7	foot
reactor =	(A _{SCR})	14.7	
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	84	feet

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole
		Density =	71 lb/ft ³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	(NOx _{in} x Q _B x EF x SFR x MW _R)/MW _{NOx} =	101	lb/hour
Reagent Usage Rate (m _{sol}) =	m _{reagent} /Csol =	202	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	21	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x t _{storage} x 24)/Reagent Density =	15,296	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n}-1=$	0.0669
	Where n = Equipment Life and i= Interest Rate	

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	A x 1,000 x 0.0056 x (CoalF x HRF) ^{0.43} =	365.95	kW
	where $A = (0.1 \times QB)$ for industrial boilers.		

Cost Estimate

Total Capital Investment (TCI)

TCI for Coal-Fired Boilers					
For Coal-Fired Boilers:	For Coal-Fired Boilers:				
	TCI = 1.3 x (SCR _{cost} + RPC + APHC + BPC)				
Capital costs for the SCR (SCR _{cost}) =	\$14,132,761	in 2016 dollars			
Reagent Preparation Cost (RPC) =	\$2,348,710	in 2016 dollars			
Air Pre-Heater Costs (APHC)* =	\$0	in 2016 dollars			
Balance of Plant Costs (BPC) =	\$3,333,099	in 2016 dollars			
Total Capital Investment (TCI) =	\$25,758,941	in 2016 dollars			
* Not applicable - This factor applies only to coal-fired boilers that burn bitumino	us coal and emits equal to or greater than 3lb/MMBtu of sulfur die	oxide.			
SCR Capital Costs (SCR _{cost})					

For Coal-Fired Industrial Boilers >250 MMBtu/hour:

For Coal-Fired Utility Boilers >25 MW:

 $SCR_{cost} = 270,000 \times (NRF)^{0.2} \times (0.1 \times Q_B \times CoalF)^{0.92} \times ELEVF \times RF$

 $SCR_{cost} = 270,000 \text{ x} (NRF)^{0.2} \text{ x} (B_{MW} \text{ x HRF x CoalF})^{0.92} \text{ x ELEVF x RF}$

SCR Capital Costs (SCR_{cost}) =

\$14,132,761 in 2016 dollars

	Reagent Preparation Costs (RPC)	
For Coal-Fired Utility Boilers >25 MW:		
	RPC = 490,000 x (NOx _{in} x B _{MW} x NPHR x EF) ^{0.25} x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	RPC = 490,000 x (NOx _{in} x Q _B x EF) ^{0.25} x RF	
Reagent Preparation Costs (RPC) =		\$2,348,710 in 2016 dollars
	Air Pre-Heater Costs (APHC)*	
For Coal-Fired Utility Boilers >25MW:		
	APHC = 69,000 x $(B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	APHC = 69,000 x (0.1 x Q_8 x CoalF) ^{0.78} x AHF x RF	
Air Pre-Heater Costs (APH _{cost}) =		\$0 in 2016 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BPC)	
For Coal-Fired Utility Boilers >25MW:	
$BPC = 460,000 \times (B_{MW} \times HRF \times CoalF)^{0.42} \times ELEVF \times RF$	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:	
BPC = $460,000 \times (0.1 \times Q_B \times CoalF)^{0.42}$ ELEVF x RF	
Balance of Plant Costs (BOP _{cost}) =	\$3,333,099 in 2016 dollars

Annual Costs

Total Annual Cost (TAC) TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$1,193,040 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$1,728,014 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$2,921,054 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)

Annual Maintenance Cost =	0.005 x TCI =	\$128,795 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$297,936 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t _{op} =	\$665,284 in 2016 dollars
Annual Catalyst Replacement Cost =		\$101,026 in 2016 dollars
For coal-fired boilers, the following method Method 1 (for all fuel types): Method 2 (for coal-fired utility boilers):	Is may be used to calcuate the catalyst replacement cost. n _{scr} x Vol _{cat} x (CC _{replace} /R _{layer}) x FWF B _{MW} x 0.4 x (CoalF) ^{2.9} x (NRF) ^{0.71} x (CC _{replace}) x 35.3	* Calculation Method 1 selected.
Direct Annual Cost =		\$1,193,040 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$4,305 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$1,723,709 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,728,014 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$2,921,054 per year in 2016 dollars
NOx Removed =	637 tons/year
Cost Effectiveness =	\$4,587 per ton of NOx removed in 2016 dollars

Air Pollution Control Cost Estimation Spreadsheet For Selective Non-Catalytic Reduction (SNCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Non-Catalytic Reduction (SNCR) control device. SNCR is a post-combustion control technology for reducing NOx emissions by injecting an ammonia-base reagent (urea or ammonia) into the furnace at a location where the temperature is in the appropriate range for ammonia radicals to react with NOx to form nitrogen and water.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SNCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SNCR control technology and the cost methodologoies, see Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SNCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM). The size and costs of the SNCR are based primarily on four parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, and the reagent consumption. This approach provides study-level estimates (±30%) of SNCR capital and annual costs. Default data in the spreadsheet is taken from the SNCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions, such as the boiler configuration and fuel type. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/power-sector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will reset the NSR, plant elevation, estimated equipment life, desired dollar year, cost index (to match desired dollar year), annual interest rate, unit costs for fuel, electricity, reagent, water and ash disposal, and the cost factors for maintenance cost and administrative charges. All other data entry fields will be blank.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SNCR is for new construction or retofit of an existing boiler. If the SNCR will be installed on an existing boiler, enter a retrofit factor equal to or greater than 0.84. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you selected coal, select the type of coal burned from the drop down menu. The NOx emissions rate, weight percent coal ash and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided.

Step 4: Complete all of the cells highlighted in yellow. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.015 and 0.03, repectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SNCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SNCR.

Adopted

November 19, 2019

Data Inputs			
Enter the following data for your combustion unit:			
Is the combustion unit a utility or industrial boiler? Is the SCR for a new boiler or retrofit of an existing boiler?	Industrial V	What type of fuel does the unit burn?	•
Please enter a retrofit factor equal to or greater than 0.84 based on the difficulty. Enter 1 for projects of average retrofit difficulty.	he level of 1.5	* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.	
Complete all of the highlighted data fields:			
		Provide the following information for coal-fired boilers:	
What is the maximum heat input rate (QB)?	497 MMBtu/hr	Type of coal burned: Sub-Bituminous	•
What is the higher heating value (HHV) of the fuel?	7,560 Btu/lb	Enter the sulfur content (%S) = 0.20 per	cent by weight
		or Select the appropriate SO ₂ emission rate:	t Applicable 🔻
What is the estimated actual annual fuel consumption?	569,114,000 lbs/year		
		Ash content (%Ash): 7 per	cent by weight
Is the boiler a fluid-bed boiler?	No		
Enter the net plant heat input rate (NPHR) If the NPHR is not known, use the default NPHR value:	IB MMBtu/MW Fuel Type Default NPHR Coal 10 MMBtu/MW Fuel Oil 11 MMBtu/MW Natural Gas 8.2 MMBtu/MW	Note: The table below is pre-populated with deenter the actual values for these parameters in parameter is not known, you may use the defauter	Second State Fuel Cost %S %Ash HHV (Btu/lb) Fuel Cost %S %Ash HHV (Btu/lb) (\$/MMBtu) 2.35 10.4 11.814 2.79 0.2 7 7.560 2.79 0.91 14.3 6,534 1.85
Enter the following design parameters for the propose			
enter the following design parameters for the proposed	SNCK.	¬	
Number of days the SNCR operates $(t_{\scriptscriptstyle SNCR})$	365 days	Plant Elevation 450 Fee	t above sea level
Inlet NO _x Emissions (NOx _{in}) to SNCR	0.37 lb/MMBtu		
NOx Removal Efficiency (EF) provided by vendor (Enter "UNK" if value is not known)	40 percent		
Estimated Normalized Stoichiometric Ratio (NSR)	1.05	*The NSR value of 1.05 is a default value. User should enter ac	tual value, if known.
Concentration of reagent as stored (C _{stored})	50 percent*	*The reagent concentration of 50% is a default value. User sho	uld enter actual value, if known.
Denisty of reagent as stored (p _{stored})	71 lb/ft ³		
Concentration of reagent injected (C _{inj})	50 percent	Densities of typical SNCR reagents:	
Number of days reagent is stored (t _{storage})	30 days	50% urea solution	71 lbs/ft ³
Estimated equipment life	20 Years	19% aqueous NH ₃	58 lbs/ft ³
Select the reagent used	Urea 🗸		

Enter the cost data for the proposed SNCR:

Desired dollar-year	2016	1
CEPCI for 2016	536.4 Enter the CEPCI value for 2016 584.6 2012 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	5.25 Percent	
Fuel (Cost _{fuel})	2.79 \$/MMBtu*	
Reagent (Cost _{reag})	1.62 \$/gallon for a 50 percent solution of urea*	
Water (Cost _{water})	0.0088 \$/gallon*	
Electricity (Cost _{elect})	0.210 \$/kWh	
Ash Disposal (for coal-fired boilers only) (Cost _{ash})	18.00 \$/ton*	
	* The values marked are default values. See the table below for the default values used	-

and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance Cost Factor (MCF) = Administrative Charges Factor (ACF) =

0.015

Data Sources for Default Values Used in Calculations:

			If you used your own site-specific values, please
Data Element	Default Value	Sources for Default Value	
Reagent Cost	\$1.62/gallon of 50% urea solution	Based on vendor quotes collected in 2014.	
Water Cost (S/gallon)	0.0088	Average combined water/wastewater rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest cities-brochure-water-wastewater-rate-survey.pdf.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for industrial plants is based on 2014 price data compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-861 and 861S, (http://www.eia.gov/electricity/data.cfm#sales).	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Fuel Cost (\$/MMBtu)	2.79	Weighted average cost based on average 2014 fuel cost data for power plants compilec by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA 923, "Power Plant Operations Report." Available at http://www.eia.gov/electricity/data/eia923/.	
Ash Disposal Cost (\$/ton)	18	Average ash disposal costs based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	
Percent sulfur content for Coal (% weight)	2.35	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet
Percent ash content for Coal (% weight)	10.40	Average ash content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet
Higher Heating Value (HHV) (Btu/lb)	11,814	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/coal/data-sheet

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q_B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tSNCR/365) =	0.99	fraction	
Total operating time for the SNCR (t_{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(Noxin - NOxout)/Noxin =	40.00	percent	
NOx removed per hour =	NOx _{in} x EF x Q _B =	73.56	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	318.39	tons/year	
Coal Factor (Coal _F) =	1 for bituminuous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not ap
Atmospheric pressure at 450 feet above sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	apply t 500 fee
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole

Density = 71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	$(NOx_{in} \times Q_B \times NSR \times MW_R)/(MW_{NOx} \times SR) =$	126	lb/hour
	(whre SR = 1 for NH_3 ; 2 for Urea		
Reagent Usage Rate (m _{sol}) =	mreagent/Csol =	252	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	27	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x tstorage x 24)/Reagent Density =	19,121	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n} - 1 =$	0.0820
	Where n = Equipment Life and i= Interest Rate	

Parameter	Equation	Calculated Value	Units
Electricity Usage: Electrcity Consumption (P) =	(0.47 x NOx _{in} x NSR x Q ₈)/NPHR =	5.04	kW/hour
Water Usage: Water consumption (q _w) =	$(m_{sol}/Density of water) x ((C_{stored}/C_{inj}) - 1) =$	0	gallons/hour
Fuel Data: Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	Hv x m _{reagent} x ((1/C _{inj})-1) =	0.11	MMBtu/hour
Ash Disposal: Additional ash produced due to increased fuel consumption (Δash) =	(Δfuel x %Ash x 1E6)/HHV =	1.05	lb/hour

Cost Estimate

Total Capital Investment (TCI) For Coal-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$ For Fuel Oil and Natural Gas-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$ Capital costs for the SNCR (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* = \$0 in 2016 dollars Balance of Plant Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars Total Capital Investment (TCI) = \$6,208,948 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide. SNCR Capital Costs (SNCR_{cost}) For Coal-Fired Utility Boilers: $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$ For Coal-Fired Industrial Boilers: $SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: SNCR_{cost} = 147,000 x ((Q_B/NPHR)x HRF)^{0.42} x ELEVF x RF SNCR Capital Costs (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* For Coal-Fired Utility Boilers: $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$ For Coal-Fired Industrial Boilers: $APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$ Air Pre-Heater Costs (APH_{cost}) = \$0 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 0.3lb/MMBtu of sulfur dioxide. Balance of Plant Costs (BOP_{cost}) For Coal-Fired Utility Boilers: $BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $BOP_{cost} = 213,000 \text{ x} (B_{MW})^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x RF}$ For Coal-Fired Industrial Boilers: $BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: $BOP_{cost} = 213,000 \text{ x} (Q_{R}/NPHR)^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x} RF$ Balance of Plan Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars

Annual Costs

Total Annual Cost (TAC)

TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$477,565 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$511,631 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$989,197 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$93,134 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$372,444 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t_{op} =	\$9,166 in 2016 dollars
Annual Water Cost =	$q_{water} x Cost_{water} x t_{op} =$	\$0 in 2016 dollars
Additional Fuel Cost =	Δ Fuel x Cost _{fuel} x t _{op} =	\$2,739 in 2016 dollars
Additional Ash Cost =	$\Delta Ash x Cost_{ash} x t_{op} x (1/2000) =$	\$82 in 2016 dollars
Direct Annual Cost =		\$477,565 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,794 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$508,837 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$511,631 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$989,197 per year in 2016 dollars
NOx Removed =	318 tons/year
Cost Effectiveness =	\$3,107 per ton of NOx removed in 2016 dollars

Four Boilers Dry Sorbent Injection System - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Gross Output based on sum of turbines rated size; 20MW, 5MW, and 2.5 MW)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input (Heat Rate is higher because district heating is not included in unit size)
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input (Based on source testing 2011)
Type of Coal	Е	, , ,	sub-bituminous	< User Input
Particulate Capture	F		Baghouse	< User Input
Milled Trona	G		TRUE	Based on in-line milling equipment
	-			Maximum Removal Targets:
				Unmilled Trona with an ESP = 65%
		(84)		Milled Trona with an ESP = 80%
Removal Target	Н	(%)	70	Unmilled Trona with a Bachouse = 80%
				Milled Trona with Baghouse = 90%
				Simplified correlation: 70% removal with bachouse, S&L (2013)
Heat Input	J	(Btu/hr)	495.000.000	A*C*1000
i loat inpat	v	(2(0,11)	,,	$1 \text{ Junilled Trong with an ESP} = if(H_240.0.0350*H.0.352eA(0.0345*H))$
				$ \frac{1}{(1+1)} = \frac{1}{(1+1)} =$
NCP	к		1.55	$\lim_{n \to \infty} \log f_n(x_0, x_0, x_0) = \lim_{n \to \infty} f_n(x_0, x_0, x_0, x_0) = \lim_{n \to \infty} f_n(x_0, x_0, x_0, x_0, x_0) = \lim_{n \to \infty} f_n(x_0, x_0, x_0, x_0, x_0, x_0, x_0, x_0, $
NOR	ĸ		1.55	$\frac{1}{2} \frac{1}{2} \frac{1}$
				$155 \text{ Becommended for a backness a target of 70% removal S_{\text{eff}} = S_{\text{eff}} (2013)$
Trans Fried Date		(1 /	0.00	1.00 Netwine network (A 1747)
Irona Feed Rate	M	(ton/nr)	0.33	
Sorbent Waste Rate	N	(ton/hr)	0.222	(0.7035-0.00073696'H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3.
				(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV)
				For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000
Fly Ash Waste Rate	Р	(ton/hr)	0.92	For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400
				For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200
				< User Input (Usibelli Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,560)
Aux Power	Q	(%)	0.24	=if Milled Trona M*20/A else M*18/A
Trona Cost	R	(\$/ton)	550	< User Input (based on Stanley Consultant price reference)
Waste Disposal Cost	S	(\$/ton)	50	
Aux Power Cost	Т	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Operating Labor Rate	U	(\$/hr)	63	< User Input (Labor cost including all benefits [AE 2016])
IPM Model - Updates to Cost and Performat	nce for APC Technologies - I	Dry Sorbent Inje	ection for SO2 Control Co	st Development Methodology, March 2013, prepared by Sargent & Lundy LLC for USEPAhttps://www.epa.gov/sites/production/files/2015
	0		07/	/documents/append5 4.pdf
Capital Cost Calculation (2012 dollars)				Comments
· · · · · · · · · · · · · · · · · · ·				
Includes - Equipment, installation, building	ng, foundations, electrical, an	nd a retrofit diffic	ulty factor of 1.5	
	3			
Base Module (BM) (\$)		=	\$ 14,169,111	Base DSI module includes all equipment from unloading to injection, but not including field installation
Unmilled Trona = if(M>25 then (682,00	0*B*M) else 6,833,000*B*(M	^0.284)		
Milled Trona = if(M>25 then (750,000*E	^{3*} M) else 7,516,000*B*(M^0.2	284)		
BM (\$/kW)	, , , , ,	=	\$ 515	Base module cost per kW
Total Project Cost				
-				
A1 = 20% of BM		=	\$ 2,833,822	Engineering and construction management costs (CC Manual) (Stanley Consultants)
A2 = 10% of BM		=	\$ 1,416,911	Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual)
A3 = 10% of BM		=	\$ 1,416,911	Contractor profit and fees (CC Manual) (Stanley Consultants)
CECC (\$) - Excludes Owner's Costs =	BM + A1 + A2 + A3	=	\$ 19,836,755	Capital, engineering, and construction costs subtotal
CECC (\$/kW) - Excludes Owner's Cost	ts	=	\$ 721	Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 991,838	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE	CC + B1	=	\$ 20,828,593	Total project cost without Allowance for Funds Used During Construction (AFUDC)
TPC (\$/kW) - Include Owner's Costs		=	\$ 757	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)		=		AFUDC (Zero for less than 1 year engineering and construction cycle)
, , ,				
TPC (\$) = CECC + B1 + B2		=	\$ 20,682,000	Total project cost (Spreadsheet = \$20,828,523; Stanley Consultants cost estimate = \$20,682,000)
TPC (\$/kW)		=	\$ 752	Total project cost per kW

Dry Sorbent Injection System - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (2 additional operators)*(2080)*U/(A*1000) FOMM (\$/kW yr) = BM*0.01/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM) FOM (\$/kW yr) = FOMO + FOMM + FOMA	= = =	\$ \$ \$	 9.53 Fixed O&M additional operating labor costs (2 additional operators is more realistic) 3.43 Fixed O&M additional maintenance material and labor costs 0.33 Fixed O&M additional administrative labor costs 13.29 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = M*R/A VOMW (\$/MWh) = (N+P)*S/A VOMP (\$/MWh) = Q*T*10 VOM (\$/MWh) = VOMR + VOMW + VOMP	= = =	\$ \$ \$	 6.64 Variable O&M costs for Trona reagent 2.07 Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection 0.507 Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above) 9.21 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = = =	\$ \$ \$ \$	219,322 CC Manual 413,640 CC Manual 206,820 CC Manual 206,820 CC Manual Revise interest rate to prime (currently 5.25%) per EPA comment Reality is 10 years of useful life of the oldside; 30 years control equipment lifetime based on EPA comments on ADEC Prelim. BACT 1,383,976 CC Manual 2,430,578 5,015,463
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = =	\$	584.6 536.4 4,601,940
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= = =	\$	781 70 546 8,423

Four Boilers Spray Dry Absorber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on total heat input of 497 MMBtu/hour)
Retrofit Factor	В	· · · /	1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input (SDA FGD Estimation only valid up to 3lb/MMBtu SO2 Rate)
Type of Coal	Е		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous=1.05, Lignite=1.07
Heat Rate Factor	G		1.800	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Lime Rate	К	(ton/hr)	0.122	(0.6702*(D^2)+13.42*D)*A*G/2000 (Based on 95% SO2 Removal)
Waste Rate	L	(ton/hr)	0.280	(0.8016*(D^2)+31.1917*D)*A*G/2000
Aux Power	М	(%)	2.462	(0.000547*(D^2)+0.00649*D+1.3)*F*G Should be used for model input
Makeup Water Rate	N	(1000 gph)	2.876	(0.04898*(D^2)+0.5925*D+55.11)*A*F*G/1000
Lime Cost	Р	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf) (GVEA Limestone cost)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.htm)
Operating Labor Rate	Т	(\$/hr)	63	Labor cost including all benefits
IPM Mo	del - Updates to Cost and Performance for A	PC Technologi	es - SDA EGD for	SO2 Control Cost Development Methodology, March 2013, prepared by Sargent & Lundy LLC for US EPA
	https://	www.epa.gov/s	ites/production/file	se/2015-07/documents/chapter_5_appendix_5-tb_sda_fot_odf
Conital Cost Calculation (2012 dollars)	in point			Commonte anteria de la commonte de l
Capital Cost Calculation (2012 donars)				Comments
Includes - Equipment, installation, buildin	ng, foundations, electrical, and a retrofit difficu	ulty factor of 1.5		
BMR (\$) = if(A>600 then (A*92,000) else	566,000*(A^0.716))*B*(F*G)^0.6*(D/4)^0.01	=	\$ 13,028,350	Base module absorber island cost
BMF (\$) = if(A>600 then (A*48,700) else	BMF (\$) = if (A>600 then (A*48,700) else $300,000*(A^{0.716}))*B*(D*G)^{0.2}$ = \$ 4,426,798 Base module reagent preparation and waste recycle/handling cost		Base module reagent preparation and waste recycle/handling cost	
BMB (\$) = if(A>600 then (A*129,900) els	e 799,000*(A^0.716))*B*(F*G)^0.4	=	\$ 16,587,654	Base module balance of plan costs inlcuding: ID or booster fans, piping, ductwork, electrical, etc.
BM (\$) = BMR + BMF + BMB BM (\$/kW)		= =	\$ 34,042,802 \$ 1,238	Total base module cost including retrofit factor Base module cost per kW
Total Project Cost				
A1 = 10% of BM		=	\$ 3,404,280	Engineering and construction management costs
A2 = 10% of BM		=	\$ 3,404,280	Labor adjustment for 6 x 10 hour shift premium, per diem, etc.
A3 = 10% of BM		=	\$ 3,404,280	Contractor profit and fees
			, . ,	
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cost	BM + A1 + A2 + A3 s =	= =	\$ 44,255,642 \$ 1,609	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,212,782	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	CC + B1	=	\$ 46,468,425 \$ 1,690	Total project cost without Allowance for Funds Used During Construction (AFUDC)
B2 = 10% of (CECC + B1)		=	\$ 4,646,842	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and	AFUDC = CECC + B1 + B2	=	\$ 51,115,267	Total project cost
TPC (\$/kW) - Includes Owner's Costs a	and AFUDC =	=	\$ 1,859	Total project cost per kW

Spray Dry Absorber - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (4 additional operators)*(2080)*T/(A*1000) FOMM (\$/kW yr) = BM*0.015/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	= = =	\$ \$ \$	 38.12 Fixed O&M additional operating labor costs 12.38 Fixed O&M additional maintenance material and labor costs 1.29 Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	=	\$	51.79 Total Fixed O&M costs
Variable O&M Cost			
VOMR (\$/MWh) = K*P/A	=	\$	1.06 Variable O&M costs for lime reagent
VOMW (\$/MWh) = L*Q/A	=	\$	0.31 Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	=	\$	5.17 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	=	\$	0.75 Variable O&M costs for makeup water
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM	=	\$	7.29 Total Variable O&M Costs
Indirect Annual Costs			
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 525	= = = =	\$ \$ \$ \$	854,570 CC Manual 1,022,305 CC Manual 511,153 CC Manual 511,153 CC Manual
n = Equipment life (years) 30 CRF = 0.0669	=	\$	3,420,477 CC Manual
TOTAL INDIRECT ANNUAL OPERATING COSTS	=	\$	6,319,657
TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	=	\$	9,499,458
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	=		584.6 536.4
TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	=	\$	8,716,232
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons	=		781
SO ₂ REMOVAL EFFICIENCY, %	=		90
TOTAL SO ₂ REMOVED, tons	=		702
SO ₂ COST-EFFECTIVENESS, \$/ton removed	=	\$	12,408

Four Boilers Wet Scrubber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on a total heat input of 497 MMBtu/hr)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0) Sargent and Lundy has a drop down menu for selection of an additional waste water treatment plant facility, but no capital or operational cost are implemented so it is not reproduced here.
Gross Heat Rate	С	(Btu/kWh)	18.000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.36	< User Input
Type of Coal	E		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous = 1.05, Lignite = 1.07
Heat Rate Factor	G		1.8	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Limestone Rate	K	(ton/hr)	0.16	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	0.283	1.811*K
Aux Power	M	(%)	2.098	(1.05e^(0.155*D))*F*G
Makeup Water Rate	N	(1000 gph)	3.913	(1.674*D+74.68)*A*F*G/1000
Limestone Cost	P	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.html)
Operating Labor Rate	T	(\$/hr)	63	Labor cost including all benefits
IPM Model -	Updates to Cost and Performance for APC T https://www	echnologies - W .epa.gov/sites/p	et FGD for SO2 Co oduction/files/2015	ntrol Cost Development Methodology, August 2010, prepared by Sargent & Lundy LLC for US EPA. -07/documents/chapter_5_appendix_5-1a_wet_fgd.pdf
Capital Cost Calculation (2012 dollars)				Comments
BMR (\$) = $550,000^{+}(B)^{+}((F^{+}G)^{0.6})^{+}((D/B)^{-1})^{-1}(B)$	ng, roundations, electrical, minor physical/che 2)^0.02)*((A^0.716)	emical waste wa	\$ 12,531,374	Base absorber island cost
BMF (\$) = 190,000*(B)*((D*G)^0.3)*(A^0	0.716)	=	\$ 2,684,600	Base reagent preparation cost
BMW (\$) = 100,000*(B)*((D*G)^0.45)*(A	\^0.716)	=	\$ 1,323,921	Base waste handling cost
BMB (\$) = 1,010,000*(B)*((F*G)^0.4)*(A	^0.716)	=	\$ 20,968,123	Base balance of plan cost including: ID or booster fans, new wet chimney, piping, ductwork, minor waste water treatment, etc
BMWW (\$) =		=	\$-	Base wastewater treatment facility, beyond minor physical/chemcial treatment
Base Module (BM) (\$) = BMR + BMF + BM (\$/kW)	BMW + BMB + BMWW	= =	\$ 37,508,019 \$ 1,364	Total base cost including retrofit factor Base cost per kW
Total Project Cost				
A1 = 10% of BM A2 = 10% of BM A3 = 10% of BM		= = =	\$ 3,750,802 \$ 3,750,802 \$ 3,750,802	Engineering and construction management costs (CC Manual) Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual) Contractor profit and fees (CC Manual)
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cos	BM + A1 + A2 + A3 tts =	= =	\$ 48,760,424 \$ 1,773	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,438,021	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	ECC + B1	= =	\$ 51,198,446 \$ 1,862	Total project cost without Allowance for Funds Used During Construction (AFUDC) Total project cost per kW without AFUDC
B2 = 10% of (CECC + B1)		=	\$ 5,119,844.55	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and TPC (\$/kW) - Includes Owner's Costs	AFUDC = CECC + B1 + B2 and AFUDC =	=	\$ 56,318,290 \$ 2,048	Total project cost Total project cost per kW

Wet Scrubber - Chena Power Plant

	_		
Direct Annual Costs			
Fixed U&M Cost			
FOMO ($\frac{1}{k}$ vr) = (6 additional operators)*(2080)* T/(A*1000)	=	\$	28.59 Fixed O&M additional operating labor costs
FOMM ($\frac{1}{2}$ W vr) = BM*0.015/(B*A*1000)	=	\$	13.64 Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	=	\$	1.02 Fixed Q&M additional administrative labor costs
FOMWW (\$/kW yr) =		\$	- Fixed O&M costs for wastewater treatment facility
	=	φ	43.25 Total Fixed U&M Costs (arkiv yr)
Variable O&M Cost			
		•	
VOMR (\$/MWh) = K*P/A	=	\$	1.36 Variable O&M costs for limestone reagent
VOMW (\$/MWh) = L*Q/A	=	\$	0.31 Variable O&M costs for waste disposal
		•	
$VOMP (\$/MWh) = M^*R^*10$	=	\$	4.41 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	=	\$	1.02 Variable O&M costs for makeup water
	-	\$	- Variable ORM costs for wastewater treatment facility
	-	Ψ	
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW	=	\$	7.10 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs	_		
Overhead (60% of total labor and material costs)	=	\$	713,645 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment)	=	\$ \$	713,645 CC Manual 1,126,366 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment)	= = =	\$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment)	= = = =	\$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n] / [(1+i)^n - 1]$	= = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25	= = =	\$\$ \$\$ \$\$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30	= = =	\$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1]i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669	= = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS	= = = =	\$ \$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6.735.024
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1]i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669TOTAL INDIRECT ANNUAL OPERATING COSTS	= = = =	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n] / [(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)30CRF =0.0669TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [$i (1+i)^n$] / [$(1+i)^n - 1$] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Linsurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation)	= = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	= = = = = = =	\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	- - - - - -	\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = =	\$ \$ \$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = = = =	\$ \$ \$ \$ \$	713.645 CC Manual 1,126.366 CC Manual 563.183 CC Manual 563.183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons	= = = = = = = = =	\$\$\$\$ \$ \$ \$	713.645 CC Manual 1.126.366 CC Manual 563.183 CC Manual 563.183 CC Manual 3.768.647 CC Manual 6.735.024 9.634.230 584.6 536.4 8.839.892 781
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY. %		\$ \$ \$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO- REMOVED tons	-	\$\$\$\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99 773
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Linsurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons		\$\$\$\$\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99 773
Overhead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ]/[(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 30 CRF = 0.0669 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed		\$\$\$\$\$ \$ \$ \$	713,645 CC Manual 1,126,366 CC Manual 563,183 CC Manual 563,183 CC Manual 3,768,647 CC Manual 6,735,024 9,634,230 584.6 536.4 8,839,892 781 99 773 11,440 Does not include costs associated with building and maintaining a wastewater treatment facility

Appendix B (Economic Analysis Spreadsheets – V2)

Air Pollution Control Cost Estimation Spreadsheet

For Selective Catalytic Reduction (SCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Catalytic Reduction (SCR) control device. SCR is a post-combustion control technology for reducing NO_x emissions that employs a metal-based catalyst and an ammonia-based reducing reagent (urea or ammonia). The reagent reacts selectively with the flue gas NO_x within a specific temperature range to produce N₂ and water vapor.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SCR control technology and the cost methodologies, see Section 4, Chapter 2 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM) (version 5.13). The size and costs of the SCR are based primarily on five parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, reagent consumption rate, and catalyst costs. The equations for utility boilers are identical to those used in the IPM. However, the equations for industrial boilers were developed based on the IPM equations for utility boilers. This approach provides study-level estimates (±30%) of SCR capital and annual costs. Default data in the spreadsheet is taken from the SCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/powersector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will clear many of the input cells and reset others to default values.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SCR is for new construction or retofit of an existing boiler. If the SCR will be installed on an existing boiler, enter a retrofit factor between 0.8 and 1.5. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you select fuel oil or natural gas, the HHV and NPHR fields will be prepopulated with default values. If you select coal, then you must complete the coal input box by first selecting the type of coal burned from the drop down menu. The weight percent sulfur content, HHV, and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided. Method 1 is pre-selected as the default method for calculating the catalyst replacement cost. For coal-fired units, you choose either method 1 or method 2 for calculating the catalyst replacement cost.

Step 4: Complete all of the cells highlighted in yellow. If you do not know the catalyst volume (Vol _{catalyst}) or flue gas flow rate (Q_{flue gas}), please enter "UNK" and these values will be calculated for you. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.005 and 0.03, respectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SCR.

Catalyst cost (CC replace)

Operator Labor Rate

\$160/cf is a default value for the catalyst cost. User should enter actual value, if known

Data Inputs Enter the following data for your combustion unit: • Industrial Is the combustion unit a utility or industrial boiler? What type of fuel does the unit burn? Coal • • Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit Simpson, Aaron: Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for No basis was provided to justify a retrofit factor reflecting greater than average difficulty for installation of selective catalytic reduction on the boilers. 1.5 projects of average retrofit difficulty. High retrofit cost factors may be justified in unusual circumstances (e.g., long and unique ductwork and piping, site preparation, tight fits, helicopter or crane installation, additional engineering, and asbestos abatement). Complete all of the highlighted data fields: Aurora: Location of the catalyst, if it has to be installed within a temperature range of 500-800F, would be the top of the boilers just before the economizer and air prehaeter It's a titght fit, limited space, asbestos abatement necessary, duct work is complex and 497 MMBtu/hr What is the rating at full load capacity (MMBtu/hr)? 7,560 Btu/lb 0.20 percent by weight Enter the sulfur content (%S) = What is the higher heating value (HHV) of the fuel? Simpson, Aaron: Simpson, Aaron: Typical Gross As Received. http://www.usibelli.com/coal/data-sheet Typical Gross As Received. http://www.usibelli.com/coal/data-sheet What is the estimated actual annual fuel consumption? 569.114.000 lbs/year or units burning coal blends: Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided. Enter the net plant heat input rate (NPHR) 18 MMBtu/MW If the NPHR is not known, use the default NPHR value: Fuel Type Default NPHR Bituminous Coal 10 MMBtu/MW Sub-Bituminous uel Oil 11 MMBtu/MW Lignite Natural Gas 3.2 MMBtu/MW lease click the calculate button to calculate weighted values based on the data in the table above Plant Elevation 450 Feet above sea level For coal-fired boilers, you may use either Method 1 or Method 2 to calculate Rethod 1 the catalyst replacement cost. The equations for both methods are shown on O Method 2 rows 85 and 86 on the Cost Estimate tab. Please select your preferred O Not applicable method: Enter the following design parameters for the proposed SCR: Number of days the SCR operates (t_{SCR}) Number of SCR reactor chambers (n_{scr}) Simpson, Aaron 365 days Assuming baseline of 0.5 lb/MMBtu from New Source Performance Standards, Number of days the boiler operates (t_{plant}) Number of catalyst layers (R_{layer}) 365 day Subpart Da - Technical Support for Proposed Revisions to NOx Standard, U.S Inlet NO_v Emissions (NOxin) to SCR EPA, Office of Air Quality Planning and Standards, EPA-453/R-94-012, June 1997 Number of empty catalyst layers (Rempty) 1 0.37 lb/MMBtu NOx Removal Efficiency (EF) provided by vendor Ammonia Slip (Slip) provided by vendor 10 ppm 80 percent Aurora: Emission Inventory rate based on 2011 source testing. Volume of the catalyst layers (Vol_{catalyst}) Simpson, Aaron: Stoichiometric Ratio Factor (SRF) pril 7, 2016 Source Test 0.525 (Enter "UNK" if value is not known) UNK Cubic fe *The SRF value of 0.525 is a default value. User should enter actual value, if kno Flue gas flow rate (Q_{fluegas}) Aurora: Source Test dscf Simpson, Aaron: EPA's Air Pollution Control Technology Fact Sheet indicating 70 - 90 percent (Enter "UNK" if value is not known) 162098.5 179,783.2 acfm control. https://www3.epa.gov/ttncatc1/dir1/fscr.pdf 162098.5 dscf/(1-Bws) = acfm; Bws = 0.0984. Estimated operating life of the catalyst (H_{catalyst}) 24.000 hours Simpson, Aaron: Gas temperature at the SCR inlet (T) 310 °F April 7, 2016 Source Test Estimated SCR equipment life 15 Years * For industrial boilers, the typical equipment life is between 20 and 25 years Base case fuel gas volumetric flow rate factor 516 ft³/min-MMBtu/hour (Q_{fuel}) Concentration of reagent as stored (Cstored) 50 percent* The reagent concentration of 50% and density of 71 lbs/cft an efault values for urea reagent. User should enter actual values for Density of reagent as stored (p_{stored}) 71 lb/cubic feet* agent, if different from the default values provided. Number of days reagent is stored (t_{storage}) 30 days Densities of typical SCR reagents: 50% urea solution 71 lbs/ft³ 29.4% aqueous NH₃ 56 lbs/ft³ 19% aqueous NH₃ 58 lbs/ft³ • Select the reagent used Urea Enter the cost data for the proposed SCR: Desired dollar-year 2016 CEPCI for 2016 536.4 Enter the CEPCI value for 2016 2012 CEPCI CEPCI = Chemical Engineering Plant Cost Index Annual Interest Rate (i) 5.25 Percent Reagent (Cost_{reag}) 1.62 \$/gallon for a 50 percent solution of urea Simpson, Aaron: Electricity (Cost_{elect}) 0.210 \$/kWh

Appendix III.D.7.7-4896

160.00 catalyst and installation of new catalyst*

63.00 \$/hour (including benefits)

\$/kWh GVEA rates. http://www.gvea.com/rates/rates \$/cubic foot (includes removal and disposal/regeneration of existing

Adopted

November 19, 2019

* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Operator Hours/Day

4.00 hours/day*

0.005

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Alaintenance and Administrative Charges Cost Factors:	
Maintenance Cost Factor (MCF) =	
Administrative Charges Factor (ACF) =	

Data Sources for Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source
Reagent Cost (\$/gallon)	1.62	Based on the average of vendor quotes from 2011 - 2013.	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for utilities is based on 2014 electricity production cost data for fossil-fuel plants compiled by the U.S. Energy Information (EIA). Available at http://www.eia.gov/tools/faqs/faq.cfm?id=19&t=3.	\$0.210/kWh GVEA rates. http://www.gvea.com/rates/rates
Percent sulfur content for Coal (% weight)	0.31	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	0.20 percent (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Higher Heating Value (HHV) (Btu/lb)	8,730	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	7,560 Btu/lb (Typical Gross As Received). Coal data sheet at http://www.usibelli.com/Coal_data.php
Catalyst Cost (\$/cubic foot)	160	Cichanowicz, J.E. "Current Capital Cost and Cost-Effectiveness of Power Plant Emissions Control Technologies", July 2013.	

SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q _B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tscr/tplant) =	0.99	fraction	
Total operating time for the SCR $(t_{op}) =$	CF _{total} x 8760 =	8657	hours	-
NOx Removal Efficiency (EF) =	(NOxin- NOxout)/NOxin =	80.0	percent	
NOx removed per hour =	$NOx_{in} x EF x Q_B =$	147.11	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	636.77	tons/year	-
NOx removal factor (NRF) =	EF/80	1.00		
Volumetric flue gas flow rate (q _{flue gas}) =	Q _{fuel} x QB x (460 + T)/(460 + 700)n _{scr}	179,783	acfm	-
Space velocity (V _{space}) =	q _{flue gas} /Vol _{catalyst}	30.03	/hour	
Residence Time	1/V _{space}	0.03	hour	
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO_2 Emission rate =	(%S/100)x(64/32)*1E6)/HHV =	< 3	lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not applicable;
Atmospheric pressure at sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* =	14.5	psia	does not apply to plants located at
Retrofit Factor (RF)	Retrofit to existing boiler	1.50		elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Adopted

Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)(1/((1+ interest rate) ^Y -1) , where Y = H_atabut/(t _{scp} x 24 hours) rounded to the nearest integer	0.316	Fraction
Catalyst volume (Vol _{catalyst}) =	2.81 x Q _B x EF _{adj} x Slipadj x Noxadj x Sadj x (Tadj/Nscr)	5,986.26	Cubic feet
Cross sectional area of the catalyst (A _{catalyst}) =	q _{flue gas} /(16ft/sec x 60 sec/min)	187	ft²
Height of each catalyst layer (H _{layer}) =	(Vol _{catalyst} /(R _{layer} x A _{catalyst})) + 1	12	feet

SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor (A _{SCR}) =	1.15 x A _{catalyst}	215	ft ²
Reactor length and width dimentions for a square	(A _{SCR}) ^{0.5}	14.7	feet
reactor =			
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	84	feet
Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole
		Density =	71 lb/ft ³

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	(NOx _{in} x Q _B x EF x SFR x MW _R)/MW _{NOx} =	101	lb/hour
Reagent Usage Rate (m _{sol}) =	m _{reagent} /Csol =	202	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	21	gal/hour
Estimated tank volume for reagent storage =	(m _{sol} x 7.4805 x t _{storage} x 24)/Reagent Density =	15,296	gallons (storage needed to store a 30 day reagent supply)

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n}-1=$	0.0980
	Where n = Equipment Life and i= Interest Rate	

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	A x 1,000 x 0.0056 x (CoalF x HRF) ^{0.43} =	365.95	kW
	where $A = (0.1 \times QB)$ for industrial boilers.		

Cost Estimate

Total Capital Investment (TCI)

TCI for Coal-Fired Boilers				
For Coal-Fired Boilers:				
	$TCI = 1.3 \times (SCR_{cost} + RPC + APHC + BPC)$			
Capital costs for the SCR (SCR _{cost}) =	\$14,132,761	in 2016 dollars		
Reagent Preparation Cost (RPC) =	\$2,348,710	in 2016 dollars		
Air Pre-Heater Costs (APHC)* =	\$0	in 2016 dollars		
Balance of Plant Costs (BPC) =	\$3,333,099	in 2016 dollars		
Total Capital Investment (TCI) =	\$25,758,941	in 2016 dollars		
* Not applicable - This factor applies only to coal-fired bo	* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 3lb/MMBtu of sulfur dioxide.			
SCR Capital Costs (SCR _{cost})				

For Coal-Fired Utility Boilers >25 MW:		
	$SCR_{cost} = 270,000 \times (NRF)^{0.2} \times (B_{MW} \times HRF \times CoalF)^{0.92} \times ELEVF \times RF$	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	$SCR_{cost} = 270,000 \times (NRF)^{0.2} \times (0.1 \times Q_B \times CoalF)^{0.92} \times ELEVF \times RF$	
		644422764 in 2046 dellers
SCR Capital Costs (SCR _{cost}) =		\$14,132,761 in 2016 dollars
	Reagent Preparation Costs (RPC)	
For Coal-Fired Utility Boilers >25 MW:		
	RPC = 490,000 x (NO x_{in} x B _{MW} x NPHR x EF) ^{0.25} x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	RPC = 490,000 x (NOx _{in} x Q _B x EF) ^{0.25} x RF	
Reagent Preparation Costs (RPC) =		\$2,348,710 in 2016 dollars
	Air Pre-Heater Costs (APHC)*	
For Coal-Fired Utility Boilers >25MW:	· · ·	
	APHC = 69,000 x (B_{MW} x HRF x CoalF) ^{0.78} x AHF x RF	
For Coal-Fired Industrial Boilers >250 MMBtu/hour:		
	APHC = 69,000 x (0.1 x Q _B x CoalF) ^{0.78} x AHF x RF	
Air Pre-Heater Costs (APH) =		\$0 in 2016 dollars
An The Treater Costs (AT Treast) -		50 III 2010 dollars

* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

Balance of Plant Costs (BPC)			
For Coal-Fired Utility Boilers >25MW:			
$BPC = 460,000 \times (B_{MW} \times HRF \times CoalF)^{0.42} \times ELEVF \times RF$			
For Coal-Fired Industrial Boilers >250 MMBtu/hour:			
BPC = $460,000 \times (0.1 \times Q_B \times CoalF)^{0.42}$ ELEVF x RF			
Balance of Plant Costs (BOP _{cost}) =	\$3,333,099 in 2016 dollars		

Annual Costs

Total Annual Cost (TAC) TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$1,193,040 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$2,528,093 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$3,721,132 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)

Annual Maintenance Cost =	0.005 x TCI =	\$128,795 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$297,936 in 2016 dollars
Annual Electricity Cost =	P x Cost _{elect} x t _{op} =	\$665,284 in 2016 dollars
Annual Catalyst Replacement Cost =		\$101,026 in 2016 dollars
For coal-fired boilers, the following methods may be used to calcuate the catalyst replacement cost. Method 1 (for all fuel types): $n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$ Method 2 (for coal fired utility boilors): $B_{res} \times 0.4 \times (CoalE)^{2.9} \times (NRE)^{0.71} \times (CC_{replace}) \times 35.3$		* Calculation Method 1 selected.
Direct Annual Cost =		\$1,193,040 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$4,305 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$2,523,788 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$2,528,093 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$3,721,132 per year in 2016 dollars
NOx Removed =	637 tons/year
Cost Effectiveness =	\$5,844 per ton of NOx removed in 2016 dollars

Air Pollution Control Cost Estimation Spreadsheet For Selective Non-Catalytic Reduction (SNCR)

U.S. Environmental Protection Agency Air Economics Group Health and Environmental Impacts Division Office of Air Quality Planning and Standards

(May 2016)

This spreadsheet allows users to estimate the capital and annualized costs for installing and operating a Selective Non-Catalytic Reduction (SNCR) control device. SNCR is a post-combustion control technology for reducing NOx emissions by injecting an ammonia-base reagent (urea or ammonia) into the furnace at a location where the temperature is in the appropriate range for ammonia radicals to react with NOx to form nitrogen and water.

The calculation methodologies used in this spreadsheet are those presented in the U.S. EPA's Air Pollution Control Cost Manual. This spreadsheet is intended to be used in combination with the SNCR chapter and cost estimation methodology in the Control Cost Manual. For a detailed description of the SNCR control technology and the cost methodologoies, see Section 4, Chapter 1 of the Air Pollution Control Cost Manual (as updated in 2016). A copy of the Control Cost Manual is available on the U.S. EPA's "Technology Transfer Network" website at: http://www3.epa.gov/ttn/catc/products.html#cccinfo.

The spreadsheet can be used to estimate capital and annualized costs for applying SNCR, and particularly to the following types of combustion units:

- (1) Coal-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (2) Fuel oil- and natural gas-fired utility boilers with full load capacities greater than or equal to 25 MW.
- (3) Coal-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.
- (4) Fuel oil- and natural gas-fired industrial boilers with maximum heat input capacities greater than or equal to 250 MMBtu/hour.

The methodology used in this spreadsheet is based on the U.S. EPA Clean Air Markets Division (CAMD)'s Integrated Planning Model (IPM). The size and costs of the SNCR are based primarily on four parameters: the boiler size or heat input, the type of fuel burned, the required level of NOx reduction, and the reagent consumption. This approach provides study-level estimates (±30%) of SNCR capital and annual costs. Default data in the spreadsheet is taken from the SNCR Control Cost Manual and other sources such as the U.S. Energy Information Administration (EIA). The actual costs may vary from those calculated here due to site-specific conditions, such as the boiler configuration and fuel type. Selection of the most cost-effective control option should be based on a detailed engineering study and cost quotations from system suppliers. For additional information regarding the IPM, see the EPA Clean Air Markets webpage at http://www.epa.gov/airmarkets/power-sector-modeling. The Agency wishes to note that all spreadsheet data inputs other than default data are merely available to show an example calculation.

Instructions

Step 1: Please select on the Data Inputs tab and click on the Reset Form button. This will reset the NSR, plant elevation, estimated equipment life, desired dollar year, cost index (to match desired dollar year), annual interest rate, unit costs for fuel, electricity, reagent, water and ash disposal, and the cost factors for maintenance cost and administrative charges. All other data entry fields will be blank.

Step 2: Select the type of combustion unit (utility or industrial) using the pull down menu. Indicate whether the SNCR is for new construction or retofit of an existing boiler. If the SNCR will be installed on an existing boiler, enter a retrofit factor equal to or greater than 0.84. Use 1 for retrofits with an average level of difficulty. For the more difficult retrofits, you may use a retrofit factor greater than 1; however, you must document why the value used is appropriate.

Step 3: Select the type of fuel burned (coal, fuel oil, and natural gas) using the pull down menu. If you selected coal, select the type of coal burned from the drop down menu. The NOx emissions rate, weight percent coal ash and NPHR will be pre-populated with default factors based on the type of coal selected. However, we encourage you to enter your own values for these parameters, if they are known, since the actual fuel parameters may vary from the default values provided.

Step 4: Complete all of the cells highlighted in yellow. As noted in step 1 above, some of the highlighted cells are pre-populated with default values based on 2014 data. Users should document the source of all values entered in accordance with what is recommended in the Control Cost Manual, and the use of actual values other than the default values in this spreadsheet, if appropriately documented, is acceptable. You may also adjust the maintenance and administrative charges cost factors (cells highlighted in blue) from their default values of 0.015 and 0.03, repectively. The default values for these two factors were developed for the CAMD Integrated Planning Model (IPM). If you elect to adjust these factors, you must document why the alternative values used are appropriate.

Step 5: Once all of the data fields are complete, select the SNCR Design Parameters tab to see the calculated design parameters and the Cost Estimate tab to view the calculated cost data for the installation and operation of the SNCR.

Adopted

November 19, 2019

Data Inputs				
Enter the following data for your combustion unit:				
Is the combustion unit a utility or industrial boiler?	Industrial V	What type of fuel does the unit burn?		
Please enter a retrofit factor equal to or greater than 0.84 based on the difficulty. Enter 1 for projects of average retrofit difficulty.	he level of 1.5	* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.		
Complete all of the highlighted data fields:				
What is the maximum heat input rate (QB)?	497 MMBtu/hr	Provide the following information for coal-fired boilers: Type of coal burned: Sub-Bituminous		
What is the higher heating value (HHV) of the fuel?	7,560 Btu/lb	Enter the sulfur content (%S) = 0.20 percent by weig	ght	
What is the estimated actual annual fuel consumption?	569,114,000 lbs/year	or Select the appropriate SO ₂ emission rate: Not Applicable	T	
Is the boiler a fluid-bed boiler?	No	Ash content (%Ash): 7 percent by weig	şht	
Enter the net plant heat input rate (NPHR) If the NPHR is not known, use the default NPHR value:	18 MMBtu/MW Fuel Type Default NPHR Coal 10 MMBtu/MW Fuel Oil 11 MMBtu/MW Natural Gas 8.2 MMBtu/MW	For units burning coal blends: Note: The table below is pre-populated with default values for these parameters in the table be parameter is not known, you may use the default values provide the second blend with the second blend blend with the second blend blend with the second blend blen	for HHV, %5, %Ash and cost. Please slow. If the actual value for any ovided.	
Enter the following design parameters for the proposed	I SNCR:			
Number of days the SNCR operates $(t_{\mbox{\tiny SNCR}})$	365 days	Plant Elevation 450 Feet above sea	level	
Inlet NO _x Emissions (NOx _{in}) to SNCR NOx Removal Efficiency (EF) provided by vendor (Enter "UNK" if value is not known)	0.37 lb/MMBtu 40 percent			
Estimated Normalized Stoichiometric Ratio (NSR)	1.05	*The NSR value of 1.05 is a default value. User should enter actual value, if	known.	
Concentration of reagent as stored (C_{stored}) Denisty of reagent as stored (ρ_{stored}) Concentration of reagent injected (C_{inj}) Number of days reagent is stored ($t_{storage}$) Estimated equipment life	50 percent* 71 lb/ft ³ 50 percent 30 days 15 Years	*The reagent concentration of 50% is a default value. User should enter ac Densities of typical SNCR reagents: 50% urea solution 71 lb: 29.4% aqueous NH ₃ 56 lb:	tual value, if known. s/ft ³ s/ft ³	
Select the reagent used	Urea 🗸	19% aqueous NH ₃ 58 lbs	;/ft [~]	

Enter the cost data for the proposed SNCR:

Desired dollar-year	2016		
CEPCI for 2016	536.4 Enter the CEPCI value for 2016 584.6 2012 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	5.25 Percent		
Fuel (Cost _{fuel})	2.79 \$/MMBtu*		
Reagent (Cost _{reag})	1.62 \$/gallon for a 50 percent solution of urea*		
Water (Cost _{water})	0.0088 \$/gallon*		
Electricity (Cost _{elect})	0.210 \$/kWh		
Ash Disposal (for coal-fired boilers only) (Cost _{esh})	18.00 \$/ton*		
	* The values marked are default values. See the table below for the default values used	_	

and their references. Enter actual values, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance Cost Factor (MCF) = Administrative Charges Factor (ACF) =

0.015

Data Sources for Default Values Used in Calculations:

			If you used your own site-specific values, please enter the the value used and the reference source .
Data Element	Default Value	Sources for Default Value	
Reagent Cost	\$1.62/gallon of	Based on vendor quotes collected in 2014.	
	50% urea		
	solution		
Water Cost (\$/gallon)	0.0088	Average combined water/wastewater rates for industrial facilities in 2013 compiled by	
		Available at http://www.saws.org/who.we.are/community/RAC/docs/2014/50-largest	
		cities-brochure-water-wastewater-rate-survey odf	
Electricity Cost (\$/kWh)	0.039	Average annual electricity cost for industrial plants is based on 2014 price data	\$0.210/kWh GVEA rates.
		compiled by the U.S. Energy Information Administration (EIA) from data reported on	http://www.gvea.com/rates/rates
		EIA Form EIA-861 and 861S, (http://www.eia.gov/electricity/data.cfm#sales).	
Truck Const (C / A & ADA)	2.70		4
Fuel Cost (\$/MINIBLU)	2.79	by the LLS. Energy Information Administration (EIA) from data reported on EIA Form EI	A
		923. "Power Plant Operations Report." Available at	
		http://www.eia.gov/electricity/data/eia923/.	
Ash Disposal Cost (\$/ton)	18	Average ash disposal costs based on U.S. coal data for 2014 compiled by the U.S.	
		Energy Information Administration (EIA) from data reported on EIA Form EIA-923,	
		Power Plant Operations Report. Available at	
		http://www.eia.gov/electricity/data/eia923/.	
Percent sulfur content for Coal (% weight)	2.35	Average sulfur content based on U.S. coal data for 2014 compiled by the U.S. Energy	0.20 percent (Typical Gross As Received). Coal data
		Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	
Percent ash content for Coal (% weight)	10.40	Average ash content based on U.S. coal data for 2014 compiled by the U.S. Energy	7 percent (Typical Gross As Received). Coal data
		Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/eiectricity/data/eia923/.	
Higher Heating Value (HHV) (Btu/lb)	11,814	2014 coal data compiled by the Office of Oil, Gas, and Coal Supply Statistics, U.S. Energy	7,560 Btu/lb (Typical Gross As Received). Coal data
		Information Administration (EIA) from data reported on EIA Form EIA-923, Power Plant	sheet at http://www.usibelli.com/coal/data-sheet
		Operations Report. Available at http://www.eia.gov/electricity/data/eia923/.	

SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q_B) =	HHV x Max. Fuel Rate =	497	MMBtu/hour	
Maximum Annual fuel consumption (mfuel) =	(QB x 1.0E6 x 8760)/HHV =	575,888,889	lbs/year	
Actual Annual fuel consumption (Mactual) =		569,114,000	lbs/year	
Heat Rate Factor (HRF) =	NPHR/10 =	1.80		
Total System Capacity Factor (CF _{total}) =	(Mactual/Mfuel) x (tSNCR/365) =	0.99	fraction	
Total operating time for the SNCR (t _{op}) =	CF _{total} x 8760 =	8657	hours	
NOx Removal Efficiency (EF) =	(Noxin - NOxout)/Noxin =	40.00	percent	
NOx removed per hour =	NOx _{in} x EF x Q _B =	73.56	lb/hour	
Total NO _x removed per year =	(NOx _{in} x EF x Q _B x t _{op})/2000 =	318.39	tons/year	
Coal Factor (Coal _F) =	1 for bituminuous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.05		
SO ₂ Emission rate =	(%S/100)x(64/32)*1E6)/HHV = < 3 lbs/MM		lbs/MMBtu	
Elevation Factor (ELEVF) =	14.7 psia/P =			Not a
Atmospheric pressure at 450 feet above sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] ^{5.256} x (1/144)* = 14.5 psia		psia	apply 500 fe
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html.

Reagent Data:

Type of reagent used	Urea	Molecular Weight of Reagent (MW) =	60.06 g/mole

Density = 71 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate (m _{reagent}) =	$(NOx_{in} \times Q_B \times NSR \times MW_R)/(MW_{NOx} \times SR) =$	126	lb/hour
	(whre SR = 1 for NH_3 ; 2 for Urea		
Reagent Usage Rate (m _{sol}) =	mreagent/Csol =	252	lb/hour
	(m _{sol} x 7.4805)/Reagent Density	27	gal/hour
Estimated tank volume for reagent storage =		19 121	gallons (storage needed to store a 30 day reagent supply)
	(m _{sol} x 7.4805 x tstorage x 24)/Reagent Density =	15,121	

Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^{n}/(1+i)^{n} - 1 =$	0.0980
	Where n = Equipment Life and i= Interest Rate	

Parameter	Equation	Calculated Value	Units
Electricity Usage: Electrcity Consumption (P) =	(0.47 x NOx _{in} x NSR x Q ₈)/NPHR =	5.04	kW/hour
Water Usage: Water consumption (q _w) =	$(m_{sol}/Density of water) x ((C_{stored}/C_{inj}) - 1) =$	0	gallons/hour
Fuel Data: Additional Fuel required to evaporate water in injected reagent (ΔFuel) =	Hv x m _{reagent} x ((1/C _{inj})-1) =	0.11	MMBtu/hour
Ash Disposal: Additional ash produced due to increased fuel consumption (Δash) =	(Δfuel x %Ash x 1E6)/HHV =	1.05	lb/hour

Cost Estimate

Total Capital Investment (TCI) For Coal-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$ For Fuel Oil and Natural Gas-Fired Boilers: $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$ Capital costs for the SNCR (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* = \$0 in 2016 dollars Balance of Plant Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars Total Capital Investment (TCI) = \$6,208,948 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide. SNCR Capital Costs (SNCR_{cost}) For Coal-Fired Utility Boilers: $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$ For Coal-Fired Industrial Boilers: $SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: SNCR_{cost} = 147,000 x ((Q_B/NPHR)x HRF)^{0.42} x ELEVF x RF SNCR Capital Costs (SNCR_{cost}) = \$2,099,024 in 2016 dollars Air Pre-Heater Costs (APH_{cost})* For Coal-Fired Utility Boilers: $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$ For Coal-Fired Industrial Boilers: $APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$ Air Pre-Heater Costs (APH_{cost}) = \$0 in 2016 dollars * Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 0.3lb/MMBtu of sulfur dioxide. Balance of Plant Costs (BOP_{cost}) For Coal-Fired Utility Boilers: $BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Utility Boilers: $BOP_{cost} = 213,000 \text{ x} (B_{MW})^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x RF}$ For Coal-Fired Industrial Boilers: $BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x Removed/hr)^{0.12} \times BTF \times RF$ For Fuel Oil and Natural Gas-Fired Industrial Boilers: $BOP_{cost} = 213,000 \text{ x} (Q_{R}/NPHR)^{0.33} \text{ x} (NO_{x}Removed/hr)^{0.12} \text{ x} RF$ Balance of Plan Costs (BOP_{cost}) = \$2,677,090 in 2016 dollars

Annual Costs

Total Annual Cost (TAC)

TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$477,565 in 2016 dollars
Indirect Annual Costs (IDAC) =	\$611,129 in 2016 dollars
Total annual costs (TAC) = DAC + IDAC	\$1,088,694 in 2016 dollars

Direct Annual Costs (DAC)

DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$93,134 in 2016 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$372,444 in 2016 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$9,166 in 2016 dollars
Annual Water Cost =	q _{water} x Cost _{water} x t _{op} =	\$0 in 2016 dollars
Additional Fuel Cost =	Δ Fuel x Cost _{fuel} x t _{op} =	\$2,739 in 2016 dollars
Additional Ash Cost =	$\Delta Ash x Cost_{ash} x t_{op} x (1/2000) =$	\$82 in 2016 dollars
Direct Annual Cost =		\$477,565 in 2016 dollars

Indirect Annual Cost (IDAC)

IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,794 in 2016 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$608,335 in 2016 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$611,129 in 2016 dollars

Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$1,088,694 per year in 2016 dollars
NOx Removed =	318 tons/year
Cost Effectiveness =	\$3,419 per ton of NOx removed in 2016 dollars

Four Boilers Dry Sorbent Injection System - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Gross Output based on sum of turbines rated size; 20MW, 5MW, and 2.5 MW)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input (Heat Rate is higher because district heating is not included in unit size)
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input (Based on source testing 2011)
Type of Coal	Е		sub-bituminous	< User Input
Particulate Capture	F		Baghouse	< User Input
Milled Trona	G		TRUE	Based on in-line milling equipment
				Maximum Removal Targets:
				Unmilled Trong with an ESP = 65%
				Milled Trona with an ESP = 80%
Removal Target	н	(%)	70	Unmilled Trona with a Bachouse = 80%
				Milled Trona with Bachouse = 90%
				Simplified correlation: 70% removal with bachouse, S&L (2013)
Heat Input	1	(Btu/br)	495 000 000	
near mput	5	(Dtd/III)	433,000,000	1 browned by $1 browned$ and $1 browned$ by $1 browned$ browned by $1 browned$ browned by $1 browned$ browned by $1 browned$ browned
				$\frac{1}{2} \frac{1}{2} \frac{1}$
NCD	K		1 55	$\lim_{n \to \infty} u_n u_n = 0.57 = \lim_{n \to \infty} u_n (u_n (u_n (u_n (u_n (u_n (u_n (u_n ($
INSK	n		1.55	$\begin{array}{c} \text{Olymmidd} \text{Torse with all DGH} = \ (n <40,0.0215 \text{ m},0.2356^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01610 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0201 \text{ m}))\\ \text{Milled Torse with an DGH} = \ (0 <0.01600 \text{ m},0.0256^{\circ}(0.0256^{\circ$
				$\lim_{n \to \infty} u_n \le u_n u_n u_n \le u_n u_n u_n u_n u_n u_n u_n u_n $
		(; #)		1.35 Recommended for a bagnouse at a target of 70% removal. S&L (2013)
Irona Feed Rate	M	(ton/hr)	0.28	(1.2011x10~06) % A C D
Sorbent Waste Rate	N	(ton/hr)	0.185	(0.7035-0.00073696*H/K)*M Based on a final reaction product of Na2SO4 and unreacted dry sorbent as Na2CO3.
				(A*C)*Ash incoal*(1-Boiler Ash Removal)/(2*HHV)
				For Bituminous Coal: Ash in Coal = 0.12; Boiler Ash Removal = 0.2, HHV = 11,000
Fly Ash Waste Rate	Р	(ton/hr)	0.92	For PRB Coal: Ash in Coal = 0.06; Boiler Ash Removal = 0.2, HHV = 8,400
				For Lignite Coal: Ash in Coal = 0.08; Boiler Ash Removal = 0.2, HHV = 7,200
				< User Input (Usibelli Coal: Ash in Coal = 0.07; Boiler Ash Removal = 0.6; HHV = 7,560)
Aux Power	Q	(%)	0.20	=if Milled Trona M*20/A else M*18/A
Trona Cost	R	(\$/ton)	550	< User Input (based on Stanley Consultant price reference)
Waste Disposal Cost	S	(\$/ton)	50	
Aux Power Cost	 T	(\$/kWh)	0.21	< User Input (http://www.gyea.com/rates/rates)
Operating Labor Rate	U .	(\$/hr)	63	< User Input (Labor cost including all benefits (AE 2016))
IPM Model - Updates to Cost and Performan	nce for APC Technologies -	Dry Sorbent Inic	ection for SO2 Control Co	st Development Methodology, March 2013, prepared by Sargent & Lundy LLC for LISEPAhttps://www.epa.gov/sites/production/files/2015
			07/	/documents/append5 4.pdf
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment installation buildin	ng foundations electrical ar	nd a retrofit diffic	ulty factor of 1.5	
moladoo Equipmont, motanation, panan	ig, roundatione, creethear, a			
Base Module (BM) (\$)		=	\$ 14,169,111	Base DSI module includes all equipment from unloading to injection but not including field installation
Unmilled Trona = if(M >25 then (682.00)	0* <mark>B*M</mark>) else 6.833.000* <mark>B</mark> *(M	^0.284)	•,	
Milled Trona = if(M>25 then (750.000*	*M) else 7.516.000*B*(M^0.	.284)		
BM (\$/kW)	,	=	\$ 515	Base module cost per kW
			•	
Total Project Cost				
A1 = 20% of BM		=	\$ 2,833.822	Engineering and construction management costs (CC Manual) (Stanley Consultants)
A2 = 10% of BM		=	\$ 1.416.911	Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual)
A3 = 10% of BM		=	\$ 1.416.911	Contractor profit and fees (CC Manual) (Stanley Consultants)
CECC (\$) - Excludes Owner's Costs =	BM + A1 + A2 + A3	=	\$ 19,836,755	Capital, engineering, and construction costs subtotal
CECC (\$/kW) - Excludes Owner's Cost	s	=	\$ 721	Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 991,838	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE	CC + B1	=	\$ 20,828,593	Total project cost without Allowance for Funds Used During Construction (AFUDC)
TPC (\$/kW) - Include Owner's Costs		=	\$ 757	Total project cost per kW without AFUDC
B2 = 0% of (CECC + B1)		=		AFUDC (Zero for less than 1 year engineering and construction cycle)
			¢	
$IPC(\mathbf{a}) = CECC + B1 + B2$		=	\$ 20,682,000	Total project cost (spreadsneet = \$20,828,523; Stanley Consultants Cost estimate = \$20,682,000)
1 PC (\$/KW)		=	ə 752	i otal project cost per kw

Dry Sorbent Injection System - Chena Power Plant

Direct Annual Costs			
Fixed Operating and Maintenance (O&M) Cost			
FOMO (\$/kW yr) = (2 additional operators)*(2080)*U/(A*1000) FOMM (\$/kW yr) = BM*0.01/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM) FOM (\$/kW yr) = FOMO + FOMM + FOMA	= = =	\$ \$ \$	 9.53 Fixed O&M additional operating labor costs (2 additional operators is more realistic) 3.43 Fixed O&M additional maintenance material and labor costs 0.33 Fixed O&M additional administrative labor costs 13.29 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = M*R/A VOMW (\$/MWh) = (N+P)*S/A VOMP (\$/MWh) = Q*T*10 VOM (\$/MWh) = VOMR + VOMW + VOMP	= = =	\$ \$ \$	 5.53 Variable O&M costs for Trona reagent 2.00 Variable O&M costs for waste disposal that includes both the sorbent and the fly ash waste not removed prior to the sorbent injection 0.423 Variable O&M costs for additional auxiliary power required (Refer to Aux Power % above) 7.96 Total Variable O&M Costs (\$/MW yr)
Indirect Annual Costs			
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$]i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980TOTAL INDIRECT ANNUAL OPERATING COSTSTOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = =	\$ \$ \$ \$ \$ \$	219,322 CC Manual 413,640 CC Manual 206,820 CC Manual 206,820 CC Manual Revise interest rate to prime (currently 5.25%) per EPA comment Reality is 10 years of useful life of the oldside; 30 years control equipment lifetime based on EPA comments on ADEC Prelim. BACT 2,026,363 CC Manual 3,072,965 5,356,087
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= =	\$	584.6 536.4 4,914,480
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= = =	\$	651 70 456 10,785

Four Boilers Spray Dry Absorber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on total heat input of 497 MMBtu/hour)
Retrofit Factor	В	· · · /	1.5	< User Input (An "average" retrofit has a factor of 1.0. Site-specific considerations provided by Aurora in 12/22/17 BACT Addendum)
Gross Heat Rate	С	(Btu/kWh)	18,000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input (SDA FGD Estimation only valid up to 3lb/MMBtu SO2 Rate)
Type of Coal	Е		sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous=1.05, Lignite=1.07
Heat Rate Factor	G		1.800	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A*C*1000
Lime Rate	К	(ton/hr)	0.101	(0.6702*(D^2)+13.42*D)*A*G/2000 (Based on 95% SO2 Removal)
Waste Rate	L	(ton/hr)	0.234	(0.8016*(D^2)+31.1917*D)*A*G/2000
Aux Power	М	(%)	2.461	(0.000547*(D^2)+0.00649*D+1.3)*F*G Should be used for model input
Makeup Water Rate	Ν	(1000 gph)	2.874	(0.04898*(D^2)+0.5925*D+55.11)*A*F*G/1000
Lime Cost	Р	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf) (GVEA Limestone cost)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	< User Input (http://www.newsminer.com/water-rates/article 11a2ba10-c211-562e-8da9-87dd16a7b104.htm)
Operating Labor Rate	T	(\$/hr)	63	Labor cost including all benefits
IPM Mo	del - Undates to Cost and Performance for A		es - SDA EGD for	SO2 Control Cost Development Methodology, March 2013, prepared by Sargent & Lundy LLC for LIS EPA
	https://		ites/production/file	2012 Control Cost Destrophism methodology, match 2010, propared by Cargent & Editory ELC for CC ET A.
	https://	www.epa.gov/s	nes/production/me	sizo naonao naona ana ana ana ana ana ana a
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, buildin	g, foundations, electrical, and a retrofit diffic	ulty factor of 1.5		
BMR (\$) = if(A>600 then (A*92,000) else	566,000*(A^0.716))*B*(F*G)^0.6*(D/4)^0.01	=	\$ 13,004,722	Base module absorber island cost
BMF (\$) = if(A>600 then (A*48,700) else	300,000*(A^0.716))*B*(D*G)^0.2	=	\$ 4,268,968	Base module reagent preparation and waste recycle/handling cost
BMB (\$) = if(A>600 then (A*129,900) else	e 799,000*(A^0.716))*B*(F*G)^0.4	=	\$ 16,587,654	Base module balance of plan costs inlcuding: ID or booster fans, piping, ductwork, electrical, etc.
BM (\$) = BMR + BMF + BMB BM (\$/kW)		= =	\$ 33,861,344 \$ 1,231	Total base module cost including retrofit factor Base module cost per kW
Total Project Cost				
A1 = 10% of BM A2 = 10% of BM A3 = 10% of BM		= = =	 \$ 3,386,134 \$ 3,386,134 \$ 3,386,134 	Engineering and construction management costs Labor adjustment for 6 x 10 hour shift premium, per diem, etc. Contractor profit and fees
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cost	BM + A1 + A2 + A3 s =	= =	\$ 44,019,747 \$ 1,601	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,200,987	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	CC + B1	= =	\$ 46,220,735 \$ 1,681	Total project cost without Allowance for Funds Used During Construction (AFUDC) Total project cost per kW without AFUDC
B2 = 10% of (CECC + B1)		=	\$ 4,622,073	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and TPC (\$/kW) - Includes Owner's Costs a	AFUDC = CECC + B1 + B2 and AFUDC =	= =	\$ 50,842,808 \$ 1,849	Total project cost Total project cost per kW

Spray Dry Absorber - Chena Power Plant

Direct Annual Costs	
Fixed Operating and Maintenance (O&M) Cost	
FOMO (\$/kW yr) = (4 additional operators)*(2080)*T/(A*1000) FOMM (\$/kW yr) = BM*0.015/(B*A*1000) FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	= \$ 38.12 Fixed O&M additional operating labor costs = \$ 12.31 Fixed O&M additional maintenance material and labor costs = \$ 1.29 Fixed O&M additional administrative labor costs
FOM (\$/kW yr) = FOMO + FOMM + FOMA	= \$ 51.73 Total Fixed O&M costs
Variable O&M Cost	
VOMR (\$/MWh) = K*P/A	= \$ 0.88 Variable O&M costs for lime reagent
VOMW (\$/MWh) = L*Q/A	= \$ 0.25 Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	= \$ 5.17 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N *S /A	= \$ 0.75 Variable O&M costs for makeup water
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM	= \$ 7.06 Total Variable O&M Costs
Indirect Annual Costs	
Overhead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980TOTAL INDIRECT ANNUAL OPERATING COSTS	 \$ 853,468 CC Manual \$ 1,016,856 CC Manual \$ 508,428 CC Manual \$ 508,428 CC Manual \$ 508,428 CC Manual \$ 4,981,433 CC Manual \$ 7,868,614
TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= \$ 10,990,629
Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= 584.6 = 536.4 = \$ 10,084,456
TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST-EFFECTIVENESS, \$/ton removed	= 651 = 90 = 586 = \$ 17,213

Four Boilers Wet Scrubber - Chena Power Plant

Variable	Designation	Units	Value	Calculation
Unit Size (Gross)	A	(MW)	27.5	< User Input (Conservative assumption based on a total heat input of 497 MMBtu/hr)
Retrofit Factor	В		1.5	< User Input (An "average" retrofit has a factor of 1.0) Sargent and Lundy has a drop down menu for selection of an additional waste water treatment plant facility, but no capital or operational cost are implemented so it is not reproduced here.
Gross Heat Rate	С	(Btu/kWh)	18.000	< User Input
SO2 Rate	D	(lb/MMBtu)	0.30	< User Input
Type of Coal	E	(,	sub-bituminous	< User Input
Coal Factor	F		1.05	Bituminous = 1, Sub-Bituminous = 1.05, Lignite = 1.07
Heat Rate Factor	G		1.8	C/10000
Heat Input	Н	(Btu/hr)	495,000,000	A ⁺ C ⁺ 1000
Limestone Rate	К	(ton/hr)	0.13	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	0.236	1.811*K
Aux Power	Μ	(%)	2.079	(1.05e^(0.155*D))*F*G
Makeup Water Rate	N	(1000 gph)	3.908	(1.674*D+74.68)* A *F*G/1000
Limestone Cost	P	(\$/ton)	240	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Waste Disposal Cost	Q	(\$/ton)	30	< User Input (https://www3.epa.gov/ttncatc1/dir1/ffdg.pdf)
Aux Power Cost	R	(\$/kWh)	0.21	< User Input (http://www.gvea.com/rates/rates)
Makeup Water Cost	S	(\$/1000 gal)	7.17	User Input (http://www.newsminer.com/water-rates/article_11a2ba10-c211-562e-8da9-87dd16a7b104.html)
Operating Labor Rate	Т	(\$/hr)	63	Labor cost including all benefits
IPM Model -	Updates to Cost and Performance for APC T	echnologies - W	et FGD for SO2 C	ontrol Cost Development Methodology, August 2010, prepared by Sargent & Lundy LLC for US EPA.
	https://www	.epa.gov/sites/p	oduction/files/2015	-07/documents/chapter_5_appendix_5-1a_wet_fgd.pdf
Capital Cost Calculation (2012 dollars)				Comments
Includes - Equipment, installation, building	ng, foundations, electrical, minor physical/che	emical waste wa	ter treatment, and a	a retrofit difficulty factor of 1.5
BMR (\$) = 550,000*(B)*((F*G)^0.6)*((D/	2)^0.02)*(A^0.716)	=	\$ 12,485,962	Base absorber island cost
BMF (\$) = 190,000*(B)*((D*G)^0.3)*(A^0).716)	=	\$ 2,542,315	Base reagent preparation cost
BMW (\$) = 100,000*(B)*((D*G)^0.45)*(A	^0.716)	=	\$ 1,220,076	Base waste handling cost
BMB (\$) = 1,010,000*(B)*((F*G)^0.4)*(A	^0.716)	=	\$ 20,968,123	Base balance of plan cost including: ID or booster fans, new wet chimney, piping, ductwork, minor waste water treatment, etc
BMWW (\$) =		=	\$-	Base wastewater treatment facility, beyond minor physical/chemcial treatment
Base Module (BM) (\$) = BMR + BMF + I BM (\$/kW)	BMW + BMB + BMWW	= =	\$ 37,216,477 \$ 1,353	Total base cost including retrofit factor Base cost per kW
Total Project Cost				
A1 = 10% of BM A2 = 10% of BM A3 = 10% of BM		= = =	\$ 3,721,648 \$ 3,721,648 \$ 3,721,648	Engineering and construction management costs (CC Manual) Labor adjustment for 6 x 10 hour shift premium, per diem, etc. (CC Manual) Contractor profit and fees (CC Manual)
CECC (\$) - Excludes Owner's Costs = CECC (\$/kW) - Excludes Owner's Cos	BM + A1 + A2 + A3 ts =	= =	\$ 48,381,420 \$ 1,759	Capital, engineering, and construction costs subtotal Capital, engineering, and construction costst subtotal per kW
B1 = 5% of CECC		=	\$ 2,419,071	Owner's costs including all "home office" costs (owner's engineering, management, and procurement activities)
TPC (\$) - Includes Owners Costs = CE TPC (\$/kW) - Include Owner's Costs =	ECC + B1	= =	\$	Total project cost without Allowance for Funds Used During Construction (AFUDC) Total project cost per kW without AFUDC
B2 = 10% of (CECC + B1)		=	\$ 5,080,049.08	AFUDC (based on a 3 year engineering and construction cycle)
TPC (\$) - Includes Owner's Costs and TPC (\$/kW) - Includes Owner's Costs	AFUDC = CECC + B1 + B2 and AFUDC =	=	\$	Total project cost Total project cost per kW

Wet Scrubber - Chena Power Plant

		_	
Direct Annual Costs			
Fixed O&M Cost			
EOMO(\$/k/k/yr) = (6 additional operators)*(2080)*T/(4*1000)	_	¢	28.50. Fixed O&M additional operation labor costs
FOMO((5/kW yr) = (6 autilional operators) (2000) T/(A 1000) FOMM (5/kW yr) = BM*0.015/(B*A*1000)	_	¢ 2	20.55 Tixed Oak additional maintenance material and labor costs
FOMA (\$/k/(/yr) = 0.03*(FOMO+0.4*FOMM))	_	φ S	1.0.2 Fixed O&M additional amainteriance interiation and labor costs
FOMWW (\$/kW yr) = 0.03 (100000.4 100000)	-	\$	Fixed O&M costs for waterwater treatment facility
		Ψ	
FOM (\$/kW yr) = FOMO + FOMM + FOMA + FOMWW	=	\$	43.14 Total Fixed O&M costs (\$/kW yr)
Variable O&M Cost			
VOMR (\$/MWh) = K*P/A	=	\$	1.14 Variable O&M costs for limestone reagent
	_	¢	0.20 Visible OPM sects for words diagonal
VOMW(S/MVVN) = L Q/A	=	Φ	U.26 Variable U&MI Costs for waste disposar
VOMP ($\%$ /MWh) = M*R*10	=	\$	4.37 Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N* <mark>S</mark> /A	=	\$	1.02 Variable O&M costs for makeup water
		*	
VOMWW (\$/MVVn) =	=	\$	 Variable U&M costs for wastewater treatment facility
VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW	-	\$	6.78 Total Variable O&M Costs (\$/MW vr)
	-	•	
Indirect Annual Costs			
		~	711 97E CC Monual
Overhead (60% of total labor and material costs)	=	\$	
Administrative charges (2% of total capital investment)	=	\$ \$	1,117,611 CC Manual
Administrative charges (2% of total capital investment) Property tax (1% of total capital investment)	= = =	л \$ \$ \$	1,117,611 CC Manual 558,805 CC Manual
Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment)	= = =	» % % %	1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1]	= = =	» % % %	11,17,610 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25	= = =	» % %	11,17,610 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%) 5.25 n = Equipment life (years) 15	= = =	» % %	1,117,611 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980	= = = =	» % %	558,805 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs)Administrative charges (2% of total capital investment)Property tax (1% of total capital investment)Insurance (1% of total capital investment)Capital Recovery Factor (CRF) = [i $(1+i)^n / [(1+i)^n - 1]$ i = Interest rate (%)5.25n = Equipment life (years)15CRF =0.0980	= = = =	A (A (A) (A)	11,17,611 CC Manual 558,805 CC Manual 558,805 CC Manual 558,805 CC Manual
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i $(1+i)^n$] / [$(1+i)^n - 1$] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS	= = = =	> \$ \$ \$ \$ \$	11,17,61 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980	= = = =	> \$ \$ \$	111,615 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)		> \$ \$ \$ \$ \$ \$	111,615 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Linsurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)	= = = = = =	ን\$\$\$ \$ \$	1,117,61 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$)		∌\$\$\$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cert year of equation)	= = = = = =	∌\$\$\$\$ \$ \$	11,17,611 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 584.6
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review)	= = = = = = = =	♪\$\$\$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)		>>>>> \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Lospital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = = =	↑ \$\$ \$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Lospital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)	= = = = = = = = = =	∌\$\$\$\$\$\$\$\$\$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons		↑\$\$\$\$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, %		\$ \$ \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$)		\$ \$ \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Lospital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons		> S * \$ \$ \$	111,613 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644
Overnead (60% of total labor and material costs) Administrative charges (2% of total capital investment) Property tax (1% of total capital investment) Insurance (1% of total capital investment) Insurance (1% of total capital investment) Capital Recovery Factor (CRF) = [i (1+i) ⁿ] / [(1+i) ⁿ - 1] i = Interest rate (%) 5.25 n = Equipment life (years) 15 CRF = 0.0980 TOTAL INDIRECT ANNUAL OPERATING COSTS TOTAL ANNUALIZED OPERATING COSTS (2012 \$) Composite CE Index for 2012 (cost year of equation) Composite CE Index for 2016 (cost year of review) TOTAL ANNUALIZED OPERATING COSTS (2016 \$) TOTAL UNCONTROLLED SO ₂ EMISSIONS, tons SO ₂ REMOVAL EFFICIENCY, % TOTAL SO ₂ REMOVED, tons SO ₂ COST_EFEFECTIVENESS, \$/ton removed		> S S S S S S S S S	111,013 CC Manual 558,805 CC Manual 558,805 CC Manual 5,475,016 CC Manual 8,422,112 11,241,441 584.6 536.4 10,314,589 651 99 644 16 005 Doce not include costs associated with building and maintaining a wastewater tratment facility.

Appendix C (Coal Analyses Summary)

	Coal Analyses Summary (As Received)											
Year	Report	Coal	HHV	Moisture	Sulfur							
Units		(tons)	(btu/lb)	(%)	(%)							
2013	А	103,122.35	7,670	27.22	0.15							
2013	В	115,917.00	7,599	27.95	0.17							
2014	А	117,659.65	7,652	27.89	0.15							
2014	В	103,979.45	7,617	27.86	0.14							
2015	А	103,904.80	7,599	29.16	0.14							
2015	В	120,758.30	7,610	29.02	0.15							
2016	А	115,282.20	7,683	31.21	0.12							
2016	В	107,687.35	7,604	29.23	0.14							
2017	А	106,040.35	7,567	32.20	0.11							
2017	В	114,440.00	7,529	32.52	0.10							
Weight	ed average	221,758.29	7,613	29.44	0.14							

Rail Samples

Analysis	Results	for	6/1/13	to	6/30/13

Customer	Date	#Cars	вти	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	6/3/2013	8	7490	28.62	8.57	35.96	26.86	0.13	тн	V6	6	741.40
AURORA ENERGY LLC	6/4/2013	13	7552	28.06	8.58	36.44	26.93	0.12	ΤII	V6	6	1,177.90
AURORA ENERGY LLC	6/6/2013	14	7303	28.45	10.15	34.89	26.51	0.14	ΤIJ	V6	6	1,308.40
AURORA ENERGY LLC	6/10/2013	16	7414	28.08	9.77	35.36	26.78	0.13	TH	V6	6	1,513.40
AURORA ENERGY LLC	6/13/2013	19	7528	27.82	9.38	35.66	27.15	0.15	ΤH	V6	6	1,749.25
AURORA ENERGY LLC	6/17/2013	7	7626	27.41	9.41	35.51	27.67	0.15	ти	V6	6	656.20
AURORA ENERGY LLC	6/18/2013	23	7682	28.49	7.14	36.88	27.50	0.14	ΤII	V6	6	2,079.85
AURORA ENERGY LLC	6/20/2013	26	7386	27.49	10.19	35.92	26.40	0.13	ΤII	V6	6	2,365.55
AURORA ENERGY LLC	6/24/2013	14	7325	28.36	9.89	35.53	26.23	0.14	TII	V6	6	1,289.20
AURORA ENERGY LLC	6/26/2013	13	7522	28.53	8.56	34.56	28.35	0.19	ΤIJ	U4	4	1,202.85
AURORA ENERGY LLC	6/28/2013	19	7715	27.62	7.89	36.01	28.49	0.15	ТП	U4	4	1,751.50
AURORA ENERGY LLC	6/28/2013	12	7593	28.46	7.84	35.39	28.32	0.14	TH	U4	4	1,071.10
Weighted Averages Summ	ary										****	
Customer		Tons		BTU	Н	20	Ash		Volatiles	Carl	oon	Sulfur
AURORA ENERGY LLC		16906.6	D	7511.00	2	8.08	8.9	95	35.75	5 2	7.23	0.14

Rail Samples Analysis Results for 1/1/13 to 6/30/13

Customer	Date	#Cars	вти	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2013	10	7504	27.93	9.16	34.93	27.98	0.20	ΤII	Τ4	4	961.05
AURORA ENERGY LLC	1/3/2013	11	7599	26.87	9.32	35.99	27.83	0.18	P2/STK	C1	6/N	1,000.35
AURORA ENERGY LLC	1/4/2013	9	7685	27.59	8.22	36.39	27.81	0.17	P2/STK	C1	6/N	816.20
AURORA ENERGY LLC	1/5/2013	13	7711	27.47	8.17	36.74	27.63	0.18	P2/STK	C1	6/N	1,263.55
AURORA ENERGY LLC	1/7/2013	11	7612	27.77	8.70	35.41	28.12	0.17	P2/STK	C1	6/N	1,057.50
AURORA ENERGY LLC	1/8/2013	9	7565	26.55	10.25	35.37	27.84	0.17	TII/P2	T4/C1	4/6	858.05
AURORA ENERGY LLC	1/9/2013	12	7584	27.03	9.43	35.53	28.01	0.18	T II/P2	T4/C1	4/6	1,113.90
AURORA ENERGY LLC	1/10/2013	6	7692	25.65	9.78	36.60	27.96	0.17	P2/STK	C1	6/N	562.40
AURORA ENERGY LLC	1/11/2013	13	7507	27.09	10.00	35.86	27.05	0.18	P2/STK	C1	6/N	1,223.50
AURORA ENERGY LLC	1/14/2013	9	7566	26.87	9.70	35.71	27.72	0.16	P2/STK	C1	6/N	872.75
AURORA ENERGY LLC	1/15/2013	14	7632	28.16	8.04	35.42	28.38	0.20	TII	Т4	4	1,261.60
AURORA ENERGY LLC	1/16/2013	12	7784	27.66	7.41	36.36	28.57	0.17	ΤI	Т4	4	1,096.85
AURORA ENERGY LLC	1/17/2013	7	7758	27.48	8.08	35.70	28.75	0.19	P2/STK	C1	6/N	645.20
AURORA ENERGY LLC	1/18/2013	11	7788	26.88	7.92	36.52	28.68	0.16	P2/STK	C1	6/N	1,007.45
AURORA ENERGY LLC	1/21/2013	8	7678	26.95	8.63	35.72	28.71	0.17	T II/STK	T 4	4/N	737.10
AURORA ENERGY LLC	1/22/2013	13	7709	27.10	8.34	35.59	28.98	0.18	T II/STK	T4	4/N	1,166.85
AURORA ENERGY LLC	1/23/2013	14	7746	27.10	8.39	36.04	28.47	0.17	P2/STK	C1	6/S	1,223.50
AURORA ENERGY LLC	1/25/2013	7	7754	27.88	7.45	36.79	27.89	0.15	P2/STK	C1	6/N	633.50
AURORA ENERGY LLC	1/25/2013	11	7585	26.81	9.72	36.20	27.28	0.15	P2/STK	C1	6/N	994.60
AURORA ENERGY LLC	1/28/2013	9	7484	26.40	11.09	35.58	26.94	0.15	P2/STK	C1	6/S	807.55
AURORA ENERGY LLC	1/29/2013	11	7691	26.62	9.22	36.11	28.05	0.15	P2/STK	C1	6/S	994.45
AURORA ENERGY LLC	1/30/2013	13	7482	28.23	9.21	35.05	27.52	0.16	P2/STK	C1	6/S	1,150.80
AURORA ENERGY LLC	1/31/2013	10	7460	26.87	10.25	34.89	27.99	0.15	TII/P2	T3/C1	3/6	920.60
AURORA ENERGY LLC	2/1/2013	8	7529	28.24	9.08	35.07	27.61	0.14	ŤII	Т3	3	763.65
AURORA ENERGY LLC	2/4/2013	7	7545	28.48	8.71	34.47	28.34	0.13	TH	Т3	3	629.95
AURORA ENERGY LLC	2/5/2013	11	7463	28.30	9.56	34.22	27.92	0.14	ŤΠ	Т3	3	1,015.15
AURORA ENERGY LLC	2/7/2013	8	7491	28.60	8.93	34.76	27.72	0.13	P2/TII	C1/T3	6/3	755.05
AURORA ENERGY LLC	2/8/2013	12	7637	27.97	8.09	36.09	27.86	0.14	P2/TII	C1/T3	6/3	1,113.25
AURORA ENERGY LLC	2/9/2013	12	7740	26.73	8.61	37.24	27.42	0.14	P2	C1	6	1,102.05
AURORA ENERGY LLC	2/11/2013	9	⁷⁵ 86	pendix II	I. ⁹ D ⁵ 7	.7-492	028.38	0.16	T II/P2	T3/C1	3/6	848.85

Rail Samples Analysis Results for 1/1/13 to 6/30/13

Constant of the	TAXAL TRANSPORTED AND A DATA DATA DATA DATA DATA DATA DA	****					*****	*****	dalar in the second second second			
AURORA ENERGY LLC	2/12/2013	15	7649	27.94	8.20	35.09	28.77	0.15	ΤII	Т3	3	1,378.10
AURORA ENERGY LLC	2/13/2013	21	7556	27.99	9.13	34,51	28.38	0.15	ти	Т3	3	1,914.10
AURORA ENERGY LLC	2/14/2013	8	7819	26.40	8.38	36.31	28.91	0.14	P2/STK	C1	6/N	701.80
AURORA ENERGY LLC	2/15/2013	15	7437	27.31	10.59	34.59	27.51	0.15	P2/STK	C1	6/S	1,300.35
AURORA ENERGY LLC	2/18/2013	9	7616	27.77	8.69	34,75	28.80	0.14	TII	Т3	3	852.10
AURORA ENERGY LLC	2/19/2013	5	8065	26.73	6.36	37.32	29.59	0.13	P2/STK	C1	6/S	448.60
AURORA ENERGY LLC	2/20/2013	18	7824	27.32	7.48	37.11	28.09	0.15	P2/STK	C1	6/S	1,648.60
AURORA ENERGY LLC	2/21/2013	7	7607	26.43	10.17	36.29	27.11	0.15	P2/STK	C1	6/S	615.40
AURORA ENERGY LLC	2/22/2013	15	7510	28.05	9.42	35.26	27.28	0.14	TII	Т3	3	1,390.45
AURORA ENERGY LLC	2/25/2013	9	7697	28.21	7.72	34.80	29.27	0.14	TII	Т3	3	817.70
AURORA ENERGY LLC	2/26/2013	14	7588	28.23	8.43	35.08	28.26	0.14	TII/P2	T3/C1	3/6	1,275.05
AURORA ENERGY LLC	2/28/2013	17	7872	27.40	6.91	37.27	28.43	0.15	P2/STK	C1	6/S	1,587.05
AURORA ENERGY LLC	3/4/2013	11	7508	26.13	11.00	35.23	27.65	0.15	P2/TII	C1/T3	6/3	1,033.95
AURORA ENERGY LLC	3/5/2013	11	7682	26,99	8.13	36.34	28.55	0.14	P2/STK	C1	6/S	959.30
AURORA ENERGY LLC	3/6/2013	14	7648	27.25	7.96	36.56	28.23	0.15	P2/STK	C1	6/S	1,302.85
AURORA ENERGY LLC	3/7/2013	7	7717	26.40	8.27	37.82	27.53	0.15	P2/STK	C1	6/S	619.15
AURORA ENERGY LLC	3/8/2013	6	7469	26.55	9.86	37.18	26.41	0.16	P2/STK	C1	6/S	538.30
AURORA ENERGY LLC	3/11/2013	11	7857	27.02	7.45	37.34	28.20	0.15	P2/STK	C1	6/S	1,016.00
AURORA ENERGY LLC	3/12/2013	13	7868	26.99	7.27	37.32	28.43	0.14	P2/STK	C1	6/S	1,200.55
AURORA ENERGY LLC	3/13/2013	18	7437	28.70	8.86	35.07	27.37	0.14	P2/STK	C1	6/S	1,586.50
AURORA ENERGY LLC	3/15/2013	7	7253	25.91	13.37	35.02	25.70	0.14	P2/STK	C1	6/S	652.45
AURORA ENERGY LLC	3/19/2013	11	7570	26.44	10.41	36.24	26.91	0.16	P2/STK	C1	6/S	1,034.15
AURORA ENERGY LLC	3/19/2013	8	7723	26.43	9.14	36.80	27.63	0.14	P2/STK	C1	6/S	734.00
AURORA ENERGY LLC	3/20/2013	11	7812	26.67	8.36	36.58	28.40	0.15	P2/STK	C1	6/S	1,058.60
AURORA ENERGY LLC	3/21/2013	3	7805	26.35	8.46	36.75	28.44	0.15	P2/STK	C1	6/S	264.35
AURORA ENERGY LLC	3/22/2013	8	7580	26.59	10.17	36.01	27.24	0.15	P2/STK	C1	6/S	747.60
AURORA ENERGY LLC	3/25/2013	6	7835	26.61	7.98	37.07	28.35	0.15	P2/STK	C1	6/S	545.80
AURORA ENERGY LLC	3/26/2013	10	7873	26.37	7.94	37.21	28.48	0.16	P2/STK	C1	6/S	911.95
AURORA ENERGY LLC	3/27/2013	11	7633	26.67	9.68	35.80	27.86	0.16	P2/STK	C1	6/S	1,011.95
AURORA ENERGY LLC	3/28/2013	4	7776	26.70	8.29	37.09	27.93	0.15	P2/STK	C1	6/S	363.85
AURORA ENERGY LLC	4/1/2013	6	7964	26.30	7.22	37.59	28.89	0.15	P2/STK	C1	6/S	527.90
AURORA ENERGY LLC	4/2/2013	11	79 A pp	endia I	∐ €D ≋7.	73492	129.16	0.15	P2/STK	C1	6/S	993.45

Rail Samples Analysis Results for 1/1/13 to 6/30/13

227727822727827278775555555555555555555	and the second	Birdelyanson and Hanna		****		AND A DESCRIPTION OF A DESCRIPTION		ACCORDING TO A CONTRACTOR OF A	CARDINELSCORE AND ADDRESS AND ADDRESS ADDR	****		and the first of the second data with the
AURORA ENERGY LLC	4/3/2013	10	7812	27.29	7.75	36.64	28.33	0.14	P2/STK	C1	6/S	935.20
AURORA ENERGY LLC	4/4/2013	5	7779	26.72	8.53	36.84	27.92	0.14	P2/STK	C1	6/S	458.50
AURORA ENERGY LLC	4/5/2013	9	7866	26.26	8.67	36.80	28.28	0.15	P2/STK	C1	6/N	855.30
AURORA ENERGY LLC	4/8/2013	10	7363	27.30	11.58	34.23	26.89	0.16	P2/JDRC	C1/C13	6/3	934.30
AURORA ENERGY LLC	4/9/2013	14	7381	29.34	8.61	35.20	26.86	0.14	TH	V6	6	1,269.45
AURORA ENERGY LLC	4/11/2013	10	7736	28.34	7.26	36.44	27.97	0.15	TII	V6	6	885.25
AURORA ENERGY LLC	4/11/2013	6	7591	28.62	7.89	36.55	26.95	0.14	TII	V6	6	556.70
AURORA ENERGY LLC	4/16/2013	11	7286	29.40	11.50	32.67	26.44	0.15	JD/GRP	C13	3/C	1,062.00
AURORA ENERGY LLC	4/16/2013	10	7385	29.01	10.61	33.14	27.25	0.17	JDRC	C13	3	939.50
AURORA ENERGY LLC	4/18/2013	8	7746	27.55	7.98	36.17	28.31	0.15	ΤII	V6	6	730.15
AURORA ENERGY LLC	4/20/2013	8	7783	26.84	9.01	35.88	28.28	0.16	T II/STK	V6	6/W	750.40
AURORA ENERGY LLC	4/22/2013	7	7659	27.90	8.10	36.27	27.74	0.16	T II/STK	V6	6/W	657.70
AURORA ENERGY LLC	4/23/2013	8	7706	27.47	8.38	36.53	27.61	0.16	T II/STK	V6	6/W	741.05
AURORA ENERGY LLC	4/25/2013	9	7589	27.83	8.91	36.03	27,24	0.15	ΤII	V6	6	856.65
AURORA ENERGY LLC	4/25/2013	7	7505	26.90	10.26	36.16	26.69	0.14	TII	V6	6	640.30
AURORA ENERGY LLC	4/26/2013	8	7601	27.54	8.54	37.23	26.69	0.15	TII	V6	6	746.30
AURORA ENERGY LLC	4/29/2013	10	7495	28.32	8.82	35.78	27.09	0.14	ΤI	V6	6	915.65
AURORA ENERGY LLC	4/30/2013	12	7123	27.64	12.55	34.60	25.21	0.14	ТΠ	V6	6	1,130.20
AURORA ENERGY LLC	5/1/2013	12	7962	24.90	11.11	35.05	28.95	0.17	GRP/STK		M/N	1,238.65
AURORA ENERGY LLC	5/2/2013	10	7815	25.21	11.77	34.52	28.51	0.17	GRP/STK		M/S	940.15
AURORA ENERGY LLC	5/3/2013	7	7574	25.05	13.91	33.39	27.66	0.18	GRP/STK		M/S	670.35
AURORA ENERGY LLC	5/3/2013	13	8042	24.57	11.80	34,49	29.14	0.18	GRP/STK		M/S	1,223.00
AURORA ENERGY LLC	5/6/2013	3	8200	23.89	10.98	34.73	30.41	0.19	GRP/STK		M/N	278.80
AURORA ENERGY LLC	5/20/2013	8	7876	26.05	9.72	36.04	28.19	0.16	GRP/STK		M/N	765.10
AURORA ENERGY LLC	5/21/2013	16	8437	24,71	8.98	35.53	30.78	0.18	GRP/STK		M/N	1,459.45
AURORA ENERGY LLC	5/23/2013	10	8746	23.37	8.77	35.33	32.54	0.18	GRP		М	954.30
AURORA ENERGY LLC	5/23/2013	11	8414	24.03	9.96	34.57	31.45	0.17	GRP		М	1,064.60
AURORA ENERGY LLC	5/27/2013	9	8508	23.93	9.27	35.49	31.31	0.18	GRP/STK		M/N	819.70
AURORA ENERGY LLC	5/28/2013	12	8514	24.06	9.27	35.30	31.38	0.18	GRP/STK		M/N	1,151.15
AURORA ENERGY LLC	5/30/2013	10	7619	27.91	8.56	36.48	27.05	0.13	ΤII	V6	6	956.70
AURORA ENERGY LLC	6/3/2013	8	7490	28.62	8.57	35.96	26.86	0.13	TH	V6	6	741.40
AURORA ENERGY LLC	6/4/2013	13	75 A pp	enalia I	∐≴D ≋7.	7361992	226.93	0.12	TH	V6	6	1,177.90

Rail Samples Analysis Results for 1/1/13 to 6/30/13

**************************************		warmed a second state in the			Constant of the low of the low of the		*****		A A MARK MARK THAT A MARK T	****		
AURORA ENERGY LLC	6/6/2013	14	7303	28.45	10.15	34.89	26.51	0.14	ТП	V6	6	1,308.40
AURORA ENERGY LLC	6/10/2013	16	7414	28.08	9.77	35.36	26.78	0.13	ТІІ	V6	6	1,513.40
AURORA ENERGY LLC	6/13/2013	19	7528	27.82	9.38	35.66	27.15	0.15	ΤI	V6	6	1,749.25
AURORA ENERGY LLC	6/17/2013	7	7626	27.41	9.41	35.51	27.67	0.15	ти	V6	6	656.20
AURORA ENERGY LLC	6/18/2013	23	7682	28.49	7.14	36.88	27.50	0.14	ТІІ	V6	6	2,079.85
AURORA ENERGY LLC	6/20/2013	26	7386	27.49	10.19	35.92	26.40	0.13	ΤII	V6	6	2,365.55
AURORA ENERGY LLC	6/24/2013	14	7325	28.36	9.89	35.53	26.23	0.14	TII	V6	6	1,289.20
AURORA ENERGY LLC	6/26/2013	13	7522	28.53	8.56	34.56	28.35	0.19	T II	U4	4	1,202.85
AURORA ENERGY LLC	6/28/2013	19	7715	27.62	7.89	36.01	28.49	0.15	TI	U4	4	1,751.50
AURORA ENERGY LLC	6/28/2013	12	7593	28.46	7.84	35.39	28.32	0.14	ТІІ	U4	4	1,071.10
Weighted Averages Sur	nmary								_			
Customer		Tons		BTU	H	20	Ash		Volatiles	Cart	on	Sulfur
AURORA ENERGY LLC		103122.3	5	7670.00	2	7.22	9.	05	35.76	27	7.98	0.15

This analysis is representative of the coal shipped using sulfur standard ASTM D4239-12

Coleen Strompson

Rail Samples Analysis Results for 7/1/13 to 12/31/13

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/1/2013	7	7360	26.50	11.80	35.40	26.30	0.15	TBR	C1	6	652.55
AURORA ENERGY LLC	7/2/2013	21	7675	26.40	9.51	36.33	27.77	0.15	TBR	C1	6	1,961.70
AURORA ENERGY LLC	7/5/2013	23	7565	27.34	9.39	34.94	28.34	0.19	T II	U4	4	2,171.90
AURORA ENERGY LLC	7/8/2013	10	7538	28.53	8.36	34.23	28.88	0.19	TII	U4	4	917.50
AURORA ENERGY LLC	7/9/2013	29	7645	28.51	7.49	35.44	28.57	0.16	ΤII	U4	4	2,700.95
AURORA ENERGY LLC	7/11/2013	13	7502	28.50	8.82	35.62	27.06	0.18	TBR	C1	6	1,224.95
AURORA ENERGY LLC	7/15/2013	12	7485	29.53	7.66	35.01	27.81	0.19	and a second	U4	4	1,067.35
AURORA ENERGY LLC	7/16/2013	11	7317	27.95	10.29	34.12	27.68	0.25	T II	U4	4	1,019.50
AURORA ENERGY LLC	7/22/2013	11	7609	28.80	7.97	34.86	28.37	0.18	ΤI	U4	4	1,018.45
AURORA ENERGY LLC	7/24/2013	25	7467	28.43	8.50	34.68	28.41	0.19	ΤII	U4	4	2,303.20
AURORA ENERGY LLC	7/25/2013	13	7416	28.52	9.36	34.76	27.37	0.20	TI	U4	4	1,239.20
AURORA ENERGY LLC	7/29/2013	9	7339	29.30	9.16	33.88	27.67	0.20	ТΙΙ	U4	4	836.20
AURORA ENERGY LLC	8/1/2013	27	7749	27.87	8.65	34.52	28.97	0.15	JR/GRP	° C13	4/M	2,483.15
AURORA ENERGY LLC	8/5/2013	10	7833	27.43	9.00	34.23	29.35	0.17	JD/GRP	C13	4/M	948.40
AURORA ENERGY LLC	8/6/2013	18	7752	29.20	7.09	34.40	29.31	0.14	JR/GRP	C13	4/M	1,657.00
AURORA ENERGY LLC	8/8/2013	12	7737	28.58	7.91	34.30	29.22	0.14	JR/GRP	C13	4/M	1,172.25
AURORA ENERGY LLC	8/8/2013	16	7648	28.65	8.33	34.49	28.53	0.13	JR/GRP	• C13	4/M	1,524.25
AURORA ENERGY LLC	8/9/2013	12	7552	28.48	8.20	35.34	27.99	0.20	тп	U4	4	1,085.70
AURORA ENERGY LLC	8/12/2013	7	7610	28.79	7.51	34.66	29.05	0.16	TII	U4	4	657.40
AURORA ENERGY LLC	8/13/2013	17	7503	29.40	8.11	34.39	28.11	0.15	JR/T II	C13/U4	4/4	1,550.05
AURORA ENERGY LLC	8/19/2013	9	7696	28.53	8.03	34.46	29.00	0.16	JR	C13	4	834.85
AURORA ENERGY LLC	8/20/2013	17	7764	28.71	7.65	34.86	28.79	0.14	JR/GRP	C13	4/M	1,569.00
AURORA ENERGY LLC	8/22/2013	11	8309	24.18	10.01	34.82	31.00	0.20	GRP/STI	к	M/N	1,008.60
AURORA ENERGY LLC	8/22/2013	15	8288	24.11	9.99	35.32	30.58	0.17	GRP/ST	к	M/N	1,412.05
AURORA ENERGY LLC	8/26/2013	5	7656	27.01	10.63	33.80	28.57	0.19	t II/GRF	• U3	3/M	491.15
AURORA ENERGY LLC	8/27/2013	12	7557	27.38	10.91	33.44	28.26	0.15	t II/grf	° U3	3/M	1,141.90
AURORA ENERGY LLC	8/28/2013	10	7705	27.60	9.20	34.46	28.74	0.14	t II/grf	• U3	3/M	905.40
AURORA ENERGY LLC	8/29/2013	12	7822	26.89	10.18	34.14	28.79	0.15	TII/GRP	U3	3/M	1,149.70
AURORA ENERGY LLC	9/3/2013	11	7996	26.39	10.28	34.01	29.33	0.16	TII/GRP	U3	3/M	1,048.10
AURORA ENERGY LLC	9/5/2013	10	⁷ Å54	enâix II	I. ¹ D .7.	7 <u>3</u> 4924	4 ^{28.61}	0.15	t II/grf	P U3	3/M	935.45

Rail Samples Analysis Results for 7/1/13 to 12/31/13

CTO-ICITERATE/INCOMMENDIN		UCITARIATIASSISSINGUSS		CONTRACTOR DATE OF THE OWNER OWNE		****		Constant of the second s		****	514941144192721949419612wakkeeyydasaaaas	***************************************
1,051.50	3	U3	ТΙΙ	0.12	28.58	34.71	8.70	28.02	7566	12	9/5/2013	AURORA ENERGY LLC
808.00	3	U3	ТП	0.12	28.01	35.10	8.73	28.16	7584	9	9/7/2013	AURORA ENERGY LLC
479.85	3	U3	ТΠ	0.13	28.66	34.02	8.44	28.89	7525	5	9/9/2013	AURORA ENERGY LLC
1,938.20	3	C13	JR	0.13	25.09	32.88	12.49	29.54	6894	20	9/11/2013	AURORA ENERGY LLC
1,900.70	3/N	U3	TII/STK	0.13	28.50	34.77	8.74	27.99	7578	20	9/13/2013	AURORA ENERGY LLC
769.35	3	U3	TII	0.12	28.43	34.53	9.36	27.68	7507	8	9/16/2013	AURORA ENERGY LLC
1,134.85	3	U3	ТП	0.13	27.99	34.24	8.87	28.91	7474	12	9/18/2013	AURORA ENERGY LLC
1,756.50	3	U3	ŤΠ	0.12	28.06	34.11	9.45	28.38	7447	18	9/19/2013	AURORA ENERGY LLC
1,459.60	3	U3	ТΙΙ	0.12	28.75	34.37	8.52	28.36	7567	15	9/20/2013	AURORA ENERGY LLC
2,034.85	6	C1	TBR	0.15	26.81	35.65	9.98	27.57	7503	21	9/24/2013	AURORA ENERGY LLC
1,425.25	6	C1	TBR	0.15	27.16	36.33	9.92	26.60	7615	15	9/25/2013	AURORA ENERGY LLC
1,261.65	6	C1	TBR	0.15	26.88	37.08	9.47	26.57	7626	13	9/26/2013	AURORA ENERGY LLC
572.95	6	C1	TBR	0.15	26.95	35.62	10.47	26.97	7556	6	9/30/2013	AURORA ENERGY LLC
758.30	6	C1	TBR	0.18	27.20	33.98	11.21	27.62	7354	8	10/2/2013	AURORA ENERGY LLC
1,009.45	4	V4	ТΙΙ	0.16	28.69	34.36	9.13	27.82	7515	11	10/7/2013	AURORA ENERGY LLC
2,203.90	4	V4	ŤΠ	0.15	27.36	33.77	10.30	28.57	7298	23	10/10/2013	AURORA ENERGY LLC
1,618.40	4	V4	ΤII	0.21	27.32	34.26	10.17	28.25	7295	17	10/11/2013	AURORA ENERGY LLC
1,250.95	4	V4	ΤII	0.21	29.43	34.47	8.67	27.43	7770	13	10/15/2013	AURORA ENERGY LLC
834.60	4	V4	Τ (Ι	0.18	28.94	34.71	8.19	28.16	7622	9	10/16/2013	AURORA ENERGY LLC
1,448.90	4	V4	ТШ	0.19	28.78	34.73	7.77	28.73	7560	16	10/17/2013	AURORA ENERGY LLC
1,209.15	4	V4	TII	0.18	28.93	35.43	7.91	27.73	7582	13	10/18/2013	AURORA ENERGY LLC
1,476.80	4	V4	ΤII	0.20	28.53	34.45	9.19	27.84	7584	15	10/21/2013	AURORA ENERGY LLC
1,280.80	4	V4	ТΗ	0.20	27.95	34.58	9.43	28.05	7492	13	10/22/2013	AURORA ENERGY LLC
1,756.85	4	V4	ΤIJ	0.20	28.52	34.70	8.52	28.26	7557	18	10/23/2013	AURORA ENERGY LLC
1,307.25	4 4/4	V4/W4	T II/T II	0.20	27.88	34.75	9.52	27.86	7539	14	10/26/2013	AURORA ENERGY LLC
1,171.30	4	W4	TII	0.20	28.15	34.92	9,19	27.75	7536	13	10/28/2013	AURORA ENERGY LLC
1,070.25	3	Bx	Bdl	0.14	30.00	35.86	5.87	28.27	7871	12	10/29/2013	AURORA ENERGY LLC
1,251.70	3	C4	Bdl	0.12	29.52	34.73	8.16	27.59	7644	13	10/30/2013	AURORA ENERGY LLC
1,561.60	4	W4	ΤII	0.15	28.50	35.49	7.68	28.33	7709	17	11/2/2013	AURORA ENERGY LLC
828.45	3	C4	Bdl	0.17	29.13	35.46	7.16	28.25	7745	9	11/4/2013	AURORA ENERGY LLC
1,007.45	4	W4	тп	0.16	28.84	34.70	8.04	28.42	7603	11	11/5/2013	AURORA ENERGY LLC
1,280.20	4	W4	ΤII	0.18	5 28.52	734925	II. D .4.	endix I	7 ≴6p p	14	11/6/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 7/1/13 to 12/31/13

Managaran ang Managaran ang Kanagaran ang Kanagaran ang Kanagaran ang Kanagaran ang Kanagaran ang Kanagaran ang			****			174200114300393040000000000000		*****	*****	*****	*****	FIVERIDAL COMPANY AND
939.25	4	W4	ТΙΙ	0.13	28.70	35.74	6.91	28.65	7677	11	11/7/2013	AURORA ENERGY LLC
726.25	3	C4	Bdl	0.13	29.30	36.48	7.05	27.17	7833	8	11/8/2013	AURORA ENERGY LLC
1,230.50	4	W4	Tłł	0.21	28.19	34.66	9.12	28.03	7498	13	11/12/2013	AURORA ENERGY LLC
1,615.85	4	W4	ΤII	0.20	29.08	34.84	7.98	28.11	7622	17	11/13/2013	AURORA ENERGY LLC
1,368.50	4	W4	ΤII	0.21	28.39	34.21	9.91	27.50	7466	15	11/14/2013	AURORA ENERGY LLC
1,137.60	4	W4	TI	0.20	28.78	34.44	8.72	28.08	7512	12	11/15/2013	AURORA ENERGY LLC
1,169.75	4	W4	TII	0.21	28.65	34.26	9.39	27.70	7497	12	11/18/2013	AURORA ENERGY LLC
1,238.50	4	W4	TII	0.23	27.18	33.66	12.26	26.91	7183	13	11/19/2013	AURORA ENERGY LLC
928.10	4	W4	ти	0.25	27.13	33.17	12.16	27.55	7196	10	11/20/2013	AURORA ENERGY LLC
282.10	4	W4	ти	0.25	27.65	33.48	11.04	27.84	7305	3	11/21/2013	AURORA ENERGY LLC
853.00	4	W4	TII	0.22	27.77	34.53	9.57	28.14	7444	9	11/22/2013	AURORA ENERGY LLC
2,370.10	4	W4	TII	0.19	28.54	34.72	7.91	28.84	7557	25	11/23/2013	AURORA ENERGY LLC
292.95	4	W4	TI	0.20	28.18	34.71	8.47	28.65	7521	3	11/26/2013	AURORA ENERGY LLC
1,322.45	4	W4	TI	0.20	27.89	34.31	9.06	28.74	7453	14	11/27/2013	AURORA ENERGY LLC
946.40	3/N	W4	TII/STK	0.16	29.09	34.71	8.86	27.34	7658	10	11/29/2013	AURORA ENERGY LLC
1,494.70	4	W4	TII	0.18	28.56	34.99	8.37	28.09	7630	17	12/2/2013	AURORA ENERGY LLC
869.90	4	W4	ТИ	0.20	28.63	34.80	8.08	28.49	7595	10	12/3/2013	AURORA ENERGY LLC
904.75	4	W4	ΤIJ	0.17	29.76	35.11	7.78	27.36	7734	10	12/4/2013	AURORA ENERGY LLC
763.85	3	C4	Bdl	0.13	30.10	35.21	6.95	27.74	7810	8	12/5/2013	AURORA ENERGY LLC
1,063.85	4 3/4	C4/W	Bdl/Til	0.13	29.57	34.53	7.91	27.99	7711	11	12/9/2013	AURORA ENERGY LLC
1,275.10	3	C4	Bdl	0.13	29.92	34.74	7.73	27.62	7739	13	12/10/2013	AURORA ENERGY LLC
881.40	3	C4	Bdl	0.13	29.71	34.24	8.60	27.46	7674	9	12/11/2013	AURORA ENERGY LLC
286.75	3/N	C4	Bdl/STK	0.11	29.51	34.21	8.39	27.89	7696	3	12/13/2013	AURORA ENERGY LLC
852.80	3	C4	Bdl	0.12	29.94	34.06	8.54	27.46	7702	9	12/16/2013	AURORA ENERGY LLC
776.85	4	C4	Bdl	0.13	30.05	34.58	7.89	27.48	7800	8	12/17/2013	AURORA ENERGY LLC
1,176.55	3	C4	Bdl	0.13	30.85	35.46	6.37	27.33	7960	12	12/18/2013	AURORA ENERGY LLC
966.55	3	C4	Bdl	0.12	30.10	34.92	6.73	28.26	7856	10	12/19/2013	AURORA ENERGY LLC
669.90	3/N	C4	BdI/STK	0.13	29.92	34.88	7.58	27.63	7801	7	12/20/2013	AURORA ENERGY LLC
1,473.00	3/N	C4	Bdl/STK	0.12	30.09	34.75	7.12	28.04	7802	15	12/23/2013	AURORA ENERGY LLC
1,459.65	3/N	C4	Bdl/STK	0.15	29.65	34.17	8.37	27.81	7676	15	12/24/2013	AURORA ENERGY LLC
431.00	4	X4	TII	0.19	28.53	35.09	8.14	28.24	7632	5	12/27/2013	AURORA ENERGY LLC
547.85	4	X4	TII	0.22	6 27.70	.7-349920	III. D 67	oen di 🕅	7 A7 51	6	12/27/2013	AURORA ENERGY LLC

Rail Samples Analysis Results for 7/1/13 to 12/31/13

***************************************	*****	****		21479-12720-1275-50475446418584		*****		1712122940011144460		*****		******
AURORA ENERGY LLC	12/29/2013	27	7744	27.93	7.68	35.17	29.23	0.17	TII	X4	4	2,307.45
AURORA ENERGY LLC	12/30/2013	10	7520	27.94	9.09	34.77	28.20	0.22	ТП	X4	4	942.95
AURORA ENERGY LLC	12/31/2013	8	7602	27.77	8.55	34.81	28.87	0.22	ТΙΙ	X4	4	744.15
Weighted Averages Summ	ary											
Customer		Tons		BTU	Н	20	Ash		Volatiles	Carb	on	Sulfur
AURORA ENERGY LLC		115917.70	ט	7599.00	2	7.95	8.8	31	34,72	28	3.53	0.17

This analysis is representative of the coal shipped

using sulfur standard ASTM D4239-12

Colcen Shompson 1-3-14

7/2/2014 Adopted

Usibelli Coal Mine

Rail Samples

Analysis Results for 1/1/14 to 6/30/14

Customer	Date	#Cars	вти	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2014	15	7592	27.80	8.87	34.55	28.78	0.20	тп	X4	4	1,370.90
AURORA ENERGY LLC	1/3/2014	15	7615	29.16	7.32	35.00	28.52	0.17	TII	X4	4	1,440.35
AURORA ENERGY LLC	1/6/2014	8	7633	28.42	7.70	34.85	29.03	0.16	ΤII	X4	4	779.40
AURORA ENERGY LLC	1/7/2014	12	7642	28.93	7.31	34.80	28.97	0.17	тн	X4	4	1,137.10
AURORA ENERGY LLC	1/8/2014	13	7615	28.31	8.20	34.76	28.74	0.19	ТШ	X4	4	1,229.35
AURORA ENERGY LLC	1/9/2014	11	7538	28.03	8.94	34.41	28.63	0.23	ти	X4	4	1,070.75
AURORA ENERGY LLC	1/10/2014	13	7571	28.86	8.02	34.63	28.49	0.18	TI	X4	4	1,216.15
AURORA ENERGY LLC	1/13/2014	10	7453	27.84	9.86	34.82	27.48	0.22	ΤII	X4	4	984.25
AURORA ENERGY LLC	1/14/2014	11	7489	28.42	8.99	34.32	28.27	0.22	Bdl	C4	3	1,031.80
AURORA ENERGY LLC	1/15/2014	8	7608	28.12	8.69	34.32	28.87	0.20	ΤII	X4	4	756.60
AURORA ENERGY LLC	1/16/2014	13	7588	28.25	8.55	34.40	28.80	0.20	тп	X4	4	1,251.05
AURORA ENERGY LLC	1/18/2014	16	7679	29.63	6.32	34.82	29.24	0.14	TII	X4	4	1,478.00
AURORA ENERGY LLC	1/20/2014	10	7735	28.53	7.06	34.71	29.71	0.16	ΤII	X4	4	953.85
AURORA ENERGY LLC	1/21/2014	9	7833	28.40	6.48	34.96	30.17	0.13	Bdl	C4	3	805.85
AURORA ENERGY LLC	1/22/2014	12	7767	27.95	7.35	34.72	29.99	0.13	Bdl	C4	3	1,168.20
AURORA ENERGY LLC	1/23/2014	3	7759	28.53	7.30	34.21	29.97	0.13	Bdl	C4	3	293.50
AURORA ENERGY LLC	1/27/2014	9	7379	28.65	9.78	33.16	28.41	0.12	Bdl/JR	C4/C13	3/3	853.10
AURORA ENERGY LLC	1/28/2014	9	7700	28.25	7.82	34.50	29.43	0.15	Bdl/JR	C4/C13	3/3	810.95
AURORA ENERGY LLC	1/29/2014	10	7721	28.70	7.00	34.48	29.82	0.14	Bdl/STK	C4	3/N	917.25
AURORA ENERGY LLC	1/30/2014	15	7737	28.41	7.34	34.81	29.44	0.13	Bdl	C4	3	1,357.75
AURORA ENERGY LLC	1/31/2014	22	7529	29.01	8.13	33.66	29.21	0.12	Bdl	C4	3	2,046.90
AURORA ENERGY LLC	2/3/2014	19	7560	28.92	8.26	33.56	29.26	0.14	Bdl	C4	3	1,809.10
AURORA ENERGY LLC	2/4/2014	12	7527	29.18	8.14	33.53	29.14	0.13	Bdl/ T II	C4/X3	3/3	1,138.90
AURORA ENERGY LLC	2/5/2014	6	7533	28.73	8.62	34.00	28.66	0.13	TII	X 3	3	549.45
AURORA ENERGY LLC	2/6/2014	9	7582	28.26	8.89	33.92	28.93	0.12	ΤIJ	X3	3	833.35
AURORA ENERGY LLC	2/10/2014	11	7548	28.78	8.49	33.65	29.08	0.13	ΤIJ	Х3	3	997.40
AURORA ENERGY LLC	2/12/2014	13	7669	28.02	8.03	34.85	29.10	0.13	ТИ	Х3	3	1,178.00
AURORA ENERGY LLC	2/12/2014	8	7568	27.51	9.42	34.40	28.68	0.12	ŤII	Х3	3	735.35
AURORA ENERGY LLC	2/13/2014	12	7810	26.92	8.17	35.24	29.67	0.19	Bdl	A	4	1,085.25
AURORA ENERGY LLC	2/15/2014	10	⁷⁸ App	peffdl% I	II? D ?7	.7 <u>-</u> 492	8 ^{29.07}	0.21	Bdl	A	4	964.15

Rail Samples Analysis Results for 1/1/14 to 6/30/14

							-		SS/SAUDIACADININA SAUDIA STATISTICS CONTRACTOR AND
0.26 Bdl A	2 0.26	9 29.02	36.19	8.59	26.21	7821	8	2/17/2014	AURORA ENERGY LLC
0.23 Bdl A	1 0.23	0 29.61	35.90	8.45	26.05	7857	12	2/18/2014	AURORA ENERGY LLC
0.21 Bdl/STK A	5 0.21	1 29.15	35.91	8.75	26.19	7803	16	2/19/2014	AURORA ENERGY LLC
0.20 Bdl/STK A	2 0.20	5 28.82	35.75	9.11	26.33	7738	7	2/20/2014	AURORA ENERGY LLC
0.20 Bdl/STK A	3 0.20	7 28.63	35.77	8.70	26.91	7702	18	2/21/2014	AURORA ENERGY LLC
0.19 Bdl/STK A	7 0.19	5 29.07	35.25	8.35	27.34	7721	13	2/24/2014	AURORA ENERGY LLC
0.15 TII/Bdl X3/	5 0.15	1 29.15	34.81	8.50	27.53	7663	14	2/25/2014	AURORA ENERGY LLC
0.14 TII X3	0.14	3 29.20	35.13	7.88	27.80	7704	18	2/27/2014	AURORA ENERGY LLC
0.13 Bdl/T II A/X	3 0.13	9 28.33	34.59	8.83	28.26	7519	19	2/28/2014	AURORA ENERGY LLC
0.11 TII/Bdl X3/	3 0.11	0 29.03	33.90	8.17	28.91	7539	11	3/3/2014	AURORA ENERGY LLC
0.23 Bdl/STK B	0.23	1 28.89	35.01	9.19	26.91	7678	13	3/4/2014	AURORA ENERGY LLC
0.21 Bdl/STK B	5 0.21	5 28.96	35.75	8.53	26.75	7784	11	3/5/2014	AURORA ENERGY LLC
0.18 Bdl/STK B	5 0.18	1 29.05	35.41	8.71	26.83	7723	7	3/6/2014	AURORA ENERGY LLC
0.19 Bdl/STK B	0.19	8 29.20	35.58	8.49	26.72	7758	7	3/7/2014	AURORA ENERGY LLC
0.22 Bdl/STK B	6 0.22	3 28.86	35.53	9.09	26.52	7719	7	3/10/2014	AURORA ENERGY LLC
0.20 Bdl/STK B	7 0.20	4 28.97	35.24	8.15	27.64	7675	11	3/11/2014	AURORA ENERGY LLC
0.21 Bdl/STK B	6 0.21	7 28.66	35.17	8.82	27.35	7634	4	3/12/2014	AURORA ENERGY LLC
0.25 Bdl/STK B	5 0.25	6 26.25	33.06	14.55	26.15	7120	16	3/13/2014	AURORA ENERGY LLC
0.18 Bdl/STK B	5 0.18	7 28.45	34.97	9.03	27.55	7615	12	3/14/2014	AURORA ENERGY LLC
0.18 Bdl B	2 0.18	5 29.62	36.05	7.37	26.97	7872	3	3/17/2014	AURORA ENERGY LLC
0.16 Bdl/STK B	0.16	3 29.70	34.83	7.64	27.82	7750	12	3/18/2014	AURORA ENERGY LLC
0.18 Bdl/STK B	0.18	8 29.38	35.78	7.40	27.45	7798	12	3/19/2014	AURORA ENERGY LLC
0.23 Bdl/STK B	0.23	7 29.84	36.57	7.32	26.46	7948	10	3/20/2014	AURORA ENERGY LLC
0.12 Bdl B	2 0.12	7 30.22	35.87	6.00	27.92	7916	12	3/21/2014	AURORA ENERGY LLC
0.14 Bdl/STK B	3 0.14	9 15.13	35.69	6.81	27.38	7882	12	3/24/2014	AURORA ENERGY LLC
0.13 Bdl/STK B	0.13	0 31.04	36.20	6.27	26.46	8057	1	3/25/2014	AURORA ENERGY LLC
0.12 Bdl/T II B/X	0.12	5 29.90	35.65	6.78	27.68	7887	15	3/26/2014	AURORA ENERGY LLC
0.11 TII X3	0.11	6 28.21	34.76	9.07	27.96	7482	26	3/27/2014	AURORA ENERGY LLC
0.13 T II X3	0.13	8 27.41	33.38	11.54	27.68	7310	8	3/31/2014	AURORA ENERGY LLC
0.10 Bdl A	0.10	1 30.37	35.61	5.23	28.80	7832	9	4/1/2014	AURORA ENERGY LLC
0.11 Bdl/STK A	0.11	7 30.37	35.47	5.87	28.29	7776	13	4/2/2014	AURORA ENERGY LLC
0.13 Bdl/STK A	0.13	2929.30	.7 3-419 2	III8 D 77	oendix	75 A 901	9	4/3/2014	AURORA ENERGY LLC

Rail Samples Analysis Results for 1/1/14 to 6/30/14

				****	1979932975400000011Kem	******	*****	*****	********			
AURORA ENERGY LLC	4/4/2014	5	7695	28.07	7.91	34.98	29.05	0.11	T II/Bdl	X3/A	3/3	486.30
AURORA ENERGY LLC	4/7/2014	10	7899	28.09	5.97	35.24	30.71	0.12	Bdl	А	3	913.65
AURORA ENERGY LLC	4/8/2014	10	7861	28.29	6.32	34.97	30.43	0.12	Bdl/STK	А	3/N	951.00
AURORA ENERGY LLC	4/9/2014	14	7878	27.84	6.59	35.28	30.30	0.12	Bdl/STK	А	3/N	1,358.65
AURORA ENERGY LLC	4/10/2014	13	7734	28.36	7.47	34.44	29.73	0.12	Bdl/STK	A	3/N	1,286.85
AURORA ENERGY LLC	4/11/2014	9	7609	28.55	8.22	34.50	28.74	0.12	Bdl/STK	Α	3/N	866.30
AURORA ENERGY LLC	4/14/2014	10	7769	27.99	7.38	34.83	29.80	0.11	Bdl/STK	А	3/N	938.10
AURORA ENERGY LLC	4/15/2014	12	7662	28.55	7.20	36.80	27.46	0.13	ΤII	LST	6	1,108.05
AURORA ENERGY LLC	4/16/2014	11	7262	27.55	11.33	35.30	25.83	0.13	ΤII	LST	6	950.55
AURORA ENERGY LLC	4/17/2014	13	7462	28.02	9.11	36.75	26.14	0.10	TII	LST	6	1,131.00
AURORA ENERGY LLC	4/18/2014	13	7632	29.53	4,91	36.14	29.42	0.07	Bdl/STK	А	3/N	1,247.60
AURORA ENERGY LLC	4/21/2014	9	7627	27.72	7.25	35.32	29.71	0.11	Bdl/STK	В	3/N	832.25
AURORA ENERGY LLC	4/22/2014	11	7451	27.99	9.12	35.47	27.43	0.13	ΤII	LST	6	1,070.80
AURORA ENERGY LLC	4/23/2014	11	7525	28.07	8.16	35.70	28.07	0.12	Bdl/STK	в	3/N	999.30
AURORA ENERGY LLC	4/24/2014	12	7570	28.32	8.11	36.21	27.36	0.12	тп	LST	6	1,162.05
AURORA ENERGY LLC	4/25/2014	13	7464	28.40	8.61	36.49	26.51	0.13	TH	LST	6	1,204.30
AURORA ENERGY LLC	4/28/2014	11	7451	27.57	9.55	35.68	27.20	0.13	ΤII	LST	6	1,083.20
AURORA ENERGY LLC	4/30/2014	12	7397	27.69	9.76	36.58	25.97	0.12	TH	LST	6	1,093.95
AURORA ENERGY LLC	5/1/2014	12	7464	27.86	9.03	36.29	26.82	0.13	TII	LST	6	1,094.60
AURORA ENERGY LLC	5/5/2014	11	7601	28.24	8.15	36.22	27.39	0.14	Τł	LST	6	994.65
AURORA ENERGY LLC	5/6/2014	10	7735	27.79	7.63	36.55	28.04	0.14	ти	LST	6	906.90
AURORA ENERGY LLC	5/7/2014	12	7638	28.23	7.46	36.83	27.49	0.13	ΤII	LST	6	1,121.35
AURORA ENERGY LLC	5/8/2014	14	7544	28.57	8.21	35.22	28.00	0.13	T II/Bsl	LST/A	6/3	1,403.70
AURORA ENERGY LLC	5/12/2014	16	7796	27.50	8.05	35.31	29.14	0.13	Bdl/STK	А	3/N	1,548.15
AURORA ENERGY LLC	5/14/2014	12	7746	28.25	6.78	37.35	27.62	0.12	Bdl/TII	A/LST	3/6	1,055.15
AURORA ENERGY LLC	5/15/2014	9	7712	28.25	7.12	37.35	27.28	0.12	Bdl/Tll	A/LST	3/6	858.05
AURORA ENERGY LLC	5/16/2014	10	7707	27.99	7.76	36.08	28.18	0.11	TII/Bdl	LST/A	6/3	974.80
AURORA ENERGY LLC	5/19/2014	8	7769	26.93	7.92	35.48	29.68	0.13	TII/Bdl	LST/B	6/3	769.15
AURORA ENERGY LLC	5/20/2014	11	7915	28.22	6.07	35.62	30.10	0.11	Bdl/STK	В	3/N	1,041.70
AURORA ENERGY LLC	5/21/2014	9	7761	27.26	8.12	35.07	29.56	0.12	Bdl/STK	в	3/N	891.85
AURORA ENERGY LLC	5/22/2014	7	7809	27.38	7.27	35.93	29.43	0.11	BdI/STK	в	3/N	693.85
AURORA ENERGY LLC	5/23/2014	8	77 A @pp	endix I	II6 D 27.	7384993	()26.52	0.12	TI	LST	6	724.90

Rail Samples Analysis Results for 1/1/14 to 6/30/14

AURORA ENERGY LLC		117659.6	5	7652.00	2	7.89	8.	15	35.29	20	3.54	0.15
Customer		Tons		BTU	H	20	Ash		Volatiles	Carl	oon	Sulfur
Weighted Averages Sun	nmary										****	
AURORA ENERGY LLC	6/30/2014	9	7695	28.75	7.46	34.73	29.06	0.11	Bdl/STK	с	3/N	829.70
AURORA ENERGY LLC	6/26/2014	12	7776	27.04	7.86	35.66	29.45	0.11	Bdl/STK	с	3/N	1,172.35
AURORA ENERGY LLC	6/25/2014	13	7751	28.21	7.20	34.95	29.64	0.11	Bdl/STK	С	3/N	1,259.45
AURORA ENERGY LLC	6/24/2014	10	7712	27.76	8.03	34.70	29.51	0.12	Bdl/STK	С	3/N	931.05
AURORA ENERGY LLC	6/23/2014	9	7311	28.02	10.34	35.77	25.87	0.15	тп	LST	6	867.60
AURORA ENERGY LLC	6/19/2014	18	7458	27.53	9.65	36.66	26.16	0.11	ти	LST	6	1,681.40
AURORA ENERGY LLC	6/18/2014	16	7672	27.62	7.90	37.02	27.47	0.12	ΤII	LST	6	1,534.80
AURORA ENERGY LLC	6/16/2014	10	7632	27.40	8.88	36.76	26.96	0.12	ТШ	LST	6	964.10
AURORA ENERGY LLC	6/12/2014	5	7669	27.41	8.70	37.27	26.62	0.11	GRP/TII	LST	M/6	489.40
AURORA ENERGY LLC	6/11/2014	7	7704	26.60	10.00	35.94	27.47	0.14	T II/GRP	LST	6/M	683.90
AURORA ENERGY LLC	6/9/2014	5	7676	28.30	7.60	36.90	27.20	0.12	тп	LST	6	481.65
AURORA ENERGY LLC	6/5/2014	13	7690	28.12	7.45	36.87	27.56	0.13	ти	LST	6	1,236.80
AURORA ENERGY LLC	6/3/2014	8	7949	27.23	6.72	36.14	29.91	0.11	Bdl/STK	В	3/N	779.60
AURORA ENERGY LLC	6/2/2014	8	7688	27.53	8.31	34.79	29.39	0.11	Bdl/STK	В	3/N	793.70
AURORA ENERGY LLC	5/30/2014	12	7673	27.44	8.50	34.98	29.08	0.11	Bdl/STK	В	3/N	1,150.20
AURORA ENERGY LLC	5/29/2014	12	7514	27.86	9.02	34.63	28.50	0.13	BdI/STK	В	3/N	1,174.15
AURORA ENERGY LLC	5/28/2014	14	7654	26.98	8.94	35.73	28.36	0.12	Bdl/STK	В	3/N	1,342.05
AUKOKA ENERGY LLC	0/2.0/2.0 / .	•	1120	20.01	0.10	50.02	20.00	0.12			0	01,100

This analysis is representative of the coal shipped using sulfur standard ASTM D4239 - 12 $\,$

Coleen Strompson 7-2-14

Appendix E (Coal Sulfur Summary)

Rail Samples Analysis Results for 7/1/14 to 12/31/14

TO A DESCRIPTION OF THE OWNER OWNE	\$\$\$\$\$\$\$\$ \$	***********************	201224		****	201221111112W/17132910/11/			***	022632200000000000000000000000000000000		
Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/1/2014	17	7525	28.93	8.28	34.19	28.60	0.12	Bdl/STK	с	3/N	1,638.75
AURORA ENERGY LLC	7/2/2014	11	7442	29.33	8.64	34.80	27.23	0.13	Bdl/STK	С	3/N	1,079.80
AURORA ENERGY LLC	7/4/2014	7	7656	27.98	8.07	36.98	26.97	0.11	TI	LST	6	627.85
AURORA ENERGY LLC	7/7/2014	13	7622	28.13	7.79	37.11	26.97	0.12	ΤI	LST	6	1,239.90
AURORA ENERGY LLC	7/9/2014	33	7578	28.14	8.43	36.77	26.67	0.13	ΤII	LST	6	3,141.00
AURORA ENERGY LLC	7/14/2014	13	7395	27.68	9.60	36.03	26.72	0.13	ΤII	LST	6	1,276.45
AURORA ENERGY LLC	7/16/2014	18	7619	28.26	7.73	36.94	27.08	0.12	ΤI	LST	6	1,699.05
AURORA ENERGY LLC	7/17/2014	18	7570	28.11	8.29	36.76	26.84	0.12	ΤIJ	LST	6	1,778.65
AURORA ENERGY LLC	7/21/2014	14	7442	28.16	9.30	36.11	26.43	0.13	ΤH	LST	6	1,346.20
AURORA ENERGY LLC	7/23/2014	16	7409	28.35	9.31	36.18	26.16	0.12	ти	LST	6	1,446.00
AURORA ENERGY LLC	7/24/2014	17	7621	27.21	8.61	37.30	26.88	0.11	TII	LST	6	1,544.95
AURORA ENERGY LLC	7/28/2014	5	7539	27.66	8.85	36.81	26.69	0.12	ТΙΙ	LST	6	490.95
AURORA ENERGY LLC	7/30/2014	6	7675	26.58	9.28	36.70	27.45	0.14	Bdl	C1	6	569.15
AURORA ENERGY LLC	8/4/2014	8	7404	29.01	8.95	35.65	26.39	0.13	ΤII	LST	6	795.30
AURORA ENERGY LLC	8/5/2014	8	7750	27.08	8.18	37.34	27.40	0.13	TBR	C1	6	703.80
AURORA ENERGY LLC	8/6/2014	17	7586	26.84	9.66	36.79	26.71	0.14	TBR	C1	6	1,686.45
AURORA ENERGY LLC	8/7/2014	13	7425	27,57	10.25	36.28	25.91	0.13	TBR	C1	6	1,299.70
AURORA ENERGY LLC	8/11/2014	8	7702	27.08	8.56	36.95	27.42	0.13	TBR	C1	6	781.45
AURORA ENERGY LLC	8/13/2014	18	7601	26.69	9.52	36.64	27.16	0.13	TBR	C1	6	1,605.50
AURORA ENERGY LLC	8/14/2014	16	7510	26.42	10.35	36.71	26.53	0.12	TBR	C1	6	1,500.05
AURORA ENERGY LLC	8/16/2014	10	7952	25.09	10.53	36.52	27.87	0.19	GRP/ST	к	M/N	937.00
AURORA ENERGY LLC	8/18/2014	4	7846	25.81	10.48	35.39	28.33	0.17	GRP/ST	к	M/N	403.90
AURORA ENERGY LLC	8/20/2014	5	7972	25.66	10.21	34.89	29.25	0.16	GRP/ST	к	M/N	479.00
AURORA ENERGY LLC	8/21/2014	5	7947	25.16	10.86	35.53	28.45	0.16	GRP/ST	К	M/N	472.20
AURORA ENERGY LLC	8/25/2014	6	7585	26.17	11.19	35.79	26.86	0.14	GRP/ST	к	M/N	575.15
AURORA ENERGY LLC	8/27/2014	5	7844	26.46	9.73	35.49	28.33	0.15	GRP/ST	к	M/N	459.95
AURORA ENERGY LLC	8/28/2014	5	7573	27.55	9.51	35.82	27.13	0.13	TBR	C1	6	453.20
AURORA ENERGY LLC	9/2/2014	5	7853	25.68	10.15	35.75	28.43	0.16	GRP/ST	к	M/N	444.10
AURORA ENERGY LLC	9/3/2014	7	7595	27.30	9.44	35.06	28.21	0.23	Bdl	Ε	4	599.15
AURORA ENERGY LLC	9/5/2014	9	⁷ Å4p	pendix II	II. ¹ 879	.7 ³² 493	3 ^{24.76}	0.24	GRP/ST	к	M/N	804.25

Rail Samples Analysis Results for 7/1/14 to 12/31/14

TRUESSALLING AND	Constant and the second se	****	WEINING WEINING THE REAL PROPERTY AND THE RE		**************	******			003650003002020000000000	ACCORDING OF A DESCRIPTION OF A DESCRIPR		MARKOWWY CONTRACTOR CONT
268.65	M/N		GRP/STK	0.22	27.79	34.29	14.19	23.73	7828	3	9/5/2014	AURORA ENERGY LLC
539.60	M/N		GRP/STK	0.23	27.19	33.86	15.37	23.59	7651	6	9/5/2014	AURORA ENERGY LLC
535.55	4	Ε	Bdl	0.13	25.75	36.70	10.16	27.39	7455	6	9/8/2014	AURORA ENERGY LLC
1,100.05	6	LST	ΤH	0.13	26.09	35.87	10.03	28.02	7336	12	9/10/2014	AURORA ENERGY LLC
941.35	6	LST	ТИ	0.13	25.08	34.95	12.33	27.65	7155	10	9/11/2014	AURORA ENERGY LLC
464.40	4	E	Bdl	0.17	27.25	35.72	9.62	27.42	7517	5	9/15/2014	AURORA ENERGY LLC
652.45	6	LST	ΤII	0.13	26.84	36.59	9.06	27.52	7531	7	9/17/2014	AURORA ENERGY LLC
539.45	6	LST	ΤII	0.19	27.39	35.72	8.91	27.99	7493	6	9/18/2014	AURORA ENERGY LLC
481.40	4	Е	Bdl	0.14	29.51	35.62	6.50	28.38	7793	5	9/22/2014	AURORA ENERGY LLC
864.35	6	LST	ТΠ	0.13	26.07	35.04	12.00	26.90	7206	9	9/24/2014	AURORA ENERGY LLC
971.75	6	LST	TII	0.12	26.61	36.92	8.47	28.00	7528	10	9/25/2014	AURORA ENERGY LLC
1,007.10	4	E	Bdl	0.18	28.51	36.34	6.81	28.34	7739	11	9/27/2014	AURORA ENERGY LLC
1,034.60	4	F	Bdl	0.19	29.18	35.86	6.87	28.09	7739	11	9/29/2014	AURORA ENERGY LLC
984.35	4	F	Bdl	0.16	29.41	35.47	6.60	28.54	7749	11	9/30/2014	AURORA ENERGY LLC
2,485.80	4	F	Bdl	0.16	29.32	35.84	6.55	28.29	7815	26	10/1/2014	AURORA ENERGY LLC
856.70	4/6	F/LST	Bdl/Tll	0.16	27.65	36.05	8.20	28.11	7591	10	10/6/2014	AURORA ENERGY LLC
810.80	4/6	F/LST	BdI/T II	0.16	27.07	35.31	10.14	27.49	7403	9	10/8/2014	AURORA ENERGY LLC
985.90	6	LST	ТШ	0.12	26.96	36.11	8.70	28.23	7499	11	10/8/2014	AURORA ENERGY LLC
1,116.25	6	LST	ΤII	0.12	26.52	36.91	8.40	28.17	7495	12	10/9/2014	AURORA ENERGY LLC
1,133.10	6	LST	ΤII	0.12	25.65	38.08	7.85	28.43	7566	13	10/11/2014	AURORA ENERGY LLC
676.50	6	LST	ΤII	0.13	26.43	36,23	9.44	27.91	7405	7	10/13/2014	AURORA ENERGY LLC
997.30	M/N		GRP/STK	0.15	29.13	35.38	9.33	26.15	7971	11	10/15/2014	AURORA ENERGY LLC
1,476.75	M/N		GRP/STK	0.16	29.13	36.45	8.50	25.93	8040	16	10/16/2014	AURORA ENERGY LLC
864.20	6	LST	ΤII	0.14	27.45	36.03	8.84	27.68	7629	9	10/20/2014	AURORA ENERGY LLC
1,113.15	3	D	Bdl	0.13	29.69	35.30	7.56	27.45	7874	12	10/21/2014	AURORA ENERGY LLC
1,424.60	3	E	Bdl	0.12	30.62	35.31	6.48	27.59	7932	15	10/22/2014	AURORA ENERGY LLC
1,343.80	3	Е	Bdl	0.10	30.19	36.02	6.24	27.56	7880	14	10/23/2014	AURORA ENERGY LLC
783.45			Jumbo	0.12	27.79	34.67	6.85	30.71	7169	9	10/24/2014	AURORA ENERGY LLC
1,187.15	3/N	D	Bdl/STK	0.13	29.47	35,35	7.14	28.04	7748	12	10/27/2014	AURORA ENERGY LLC
922.05	3/6	D/LST	Bdl/T II	0.12	28.13	35.64	7.79	28.45	7616	10	10/28/2014	AURORA ENERGY LLC
939.80	6	LST	тμ	0.13	26.95	35.97	8.94	28.14	7494	10	10/29/2014	AURORA ENERGY LLC
1,074.40	6	LST	TII	0.12	426.15	7 349 34	[]]. D .7.	eadix]	7App	11	10/30/2014	AURORA ENERGY LLC

Rail Samples Analysis Results for 7/1/14 to 12/31/14

And in the second s		CARACTER CONTRACTOR OF STREET	a na	***	AN SAMA AS AN AND A DESCRIPTION	***************	*****	DISTRACT PROCESSION OF SHARE	STRUCTURE AND A DESCRIPTION OF A DESCRIP	0X1100105721047211918	NACASAINSYMHÄRIMÄRINDÄSYMHIINYIMINTAINANATAININTAINANATAININTAINANATAIN	\$2001/07/02/07/07/07/07/07/07/07/07/07/07/07/07/07/
943.50	6/3	LST/D	TII/Bdl	0.13	28.06	36.13	7.39	28.43	7754	10	10/31/2014	AURORA ENERGY LLC
566.40	3/4	D	Bdl/JD	0.12	29.26	34.86	6.72	29.16	7675	6	11/3/2014	AURORA ENERGY LLC
1,279.15	3/4	D	Bdl/JD	0.11	29.59	35.24	6.73	28.44	7741	13	11/4/2014	AURORA ENERGY LLC
1,176.25	3/4	D	Bdl/JD	0.12	28.73	35.38	7.68	28.22	7651	12	11/5/2014	AURORA ENERGY LLC
848.35	3/4	D	Bdl/JD	0.12	29.07	34.84	7.42	28.67	7622	9	11/6/2014	AURORA ENERGY LLC
1,064.60	3/4	D	Bdl/JD	0.11	29.48	35.32	7.20	28.00	7769	12	11/7/2014	AURORA ENERGY LLC
650.70	3/4	D	Bdl/JD	0.10	29.71	35.31	6.77	28.21	7769	7	11/10/2014	AURORA ENERGY LLC
1,141.50	3/4	D	Bdl/JD	0.11	29.52	35.20	6.64	28.65	7739	12	11/11/2014	AURORA ENERGY LLC
1,120.25	3/4	D	Bdl/JD	0.12	29.19	34.68	6.67	29.46	7644	12	11/12/2014	AURORA ENERGY LLC
840.50	3/4	D	Bdl/JD	0.11	28.27	35.81	6.79	29.14	7613	9	11/13/2014	AURORA ENERGY LLC
638.10	3/4	D	Bdl/JD	0.14	28.52	36.16	7.75	27.58	7805	7	11/14/2014	AURORA ENERGY LLC
604.55	M/N		GRP/STK	0.19	28.16	34.65	10.84	26.36	7749	6	11/17/2014	AURORA ENERGY LLC
3,113.25	M/N		GRP/STK	0.17	25.91	33.00	14.74	26.35	7295	31	11/18/2014	AURORA ENERGY LLC
1,161.75	M/3	D	GRP/Bdl	0.17	28.14	34.90	11.05	25.92	7822	12	11/19/2014	AURORA ENERGY LLC
355.30	M/4		GRP/JD	0.14	27.80	34.70	9.54	27.96	7765	4	11/21/2014	AURORA ENERGY LLC
792.50	3/4	F	Bdl/JD	0.11	29.41	36.00	5.59	29,00	7821	9	11/24/2014	AURORA ENERGY LLC
1,101.60	3/4	F	Bdl/JD	0.10	30.05	35.63	5.94	28.38	7837	12	11/25/2014	AURORA ENERGY LLC
1,157.55	3/4	D	Bdl/JD	0.09	28.79	35.03	6.57	29.62	7636	13	11/26/2014	AURORA ENERGY LLC
775.45	3/4	F	Bdl/JD	0.09	29.58	35.55	6.04	28.82	7798	9	11/28/2014	AURORA ENERGY LLC
742.55	3/N	F	Bdl/STK	0.10	29.68	35.39	6.40	28.53	7814	8	12/1/2014	AURORA ENERGY LLC
1,039.75	3/N	F	Bdl/STK	0.11	30.13	35.16	6.73	27.99	7843	11	12/2/2014	AURORA ENERGY LLC
862.65	3/N	F	BdI/STK	0.10	29.51	35.07	7.17	28.26	7718	10	12/3/2014	AURORA ENERGY LLC
753.20	3/N	F	Bdl/STK	0.10	28.71	35.42	7.94	27.93	7659	8	12/4/2014	AURORA ENERGY LLC
1,222.65	3/N	F	Bdl/STK	0.12	28.51	35.41	8.23	27.86	7660	13	12/5/2014	AURORA ENERGY LLC
1,068.05	4/N	G	Bdl/STK	0.31	26.85	34.16	12.62	26.38	7399	11	12/8/2014	AURORA ENERGY LLC
933.35	4/N	G	Bdl/STK	0.25	28.61	35.76	8.46	27.16	7758	10	12/9/2014	AURORA ENERGY LLC
730.55	4/N	G	Bdl/STK	0.23	28.79	35.30	8.79	27.12	7671	8	12/10/2014	AURORA ENERGY LLC
846.70	4/3	G/F	Bdl/Bdl	0.21	29.12	35.48	8.01	27.40	7762	9	12/11/2014	AURORA ENERGY LLC
1,285.70	3/N	F	Bdl/STK	0.15	28.85	35.28	8.26	27.61	7657	14	12/12/2014	AURORA ENERGY LLC
1,100.15	4/4	G	Bdl/JD	0.15	27.44	35.28	8.10	29.18	7491	12	12/15/2014	AURORA ENERGY LLC
1,705.05	4/4	G	Bdl/JD	0.19	27.74	35.71	8.32	28.23	7630	18	12/16/2014	AURORA ENERGY LLC
770.15	4/4	G	Bdl/JD	0.16	528.40	73 49 B	[]] <i>1</i> D \$7	oenalix]	76 A pr	8	12/17/2014	AURORA ENERGY LLC
Rail Samples
Analysis Results for 7/1/14 to 12/31/14

	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	and a subject to the subject of the			and and the second second		2011FRAUEHR225601	******	*****	nisiya kaya ka	and a second
AURORA ENERGY LLC	12/18/2014	20	7528	31.48	6.44	34.37	27.71	0.13	JD		4	1,850.00
AURORA ENERGY LLC	12/19/2014	4	7626	28.8 9	7.57	35.42	28.12	0.15	Bdl/JD	G	4/4	372.05
AURORA ENERGY LLC	12/22/2014	10	7561	28.72	8.34	35.26	27.69	0.18	Bdl/JD	G	4/4	981.45
AURORA ENERGY LLC	12/23/2014	17	7598	28.65	8.05	35.35	27.95	0.18	Bdl/JD	G	4/4	1,535.65
AURORA ENERGY LLC	12/24/2014	12	7563	28.54	8.75	35.22	27.50	0.19	Bdl/JD	G	4/4	1,037.65
AURORA ENERGY LLC	12/26/2014	6	7418	26.62	12.03	34.98	26.37	0.28	Bdl/JD	G	4/4	550.45
AURORA ENERGY LLC	12/29/2014	8	7385	27.89	10.46	34.77	26.89	0.25	Bdl/JD	G	4/4	778.85
AURORA ENERGY LLC	12/30/2014	12	7568	29.02	8.07	34.65	28.26	0.21	Bdl/JD	G	4/4	1,145.15
AURORA ENERGY LLC	12/31/2014	10	7643	29.27	7.21	35.29	28.24	0.18	Bdl/JD	G	4/4	880.85
Weighted Averages Sum	mary											
Customer		Tons		BTU	٣	20	Ash		Volatiles	Car	bon	Sulfur
AURORA ENERGY LLC		103979.4	5	7617.00	2	7.86	8.1	67	35.66	2	7.82	0.14

This analysis is representative of the coal shipped using sulfur ASTM D4239-12 $\,$

Colien Thompson 1-5-15

Appendix E (Coal Sulfur Summary)

Adopted 7/1/2015

Usibelli Coal Mine

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 1/1/15 to 6/30/15

Customer	Date	#Cars	BTU	%H20	%A	%V	%С	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	1/2/2015	10	7542	28.10	8.78	35.14	27.98	0.22	Bdl/JD	G	4/4	913.35
AURORA ENERGY LLC	1/5/2015	8	7586	29.30	7.87	34.51	28.33	0.21	Bdl/JD	G	4/4	761.95
AURORA ENERGY LLC	1/6/2015	15	7593	29.68	7.16	34.84	28.32	0.21	Bdl/JD	G	4/4	1,331.30
AURORA ENERGY LLC	1/7/2015	10	7609	29.88	6.82	34.57	28.74	0.19	Bdl/JD	G	4/4	913.10
AURORA ENERGY LLC	1/8/2015	13	7572	27.19	9.58	35.09	28.15	0.24	Bdl/JD	G	4/4	1,217.90
AURORA ENERGY LLC	1/9/2015	13	7658	28.66	7.66	35.64	28.04	0.20	Bdl/JD	G	4/4	1,270.65
AURORA ENERGY LLC	1/12/2015	8	7612	27.19	9.36	35.22	28.24	0.22	Bdl/ T II	G/LST	4/6	735.75
AURORA ENERGY LLC	1/13/2015	13	7605	27.86	8.81	35.00	28.33	0.21	Bdl/T II	G/LST	4/6	1,249.40
AURORA ENERGY LLC	1/14/2015	30	7355	26.04	12.63	34.27	27.07	0.31	Bdl/STK	G	4/N	2,906.30
AURORA ENERGY LLC	1/14/2015	10	7413	26.77	11.28	34.53	27.42	0.30	Bdl/STK	G	4/N	985.30
AURORA ENERGY LLC	1/19/2015	8	7722	27.69	7.86	35.65	28.80	0.15	Bdl/STK	G	4/N	710.60
AURORA ENERGY LLC	1/20/2015	13	7615	28.20	7.93	36.17	27.71	0.15	TII/STK	LST	6/N	1,225.25
AURORA ENERGY LLC	1/21/2015	10	7493	27.67	9.57	36.02	26.75	0.14	тШ	LST	6	954.30
AURORA ENERGY LLC	1/22/2015	8	7625	27.33	8.98	35.40	28.28	0.22	Bdl/STK	G	4/N	778.30
AURORA ENERGY LLC	1/26/2015	9	7635	27.97	7.73	35.95	28.36	0.15	Bdl/T II	F/LST	3/6	835.50
AURORA ENERGY LLC	1/27/2015	7	7516	28.18	8.81	36.32	26.69	0.14	тш	LST	6	645.20
AURORA ENERGY LLC	1/28/2015	5	7469	28.31	9.15	36.13	26.41	0.15	тш	LST	6	448.45
AURORA ENERGY LLC	1/29/2015	6	7515	28.38	8.44	36.63	26.56	0.13	тп	LST	6	554.05
AURORA ENERGY LLC	1/29/2015	5	7607	28.03	8.04	36.88	27.05	0.13	ти	LST	6	424.60
AURORA ENERGY LLC	1/30/2015	14	7541	28.33	8.44	37.02	26.22	0.13	тп	LST	6	1,209.20
AURORA ENERGY LLC	2/2/2015	9	7551	28.26	8.55	36.52	26.67	0.14	тіі	LST	6	834.90
AURORA ENERGY LLC	2/3/2015	31	7078	28.44	12.14	34.70	24.73	0.15	Т II	LST	6	2,869.90
AURORA ENERGY LLC	2/3/2015	11	7036	27.65	12.98	35.06	24.32	0.14	ТШ	LST	6	969.85
AURORA ENERGY LLC	2/4/2015	12	7065	28.03	12.16	34.62	25.20	0.15	ΤII	LST	6	1,138.45
AURORA ENERGY LLC	2/9/2015	9	7620	27.91	7.79	35.30	29.02	0.13	Bdl/JD	F	3/4	742.75
AURORA ENERGY LLC	2/10/2015	14	7917	27.82	5.80	35.90	30.48	0.12	Bdl/JD	F	3/4	1,277.15
AURORA ENERGY LLC	2/11/2015	8	7702	29.02	6.64	35.33	29.02	0.12	Bdl/JD	F	3/4	680.85
AURORA ENERGY LLC	2/12/2015	6	7618	28.59	7.59	35.98	27.84	0.12	Bdl/JD	F	3/4	525.70
AURORA ENERGY LLC	2/13/2015	8	7614	29.50	7.11	35.67	27.72	0.12	Bdl/JD	F	3/4	674.15
AURORA ENERGY LLC	2/16/2015	8	7681 App	29.80 pendix II	6.49 [I.D.7	35.97 .7-493	27.74 8	0.11	T II/JD	LST	6/4	716.15

Rail Samples Analysis Results for 1/1/15 to 6/30/15

-					-		_					
AURORA ENERGY LLC	2/17/2015	10	7645	30.40	6.24	35.65	27.71	0.12	JD		4	871.10
AURORA ENERGY LLC	2/18/2015	9	7411	30.93	6.97	34.84	27.27	0.13	T II/JD	LST	6/4	775.50
AURORA ENERGY LLC	2/19/2015	10	7474	29.85	7.43	36.13	26.59	0.12	JD/T II	LST	4/6	893.10
AURORA ENERGY LLC	2/20/2015	12	7556	30.19	6.65	36.82	26.35	0.12	T II/JD	LST	6/4	1,087.75
AURORA ENERGY LLC	2/23/2015	8	7490	30.65	6.82	35.48	27.06	0.13	T II/JD	LST	6/4	756.30
AURORA ENERGY LLC	2/24/2015	11	7576	29.59	7,24	35.95	27.22	0.14	JD/TII	LST	4/6	975.50
AURORA ENERGY LLC	2/25/2015	11	7551	29.41	7.42	35.92	27.25	0.13	T II/JD	LST	6/4	1,033.85
AURORA ENERGY LLC	2/26/2015	11	7582	29.74	6.75	36.28	27.23	0.12	T II/JD	LST	6/4	1,003.80
AURORA ENERGY LLC	2/27/2015	11	7588	29.97	6.61	36.05	27.37	0.12	TII/JD	LST	6/4	1,039.00
AURORA ENERGY LLC	3/2/2015	8	7571	29.92	6.43	36.02	27.64	0.12	TII/JD	LST	6/4	730.55
AURORA ENERGY LLC	3/3/2015	10	7698	29.84	5.91	36.58	27.67	0.11	TII/JD	LST	6/4	910.05
AURORA ENERGY LLC	3/4/2015	4	7547	30.62	6.34	35.70	27.34	0.11	TII/JD	LST	6/4	356.15
AURORA ENERGY LLC	3/5/2015	10	7705	29.51	6.01	36.35	28.13	0.11	TII/JD	LST	6/4	927.65
AURORA ENERGY LLC	3/6/2015	11	7662	30.66	5.49	36.26	27.60	0.11	TII/JD	LST	6/4	1,032.00
AURORA ENERGY LLC	3/10/2015	6	7505	30.34	6.76	36.30	26.60	0.11	TII/JD	LST	6/4	549.70
AURORA ENERGY LLC	3/11/2015	26	7109	31.44	7.90	34.89	25.76	0.10	TII/JD	LST	6/4	2,416.95
AURORA ENERGY LLC	3/12/2015	7	7483	29.94	7.34	35.71	27.02	0.11	TII/JD	LST	6/4	620.10
AURORA ENERGY LLC	3/16/2015	4	7525	29.76	7.33	35.86	27.05	0.14	TII/JD	LST	6/4	370.10
AURORA ENERGY LLC	3/17/2015	5	7468	30.08	7.36	35.59	26.98	0.11	TII/JD	LST	6/4	463.30
AURORA ENERGY LLC	3/18/2015	12	7545	30.21	6.84	35.43	27.53	0.12	TII/JD	LST	6/4	1,088.95
AURORA ENERGY LLC	3/19/2015	12	7549	29.60	7.58	35.96	26.86	0.14	TII/JD	LST	6/4	1,105.10
AURORA ENERGY LLC	3/20/2015	7	7620	29.93	7.00	36.02	27.06	0.12	TII/JD	LST	6/4	680.20
AURORA ENERGY LLC	3/23/2015	5	7555	29.89	6.88	35.98	27.26	0.12	TII/JD	LST	6/4	453.55
AURORA ENERGY LLC	4/2/2015	7	7727	30.71	5.38	35.08	28.84	0.12	JD		4	641.55
AURORA ENERGY LLC	4/6/2015	10	7763	31.03	4.67	35.18	29.13	0.11	JD		4	908.40
AURORA ENERGY LLC	4/7/2015	12	7826	30.95	4.55	35.57	28.93	0.11	JD		4	1,081.35
AURORA ENERGY LLC	4/8/2015	11	7669	31.37	5.35	34.58	28.71	0.11	JD		4	1,022.50
AURORA ENERGY LLC	4/9/2015	13	7561	31.87	5.36	34.64	28.14	0.12	JD		4	1,161.20
AURORA ENERGY LLC	4/10/2015	7	7759	30.74	5.03	35.70	28.54	0.11	JD		4	660.95
AURORA ENERGY LLC	4/13/2015	9	7711	31.37	4.82	34.74	29.07	0.11	JD		4	798.25
AURORA ENERGY LLC	4/14/2015	12	7710	31.37	4.77	35.27	28.60	0.11	JD		4	1,105.30
AURORA ENERGY LLC	4/20/2015	9	7625 Apj	30.63 pendix	5.99 III.D.7	34.56 .7-493	28.82 9	0.09	JD		4	836.95

Rail Samples Analysis Results for 1/1/15 to 6/30/15

		_		-		_	-				_	
AURORA ENERGY LLC	4/21/2015	11	7544	30.03	7.59	33.80	28.58	0.11	JD		4	989.35
AURORA ENERGY LLC	4/22/2015	8	7626	29.64	7.23	34.32	28.81	0.14	Bdi/JD	G	4/4	768.10
AURORA ENERGY LLC	4/27/2015	8	7881	29.30	5.28	35.34	30.09	0.11	JD/Bdl	G	4/3	745.75
AURORA ENERGY LLC	4/28/2015	10	7853	29.01	5.21	35.72	30.06	0.11	Bdl/JD	G	3/4	903.75
AURORA ENERGY LLC	4/29/2015	10	7620	31.74	4.50	35.15	28.61	0.10	JD		4	904.95
AURORA ENERGY LLC	4/30/2015	12	7648	28.84	7.36	34.53	29.28	0.11	Bdl/JD	G	3/4	1,151.95
AURORA ENERGY LLC	5/1/2015	8	7453	31.00	6.78	34.50	27.73	0.10	JD		4	733.95
AURORA ENERGY LLC	5/4/2015	10	7424	31.57	6.35	34.12	27.97	0.12	JD		4	891.35
AURORA ENERGY LLC	5/5/2015	8	7414	31.82	6.59	33.68	27.91	0.11	JD		4	747.95
AURORA ENERGY LLC	5/6/2015	11	7610	30.24	6.28	34.87	28.62	0.11	Bdl/JD	G	3/4	980.55
AURORA ENERGY LLC	5/7/2015	9	7511	31.23	6.16	34.56	28.05	0.11	JD		4	873.00
AURORA ENERGY LLC	5/8/2015	8	7743	29.92	5.94	35.21	28.94	0.12	JD		4	704.65
AURORA ENERGY LLC	5/12/2015	15	7685	29.76	6.46	35.56	28.22	0.11	JD		4	1,411.50
AURORA ENERGY LLC	5/13/2015	15	7530	29.73	7.50	35.02	27.76	0.12	Bdl/JD	G	3/4	1,361.45
AURORA ENERGY LLC	5/14/2015	1	7565	30.33	6.72	34.88	28.08	0.11	JD		4	99.55
AURORA ENERGY LLC	5/18/2015	13	7707	29.87	6.38	35.17	28.58	0.11	JD		4	1,253.45
AURORA ENERGY LLC	5/19/2015	8	7694	30.15	6.19	34.79	28.88	0.11	JD		4	704.35
AURORA ENERGY LLC	5/20/2015	12	7626	30.39	6.33	34.90	28.38	0.12	JD		4	1,155.60
AURORA ENERGY LLC	5/21/2015	12	7494	31.30	6.38	34.44	27.89	0.11	JD		4	1,157.45
AURORA ENERGY LLC	5/23/2015	18	7765	29.51	6.18	35.46	28.85	0.11	JD		4	1,660.70
AURORA ENERGY LLC	5/26/2015	8	7580	29.83	7.16	34.99	28.03	0.12	JD		4	732.30
AURORA ENERGY LLC	5/27/2015	14	7685	28.61	7.56	35.32	28.52	0.12	JD		4	1,376.90
AURORA ENERGY LLC	5/28/2015	14	7626	29.63	6.99	34.90	28.48	0.12	JD		4	1,353.00
AURORA ENERGY LLC	5/29/2015	6	7579	30.41	6.82	34.66	28.11	0.13	JD		4	565.25
AURORA ENERGY LLC	6/1/2015	9	7636	30.25	6.18	35.13	28.44	0.12	JD		4	857.75
AURORA ENERGY LLC	6/2/2015	8	7728	31.26	4.72	35.04	28.98	0.12	JD		4	727.00
AURORA ENERGY LLC	6/3/2015	12	7547	31.16	6.51	33.90	28.44	0.12	JD		4	1,199.65
AURORA ENERGY LLC	6/4/2015	13	7792	30.16	5.50	34.95	29.39	0.12	JD		4	1,262.20
AURORA ENERGY LLC	6/5/2015	13	7703	30.94	5.14	35.45	28.48	0.11	JD		4	1,158.10
AURORA ENERGY LLC	6/8/2015	10	7842	30.61	4.60	35.17	29.63	0.11	JD		4	944.15
AURORA ENERGY LLC	6/9/2015	8	7726	30.82	5.57	34.59	29.03	0.12	JD		4	772.90
AURORA ENERGY LLC	6/10/2015	9	7794 App	30.29 bendix l	4.94 [II.D.7	35.61 .7-494	29.16 0	0.12	JD		4	865.10

7/1/2015 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 1/1/15 to 6/30/15

AURORA ENERGY LLC		103904.8	0	7599.00	2	9.16	7.	65	35.23	27	.96	0.14
Customer		Tons		BTU	Н	20	Ash		Volatiles	Carbo	on	Sulfur
Weighted Averages Sun	nmary											
AURORA ENERGY LLC	6/30/2015	14	7934	27.67	7.69	35.54	29.11	0.14	JD		4	1,330.30
AURORA ENERGY LLC	6/29/2015	14	8027	26.68	8.75	34.64	29.93	0.15	GRP/STK		M/N	1,393.95
AURORA ENERGY LLC	6/26/2015	10	8048	26.19	8.73	35.21	29.87	0.15	GRP/STK		M/N	959.85
AURORA ENERGY LLC	6/25/2015	8	7813	27.83	6.96	35.60	29.62	0.11	Bdl/STK	Ĺ	3/N	748.55
AURORA ENERGY LLC	6/24/2015	9	7885	27.12	7.70	35.35	29.83	0.13	Bdl/STK		6/N	861.60
AURORA ENERGY LLC	6/23/2015	12	7581	28.39	8.07	34.39	29.15	0.13	Bdl		3	1,185.10
AURORA ENERGY LLC	6/22/2015	10	7649	28.27	8.58	35.13	28.03	0.13	JD		4	976.50
AURORA ENERGY LLC	6/17/2015	9	7518	24.53	13.61	35.06	26.81	0.15	GRP/STK		M/N	868.65
AURORA ENERGY LLC	6/17/2015	29	7528	24.32	14.26	34.44	26.99	0.15	GRP/STK		M/N	2,832.55
AURORA ENERGY LLC	6/16/2015	6	7887	25.37	10.64	35.26	28.73	0.15	GRP/STK		M/N	588.95
AURORA ENERGY LLC	6/15/2015	10	7900	26.99	8.73	35.33	28.95	0.14	GRP/STK		M/N	996.05
AURORA ENERGY LLC	6/12/2015	11	7855	28.23	7.74	34.69	29.34	0.14	GRP/STK		M/N	1,098.10
AURORA ENERGY LLC	6/11/2015	2	7952	29.43	5.92	34.72	29.93	0.12	GRP/STK		M/N	194.00
No. of Contract of												

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239. Coleen Thompson Date 7-1-15

Date ______ Colum Thompson

Signature

Appendix E (Coal Sulfur Summary)

1/7/2016 Adopted

Usibelli Coal Mine

November 19, 2019 Page 1 of 4

Rail Samples Analysis Results for 7/1/15 to 12/31/15

Customer	Date	#Cars	BTU	%H20	%A	%V	%C	%S	Site	Bench	Seam	Tons
AURORA ENERGY LLC	7/2/2015	5	7689	29.31	7.19	35.30	28.21	0.13	Bdl/GR	> [3/M	497.30
AURORA ENERGY LLC	7/6/2015	14	7636	28.59	7.92	35.01	28.49	0.15	Bld	1	4	1,372.10
AURORA ENERGY LLC	7/7/2015	14	7874	26.58	7.76	36.94	28.71	0.21	Bdl	T	4	1,382.00
AURORA ENERGY LLC	7/8/2015	3	7865	26.43	7.83	36.21	29.54	0.21	BLD	1	4	316.65
AURORA ENERGY LLC	7/9/2015	8	7770	26.23	8.84	36.65	28.29	0.23	Bdl	1	4	785.95
AURORA ENERGY LLC	7/10/2015	5	7921	25.95	8.00	36.75	29.31	0.19	Bdl	1	4	508.65
AURORA ENERGY LLC	7/13/2015	10	7931	25.76	7.97	36.81	29.47	0.18	Bdl	1	4	979.25
AURORA ENERGY LLC	7/14/2015	10	7750	26.64	8.53	36.28	28.56	0.21	Bdl	1	4	954.80
AURORA ENERGY LLC	7/15/2015	10	7867	26.76	7.54	36.58	29.13	0.21	Bdl	1	4	982.35
AURORA ENERGY LLC	7/16/2015	15	7868	26.59	7.56	36.90	28.95	0.21	Bdl	1	4	1,462.70
AURORA ENERGY LLC	7/17/2015	8	7832	26.21	7.83	37.22	28.75	0.22	Bdl	1	4	765.40
AURORA ENERGY LLC	7/20/2015	8	7860	27.03	7.13	36.27	29.58	0.19	Bdl	1	4	766.65
AURORA ENERGY LLC	7/21/2015	9	7694	27.61	7.96	35.51	28.93	0.20	Bdl/STh	< 1	4/N	908.35
AURORA ENERGY LLC	7/22/2015	9	7657	29.32	6.95	35.01	28.72	0.15	JD		4	877.65
AURORA ENERGY LLC	7/23/2015	9	7438	30.33	7.55	34.18	27.95	0.12	JD		4	859.90
AURORA ENERGY LLC	7/24/2015	8	7636	29.50	6.86	35.30	28.35	0.11	JD		4	772.45
AURORA ENERGY LLC	7/27/2015	9	7432	31.12	7.58	33.61	27.70	0.13	JD		4	899.50
AURORA ENERGY LLC	7/28/2015	11	7523	30.83	6.76	34.27	28.14	0.12	JD		4	1,073.20
AURORA ENERGY LLC	7/30/2015	7	7425	30.34	7.77	34.10	27.79	0.14	JD		4	693.90
AURORA ENERGY LLC	7/31/2015	8	7734	27.22	7.93	35.90	28.96	0.22	Bdl/Bd	I 1/1	3/4	724.30
AURORA ENERGY LLC	8/3/2015	9	7654	28.48	7.69	35.42	28.41	0.16	JD		4	867.75
AURORA ENERGY LLC	8/4/2015	10	7670	29.51	6.73	35.20	28.57	0.14	JD		4	937.50
AURORA ENERGY LLC	8/5/2015	12	7566	30.37	6.67	35.07	27.90	0.13	JD		4	999.75
AURORA ENERGY LLC	8/6/2015	11	7279	30.35	9.11	34.22	26.33	0.14	JD		4	1,037.80
AURORA ENERGY LLC	8/7/2015	11	7368	30.17	8.21	34.20	27.42	0.15	Bdl/JD	1	4/4	1,056.30
AURORA ENERGY LLC	8/10/2015	18	7660	29.39	6.76	35.20	28.65	0.15	JD/Bdl	/1	4/4	1,653.75
AURORA ENERGY LLC	8/12/2015	15	7359	31.58	7.10	33.94	27.40	0.14	JD		4	1,416.85
AURORA ENERGY LLC	8/13/2015	18	7510	30.41	6.79	34.63	28.16	0.17	Bdl/JD	1	4/4	1,775.95
AURORA ENERGY LLC	8/14/2015	15	7733	27.83	7.35	36.00	28.82	0.14	Bdl	4	4	1,397.60
AURORA ENERGY LLC	8/17/2015	10	7663	29.07	7.20	35.01	28.73	0.13	JD		4	943.65
			App	endix II	I.D.7.	7-4943	3					

Rail Samples Analysis Results for 7/1/15 to 12/31/15

		-			_			_				
AURORA ENERGY LLC	8/18/2015	13	7658	28.80	7.07	35.38	28.76	0.16	JD		4	1,265.45
AURORA ENERGY LLC	8/20/2015	15	7311	31.47	7.37	33.83	27.33	0.12	Bdl/JD	1/	3/4	1,386.75
AURORA ENERGY LLC	8/22/2015	18	7564	31.72	6.35	34.30	27.63	0.10	JD		4	1,546.75
AURORA ENERGY LLC	8/26/2015	15	7740	28.52	8.85	34.07	28.56	0.17	JD/GRP		4/M	1,471.40
AURORA ENERGY LLC	8/28/2015	3	7642	28.09	8.57	35.40	27.94	0.15	GPR/Bdl		M/6	261.50
AURORA ENERGY LLC	8/31/2015	8	7628	27.35	8.96	36.33	27.37	0.14	Bdl		6	720.95
AURORA ENERGY LLC	9/1/2015	17	7681	27.34	8.39	36.84	27.43	0.13	Bdi		6	1,651.15
AURORA ENERGY LLC	9/2/2015	19	7563	27.07	9.34	36.51	27,09	0.14	Bdl		6	1,898.00
AURORA ENERGY LLC	9/3/2015	27	7665	27.56	8.27	35.87	28.31	0.13	Bdl		6	2,698.95
AURORA ENERGY LLC	9/8/2015	17	7806	27.29	7.46	35.64	29.61	0.13	Bdl/STK	1/	3/N	1,594.85
AURORA ENERGY LLC	9/10/2015	20	7891	26.52	7.77	35.76	29.97	0.14	Bdl/GRP	1/	3/M	1,863.50
AURORA ENERGY LLC	9/11/2015	21	7710	26.65	9.21	35.53	28.61	0.14	Bdl/GRP	1	3/M	1,974.90
AURORA ENERGY LLC	9/15/2015	18	7420	26.03	13.40	33.43	27.10	0.16	Bdl/GRP	I	3/M	1,735.35
AURORA ENERGY LLC	9/16/2015	17	7697	26.35	10.77	36.32	26.56	0.16	GRP/Bdl		M/6	1,681.25
AURORA ENERGY LLC	9/17/2015	17	7519	26.86	10.99	35.61	26.55	0.16	Bdl/GRP		6/M	1,555.60
AURORA ENERGY LLC	9/22/2015	19	7186	27.11	12.93	34.08	25.88	0.17	Bdl/GRP		6/M	1,877.05
AURORA ENERGY LLC	9/23/2015	18	7544	27.46	9.76	34.45	28.34	0.15	Bdl	3	3	1,812.45
AURORA ENERGY LLC	9/24/2015	6	7573	26.47	10.49	34.19	28.85	0.14	Bdl	1	3	604.35
AURORA ENERGY LLC	9/29/2015	6	7141	28.88	11.36	33.89	25.87	0.15	Bdl/GRP	1	3/M	603.55
AURORA ENERGY LLC	9/30/2015	5	7514	28.44	8.69	34.21	28.66	0.13	Bdl/Bdl	1	3/6	490.85
AURORA ENERGY LLC	10/1/2015	10	7360	29.29	9.35	33.72	27.64	0.14	Bdl/Bdl	1	3/6	949.70
AURORA ENERGY LLC	10/6/2015	17	7434	28.25	9.47	34.75	27,54	0.14	Bdl		6	1,697.60
AURORA ENERGY LLC	10/7/2015	16	7427	28.14	9.75	33.75	28.48	0.13	Bdl/STK	1	3/N	1,590.90
AURORA ENERGY LLC	10/8/2015	16	7766	28.02	6.97	35.04	29.97	0.14	Bdl/STK	I	3/N	1,550.35
AURORA ENERGY LLC	10/12/2015	12	7509	28.74	8.47	34.02	28.77	0.11	Bdl/JD	1	3/4	1,188.55
AURORA ENERGY LLC	10/13/2015	14	7448	29.46	8.57	34.10	27.88	0.11	Bdl/JD	1	3/4	1,378.00
AURORA ENERGY LLC	10/14/2015	15	7329	31.93	7.28	33.16	27.63	0.11	Bdl/JD	1	3/4	1,487.05
AURORA ENERGY LLC	10/15/2015	5	7435	31.66	6.81	34.31	27.23	0.11	JD		4	472.55
AURORA ENERGY LLC	10/16/2015	6	7723	31.20	5.10	35.54	28.17	0.11	JD		4	564.80
AURORA ENERGY LLC	10/20/2015	15	7561	31.93	5.92	34.77	27.38	0.11	JD		4	1,442.25
AURORA ENERGY LLC	10/21/2015	14	7609	31.67	5.47	34.54	28.32	0.11	JD		4	1,346.70
AURORA ENERGY LLC	10/22/2015	13	7492 App	32.01 endix I	6.01 II.D.7.	34.29 7-4944	27.70 4	0.11	JD		4	1,264.45

.

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/15 to 12/31/15

AURORA ENERGY LLC	10/23/2015	15	7347	32.39	6.71	33.49	27.42	0.12	JD		4	1,492,50
AURORA ENERGY LLC	10/27/2015	9	7404	30.15	8.49	34.36	27.00	0.18	Bdl	J	4	910.80
AURORA ENERGY LLC	10/28/2015	11	7586	30.32	6.73	35.02	27.93	0.14	Bld/JD	J/	4/4	1,018.90
AURORA ENERGY LLC	10/29/2015	9	7861	26.44	7.92	36.05	29.59	0.19	Bdl	J	4	922.55
AURORA ENERGY LLC	10/30/2015	11	7948	26.92	7.00	36.90	29.19	0.17	Bdl	J	4	1,070.45
AURORA ENERGY LLC	11/3/2015	10	7438	27.87	10.34	34.56	27.24	0.28	Bdl/JD	J/	4/4	994.40
AURORA ENERGY LLC	11/4/2015	16	7495	29.67	8.21	34.18	27.95	0.20	Bdl	J	4	1,577.40
AURORA ENERGY LLC	11/5/2015	11	7320	29.67	9.27	33.61	27.46	0.22	Bdl	J	4	1,052.25
AURORA ENERGY LLC	11/6/2015	12	7629	27.60	8.75	35.23	28.42	0.25	Bdl/JD	J/	4/4	1,175.00
AURORA ENERGY LLC	11/10/2015	12	7640	28.50	7.97	35.25	28.29	0.19	Bdl	J	4	1,130.35
AURORA ENERGY LLC	11/11/2015	14	7865	27.22	7.50	35.71	29.58	0.21	Bdl	J	4	1,331.05
AURORA ENERGY LLC	11/12/2015	12	7797	27.25	7.73	35.48	29.54	0.23	Bdl	J	4	1,146.35
AURORA ENERGY LLC	11/13/2015	14	7947	26.11	7.79	36.51	29.60	0.19	Bdl	J	4	1,368.95
AURORA ENERGY LLC	11/17/2015	9	7760	27.53	7.86	35.47	29.14	0.20	Bdl/JD	J/	4/4	848,40
AURORA ENERGY LLC	11/18/2015	11	7705	28.38	7.44	35.64	28.55	0.18	Bdl/JD	J	4/4	1,026.00
AURORA ENERGY LLC	11/19/2015	8	7644	30.78	6.20	34.89	28.13	0.15	Bdl/JD	J	4/4	714.95
AURORA ENERGY LLC	11/20/2015	10	7783	29.27	6.29	35.70	28.73	0.15	JD/Bdl	/J	4/4	863.55
AURORA ENERGY LLC	11/23/2015	11	7793	29.35	6.29	35.57	28.79	0.15	JD		4	1,046.45
AURORA ENERGY LLC	11/24/2015	16	7682	30.62	5.97	34.92	28.49	0.12	JD		4	1,518.80
AURORA ENERGY LLC	11/25/2015	13	7770	29.54	6.19	35.63	28.65	0.14	JD/Bdl	/J	4/4	1,206.80
AURORA ENERGY LLC	11/27/2015	12	7612	28.41	7.98	35.68	27.94	0.19	BdI/STK	J/	4/N	1,178.80
AURORA ENERGY LLC	12/1/2015	21	7514	29.25	8.35	34.58	27.83	0.20	Bdl/STK	J/	4/N	1,971.15
AURORA ENERGY LLC	12/2/2015	9	7587	30.48	6.72	34.32	28.49	0.16	JD		4	834.10
AURORA ENERGY LLC	12/3/2015	12	7577	32.45	4.74	33.98	28.84	0.10	JD		4	1,097.45
AURORA ENERGY LLC	12/4/2015	10	7503	31.28	6.60	33.78	28.35	0,12	JD		4	915.25
AURORA ENERGY LLC	12/8/2015	13	7594	29.65	7.36	34.53	28.47	0.17	Bdl/JD	J/	4/4	1,204.60
AURORA ENERGY LLC	12/9/2015	13	7627	28.50	8.21	34.71	28.58	0.23	Bdl/JD	J/	4/4	1,254.80
AURORA ENERGY LLC	12/10/2015	12	7651	29.18	7.10	35.18	28.55	0.17	Bdl/JD	J/	4/4	1,090.15
AURORA ENERGY LLC	12/11/2015	10	7159	33.74	6.25	34.17	25.84	0.14	JD		4	935.95
AURORA ENERGY LLC	12/15/2015	14	7591	31.15	5.91	35.16	27.78	0.15	Bdl/JD	J	4/4	1,235.25
AURORA ENERGY LLC	12/16/2015	14	7527	31.73	6.00	35.00	27.27	0,16	Bdl/JD	J	4/4	1,288.80
AURORA ENERGY LLC	12/17/2015	14	7639	29.80	6.85	35.24	28.12	0.16	Bdl/JD	J	4/4	1,258.85
			App	endix I	II.D.7.	/-4945)					

1/7/2016 Adopted

Usibelli Coal Mine

Rail Samples Analysis Results for 7/1/15 to 12/31/15

AURORA ENERGY LLC	12/18/2015	14	7571	30.68	6.58	34.72	28.03	0.13	Bdl/JD	J	4/4	1,314.95
AURORA ENERGY LLC	12/21/2015	14	7631	30.24	6.30	35.17	28.29	0.15	Bdl/JD	J	4/4	1,318.90
AURORA ENERGY LLC	12/22/2015	14	7549	31.19	5.71	34.71	28.39	0.13	Bdl/JD	J	4/4	1,250.95
AURORA ENERGY LLC	12/23/2015	14	7686	31.43	4.63	35.27	28.68	0.10	Bdl/JD	J	4/4	1,262.70
AURORA ENERGY LLC	12/24/2015	10	7627	31.52	4.92	35.64	27.93	0.11	Bdl/JD	J	4/4	933.25
AURORA ENERGY LLC	12/28/2015	14	7714	30.71	4.93	36.01	28.36	0.11	Bdl/JD	J	4/4	1,246.45
AURORA ENERGY LLC	12/29/2015	16	7780	30.08	5.31	35.97	28.65	0.12	Bdi/JD	j	4/4	1,424.70
AURORA ENERGY LLC	12/30/2015	11	7673	31.40	5.02	35.64	27.95	0.12	Bdl/JD	J	4/4	968.20
AURORA ENERGY LLC	12/31/2015	12	7705	31.63	4.47	35.57	28.34	0.12	Bdl/JD	J	3/4	1,059.70
Weighted Averages Sun	nmary											
Customer		Tons		BTU	н	120	Ash		Volatiles	Cart	oon	Sulfur
AURORA ENERGY LLC		120758.3	0	7610.00	2	29.02	7.	69	35.09	2	3.20	0.15

This analysis is representative of the coal shipped. The sulfur content in this shipment was analyzed using sulfur standard ASTM D4239.

Coleen Thompson

1-7-16 Nompson Date Coleer

Signature