

**TABLE 1 SUMMARY OF UPDATED  
KING SALMON JULY 2019 PRIVATE WELL RESULTS**

Analyte			Perluoro-butane sulfonic acid (PFBS)	Perfluoro-heptanoic acid (PFHpA)	Perfluoro-nonanoic acid (PFNA)	Perfluoro-hexane sulfonic acid (PFHxS)	Perfluoro-octanoic acid (PFOA)	Perfluoro-octane sulfonate (PFOS)	LHA Combined (PFOS + PFOA)
Action Level				70†					70†
Sample Name	Address	Sample Date	ppt	ppt	ppt	ppt	ppt	ppt	ppt
AKNPW-005		7/25/2019	1.1 J	<2.0	<2.0	1.9 J	1.8 J	<2.0	1.8 J‡
AKNPW-007		7/25/2019	<2.0	3.1	<2.0	2.4	2.2	<2.0	2.2 ‡
AKNPW-008		7/26/2019	1.6 J	<2.0	<2.0	1.5 J	2.8	<2.0	2.8 ‡
AKNPW-011		7/24/2019	<2.0	<2.0	<2.0	2.1	4.2	<2.0	4.2 ‡
AKNPW-111		7/24/2019	<2.0	<2.0	<2.0	2.0	4.1	<2.0	4.1 ‡
AKNPW-012		7/24/2019	2.5	2.6	<2.0	6.7	13	<2.0	13 ‡
AKNPW-018		7/24/2019	<2.0	<2.0	<2.0	<2.0	<2.0	<2.0	N/A
AKNPW-208		7/25/2019	4.3	3.9	0.93 J	9.7	23	2.7	26
AKNPW-422		7/25/2019	1.1 J	<2.0	<2.0	1.7 J	3.1	<2.0	3.1 ‡
AKNPW-424		7/25/2019	8.0	1.2 J	<2.0	6.4	2.4	<2.0	2.4 ‡

ppt parts per trillion, equivalent to nanograms per liter

LHA U.S. Environmental Protection Agency Lifetime Health Advisory

† LHA level is 70 ppt for PFOS and PFOA combined.

DUP Field-duplicate sample

< Analyte not detected; listed as less than the reporting limit (RL) unless otherwise flagged due to quality-control (QC) failures.

J Estimated concentration, detected greater than the method detection limit (MDL) and less than the RL. Flag applied by the laboratory.

‡ Minimum concentration, the LHA Combined concentration includes one or more result that is not detected greater than the MDL.

N/A Not applicable. The LHA Combined concentration could not be calculated because PFOS and PFOA were not detected in the sample.