



# NOTICE OF REVIEW

## APDES Preliminary Draft Individual Permit

Alaska Department of Environmental Conservation (DEC)  
Wastewater Discharge Authorization Program  
555 Cordova Street  
Anchorage, Alaska 99501

NOTICE OF REVIEW OF AN  
ALASKA POLLUTANT DISCHARGE ELIMINATION SYSTEM (APDES)  
**PRELIMINARY DRAFT INDIVIDUAL PERMIT**  
TO DISCHARGE TO WATERS OF THE UNITED STATES

DEC has prepared an APDES Preliminary Draft Individual Permit, AK0000370 – **Crowley Petroleum Distribution Alaska, LLC Anchorage Bulk Petroleum Storage Facility** (Permit). The Preliminary Draft Permit, Fact Sheet, and associated documents are available to the applicant for a 10-day review. Following the close of the 10-day applicant review period, DEC will prepare a draft permit and fact sheet for a formal 30-day public review period. Public comments will be accepted during the formal 30-day review period. You can access the documents on the DEC Wastewater Discharge Authorization Program webpage at:  
<http://dec.alaska.gov/water/wastewater/>

**Alaska DEC Contact:** Marc Bentley, B.S., M.S.  
Alaska Department of Environmental Conservation  
Division of Water - Wastewater Discharge Authorization Program  
1700 East Bogard Road, Bldg. B, Suite 103  
Wasilla, AK 99654  
(907) 376-1853  
[Email.Address@alaska.gov]

**Preliminary Draft Permit Review:**

**Start Date:** July 22, 2020

**End Date:** August 6, 2020, at 5:00 p.m. Alaska Daylight Time

**Permit No.:** AK0000370

**Applicant:** Crowley Petroleum Distribution Alaska, LLC  
Anchorage Bulk Petroleum Storage Facility  
459 West Bluff Road  
Anchorage, AK 99501

### **Proposed Permit Coverage:**

The proposed Permit is a reissuance of the existing APDES Permit for the facility for another five-year term. The Anchorage Petroleum Storage Facility has a single discharge (Outfall 001) that discharges to the waters of Cook Inlet, Alaska at 61.2322 Latitude and -149.8948 Longitude.

Periodic discharges from the single outfall consists of accumulated rain or snowmelt from Secondary Containment Areas that encompass the rail rack and fuel storage tanks at a variable maximum rate of approximately 1.0 million gallons per day. The Permit establishes monitoring requirements and/or limits for oil and grease sheen, pH, as well as monitoring for total aromatic hydrocarbons, and total aqueous hydrocarbons.

### **Deadline for Written Applicant Review Comments:**

The deadline for proposed final permit review comments by the applicant is **August 6, 2020, 5:00 p.m. Alaska Daylight Time.**

### **Administrative Record:**

The APDES Preliminary Draft Permit, Fact Sheet, and associated documents are available for public review at the DEC offices located in Anchorage and Soldotna. Please contact the office of your choice to arrange for hard copies of the documents to be available for your review.

43335 Kalifornsky Beach Road  
Suite #11  
Soldotna, AK 99669  
907-262-5210

555 Cordova Street  
Anchorage, AK 99501  
907-269-6285

If you would like further information or to see any additional supporting technical documents, contact the permit writer at the address shown on page 1.

The permit documents can be accessed from the DEC Wastewater Discharge Authorization Program website at <http://dec.alaska.gov/water/wastewater/>

To receive email notifications about the APDES Program, including when permits are available to review, follow the link below to join the APDES email list.

<http://list.state.ak.us/mailman/listinfo/DEC-APDES/>

### **Disability Reasonable Accommodation Notice**

The State of Alaska, DEC complies with Title II of the Americans with Disabilities Act of 1990. If you are a person with a disability who may need a special accommodation in order to participate in this public process, please contact Kate Orozco at (907) 465-6171 or TDD Relay Service 1-800-770-8973/TTY or dial 711 within 10-days of publication of this notice to ensure that any necessary accommodations can be provided.