

**ALASKA DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Air Permits Program**

**PRELIMINARY
BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION
for
Golden Valley Electric Association
Zehnder Facility**

Prepared by: Aaron Simpson
Supervisor: James R. Plosay
Preliminary Date: March 22, 2018

http://adecteams.dec.alaska.gov/sites/AQ/crossprogramprojects/SIPBACT/Shared Documents/DRAFT_BACTdeterminations/Zehnder Facility/DRAFT Preliminary BACT Determination for Zehnder.docx

Table of Contents

1.	INTRODUCTION.....	1
2.	BACT EVALUATION.....	1
3.	BACT DETERMINATION FOR NO _x	3
3.1	NO _x BACT for Fuel Oil-Fired Simple Cycle Gas Turbines.....	3
3.2	NO _x BACT for Large Diesel-Fired Engines.....	7
3.3	NO _x BACT for Diesel-Fired Boilers	10
4.	BACT DETERMINATION FOR PM-2.5.....	13
4.1	PM-2.5 BACT for Fuel Oil-Fired Simple Cycle Gas Turbines	13
4.2	PM-2.5 BACT for Large Diesel Fired Engines.....	15
4.3	PM-2.5 BACT for Diesel Fired Boilers	18
5.	BACT DETERMINATION FOR SO ₂	20
5.1	SO ₂ BACT for Fuel Oil-Fired Simple Cycle Gas Turbines	20
5.2	SO ₂ BACT for Large Diesel-Fired Engines	23
5.3	SO ₂ BACT for Diesel Fired Boilers	26
6.	BACT DETERMINATION SUMMARY.....	28

Abbreviations/Acronyms

AAC	Alaska Administrative Code
AAAQS	Alaska Ambient Air Quality Standards
Department	Alaska Department of Environmental Conservation
BACT	Best Available Control Technology
CFB	Circulating Fluidized Bed
CFR	Code of Federal Regulations
Cyclones	Mechanical Separators
DFP	Diesel Particulate Filter
DLN	Dry Low NOx
DOC	Diesel Oxidation Catalyst
EPA	Environmental Protection Agency
ESP	Electrostatic Precipitator
EU	Emission Unit
FITR	Fuel Injection Timing Retard
GCPs	Good Combustion Practices
HAP	Hazardous Air Pollutant
ITR	Ignition Timing Retard
LEA	Low Excess Air
LNB	Low NOx Burners
MR&Rs	Monitoring, Recording, and Reporting
NESHAPS	National Emission Standards for Hazardous Air Pollutants
NSCR	Non-Selective Catalytic Reduction
NSPS	New Source Performance Standards
ORL	Owner Requested Limit
PSD	Prevention of Significant Deterioration
PTE	Potential to Emit
RICE, ICE	Reciprocating Internal Combustion Engine, Internal Combustion Engine
SCR	Selective Catalytic Reduction
SIP	Alaska State Implementation Plan
SNCR	Selective Non-Catalytic Reduction
ULSD	Ultra Low Sulfur Diesel

Units and Measures

gal/hr	gallons per hour
g/kWh	grams per kilowatt hour
g/hp-hr	grams per horsepower hour
hr/day	hours per day
hr/yr	hours per year
hp	horsepower
lb/hr	pounds per hour
lb/MMBtu	pounds per million British thermal units
lb/1000 gal	pounds per 1,000 gallons
kW	kilowatts
MMBtu/hr	million British thermal units per hour
MMscf/hr	million standard cubic feet per hour
ppmv	parts per million by volume
tpy	tons per year

Pollutants

CO	Carbon Monoxide
HAP	Hazardous Air Pollutant
NOx	Oxides of Nitrogen
SO ₂	Sulfur Dioxide
PM-2.5	Particulate Matter with an aerodynamic diameter not exceeding 2.5 microns
PM-10	Particulate Matter with an aerodynamic diameter not exceeding 10 microns

1. INTRODUCTION

The Zehnder Facility (Zehnder) is an electric generating facility that combusts distillate fuel in combustion turbines to provide power to the Golden Valley Electric Association (GVEA) grid. The power plant contains two fuel oil-fired simple cycle gas combustion turbines and two diesel-fired generators (electro-motive diesels) used for emergency power and to serve as black start engines for the GVEA generation system. The primary fuel is stored in two 50,000 gallon aboveground storage tanks. Turbine startup fuel and electro-motive diesels primary fuel is stored in a 12,000 gallon above ground storage tank.

In a letter dated April 24, 2015, the Alaska Department of Environmental Conservation (Department) requested the stationary sources expected to be major stationary sources in the particulate matter with an aerodynamic diameter less than or equal to a nominal 2.5 micrometers (PM-2.5) serious nonattainment area perform a voluntary Best Available Control Technology (BACT) review in support of the state agency's required SIP submittal once the nonattainment area is re-classified as a Serious PM-2.5 nonattainment area. The designation of the area as "Serious" with regard to nonattainment of the 2006 24-hour PM-2.5 ambient air quality standards was published in Federal Register Vol. 82, No. 89, May 10, 2017, pages 21703-21706, with an effective date of June 9, 2017.¹

This report addresses the significant emissions units (EUs) listed in the Zehnder facility's operating permit AQ0109TVP03. This report provides the Department's preliminary review of the BACT analysis for PM-2.5 and BACT analyses provided for oxides of nitrogen (NO_x) and sulfur dioxide (SO₂) emissions, which are precursor pollutants that can form PM-2.5 in the atmosphere post combustion.

The following sections review GVEA's BACT analysis for the Zehnder Facility for technical accuracy and adherence to accepted engineering cost estimation practices.

2. BACT EVALUATION

A BACT analysis is an evaluation of all available control options for equipment emitting the triggered pollutants and a process for selecting the best option based on feasibility, economics, energy, and other impacts. 40 CFR 52.21(b)(12) defines BACT as a site-specific determination on a case-by-case basis. The Department's goal is to identify BACT for the permanent emission units (EUs) at the GVEA Zehnder facility that emit NO_x, PM-2.5, and SO₂, establish emission limits which represent BACT, and assess the level of monitoring, recordkeeping, and reporting (MR&R) necessary to ensure GVEA applies BACT for the EUs. The Department based the BACT review on the five-step top-down approach set forth in Federal Register Volume 61, Number 142, July 23, 1996 (Environmental Protection Agency). Table A presents the EUs subject to BACT review.

¹ Federal Register, Vol. 82, No. 89, Wednesday May 10, 2017 (<https://dec.alaska.gov/air/anpms/comm/docs/2017-09391-CFR.pdf>)

Table A: Emission Units Subject to BACT Review

EU ID	Description of EU	Rating/Size	Installation or Construction Date
1	Fuel Oil-Fired Regenerative Simple Cycle Gas Turbine	268 MMBtu/hr (18.4 MW)	1971
2	Fuel Oil-Fired Regenerative Simple Cycle Gas Turbine	268 MMBtu/hr (18.4 MW)	1972
3	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr (2.75 MW)	1970
4	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr (2.75 MW)	1970
10	Diesel-Fired Boiler	1.7 MMBtu/hr	2012
11	Diesel-Fired Boiler	1.7 MMBtu/hr	2012

Five-Step BACT Determinations

The following sections explain the steps used to determine BACT for NO_x, PM-2.5, and SO₂ for the applicable equipment.

Step 1 Identify All Potentially Available Control Technologies

The Department identifies all available control options for the EU and the pollutant under consideration. This includes technologies used throughout the world or emission reductions through the application of available control techniques, changes in process design, and/or operational limitations. To assist in identifying available controls, the Department reviews available controls listed on the Reasonably Available Control Technology (RACT), BACT, and Lowest Achievable Emission Rate (LAER) Clearinghouse (RBLC). The RBLC is an EPA database where permitting agencies nationwide post imposed BACT for PSD sources. It is usually the first stop for BACT research. In addition to the RBLC search, the Department used several search engines to look for emerging and tried technologies used to control NO_x, PM-2.5, and SO₂ emissions from equipment similar to those listed in Table A.

Step 2 Eliminate Technically Infeasible Control Technologies:

The Department evaluates the technical feasibility of each control technology based on source specific factors in relation to each EU subject to BACT. Based on sound documentation and demonstration, the Department eliminates control technologies deemed technically infeasible due to physical, chemical, and engineering difficulties.

Step 3 Rank the Remaining Control Technologies by Control Effectiveness

The Department ranks the remaining control technologies in order of control effectiveness with the most effective at the top.

Step 4 Evaluate the Most Effective Controls and Document the Results as Necessary

The Department reviews the detailed information in the BACT analysis about the control efficiency, emission rate, emission reduction, cost, environmental, and energy impacts for each option to decide the final level of control. The analysis must present an objective evaluation of both the beneficial and adverse energy, environmental, and economic impacts. A proposal to use the most effective option does not need to provide the detailed information for the less effective options. If cost is not an issue, a cost analysis is not required. Cost effectiveness for a control

option is defined as the total net annualized cost of control divided by the tons of pollutant removed per year. Annualized cost includes annualized equipment purchase, erection, electrical, piping, insulation, painting, site preparation, buildings, supervision, transportation, operation, maintenance, replacement parts, overhead, raw materials, utilities, engineering, start-up costs, financing costs, and other contingencies related to the control option. Sections 3, 4, and 5 present the Department's Preliminary BACT Determinations for NO_x, PM-2.5, and SO₂.

Step 5 Select BACT

The Department selects the most effective control option not eliminated in Step 4 as BACT for the pollutant and EU under review and lists the final BACT requirements determined for each EU in this step. A project may achieve emission reductions through the application of available technologies, changes in process design, and/or operational limitations. The Department reviewed GVEA's BACT analysis and made preliminary BACT determinations for NO_x, PM-2.5, and SO₂ for the GVEA Zehnder Facility. These preliminary BACT determinations are based on the information submitted by GVEA in their analysis, information from vendors, suppliers, sub-contractors, RBLC, and an exhaustive internet search.

3. BACT DETERMINATION FOR NO_x

The NO_x controls proposed in this section are not planned to be implemented. The optional preliminary precursor demonstration (as allowed under 40 C.F.R. 51.1006) for the precursor gas NO_x for point sources illustrates that NO_x controls are not needed. DEC is planning to submit with the Serious SIP a final precursor demonstration as justification not to require NO_x controls. Please see the preliminary precursor demonstration for NO_x posted at <http://dec.alaska.gov/air/anpms/communities/fbks-pm2-5-serious-sip-development>. The PM_{2.5} NAAQS Final SIP Requirements Rule states if the state determines through a precursor demonstration that controls for a precursor gas are not needed for attaining the standard, then the controls identified as BACT/BACM or Most Stringent Measure for the precursor gas are not required to be implemented.² Final approval of the precursor demonstration is at the time of the Serious SIP approval.

The GVEA Zehnder Facility has two existing 268 MMBtu/hr General Electric Frame 5 MS 5001-M simple cycle combustion gas turbines, two 28 MMBtu/hr General Motors Electro-Motive Diesel Generators, and two 1.7 MMBtu/hr Weil-Mclain diesel-fired boilers subject to BACT. The Department based its NO_x assessment on BACT determinations found in the RBLC, internet research, and BACT analyses submitted to the Department by Golden Valley Electric Association (GVEA) for the North Pole Power Plant and Zehnder Facility, Aurora Energy, LLC (Aurora) for the Chena Power Plant, U.S. Army Corps of Engineers (US Army) for Fort Wainwright, and the University of Alaska Fairbanks (UAF) for the Combined Heat and Power Plant.

3.1 NO_x BACT for the Fuel Oil-Fired Simple Cycle Gas Turbines

Possible NO_x emission control technologies for the fuel oil-fired simple cycle turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years

² <https://www.gpo.gov/fdsys/pkg/FR-2016-08-24/pdf/2016-18768.pdf>

under the process code 15.190, Liquid Fuel-Fired Simple Cycle Gas Turbines (> 25 MW). The search results for simple cycle gas turbines are summarized in Table 3-1.

Table 3-1. RBLC Summary of NOx Controls for Fuel Oil-Fired Simple Cycle Gas Turbines

Control Technology	Number of Determinations	Emission Limits (ppmv)
Selective Catalytic Reduction	2	7
Low NOx Burners	12	5 – 15
Good Combustion Practices	3	15

RBLC Review

A review of similar units in the RBLC indicates selective catalytic reduction, low NOx burners, and good combustion practices are the principle NOx control technologies installed on fuel oil-fired simple cycle gas turbines. The lowest NOx emission rate listed in the RLBC is 5 parts per million by volume (ppmv).

Step 1 - Identification of NOx Control Technology for the Simple Cycle Gas Turbines

From research, the Department identified the following technologies as available for control of NOx emissions from fuel oil-fired simple cycle gas turbines rated at 25 MW or more:

(a) Selective Catalytic Reduction (SCR)

SCR is a post-combustion gas treatment technique for reducing nitric oxide (NO) and nitrogen dioxide (NO₂) in the turbine exhaust stream to molecular nitrogen (N₂), water, and oxygen (O₂). In the SCR process, aqueous or anhydrous ammonia (NH₃) is injected into the flue gas upstream of a catalyst bed. The catalyst lowers the activation energy of the NOx decomposition reaction. NOx and NH₃ combine at the catalyst surface forming an ammonium salt intermediate, which subsequently decomposes to produce elemental N₂ and water. Depending on the overall NH₃-to-NOx ratio, removal efficiencies are generally 80 to 90 percent. Challenges associated with using SCR on fuel oil-fired simple cycle gas turbines include a narrow window of acceptable inlet and exhaust temperatures (500°F to 800°F), emission of NH₃ into the atmosphere (NH₃ slip) caused by non-stoichiometric reduction reaction, and disposal of depleted catalysts. The Department considers SCR a technically feasible control technology for the fuel oil-fired simple cycle gas combustion turbines.

(b) Water Injection

Water/steam injection involves the introduction of water or steam into the combustion zone. The injected fluid provides a heat sink which absorbs some of the heat of reaction, causing a lower flame temperature. The lower flame temperature results in lower thermal NOx formation. Both steam and water injections are capable of obtaining the same level of control. The process requires approximately 0.8 to 1.0 pound of water or steam per pound of fuel burned. The main technical consideration is the required purity of the water or steam, which is required to protect the equipment from dissolved solids. Obtaining water or steam of sufficient purity requires the installation of rigorous water treatment and deionization systems. Water/steam injection is a proven technology for NOx emissions reduction from turbines. However, the arctic environment presents significant challenges to water/steam injection due to cost of water treatment, freezing potential due to extreme cold ambient temperatures, and increased maintenance problems due to

accelerated wear in the hot sections of the turbines. Moreover, the vendor of the turbines does not recommend using water/steam injection to control NO_x emissions from the turbines because of the extra maintenance problems. The Department considers water/steam injection a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

(c) Dry Low NO_x (DLN)

Two-stage lean/lean combustors are essentially fuel-staged, premixed combustors in which each stage burns lean. The two-stage lean/lean combustor allows the turbine to operate with an extremely lean mixture while ensuring a stable flame. A small stoichiometric pilot flame ignites the premixed gas and provides flame stability. The NO_x emissions associated with the high temperature pilot flame are insignificant. Low NO_x emission levels are achieved by this combustor design through cooler flame temperatures associated with lean combustion and avoidance of localized "hot spots" by premixing the fuel and air. DLN is designed for natural gas-fired or dual-fuel fired units and is not effective in controlling NO_x emissions from fuel oil-fired units. The Department does not consider DLN a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

(d) Limited Operation

Limiting the operation of emission units reduces the potential to emit for those units. The Department considers limited operation a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

(e) Good Combustion Practices (GCPs)

GCPs typically include the following elements:

1. Sufficient residence time to complete combustion;
2. Providing and maintaining proper air/fuel ratio;
3. High temperatures and low oxygen levels in the primary combustion zone;
4. High enough overall excess oxygen levels to complete combustion and maximize thermal efficiency.

Combustion efficiency is dependent on the gas residence time, the combustion temperature, and the amount of mixing in the combustion zone. GCPs are accomplished primarily through combustion chamber design as it relates to residence time, combustion temperature, air-to-fuel mixing, and excess oxygen levels. The Department considers GCPs a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

Step 2 - Elimination of Technically Infeasible NO_x Control Technologies for Gas Turbines

As explained in Step 1 of Section 3.1, the Department does not consider dry low NO_x as technically feasible technology to control NO_x emissions from the fuel oil-fired simple cycle gas turbines.

Step 3 - Rank the Remaining NO_x Control Technologies for the Simple Cycle Gas Turbines

The following control technologies have been identified and ranked for control of NO_x emissions from the fuel oil-fired simple cycle gas turbines:

- (a + b) Selective Catalytic Reduction and Water Injection (95% Control)
- (a) Selective Catalytic Reduction (90% Control)
- (b) Water Injection (70% Control)
- (g) Good Combustion Practices (Less than 40% Control)
- (d) Limited Operation (0% Control)

Control technologies already in practice at the stationary source or included in the design of the EU are considered 0% control for the purpose of the SIP BACT for existing stationary sources.

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA provided an economic analysis of the control technologies available for the fuel oil-fired simple cycle turbines to demonstrate that the use of water injection with SCR, SCR, or water injection in conjunction with limited operation is not economically feasible on these units. A summary of the analyses for EUs 1 and 2 is shown in Table 3-2:

Table 3-2. GVEA Economic Analysis for Technically Feasible NOx Controls per Turbine

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR and Water Injection	1,033	929.7	\$18,729,680	\$4,915,081	\$5,287
SCR	1,033	878.1	\$12,931,360	\$2,837,279	\$3,231
Water Injection	1,033	754.1	\$3,710,000	\$1,673,057	\$2,219

Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)

GVEA contends that the economic analysis indicates the level of NOx reduction does not justify the use of SCR, Water Injection, or SCR and Water Injection for the fuel oil-fired simple cycle gas turbines based on the excessive cost per ton of NOx removed per year.

GVEA proposes the following as BACT for NOx emissions from the fuel oil-fired simple cycle gas turbines:

- (a) NOx emissions from the operation of the fuel oil-fired simple cycle gas turbines will be controlled with good combustion practices; and
- (b) NOx emissions from the fuel oil-fired simple cycle gas turbines will not exceed 0.88 lb/MMBtu over a 4-hour averaging period.

Department Evaluation of BACT for NOx Emissions from the Simple Cycle Gas Turbines

The Department revised the cost analyses provided by GVEA for the installation of SCR and Water Injection using the unrestricted potential to emit from the fuel oil-fired simple cycle turbines, a baseline emission rate of 0.88 lb NOx/MMBtu, a NOx removal efficiency of 95% for SCR and Water Injection, and a 20 year equipment life. A summary of the analysis is shown below:

Table 3-3. Department Economic Analysis for Technically Feasible NOx Controls per Turbine

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
SCR and Water Injection	1,033	981.4	\$18,729,680	\$4,016,346	\$4,093
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipment life)					

The Department’s preliminary economic analysis indicates the level of NOx reduction justifies the installation of SCR and water injection for the fuel oil-fired simple cycle gas turbines located in the Serious PM-2.5 nonattainment area.

Step 5 - Preliminary Selection of NOx BACT for the Simple Cycle Gas Turbines

The Department’s preliminary finding is that the BACT for NOx emissions from the fuel oil-fired simple cycle gas turbines is as follows:

- (a) NOx emissions from EUs 1 & 2 shall be controlled by operating and maintaining selective catalytic reduction and water injection at all times the units are in operation;
- (b) NOx emissions from EUs 1 & 2 shall not exceed 0.044 lb/MMBtu averaged over a 3-hour period; and
- (c) Initial compliance with the proposed NOx emission limit will be demonstrated by conducting a performance test to obtain an emission rate.

Table 3-4 lists the proposed NOx BACT determination for this facility along with those for other fuel oil-fired simple cycle turbines in the Serious PM-2.5 nonattainment area.

Table 3-4. Comparison of NOx BACT for Simple Cycle Gas Turbines at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
North Pole	Two Fuel Oil-Fired Simple Cycle Gas Turbines	1,344 MMBtu/hr	0.044 lb/MMBtu	Selective Catalytic Reduction Water Injection
Zehnder	Two Fuel Oil-Fired Simple Cycle Gas Turbines	536 MMBtu/hr	0.044 lb/MMBtu	Selective Catalytic Reduction Water Injection

3.2 NOx BACT for the Large Diesel-Fired Engines

Possible NOx emission control technologies for large engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.100 to 17.190, Large Internal Combustion Engines (>500 hp). The search results for large diesel-fired engines are summarized in Table 3-5.

Table 3-5. RBLC Summary of NOx Controls for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Selective Catalytic Reduction	3	0.5 - 0.7
Other Add-On Control	1	1.0
Federal Emission Standards	13	3.0 - 6.9
Good Combustion Practices	31	3.0 - 13.5
No Control Specified	60	2.8 - 14.1

RBLC Review

A review of similar units in the RBLC indicates selective catalytic reduction, good combustion practices, and compliance with federal emission standards are the principle NO_x control technologies installed on large diesel-fired engines. The lowest NO_x emission rate listed in the RBLC is 0.5 g/hp-hr.

Step 1 - Identification of NO_x Control Technology for the Large Diesel-Fired Engines

From research, the Department identified the following technologies as available for control of NO_x emissions from diesel-fired engines rated at 500 hp or greater:

(a) Selective Catalytic Reduction

The theory of SCR was discussed in detail in the NO_x BACT for the turbines and will not be repeated here. The Department considers SCR a technically feasible control technology for the large diesel-fired engines.

(b) Turbocharger and Aftercooler

Turbocharger technology involves the process of compressing intake air in a turbocharger upstream of the air/fuel injection. This process boosts the power output of the engine. The air compression increases the temperature of the intake air so an aftercooler is used to reduce the intake air temperature. Reducing the intake air temperature helps lower the peak flame temperature which reduces NO_x formation in the combustion chamber. EU 3 and 4 are currently operating with a turbocharger and aftercooler. The Department considers turbocharger and aftercooler a technically feasible control technology for the large diesel-fired engines.

(c) Fuel Injection Timing Retard (FITR)

FITR reduces NO_x emissions by the delay of the fuel injection in the engine from the time the compression chamber is at minimum volume to a time the compression chamber is expanding. Timing adjustments are relatively straightforward. The larger volume in the compression chamber produces a lower peak flame temperature. With the use of FITR the engine becomes less fuel efficient, particulate matter emissions increase, and there is a limit with respect to the degree the timing may be retarded because an excessive timing delay can cause the engine to misfire. The timing retard is generally limited to no more than three degrees. Diesel engines may also produce more black smoke due to a decrease in exhaust temperature and incomplete combustion. FITR can achieve up to 50 percent NO_x reduction. Due to the increase in particulate matter emissions resulting from FITR, this technology will not be carried forward.

(d) Ignition Timing Retard (ITR)

ITR lowers NO_x emissions by moving the ignition event to later in the power stroke, after the piston has begun to move downward. Because the combustion chamber volume is not at a minimum, the peak flame temperature is not as high, which lowers combustion temperature and produces less thermal NO_x. Use of ITR can cause an increase in fuel usage, an increase PM emissions, and engine misfiring. ITR can achieve between 20 to 30 percent NO_x reduction. Due to the increase in particulate matter emissions resulting from ITR, this technology will not be carried forward.

(e) Federal Emission Standards

RBLC NO_x determinations for federal emission standards require the engines meet the requirements of 40 C.F.R. 60 NSPS Subpart IIII, 40 C.F.R 63 Subpart ZZZZ, non-road engines (NREs), or EPA tier certifications. NSPS Subpart IIII applies to stationary compression ignition internal combustion engines that are manufactured or reconstructed after July 11, 2005. The Department considers meeting the technology based New Source Performance Standards (NSPS) of Subpart IIII as a technically feasible control technology for the large diesel-fired engines.

(f) Limited Operation

Limiting the operation of emissions units reduces the potential to emit of those units. The Department considers limited operation a technically feasible control technology for the large diesel-fired engines.

(g) Good Combustion Practices

The theory of GCPs was discussed in detail in the NO_x BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process will result in a reduction of NO_x emissions. The Department considers GCPs a technically feasible control technology for the large diesel-fired engine.

Step 2 - Eliminate Technically Infeasible NO_x Control Technologies for the Large Engines

As explained in Step 1 of Section 3.2, the Department does not consider fuel injection timing retard and ignition timing retard as technically feasible technologies to control NO_x emissions from the large diesel-fired engines.

Step 3 - Rank the Remaining NO_x Control Technologies for the Large Diesel-Fired Engines

The following control technologies have been identified and ranked by efficiency for the control of NO_x emissions from the large diesel-fired engines.

- (f) Limited Operation (94% Control)
- (a) Selective Catalytic Reduction (90% Control)
- (g) Good Combustion Practices (Less than 40% Control)
- (e) Federal Emission Standards (Baseline)
- (b) Turbocharger and Aftercooler (0% Control)

Control technologies already in practice at the stationary source or included in the design of the EU are considered 0% control for the purpose of the SIP BACT for existing stationary sources.

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA proposes the following as BACT for NO_x emissions from the large diesel-fired engines:

- (a) NO_x emissions from the operation of the diesel-fired engines shall be controlled with turbocharger and aftercooler;
- (b) NO_x emissions from the operation of the diesel-fired engines shall not exceed 0.024 lb/hp-hr over a 4-hour averaging period; and
- (c) Limited Operation.

Department Evaluation of BACT for NOx Emissions from the Large Diesel-Fired Engines

The Department reviewed GVEA’s proposal and finds that NOx emissions from the large diesel-fired engines can additionally be controlled by good combustion practices.

Step 5 - Preliminary Selection of NOx BACT for the Large Diesel-Fired Engines

The Department’s preliminary finding is that the BACT for NOx emissions from the large diesel-fired engines is as follows:

- (a) NOx emissions from the operation of the diesel-fired engines will be controlled with turbocharger and aftercooler;
- (b) Limit non-emergency operation of EUs 3 and 4 to no more than 500 hours per year each for maintenance checks and readiness testing;
- (c) NOx emissions from EU 7 shall not exceed 0.024 lb/hp-hr over a 3-hour averaging period; and
- (d) Maintain good combustion practices by following the manufacturer’s maintenance procedures at all times of operation.

Table 3-6 lists the proposed BACT determination for this facility along with those for other diesel-fired engines rated at more than 500 hp located in the Serious PM-2.5 nonattainment area.

Table 3-6. Comparison of NOx BACT for Large Diesel-Fired Engines at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
Fort Wainwright	8 Large Diesel-Fired Engines	> 500 hp	4.77 – 10.88 g/hp-hr	Limited Operation Good Combustion Practices Federal Emission Standards
UAF	Large Diesel-Fired Engine	13,266 hp	0.0020 g/hp-hr	Selective Catalytic Reduction Turbocharger and Aftercooler Good Combustion Practices Limited Operation
GVEA North Pole	Large Diesel-Fired Engine	600 hp	10.88 g/hp-hr	Turbocharger and Aftercooler Good Combustion Practices Limited Operation
GVEA Zehnder	2 Large Diesel-Fired Engines	11,000 hp (each)	3.69 g/hp-hr	Turbocharger and Aftercooler Good Combustion Practices Limited Operation

3.3 NOx BACT for the Diesel-Fired Boilers

Possible NOx emission control technologies for diesel-fired boilers were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.220, Commercial/Institutional Size Boilers (<100 MMBtu/hr). The search results for diesel-fired engines are summarized in Table 3-7.

Table 3-7. RBLC Summary of NOx Control for Diesel-Fired Boilers

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Low-NOx Burner	8	0.023 - 0.14
Good Combustion Practices	1	0.01
No Control Specified	2	0.070 - 0.12

RBLC Review

A review of similar units in the RBLC indicates low-NOx burners and good combustion practices are the principle NOx control technologies installed on diesel-fired boilers. The lowest NOx emission rate listed in the RBLC is 0.01 lb/MMBtu.

Step 1 - Identification of NOx Control Technology for the Diesel-Fired Boilers

From research, the Department identified the following technologies as available for control of NOx emissions from diesel fired boilers rated at less than 100 MMBtu/hr:

(a) Low NOx Burners

Using LNBs can reduce formation of NOx through careful control of the fuel-air mixture during combustion. Control techniques used in LNBs includes staged air, and staged fuel, as well as other methods that effectively lower the flame temperature. Experience suggests that significant reduction in NOx emissions can be realized using LNBs. The U.S. EPA reports that LNBs have achieved reduction up to 80%, but actual reduction depends on the type of fuel and varies considerably from one installation to another. Typical reductions range from 40% - 60% but under certain conditions, higher reductions are possible. Air staging or two-stage combustion, is generally described as the introduction of overfire air into the boiler or furnace. Overfire air is the injection of air above the main combustion zone. As indicated by EPA's AP-42, LNBs are applicable to tangential and wall-fired boilers of various sizes but are not applicable to other boiler types such as cyclone furnaces or stokers. The Department considers LNB a technically feasible control technology for the diesel-fired boilers.

(b) Flue Gas Recirculation (FGR)

Flue gas recirculation involves extracting a portion of the flue gas from the economizer section or air heater outlet and readmitting it to the furnace through the furnace hopper, the burner windbox, or both. This method reduces the concentration of oxygen in the combustion zone and may reduce NOx by as much as 40 to 50 percent in some boilers. Chapter 1.3-7 from AP-42 indicates that FGR can require extensive modifications to the burner and windbox and can result in possible flame instability at high FGR rates. The Department does not consider FGR a technically feasible control technology for the diesel-fired boilers.

(c) Good Combustion Practices

The theory of GCPs was discussed in detail in the NOx BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. The Department considers GCPs a technically feasible control technology for the mid-sized diesel fired boilers.

Step 2 - Eliminate Technically Infeasible NOx Control Technologies for the Diesel-Fired Boilers

As explained in Step 1 of Section 3.3, the Department does not consider flue gas recirculation as technically feasible technologies for the diesel-fired boilers.

Step 3 - Rank the Remaining NOx Control Technologies for the Diesel-Fired Boilers

The following control technologies have been identified and ranked by efficiency for the control of NOx emissions from the diesel-fired boilers:

- (a) Low NOx Burners (40% - 60% Control)
- (c) Good Combustion Practices (Less than 40% Control)

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA provided an economic analysis for the installation of LNB per diesel-fired boiler. A summary of the analysis is shown below:

Table 3-8. Economic Analysis for Low NOx Burners per Diesel-Fired Boiler

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
LNB	1.1	0.37	\$21,820	\$3,107	\$8,396
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

GVEA contends that the economic analysis indicates the level of NOx reduction does not justify installing LNBS on the diesel-fired boilers based on the excessive cost per ton of NOx removal per year.

GVEA proposes the following as BACT for NOx emissions from the diesel-fired boilers:

- (a) NOx emissions from the operation of the diesel fired boilers shall be controlled by good combustion practices; and
- (b) NOx emissions from EU 10 and 11 shall not exceed 20 lb/1000 gallons of diesel fuel over a 4-hour averaging period.

Department Evaluation of BACT for NOx Emissions from the Diesel-Fired Boilers

The Department reviewed GVEA’s proposal and finds that the two diesel-fired boilers have a combined potential to emit (PTE) of less than three tons per year (tpy) for NOx based on continuous operation of 8,760 hours per year. At three tpy, the cost effectiveness in terms of dollars per ton for add-on pollution control for these units is economically infeasible.

Step 5 - Selection of NOx BACT for the Diesel-Fired Boilers

The Department’s preliminary finding is that BACT for NOx emissions from the diesel-fired boilers is as follows:

- (a) NOx emissions from the diesel-fired boilers shall not exceed 20 lb/1000 gallons of diesel fuel; and
- (b) Maintain good combustion practices by following the manufacturer’s maintenance procedures at all times of operation.

Table 3-9 lists the proposed NOx BACT determination for the facility along with those for other diesel-fired boilers rated at less than 100 MMBtu/hr in the Serious PM-2.5 nonattainment area.

Table 3-9. Comparison of NOx BACT for the Diesel-Fired Boilers at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
UAF	3 Small Diesel-Fired Boilers	< 100 MMBtu/hr	0.0027 lb/MMBtu	Limited Operation
Fort Wainwright	27 Small Diesel-Fired Boilers	< 100 MMBtu/hr	Varies	Limited Operation for Non-Emergency Use (500 hours per year each) Good Combustion Practices
GVEA Zehnder	2 Small Diesel-Fired Boilers	< 100 MMBtu/hr	0.10 lb/MMBtu	Low NOx Burners

4. BACT DETERMINATION FOR PM-2.5

The Department based its PM-2.5 assessment on BACT determinations found in the RBLC, internet research, and BACT analyses submitted to the Department by GVEA for the North Pole Power Plant and Zehnder Facility, Aurora for the Chena Power Plant, US Army for Fort Wainwright, and UAF for the Combined Heat and Power Plant.

4.1 PM-2.5 BACT for the Fuel Oil-Fired Simple Cycle Gas Turbines (EUs 1 and 2)

Possible PM-2.5 emission control technologies for the fuel oil-fired simple cycle gas turbines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.190, Simple Cycle Gas Turbines (> 25 MW) The search results for simple cycle gas turbines are summarized in Table 4-1.

Table 4-1. RBLC Summary of PM-2.5 Control for Simple Cycle Gas Turbines

Control Technology	Number of Determinations	Emission Limits
Good Combustion Practices	25	0.0038 – 0.0076 lb/MMBtu
Clean Fuels	12	5 – 14 lb/hr

RBLC Review

A review of similar units in the RBLC indicates restrictions on fuel sulfur contents and good combustion practices are the principle PM control technologies installed on simple cycle gas turbines. The lowest PM-2.5 emission rate listed in the RBLC is 0.0038 lb/MMBtu.

Step 1 - Identification of PM-2.5 Control Technology for the Simple Cycle Gas Turbines

From research, the Department identified the following technologies as available for control of PM-2.5 emissions from fuel oil-fired simple cycle gas turbines:

(a) Low Sulfur Fuel

Low sulfur fuel has been known to reduce particulate matter emissions. PM-2.5 emission rates for low sulfur fuel are not available and therefore a BACT emissions rate cannot be set for low sulfur fuel. The Department does not consider low sulfur fuel a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

(b) Low Ash Fuel

Residual fuels and crude oil are known to contain ash forming components, while refined fuels are low ash. Fuels containing ash can cause excessive wear to equipment and foul combustion components. EUs 1 and 2 are fired exclusively on distillate fuel which is a form of refined fuel, and potential PM-2.5 emissions are based on emission factors for distillate fuel. The Department considers low ash fuel a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

(c) Limited Operation

Limiting the operation of emission units reduces the potential to emit for those units. Due to EUs 1 and 2 currently operating under limits, the Department considers limited operation as a feasible control technology for the fuel oil-fired simple cycle gas turbines.

(d) Good Combustion Practices

The theory of GCPs was discussed in detail in the NO_x BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process will result in a reduction of PM. The Department considers GCPs a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

Step 2 - Eliminate Technically Infeasible PM-2.5 Controls for the Simple Cycle Gas Turbines

As explained in Step 1 of Section 4.1, the Department does not consider low sulfur fuel as technically feasible technology to control PM-2.5 emissions from the fuel oil-fired simple cycle gas turbines.

Step 3 - Rank the Remaining PM-2.5 Control Technologies for the Simple Cycle Gas Turbines

The following control technologies have been identified and ranked by efficiency for the control of PM-2.5 emissions from the fuel oil-fired simple cycle gas turbines:

- | | |
|-------------------------------|-------------------------|
| (d) Good Combustion Practices | (Less than 40% Control) |
| (b) Low Ash Fuel | (0% Control) |
| (c) Limited Operation | (0% Control) |

Control technologies already in practice at the stationary source or included in the design of the EU are considered 0% control for the purpose of the SIP BACT for existing stationary sources.

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA proposes the following as BACT for PM-2.5 emissions from the fuel oil-fired simple cycle gas turbines:

- (a) PM-2.5 emissions from EUs 1 and 2 shall not exceed 0.12 lb/MMBtu over a 4-hour averaging period; and
- (b) Maintaining good combustion practices.

Step 5 - Preliminary Selection of PM-2.5 BACT for the Simple Cycle Gas Turbines

The Department’s preliminary finding is that BACT for PM-2.5 emissions from the fuel oil-fired simple cycle gas turbines is as follows:

- (a) PM-2.5 emissions from EUs 1 and 2 shall be controlled by combusting only low ash fuel;
- (b) Maintain good combustion practices at all times of operation by following the manufacturer’s operation and maintenance procedures;
- (c) PM-2.5 emissions from EUs 1 & 2 shall not exceed 0.012 lb/MMBtu over a 3-hour averaging period; and
- (d) Compliance with the PM-2.5 emission limit will be demonstrated by conducting an initial performance test to obtain an emission rate.

Table 4-2 lists the proposed PM-2.5 BACT determination for this facility along with those for other fuel oil-fired simple cycle gas turbines located in the Serious PM-2.5 nonattainment area.

Table 4-2. Comparison of PM-2.5 BACT for Simple Cycle Gas Turbines at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
GVEA – North Pole	Two Fuel Oil-Fired Simple Cycle Gas Turbines	1,344 MMBtu/hr	0.012 lb/MMBtu ³ (3-hour averaging period)	Good Combustion Practices
GVEA – Zehnder	Two Fuel Oil-Fired Simple Cycle Gas Turbines	536 MMBtu/hr	0.012 lb/MMBtu ³ (3-hour averaging period)	Good Combustion Practices

4.2 PM-2.5 BACT for the Large Diesel Fired Engines

Possible PM-2.5 emission control technologies for large engine was obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.110-17.190, Large Internal Combustion Engines (>500 hp). The search results for large diesel-fired engines are summarized in Table 4-3.

Table 4-3. RBLC Summary of PM-2.5 Control for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Federal Emission Standards	12	0.03 – 0.02
Good Combustion Practices	28	0.03 – 0.24
Limited Operation	11	0.04 – 0.17
Low Sulfur Fuel	14	0.15 – 0.17
No Control Specified	14	0.02 – 0.15

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices, compliance with the federal emission standards, low ash/sulfur diesel, and limited operation are the principle

³ Table 3.1-2a of US EPA’s AP-42 Emission Factors. <https://www3.epa.gov/ttn/chief/ap42/ch03/final/c03s01.pdf>

PM-2.5 control technologies installed on large diesel-fired engines. The lowest PM-2.5 emission rate in the RBLC is 0.02 g/hp-hr.

Step 1 - Identification of PM-2.5 Control Technology for the Large Diesel-Fired Engines

From research, the Department identified the following technologies as available for controls of PM-2.5 emissions from diesel fired engines rated at 500 hp or greater:

- (a) Diesel Particulate Filter (DPF)
DPFs are a control technology that is designed to physically filter particulate matter from the exhaust stream. Several designs exist which require cleaning and replacement of the filter media after soot has become caked onto the filter media. Regenerative filter designs are also available that burn the soot on a regular basis to regenerate the filter media. DPF can reduce PM-2.5 emissions by 85%. The Department considers DPF a technically feasible control technology for the large diesel-fired engines.
- (b) Diesel Oxidation Catalyst (DOC)
DOC can reportedly reduce PM-2.5 emissions by 30% and PM emissions by 50%. A DOC is a form of “bolt on” technology that uses a chemical process to reduce pollutants in the diesel exhaust into decreased concentrations. They replace mufflers on vehicles, and require no modifications. More specifically, this is a honeycomb type structure that has a large area coated with an active catalyst layer. As CO and other gaseous hydrocarbon particles travel along the catalyst, they are oxidized thus reducing pollution. The Department considers DOC a technically feasible control technology for the large diesel-fired engines.
- (c) Positive Crankcase Ventilation
Positive crankcase ventilation is the process of re-introducing the combustion air into the cylinder chamber for a second chance at combustion after the air has seeped into and collected in the crankcase during the downward stroke of the piston cycle. This process allows any unburned fuel to be subject to a second combustion opportunity. Any combustion products act as a heat sink during the second pass through the piston, which will lower the temperature of combustion and reduce the thermal NOx formation. The Department considers positive crankcase ventilation a technically feasible control technology for the large diesel-fired engines.
- (d) Low Sulfur Fuel
Low sulfur fuel has been known to reduce particulate matter emissions. The Department considers low sulfur fuel as a technically feasible control technology for the large diesel-fired engine.
- (e) Low Ash Diesel
Residual fuels and crude oil are known to contain ash forming components, while refined fuels are low ash. Fuels containing ash can cause excessive wear to equipment and foul engine components. The Department considers low ash diesel a technically feasible control technology for the large diesel-fired engines.

- (f) **Federal Emission Standards**
RBLC NOx determinations for federal emission standards require the engines meet the requirements of 40 C.F.R. 60 NSPS Subpart IIII, 40 C.F.R 63 Subpart ZZZZ, non-road engines (NREs), or EPA tier certifications. NSPS Subpart IIII applies to stationary compression ignition internal combustion engines that are manufactured or reconstructed after July 11, 2005. The Department considers meeting the technology based New Source Performance Standards (NSPS) as a technically feasible control technology for the large diesel-fired engines.
- (g) **Limited Operation**
Limiting the operation of emissions units reduces the potential to emit of those units. The Department considers limited operation as a feasible control technology for the large diesel-fired engines.
- (h) **Good Combustion Practices**
The theory of GCPs was discussed in detail in the NOx BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process will result in a reduction of PM-2.5 emissions. The Department considers GCPs a technically feasible control technology for the large diesel-fired engines.

Step 2 - Eliminate Technically Infeasible PM-2.5 Control Technologies for the Large Engines

PM-2.5 emission rates for low sulfur fuel are not available and therefore a BACT emissions rate cannot be set for low sulfur fuel. Low sulfur fuel is not a technically feasible control technology.

Step 3 - Rank the Remaining PM-2.5 Control Technologies for the Large Diesel-Fired Engines

The following control technologies have been identified and ranked by efficiency for the control of PM-2.5 emissions from the large diesel-fired engines:

- (g) Limited Operation (94% Control)
- (a) Diesel Particulate Filters (85% Control)
- (h) Good Combustion Practices (Less than 40% Control)
- (b) Diesel Oxidation Catalyst (30% Control)
- (e) Low Ash Diesel (25% Control)
- (c) Positive Crankcase Ventilation (10% Control)
- (f) Federal Emission Standards (Baseline)

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA proposes limited operation as BACT for PM-2.5 emissions from the large diesel-fired engines:

- (a) Limit non-emergency operation of EUs 3 and 4 to no more than 500 hours per year each for maintenance checks and readiness testing; and
- (b) PM-2.5 emissions from EUs 3 and 4 shall not exceed 0.1 lb/MMBtu⁴ over a 4-hour averaging period.

⁴ Table 3.4-1 of US EPA's AP-42 Emission Factors. <https://www3.epa.gov/ttn/chief/ap42/ch03/final/c03s04.pdf>

Department Evaluation of BACT for PM-2.5 Emissions from the Large Diesel-Fired Engines

The Department reviewed GVEA’s proposal finds that PM-2.5 emissions from the large diesel-fired engines can also be controlled by good combustion practices.

Step 5 - Preliminary Selection of PM-2.5 BACT for the Large Diesel-Fired Engines

The Department’s preliminary finding is that the BACT for PM-2.5 emissions from the large diesel-fired engines is as follows:

- (a) Limit non-emergency operation of EUs 3 and 4 to no more than 500 hours per year each for maintenance checks and readiness testing; and
- (b) PM-2.5 emissions from EUs 3 and 4 shall not exceed 0.1 lb/MMBtu⁵ over a 3-hour averaging period.

Table 4-4 lists the proposed PM-2.5 BACT determination for the facility along with those for other diesel-fired engines rated at more than 500 hp located in the Serious PM-2.5 nonattainment area.

Table 4-4. Comparison of PM-2.5 BACT for Large Diesel Engines at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
UAF	Large Diesel-Fired Engine	13,266 hp	0.32 g/hp-hr	Positive Crankcase Ventilation Limited Operation
Fort Wainwright	8 Large Diesel-Fired Engines	> 500 hp	0.15 – 10.9 g/hp-hr	Limited Operation Ultra-Low Sulfur Diesel Federal Emission Standards
GVEA North Pole	Large Diesel-Fired Engine	600 hp	0.031 g/hp-hr	Positive Crankcase Ventilation Good Combustion Practices
GVEA Zehnder	2 Large Diesel-Fired Engines	11,000 hp (each)	0.12 g/hp-hr	Limited Operation Good Combustion Practices

4.3 PM-2.5 BACT for the Diesel Fired Boilers

Possible PM-2.5 emission control technologies for small diesel-fired boilers were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.220, Commercial/Institutional Size Boilers (<100 MMBtu/hr). The search results for diesel-fired boilers are summarized in Table 4-5.

Table 4-5. RBLC Summary of PM-2.5 Control for Diesel Fired Boilers

Control Technology	Number of Determinations	Emission Limits
Good Combustion Practices	3	0.25 lb/gal
		0.1 tpy
		2.17 lb/hr

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices is the principle PM-2.5 control technology determined for small diesel-fired boilers. The lowest PM-2.5 emission rate listed in the RBLC is 0.1 tpy.

⁵ Table 3.4-1 of US EPA’s AP-42 Emission Factors. <https://www3.epa.gov/ttn/chief/ap42/ch03/final/c03s04.pdf>

Step 1 - Identification of PM-2.5 Control Technology for the Diesel Fired Boilers

From research, the Department identified the following technologies as available for control of PM-2.5 emissions from diesel-fired boilers:

(a) Wet Scrubbers

Wet scrubbers use a scrubbing solution to remove PM/PM₁₀/PM_{2.5} from exhaust gas streams. The mechanism for particulate collection is impaction and interception by water droplets. Wet scrubbers are configured as counter-flow, cross-flow, or concurrent flow, but typically employ counter-flow where the scrubbing fluid is in the opposite direction as the gas flow. Wet scrubbers have control efficiencies of 50% - 99%.⁶ One advantage of wet scrubbers is that they can be effective on condensable particulate matter. A disadvantage of wet scrubbers is that they consume water and produce water and sludge. For fine particulate control, a venturi scrubber can be used, but typical loadings for such a scrubber are 0.1-50 grains/scf. The Department considers the use of wet scrubbers a technically feasible control technology for the diesel-fired boilers.

(b) Good Combustion Practices

The theory of GCPs was discussed in detail in the NO_x BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process will result in a reduction of PM-2.5 emissions. The Department considers GCPs a technically feasible control technology for the diesel-fired boilers.

Step 2 - Eliminate Technically Infeasible PM-2.5 Control Technologies for the Diesel Fired Boilers

All identified control devices are technically feasible for the diesel-fired boilers.

Step 3 - Rank the Remaining PM-2.5 Control Technologies for the Diesel Fired Boilers

The following control technologies have been identified and ranked by efficiency for the control of PM-2.5 emissions from the diesel-fired boilers:

- (a) Wet Scrubbers (50% - 99% Control)
- (b) Good Combustion Practices (Less than 40% Control)

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA proposes the following as BACT for PM-2.5 emissions from the diesel-fired boilers:

- (a) Good Combustion Practices; and
- (b) PM-2.5 emissions shall not exceed 2.13 lb/1,000 gallons⁷ over a 4-hour averaging period.

Department Evaluation of BACT for PM-2.5 Emissions from Diesel-Fired Boilers

The Department reviewed GVEA's proposal and finds that the two diesel-fired boilers have a combined PTE of less than two tpy for PM-2.5 based on continuous operation of 8,760 hours per

⁶ <https://www3.epa.gov/ttn/catc/dir1/fcondnse.pdf>
<https://www3.epa.gov/ttn/catc/dir1/fiberbed.pdf>
<https://www3.epa.gov/ttn/catc/dir1/fventuri.pdf>

⁷ Tables 1.3-2 & 1.3-7 of US EPA's AP-42 Emission Factors: <https://www3.epa.gov/ttn/chief/ap42/ch01/final/c01s03.pdf>

year. At two tpy, the cost effectiveness in terms of dollars per ton for add-on pollution control for these units is economically infeasible.

Step 5 - Preliminary Selection of PM-2.5 BACT for the Diesel-Fired Boilers

The Department’s preliminary finding is that BACT for PM-2.5 emissions from the diesel-fired boilers is as follows:

- (a) PM-2.5 emissions from the diesel-fired boilers shall not exceed 2.13 lb/1000 gallons of diesel fuel over a 3-hour averaging period; and
- (b) Maintain good combustion practices by following the manufacturer’s operating and maintenance procedures at all times of operation.

Table 4-6 lists the proposed PM-2.5 BACT determination for this facility along with those for other diesel-fired boilers rated at less than 100 MMBtu/hr in the Serious PM-2.5 nonattainment area.

Table 4-6. Comparison of PM-2.5 BACT for the Diesel-Fired Boilers at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
UAF	3 Small Diesel-Fired Boilers	< 100 MMBtu/hr	7.06 g/MMBtu	Limited Operation
Fort Wainwright	26 Small Diesel-Fired Boilers	< 100 MMBtu/hr	Varies	Good Combustion Practices
Chena	2 Small Diesel-Fired Boilers	< 100 MMBtu/hr		
GVEA Zehnder	2 Small Diesel-Fired Boilers	1.7 MMBtu/hr (each)	2.13 lb/1000 gal	Good Combustion Practices

5. BACT DETERMINATION FOR SO₂

The Department based its SO₂ assessment on BACT determinations found in the RBLC, internet research, and BACT analyses submitted to the Department by GVEA for the North Pole Power Plant and Zehnder Facility, Aurora for the Chena Power Plant, US Army for Fort Wainwright, and UAF for the Combined Heat and Power Plant.

5.1 SO₂ BACT for the Fuel Oil-Fired Simple Cycle Gas Turbines

Possible SO₂ emission control technologies for the large dual fuel fired boiler was obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 15.190, Liquid Fuel-Fired Simple Cycle Gas Turbines (> 25 MW). The search results for simple cycle gas turbines are summarized in Table 5-1.

Table 5-1. RBLC Summary of SO₂ Controls for Fuel Oil-Fired Simple Cycle Gas Turbines

Control Technology	Number of Determinations	Emission Limits
Ultra-Low Sulfur Diesel	7	0.0015 % S by wt.
Low Sulfur Fuel	2	0.0026 – 0.055 lb/MMBtu
Good Combustion Practices	3	0.6 lb/hr

RBLC Review

A review of similar units in the RBLC indicates that limiting the sulfur content of fuel and good combustion practices are the principle SO₂ control technologies determined as BACT for fuel

oil-fired simple cycle gas turbines. The lowest SO₂ emission rate listed in the RBLC is combustion of ULSD at 0.0015 % S by wt.

Step 1 - Identification of SO₂ Control Technology for the Simple Cycle Gas Turbines

From research, the Department identified the following technologies as available for control of SO₂ emissions from fuel oil-fired simple cycle gas turbines:

- (a) Ultra Low Sulfur Diesel (ULSD)
ULSD has a fuel sulfur content of 0.0015 percent sulfur by weight or less. Using ULSD would reduce SO₂ emissions because the fuel oil-fired simple cycle gas turbines are combusting standard diesel that has a sulfur content of up to 0.5 percent sulfur by weight. Switching to ULSD could reach a great than 99 percent decrease in SO₂ emissions from the fuel oil-fired simple cycle gas turbines. The Department considers ULSD a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.
- (b) Low Sulfur Fuel
Low sulfur fuel has a fuel sulfur content of 0.05 percent sulfur by weight. Using low sulfur fuel would reduce SO₂ emissions because the fuel oil-fired simple cycle gas turbines are combusting standard diesel that has a sulfur content of up to 0.5 percent sulfur by weight. Switching to low sulfur fuel could reach a 93 percent decrease in SO₂ emissions from the fuel oil-fired simple cycle gas turbines during non-startup operation. The Department considers low sulfur diesel a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.
- (c) Good Combustion Practices (GCPs)
The theory of GCPs was discussed in detail in the NO_x BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process will result in a reduction of SO₂. The Department considers GCPs a technically feasible control technology for the fuel oil-fired simple cycle gas turbines.

Step 2 - Eliminate Technically Infeasible SO₂ Controls for the Simple Cycle Gas Turbines

All control technologies identified are technically feasible for the fuel oil-fired simple cycle gas turbines.

Step 3 - Rank Remaining SO₂ Control Technologies for the Simple Cycle Gas Turbines

The following control technologies have been identified and ranked for control of SO₂ emissions from the fuel oil-fired simple cycle turbines:

- (a) Ultra Low Sulfur Diesel (99.7% Control)
- (b) Low Sulfur Fuel (93% Control)
- (c) Good Combustion Practices (Less than 40% Control)

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA provided an economic analysis for switching the fuel combusted in the simple cycle gas turbines to ultra low sulfur diesel. A summary of the analysis is shown below:

Table 5-2. GVEA Economic Analysis for Technically Feasible SO₂ Controls per Turbine

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
ULSD (0.0015 % S wt.)	580	578	\$4,337,181	\$5,609,166	\$9,701
Low Sulfur Fuel (0.05 % S wt.)	580	522	???	???	???
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

GVEA contends that the economic analysis indicates the level of SO₂ reduction does not justify the fuel switch to ULSD in the simple cycle turbines based on the excessive cost per ton of SO₂ removed per year.

GVEA proposes the following as BACT for SO₂ emissions from the simple cycle gas turbines:

- (a) SO₂ emissions from the operation of the fuel oil-fired simple cycle gas turbines will be controlled with good combustion practices; and
- (b) Fuel burned in the fuel oil-fired simple cycle gas turbine will be limited to a sulfur content of 0.5 percent by weight.

Department Evaluation of BACT for SO₂ Emissions from the Simple Cycle Gas Turbines

The Department revised the cost analysis provided for the fuel switch to ULSD in the simple cycle gas turbines using the unrestricted potential to emit for the units and a 20 year equipment life. Additionally, the Department reviewed the cost information provided by GVEA to appropriately evaluate the total capital investment of installing two new 1.5 million gallon ULSD storage tanks at GVEA’s North Pole facility. A summary of this analysis is shown in Table 5-3:

Table 5-3. Department Economic Analysis for Technically Feasible SO₂ Controls per Turbine

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
ULSD	598.6	597	\$4,337,181	\$5,401,048	\$9,050
Capital Recovery Factor = 0.0944 (7% interest rate for a 20 year equipmnt life)					

The Department’s preliminary economic analysis indicates the level of SO₂ reduction justifies the use of ULSD as BACT for the fuel oil-fired simple cycle gas turbines located in the Serious PM-2.5 nonattainment area.

Step 5 - Preliminary Selection of SO₂ BACT for the Simple Cycle Gas Turbines

The Department’s preliminary finding is that BACT for SO₂ emissions from the fuel oil-fired simple cycle gas turbines is as follows:

- (a) SO₂ emissions from EUs 1 and 2 shall be controlled by limiting the sulfur content of fuel combusted in the turbines to no more than 0.0015 percent by weight.

- (b) Compliance with the proposed fuel sulfur content limit will be demonstrated with fuel shipment receipts and/or fuel test results for sulfur content.

Table 5-4 lists the proposed SO₂ BACT determination for this facility along with those for other fuel oil-fired simple cycle gas turbines located in the Serious PM-2.5 nonattainment area.

Table 5-4. Comparison of SO₂ BACT for Simple Cycle Gas Turbines at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
GVEA – North Pole	Two Fuel Oil-Fired Simple Cycle Gas Turbines	1,344 MMBtu/hr	0.0015 % S wt.	Ultra Low Sulfur Diesel
GVEA – Zehnder	Two Fuel Oil-Fired Simple Cycle Gas Turbines	536 MMBtu/hr	0.0015 % S wt.	Ultra Low Sulfur Diesel

5.2 SO₂ BACT for the Large Diesel-Fired Engines

Possible SO₂ emission control technologies for large engines were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process codes 17.100 to 17.190, Large Internal Combustion Engines (>500 hp). The search results for large diesel-fired engines are summarized in Table 5-5.

Table 5-5. RBLC Summary Results for SO₂ Control for Large Diesel-Fired Engines

Control Technology	Number of Determinations	Emission Limits (g/hp-hr)
Low Sulfur Diesel	27	0.005 – 0.02
Federal Emission Standards	6	0.001 – 0.005
Limited Operation	6	0.005 – 0.006
Good Combustion Practices	3	None Specified
No Control Specified	11	0.005 – 0.008

RBLC Review

A review of similar units in the RBLC indicates combustion of low sulfur fuel, limited operation, good combustion practices, and compliance with the federal emission standards are the principle SO₂ control technologies installed on large diesel-fired engines. The lowest SO₂ emission rate listed in the RBLC is 0.001 g/hp-hr.

Step 1 - Identification of SO₂ Control Technology for the Large Diesel-Fired Engines

From research, the Department identified the following technologies as available for control of SO₂ emissions from diesel fired engines rated at 500 hp or greater:

- (a) Ultra Low Sulfur Diesel
The theory of ULSD was discussed in detail in the SO₂ BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. The Department considers ULSD a technically feasible control technology for the large diesel-fired engines.
- (b) Federal Emission Standards
The theory of federal emission standards was discussed in detail in the NO_x BACT for the large diesel-fired engine and will not be repeated here. The Department considers

meeting the technology based NSPS of Subpart III as a technically feasible control technology for the large diesel-fired engines.

(c) Limited Operation

Limiting the operation of emission units reduces the potential to emit for those units. The Department considers limited operation a technically feasible control technology for the large diesel-fired engines.

(d) Good Combustion Practices

The theory of GCPs was discussed in detail in the NO_x BACT for the fuel oil-fired simple cycle gas turbines and will not be repeated here. Proper management of the combustion process will result in a reduction of SO₂ emissions. The Department considers GCPs a technically feasible control technology for the large diesel-fired engines.

Step 2 - Eliminate Technically Infeasible SO₂ Control Technologies for the Large Engines

All identified control technologies are technically feasible for the large diesel-fired engines.

Step 3 - Rank the Remaining SO₂ Control Technologies for the Large Diesel-Fired Engines

The following control technologies have been identified and ranked by efficiency for the control of SO₂ emissions from the large diesel-fired engines.

- (a) Ultra-Low Sulfur Diesel (99% Control)
- (c) Limited Operation (94% Control)
- (d) Good Combustion Practices (Less than 40% Control)
- (b) Federal Emission Standards (Baseline)

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA provided an economic analysis of the control technologies available for the large diesel-fired engine to demonstrate that the use of ULSD with limited operation is not economically feasible on these units. A summary of the analysis for EUs 3 and 4 is shown below:

Table 5-6. GVEA Economic Analysis for Technically Feasible SO₂ Controls per Engine

Control Alternative	Potential to Emit (tpy)	Emission Reduction (tpy)	Total Capital Investment (\$)	Total Annualized Costs (\$/year)	Cost Effectiveness (\$/ton)
ULSD	3.71	3.70	--	\$28,732	\$7,768
Capital Recovery Factor = 0.1424 (7% interest rate for a 10 year equipment life)					

GVEA contends that the economic analysis indicates the level of SO₂ reduction does not justify the use of ULSD for the large diesel-fired engines based on the excessive cost per ton of SO₂ removed per year.

GVEA proposes the following as BACT for SO₂ emissions from the diesel-fired engines:

- (a) SO₂ emissions from the operation of the diesel fired engines will be controlled with good combustion practices; and
- (b) Limit the sulfur content of fuel combusted in EUs 3 and 4 to no more than 0.5 percent sulfur by weight.

Department Evaluation of BACT for SO₂ Emissions from the Diesel-Fired Engines

The Department reviewed GVEA’s proposal for EUs 3 and 4 and finds that ULSD is an economically feasible control technology for large diesel-fired engines located in the Serious PM-2.5 nonattainment area.. The Department does not agree with some of the assumptions provided in GVEA’s cost analysis that cause an overestimation of the cost effectiveness. However, since this overestimation is still cost effective, the Department did not revise the cost analysis. The Department further finds that SO₂ emissions from the large diesel-fired engines can additionally be controlled by limiting the use of the units during non-emergency operation.

Step 5 - Preliminary Selection of SO₂ BACT for the Diesel Fired Engines

The Department’s preliminary finding is that the BACT for SO₂ emissions from the diesel-fired engines is as follows:

- (a) SO₂ emissions from EUs 3 and 4 shall be controlled by combusting ULSD at all time the units are in operation;
- (b) Limit non-emergency operation of EUs 3 and 4 to no more than 500 hours per year each, for maintenance checks and readiness testing; and
- (c) Maintain good combustion practices by following the manufacturer’s maintenance procedures at all times of operation.

Table 5-7 lists the proposed SO₂ BACT determination for this facility along with those for other diesel-fired engines rated at more than 500 hp located in the Serious PM-2.5 nonattainment area.

Table 5-7. Comparison of SO₂ BACT for Large Diesel-Fired Engines at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
Fort Wainwright	8 Large Diesel-Fired Engines	> 500 hp	15 ppmw S in fuel	Limited Operation Good Combustion Practices Ultra-Low Sulfur Diesel
UAF	Large Diesel-Fired Engine	13,266 hp	15 ppmw S in fuel	Limited Operation Good Combustion Practices Ultra-Low Sulfur Diesel
GVEA North Pole	Large Diesel-Fired Engine	600 hp	500 ppmw S in fuel	Limited Operation Good Combustion Practices
GVEA Zehnder	2 Large Diesel-Fired Engines	11,000 hp	15 ppmw S in fuel	Good Combustion Practices Ultra-Low Sulfur Diesel

5.3 SO₂ BACT for the Diesel Fired Boilers

Possible SO₂ emission control technologies for small diesel-fired boilers were obtained from the RBLC. The RBLC was searched for all determinations in the last 10 years under the process code 13.220, Industrial Size Boilers (<100 MMBtu/hr). The search results for diesel-fired engines are summarized in Table 5-8.

Table 5-8. RBLC Summary of SO₂ Control for the Small Diesel-Fired Boilers

Control Technology	Number of Determinations	Emission Limits (lb/MMBtu)
Low Sulfur Fuel	5	0.0036 – 0.0094
Good Combustion Practices	4	0.0005
No Control Specified	5	0.0005

RBLC Review

A review of similar units in the RBLC indicates that good combustion practices and combustion of low sulfur fuel are the principle SO₂ control technologies installed on diesel-fired boilers. The lowest SO₂ emission rate listed in the RBLC is 0.0005 lb/MMBtu.

Step 1 - Identification of SO₂ Control Technology for the Diesel Fired Boilers

From research, the Department identified the following technologies as available for SO₂ control for the diesel-fired boilers:

- (a) Ultra Low Sulfur Diesel
ULSD has a fuel sulfur content of 0.0015 percent sulfur by weight or less. Using ULSD would reduce SO₂ emissions because the mid-sized diesel boilers are combusting standard diesel that has a sulfur content of up to 0.5 percent sulfur by weight. Switching to ULSD could control 99 percent decrease in SO₂ emissions from the diesel fired boilers. The Department considers ULSD a technically feasible control technology for the diesel-fired boilers.
- (b) Good Combustion Practices
The theory of GCPs was discussed in detail in the NO_x BACT for the fuel oil-fired simple cycle gas turbine and will not be repeated here. Proper management of the combustion process will result in a reduction of SO₂ emissions. The Department considers GCPs a technically feasible control technology for the diesel-fired boilers.

Step 2 - Eliminate Technically Infeasible SO₂ Control Technologies for the Diesel-Fired Boilers

All identified control technologies are technically feasible for the diesel-fired boilers.

Step 3 - Rank the Remaining SO₂ Control Technologies for the Diesel-Fired Boilers

The following control technologies have been identified and ranked by efficiency for the control of SO₂ emissions from the diesel-fired boilers.

- (a) Ultra Low Sulfur Diesel (99% Control)
- (b) Good Combustion Practices (Less than 40% Control)

Step 4 - Evaluate the Most Effective Controls

GVEA BACT Proposal

GVEA proposes the following as BACT for SO₂ emissions from the diesel-fired boilers:

- (a) Combust only ULSD.

Department Evaluation of BACT for SO₂ Emissions from Diesel-Fired Boilers

The Department reviewed GVEA’s proposal and finds that SO₂ emissions from the diesel-fired boilers can additionally be controlled with good combustion practices.

Step 5 - Preliminary Selection of SO₂ BACT for the Diesel-Fired Boilers

The Department’s preliminary finding is that BACT for SO₂ emissions from the diesel-fired boilers is as follows:

- (a) SO₂ emissions from EUs 10 and 11 shall be controlled by only combusting ULSD; and
- (b) Maintain good combustion practices by following the manufacturer’s operating and maintenance procedures at all times of operation.

Table 5-9 lists the proposed SO₂ BACT determination for this facility along with those for other diesel-fired boilers rated at less than 100 MMBtu/hr in the Serious PM-2.5 nonattainment area.

Table 5-9. Comparison of SO₂ BACT for the Diesel-Fired Boilers at Nearby Power Plants

Facility	Process Description	Capacity	Limitation	Control Method
Fort Wainwright	Diesel-Fired Boilers	< 100 MMBtu/hr	15 ppmw S in fuel	Limited Operation Good Combustion Practices Ultra-Low Sulfur Diesel
	Waste Fuel-Fired Boilers		0.5 % S by weight	Good Combustion Practices
UAF	3 Diesel-Fired Boilers	< 100 MMBtu/hr	15 ppmw S in fuel	Good Combustion Practices Ultra-Low Sulfur Diesel
GVEA Zehnder	2 Diesel-Fired Boilers	< 100 MMBtu/hr	15 ppmw S in fuel	Good Combustion Practices Ultra-Low Sulfur Diesel

6. BACT DETERMINATION SUMMARY

Table 6-1. Proposed NOx BACT Limits

EU ID	Description of EU	Capacity	Proposed BACT Limit	Proposed BACT Control
1	Fuel Oil-Fired Regenerative Gas Simple Cycle Gas Turbine	268 MMBtu/hr	0.04 lb/MMBtu	Selective Catalytic Reduction
2	Fuel Oil-Fired Regenerative Gas Simple Cycle Gas Turbine	268 MMBtu/hr	0.04 lb/MMBtu	Water Injection
3	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr	0.024 lb/hp-hr	Turbocharger & Aftercooler Good Combustion Practices
4	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr	0.024 lb/hp-hr	Limited Operation (500 hours/year each, for non-emergency operation)
10	Diesel-Fired Boiler	1.7 MMBtu/hr	20 lb/1000 gal	Good Combustion Practices
11	Diesel-Fired Boiler	1.7 MMBtu/hr	20 lb/1000 gal	

Table 6-2. Proposed PM-2.5 BACT Limits

EU ID	Description of EU	Capacity	Proposed BACT Limit	Proposed BACT Control
1	Fuel Oil-Fired Regenerative Gas Simple Cycle Gas Turbine	268 MMBtu/hr	0.012 lb/MMBtu	Low Ash Fuel
2	Fuel Oil-Fired Regenerative Gas Simple Cycle Gas Turbine	268 MMBtu/hr	0.012 lb/MMBtu	Good Combustion Practices
3	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr	0.1 lb/MMBtu	Good Combustion Practices
4	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr	0.1 lb/MMBtu	Limited Operation (500 hours/year each, for non-emergency operation)
10	Diesel-Fired Boiler	1.7 MMBtu/hr	1.1 lb/1000 gal	Good Combustion Practices
11	Diesel-Fired Boiler	1.7 MMBtu/hr	1.1 lb/1000 gal	

Table 6-3. Proposed SO₂ BACT Limits

EU ID	Description of EU	Capacity	Proposed BACT Limit	Proposed BACT Control
1	Fuel Oil-Fired Regenerative Gas Simple Cycle Gas Turbine	268 MMBtu/hr	15 ppmv S in Fuel	Ultra Low Sulfur Diesel
2	Fuel Oil-Fired Regenerative Gas Simple Cycle Gas Turbine	268 MMBtu/hr	15 ppmv S in Fuel	
3	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr	15 ppmv S in Fuel	Ultra Low Sulfur Diesel Good Combustion Practices
4	Diesel-Fired Emergency Generator Engine	28 MMBtu/hr	15 ppmv S in Fuel	Limited Operation (500 hours/year each, for non-emergency operation)
10	Diesel-Fired Boiler	1.7 MMBtu/hr	20 lb/1000 gal	Ultra Low Sulfur Diesel
11	Diesel-Fired Boiler	1.7 MMBtu/hr	20 lb/1000 gal	Good Combustion Practices

DRAFT