

# STATE OF ALASKA

FRANK H. MURKOWSKI, GOVERNOR

DEPT. OF ENVIRONMENTAL CONSERVATION  
DIVISION OF SPILL PREVENTION AND RESPONSE  
INDUSTRY PREPAREDNESS PROGRAM

555 Cordova Street  
Anchorage, AK 99501  
PHONE: (907) 269-3094  
FAX: (907) 269-7687  
<http://www.state.ak.us/dec>

December 12, 2003

FILE COPY

File No. 304.20.3124

3024

## OIL DISCHARGE PREVENTION AND CONTINGENCY PLAN APPROVAL

Joseph M. Stankiewicz  
North Slope Borough  
P. O. Box 69  
Barrow, AK 99723

Dear Mr. Stankiewicz:

**SUBJECT: Barrow Bulk Fuel Storage Facility, Oil Discharge Prevention and Contingency Plan, Dated December 2003, Plan Number 003-CP-3121.**

The Alaska Department of Environmental Conservation has completed the review of the following oil discharge prevention and contingency plan (plan) received February 12, 2003:

Plan Title: Barrow Bulk Fuel Storage Facility, Oil Discharge Prevention and Contingency Plan, Dated December 2003, consisting of 1 volume.

Plan Holder: North Slope Borough

Covered Facility: Barrow Bulk Fuel Storage Facility, Barrow, Alaska

**PLAN APPROVAL:** The Department has determined that the referenced plan satisfies minimum planning standards and other requirements established under applicable statutes and regulations. Therefore, the Barrow Fuel Storage Facility plan is hereby approved effective December 12, 2003. This approval supersedes the previous plan approval and certificate of approval issued by the Department dated June 30, 2003, for the facility covered by this plan.

A certificate of approval stating that the plan has been approved by the Department is enclosed.

A certificate of approval stating that the plan has been approved by the Department is enclosed.

**This approval is subject to the following terms and conditions:**

**APPROVAL CONDITIONS:** This approval is contingent upon demonstrating compliance with the corrosion control program described in Section 2.1.8 of the Oil Discharge Prevention and Contingency Plan by October 1, 2004 and Section 2.7 conditions.

**EXPIRATION:** This approval expires December 13, 2008. After the approval expires, operation of the facility is prohibited by Alaska law until an approved plan is once again in effect.

**RENEWAL:** To renew this approval, the plan holder must submit a completed renewal application and plan to the Department no later than 180 days prior to the expiration of this approval. This is to ensure the submitted plan is approved before the current plan in effect expires (18AAC 75.420).

**REVOCAION, SUSPENSION, OR MODIFICATION:** This approval is effective only while the plan holder is in "compliance with the plan" and with all of the terms and conditions described above. The Department may, after notice and opportunity for a hearing, revoke, suspend, or require the modification of an approved plan if the plan holder is not in compliance with it, or for any other reason stated in AS 46.04.030(f). In addition, Alaska law provides that a vessel or facility that is not in "compliance with the plan" may not operate (AS 46.04.030). The Department may terminate approval prior to the expiration date if deficiencies are identified that would adversely affect spill prevention, response or preparedness capabilities.

**DUTY TO RESPOND:** Notwithstanding any other provisions or requirements of this contingency plan a person causing or permitting the discharge of oil is required by law to immediately contain and cleanup the discharge regardless of the adequacy or inadequacy of a contingency plan (AS 46.04.020).

**NOTIFICATION OF NON-READINESS:** Within twenty four (24) hours after any significant response equipment specified in the plan becomes nonoperational or is removed from its designated storage location the plan holder must notify the Department in writing and provide a schedule for the equipments substitution, repair, or return to service (18 AAC 75.475(b)).

**CIVIL AND CRIMINAL SANCTIONS:** Failure to comply with the plan may subject the plan holder to civil liability for damages and to civil and criminal penalties. Civil and criminal sanctions may also be imposed for any violation of AS 46.04, any regulation issued thereunder, or any violation of a lawful order of the Department.

**INSPECTIONS, DRILLS, RIGHTS TO ACCESS AND VERIFICATION OF EQUIPMENT, SUPPLIES AND PERSONNEL:** The Department has the right to verify the ability of the plan holder to carry out the provisions of its contingency plan and access to

purposes and to otherwise ensure compliance with the plan and the terms and conditions (AS 46.04.030(e) and AS 46.04.060). The plan holder shall conduct exercises for the purpose of testing the adequacy of the contingency plan and its implementation (18 AAC 75.480 and 485).


**FAILURE TO PERFORM:** In granting approval of the plan, the Department has determined that the plan, as represented to it by the applicant in the plan and application for approval, satisfies the minimum planning standards and other requirements established by applicable statutes and regulations, taking as true all information provided by the applicant. The Department does not warrant to the applicant, the plan holder, or any other person or entity: (1) the accuracy or validity of the information or assurances relied upon; (2) that the plan is or will be implemented; or (3) that even full compliance and implementation with the plan will result in complete containment, control, or clean-up of any given oil spill, including a spill specifically described in the planning standards. The plan holder is encouraged to take any additional precautions and obtain any additional response capability it deems appropriate to further guard against the risk of oil spills and to enhance its ability to comply with its duty under AS 46.04.020(a) to immediately contain and clean up an oil discharge.

**COMPLIANCE WITH APPLICABLE LAWS:** If amendments to the approved plan are necessary to meet the requirements of any new laws or regulations, the plan holder must submit an application for amendment to the Department at the above address. The plan holder must adhere to all applicable state statutes and regulations as they may be amended from time to time. This approval does not relieve the plan holder of the responsibility for securing other federal, state or local approvals or permits, and that the plan holder is still required to comply with all other applicable laws.

**ADJUDICATORY HEARING:** Any person who disagrees with this decision may request an adjudicatory hearing in accordance with 18 AAC 15.195- 18 AAC 15.340 or an informal review by the Division Director in accordance with 18 AAC 15.185. **Informal review requests** must be delivered to the Division Director, 410 Willoughby Avenue, Suite 303, Juneau, Alaska 99801 within 15 days of the permit decision. **Adjudicatory hearing requests** must be delivered to the Commissioner of the Department of Environmental Conservation, 410 Willoughby Avenue, Suite 303, Juneau, Alaska 99801, within 30 days of the permit decision. If a hearing is not requested within 30 days, the right to appeal is waived.

If you have any questions, please contact Natalie Howard at (907) 451-5960.

Sincerely,

  
Bill Hutmacher  
Program Manager

Enclosure: Certificate of Approval, Number 03-CER-3615

Joseph M. Stankiewicz  
North Slope Borough



4

December 12, 2003

cc: Bob Dreyer, TTF Section Manager  
Mark Fink, ADF&G, Anchorage  
Sam Means, ADNR, Anchorage  
Matt Carr, USEPA, Anchorage  
Nancy Boardman, Brady & Co.  
Sheldon Adams, ACMP