

## *Drinking Water Total Coliform Report – May 2005*

<i>PWSID #</i>	<i>NAME</i>	<i>COLLECTION DATE</i>	<i>RT= Routine Special</i>	<i>S= A= Absent (ND) P= Present</i>
<b>AK2130198</b>	<i>BARTLETT COVE WATER SYSTEM</i>	5/3/2005	RT	A
<b>AK2260414</b>	<i>COLD BAY</i>	5/2/2005	RT	A
<b>AK2111470</b>	<i>COMMUNITY OF ELFIN COVE</i>	5/12/2005	RT	A
		5/12/2005	RT	A
		5/12/2005	RT	P
		5/12/2005	RT	A
		5/12/2005	RT	P
		5/12/2005	RT	P
		5/12/2005	RT	A
		5/12/2005	RT	P

The Community of Elfin Cove Public Water System was on a Boil Water Notice during the month of May, 2005. Follow up samples collected on June 8, 2005 were free of bacteria and the Boil Water Notice was lifted.

**AK2293205**      *CORDOVA CITY WATER*

15 routine distribution system samples were collected in May, 15 were free of bacteriological contamination.

<b>AK2130596</b>	<i>GUSTAVUS WATER SYSTEM</i>	5/3/2005	RT	A
<b>AK2110619</b>	<i>HAINES</i>	5/19/2005	RT	A
		5/19/2005	RT	A
		5/19/2005	RT	A

**AK2240456**      *HOMER*

7 routine distribution system samples were collected in May, 7 were free of bacteriological contamination.

**AK2110342**      *JUNEAU*

41 routine distribution system samples were collected in May, 41 were free of bacteriological contamination.

<b>AK2130083</b>	<i>KAKE MUNICIPAL WATER</i>	5/19/2005	RT	A
------------------	-----------------------------	-----------	----	---

**AK2120232**      *KETCHIKAN PUBLIC UTILITIES*

21 routine distribution system samples were collected in Amy, 21 were free of bacteriological contamination.

<i>PWSID #</i>	<i>NAME</i>	<i>COLLECTION DATE</i>	<i>RT= Routine Special</i>	<i>S= A= Absent (ND) P= Present</i>
----------------	-------------	------------------------	--------------------------------	---

**AK2250011**      *KODIAK WATER SYSTEM*

10 routine distribution system samples were collected in May, 10 were free of bacteriological contamination.

**AK2340735**      *MOONLIGHT WATER DELIVERY*

5/31/2005	RT	A
-----------	----	---

**AK2210906**      *MUNICIPALITY OF ANCHORAGE*

168 routine distribution system samples were collected in May, 168 were free of bacteriological contamination.

**AK2130148**      *PETERSBURG*

5 routine distribution system samples were collected in May, 6 were free of bacteriological contamination.

**AK2240757**      *SEWARD*

4 routine distribution system samples were collected in May, 4 were free of bacteriological contamination

**AK2130075**      *SITKA*

12 routine distribution system samples were collected in May, 12 were free of bacteriological contamination.

**AK2110601**      *SKAGWAY*

5/2/2005	RT	A
5/31/2005	RT	A

**AK2260309**      *UNALASKA WATER SYSTEM*

10 routine distribution system samples were collected in May, 10 were free of bacteriological contamination.

**AK2298103**      *VALDEZ - MAIN*

5 routine distribution system samples were collected in April, 5 were free of bacteriological contamination.

**AK2211952**      *WHITTIER WATER SYSTEM*

5/3/2005	RT	A
5/17/2005	RT	A
6/7/2005	RT	A

**AK2120143**      *WRANGELL*

5/11/2005	RT	A
5/11/2005	RT	A