



NOTICE OF REVIEW APDES Preliminary Draft Permit

Alaska Department of Environmental Conservation (DEC)
Wastewater Discharge Authorization Program
555 Cordova Street
Anchorage, Alaska 99501

NOTICE OF REVIEW OF AN ALASKA POLLUTANT DISCHARGE ELIMINATION SYSTEM (APDES) **PRELIMINARY DRAFT PERMIT** TO DISCHARGE TO WATERS OF THE UNITED STATES

ADEC has prepared an APDES preliminary draft permit for the City of Fairbanks and Golden Heart Utilities, Inc. Wastewater Treatment Facility. The Preliminary Draft Permit and associated documents are available to the applicant for a 10-day review. Following the close of the 10-day applicant review period, DEC will prepare a draft permit and fact sheet for a formal 30-day public review period. Public comments will be accepted during the formal 30-day review period. You can access the documents on DEC's Wastewater Discharge Authorization Program webpage at: <http://www.dec.state.ak.us/water/wwdp/index.htm>

DEC Contact:

Marie Klingman
610 University Avenue
Fairbanks, AK 99709
(907) 451-2101
marie.klingman@alaska.gov

Preliminary Draft Permit Review:

Start Date: October 20, 2015
End Date: November 3, 2015

Permit No.: AK0023451

Applicant:

City of Fairbanks and Golden Heart Utilities, Inc.
4247 Peger Road
Fairbanks, Alaska 99709

Proposed Project and Location:

The discharge of secondary treated domestic wastewater from the City of Fairbanks and Golden Heart Utilities, Inc. Wastewater Treatment Facility located at 64°48' 12" North and 147° 46' 31"

West will occur at a maximum rate of 8.0 million gallons per day to the Tanana River. A mixing zone is proposed for ammonia, copper, total residual chlorine, and whole effluent toxicity.

Administrative Record:

The APDES preliminary draft permit, fact sheet, and associated documents are available for public review at the ADEC offices located in Anchorage, Fairbanks, Juneau, Soldotna, and Wasilla. Please contact the office of your choice to arrange for hard copies of the documents to be available for your review.

555 Cordova Street
Anchorage, AK 99501
907-269-6285

610 University Avenue
Fairbanks, AK 99709
907-451-2100

410 Willoughby Ave #303
Juneau, AK 99811
907-465-5300

43335 Kalifornsky Beach Road
Soldotna, AK 99615
907-262-5210

1700 E Bogard Road #B
Suite #103
Wasilla, AK 99654
907-376-1850

If you would like to see any additional supporting technical documents, please contact the DEC contact listed above.

The documents are also accessible from the DEC website at:
<http://www.dec.state.ak.us/water/wwdp/index.htm>

Disability Reasonable Accommodation Notice

The State of Alaska, Department of Environmental Conservation complies with Title II of the Americans with Disabilities Act of 1990. If you are a person with a disability who may need a special accommodation in order to participate in this review, please contact Natalie Wolfe at (907) 269-0291 or TDD Relay Service 1-800-770-8973/TTY or dial 711 within 10 days of publication of this notice to ensure that any necessary accommodations can be provided.